

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 12/Nov/2023 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	160.051	2043.881	1) Gujrat	4.096	30.481
2) Hydro	5.767	97.823	2) Madhya Pradesh	2.846	50.803
3) Gas	3.268	71.275	3) Chattisgarh	7.090	91.950
Total MSPGCL	169.086	2212.979	4) Maharashtra	192.107	2519.579
B) 1) APML	24.193	679.056	5) Goa (Amona)	-1.085	-17.493
2) JSWEL	19.350	301.087	Total	205.054	2675.320
3) VIPL	0.000	0.000	a) Mumbai Schedule	38.509	463.134
4) RPL(AMT)	18.270	289.285	b) Mumbai Drawl	41.838	489.033
5) SWPGPL	9.265	124.075	c) MSEDCL Bilateral *	82.315	1209.077
6) Other IPP	28.806	250.000	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	38.509	463.117
C) 1) TPCL Thermal	9.596	150.410	Include PX	0.000	0.000
2) TPCL Hydro	1.756	32.239	Standby	0.000	0.017
3) TPCL Gas	1.865	28.820	H) ENERGY CATERED (MUs)		
4) AEML Thermal	4.247	114.757	1) MSEDCL	447.053	6189.444
D) STATE			2) Mumbai Discoms	59.302	815.256
1) Thermal	273.778	3952.551	3) Other Discoms	10.174	126.091
(A1+C1+C4+(B1-B6))			TOTAL STATE	516.529	7130.791
2) Hydro	7.523	130.062			
(A2+C2)					
3) Gas	5.133	100.095			
(A3+B7+C3)					
4) Wind	10.911	118.352			
6) SOLAR	14.130	154.414			
TOTAL STATE	311.475	4455.474			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	6280	5446	7205	6419
MSPGCL Hydro	217	217	288	203
MSPGCL Gas	135	128	133	139
MSPGCL Total Generation	6632	5791	7626	6761
Central Sector Receipt	8631	8811	8370	7461
WIND	465	647	251	474
CPP / IPP Thermal	4177	3935	3967	3926
CPP / IPP Gas	0	0	0	0
SOLAR	1935	2099	0	0
Exchange with Mumbai	-1791	-1828	-1933	-1895
MSEDCL DEMAND MET	19605	19002	17843	16303
Load Shedding	0	0	0	0
MSEDCL DEMAND	19605	19002	17843	16303
TPCL GENERATION	520	521	660	543
AEML GENERATION	153	148	182	160
MUMBAI DEMAND	2464	2497	2775	2598
OTHER DISCOM DEMAND	444	453	438	424
STATE DEMAND MET	22513	21952	21056	19325
STATE DEMAND	22513	21952	21056	19325
Frequency (Hz)	50.12	50.06	50.11	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.37 Hz at 10.02 Hrs	49.83 Hz at 05.39 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 12/Nov/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.00	49.84	135	90
Unit 8	13.11	112.91	622	383
Unit 9	12.94	158.10	592	375
Unit 10	13.05	166.88	600	386
Total	42.10	487.74		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	7.48	95.58	425	195
Unit 5	8.44	116.98	460	280
Total	15.92	212.56		
Parli				
Unit 6	4.01	58.34	247	124
Unit 7	4.10	46.31	245	144
Unit 8	4.15	62.80	250	142
Total	12.25	167.46		
Chandrapur				
Unit 3	3.34	42.35	160	121
Unit 4	3.26	43.24	148	122
Unit 5	9.26	124.35	460	305
Unit 6	7.64	99.22	365	265
Unit 7	7.62	93.32	352	282
Unit 8	9.56	130.54	479	274
Unit 9	10.03	133.20	478	302
Total	50.72	666.22		
Paras				
Unit 3	5.29	64.65	236	167
Unit 4	5.35	64.22	235	177
Total	10.64	128.87		
Khaparkheda				
Unit 1	3.78	38.30	185	120
Unit 2	3.11	33.04	137	118
Unit 3	4.16	44.46	183	139
Unit 4	0.00	36.95	0	0
Unit 5	11.08	128.70	470	450
Total	22.14	281.45		
Nasik				
Unit 3	3.16	34.59	150	120
Unit 4	3.13	39.41	148	122
Unit 5	0.00	25.59	0	0
Total	6.29	99.58		
Uran				
All Units	3.27	71.28	142	127
Total	3.27	71.28		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.87	11.16	39	36
Total	0.87	11.16		
Koyna				
Stage 1-2	1.12	25.28	130	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	12.96	0	0
Stage 3	0.39	9.06	80	0
Total	1.50	47.31		
Hydro				
KDPH	0.33	6.08	18	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.12	1.92	40	0
SMLHY_PTN	2.94	29.90	125	120
GHATGHAR	0.00	1.46	0	0
Total	3.39	39.36		
Wind				
Total	10.91	118.35	0	0
Total	10.91	118.35		
CPP				
APML(Mus)	24.19	679.06	0	0
JSWEL(Mus)	19.35	301.09	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	18.27	289.28	0	0
SWPGPL-Mus	9.26	124.08	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.33	64.40	270	187
Other(Mus)	23.47	180.79	0	0
JPL	0.00	4.81	0	0
Total	99.88	1643.50		
SOLAR				
Total	14.13	154.41	0	0
Total	14.13	154.41		
Tata				
Trombay 5	6.38	98.03	274	259
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.01	16.69	46	40
Trombay 7B	0.85	12.13	38	34
TATA Hydro	1.76	32.24	191	27
Trombay 8	3.21	52.38	157	130
Total	13.22	211.47		
AEML				
DTPS U-1&2	4.25	114.76	245	148
Total	4.25	114.76		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	160.05	2043.88	MSPGCL Total	169.09	2212.98
			MSPGCL Thml+Gas	163.32	2115.16	Koyna 1,2 & 4 Total	1.12	38.25
			MSPGCL Hydro	5.77	97.82	State Total	311.48	4455.47

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 12/Nov/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7106	220	140	7466	459	4518	0	0	9192	9071	-1938	19167	0	0	19167	2652	409	22228	49.99
2	7306	220	141	7667	524	4571	0	0	8845	8730	-1787	19307	0	0	19307	2470	398	22175	49.96
3	7204	219	141	7564	562	4443	0	0	9143	8588	-1618	19173	0	0	19173	2310	366	21849	49.99
4	6955	245	141	7341	600	4317	0	0	8909	8923	-1518	19299	0	0	19299	2200	364	21863	49.96
5	7166	305	141	7612	598	4429	0	0	8762	8859	-1399	19721	0	0	19721	2158	378	22257	49.95
6	7441	219	141	7801	596	4689	0	0	9419	9552	-1416	20821	0	0	20821	2198	401	23420	49.93
7	7493	279	142	7914	543	4864	0	28	9709	9370	-1483	20806	0	3	20806	2234	430	23470	49.99
8	7402	279	140	7821	473	4463	0	370	9317	8818	-1522	19985	0	4	19985	2248	438	22671	50.03
9	6980	261	138	7379	326	4272	0	1011	8635	8443	-1642	19336	0	0	19336	2302	453	22091	50.06
10	6435	216	137	6788	363	4215	0	1518	8669	8321	-1673	19077	0	4	19077	2369	455	21901	50.09
11	6280	217	135	6632	465	4177	0	1935	8951	8631	-1791	19605	0	4	19605	2464	444	22513	50.12
12	5692	217	132	6041	658	4101	0	2118	9071	8783	-1804	19437	0	0	19437	2500	460	22397	50.03
13	5446	217	128	5791	647	3935	0	2099	8739	8811	-1828	19002	0	0	19002	2497	453	21952	50.06
14	5536	217	129	5882	565	3773	0	1925	8695	8998	-1826	18892	0	3	18892	2491	425	21808	50.12
15	5763	223	127	6113	460	3783	0	1582	8878	9071	-1813	18750	0	3	18750	2522	446	21718	49.98
16	6560	311	130	7001	373	3887	0	1024	8850	8767	-1794	18814	0	1	18814	2549	444	21807	49.94
17	6851	294	131	7276	230	3954	0	454	8615	8421	-1769	18125	0	0	18125	2517	441	21083	49.97
18	6934	298	132	7364	234	3921	0	66	7863	8259	-1727	17669	0	0	17669	2551	448	20668	50.01
19	7205	288	133	7626	251	3967	0	0	8599	8370	-1933	17843	0	0	17843	2775	438	21056	50.11
20	6780	219	136	7135	279	3920	0	0	8591	8189	-1967	17136	0	0	17136	2772	420	20328	50.01
21	6509	199	136	6844	277	3909	0	0	7608	7600	-1916	16306	0	0	16306	2683	408	19397	49.98
22	6248	198	138	6584	436	3920	0	0	7540	7465	-1862	16135	0	0	16135	2615	408	19158	50.00
23	6419	203	139	6761	474	3926	0	0	7563	7461	-1895	16303	0	0	16303	2598	424	19325	49.99
24	6340	203	140	6683	518	3930	0	0	7593	7553	-1917	16343	0	0	16343	2627	424	19394	50.03
MUs	160.05	5.77	3.27	169.09	10.91	99.88	0.00	14.13	207.76	205.05	-41.84	447.05	0.00	0.02	447.05	59.30	10.17	516.53	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)Due to 25 MVA 132/33kV TF-1 & TF-2 are parallel & HV overload at 132kV Wadzire S/stn.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 12/Nov/2023

Position as on 6.30 Hrs of 13/Nov/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	15/02/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
AEML	AEML Unit 1	250	11/11/2023	21:17		Continued.	For Boiler license renewal	21/11/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
MSPGCL	Uran Unit 6	108	05/10/2023	00:29		Continued.	Gas shortage	
IPP	RPL(AMT) U-2	270	12/10/2023	07:59		Continued.	Tripped Due to Electrical protection opted.	20/11/2023
MSPGCL	Bhusawal Unit 3	210	31/10/2023	23:45		Continued.	ID Fan Problem	16/11/2023
IPP	JPL Unit 1	150	03/11/2023	00:01		Continued.	For attending Hotspot of 220 KV Evacuation Line	20/11/2023
IPP	SWPGPL U-3	135	09/11/2023	00:09		Continued.	SSC CHAIN PROBLEM.	14/11/2023
MSPGCL	Nasik Unit 5	210	09/11/2023	15:48		Continued.	ID Fan Problem	15/11/2023
MSPGCL	Khaparkheda Unit 4	210	10/11/2023	13:48		Continued.	Air heater 4A stopped rotating	15/11/2023
IPP	RPL(AMT) U-3	270	10/11/2023	14:00	13/11/2023	21:08	Master fuel tripped	13/11/2023
MSPGCL	Uran Unit 7	108	11/11/2023	00:14		Continued.	Gas shortage	
IPP	Adani U-3	660	11/11/2023	22:00		Continued.	Zero Schedule	16/11/2023
IPP	Adani U-2	660	12/11/2023	00:37		Continued.	Zero Schedule	16/11/2023
IPP	Adani U-1	660	12/11/2023	14:11		Continued.	Zero Schedule	16/11/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 13/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
400/11.5 KV 110MVA STN T/F 6A @ DEEPNAGAR	InterState	09/11/2023	15:36			PO	For alignment work of 89L isolator of Station Transformer 6A
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1) Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of $\Delta Y \Delta$ phase Protection CT Of NTPP I (RPL 1)
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/10/2023	08:04			HT	H/T for load management.
KHARGHAR - VIKHROLI GIS CKT - 1	IntraState	29/10/2023	04:43	13/11/2023	15:37	HT	Line Hand tripped for safety purpose during tap period of Katai nakka.
KHARGHAR - VIKHROLI GIS CKT - 2	IntraState	29/10/2023	04:45			HT	Line Hand tripped for safety purpose during tap period of Katai nakka.
JAIGAD - KARAD CKT - 1	IntraState	11/11/2023	23:55		Continued.	HT	H/T on overvoltage
DABHOL - NAGOTHANE CKT - 2	IntraState	12/11/2023	17:15	13/11/2023	00:19	T	Line tripped on distance protection.
KHADKA-AURANGABAD (WALUJ)	IntraState	12/11/2023	19:27		Continued.	HT	For overvoltage management.
LONIKAND I - KOYNA STAGE-IV	IntraState	12/11/2023	19:39	13/11/2023	08:41	HT	Handtripped to control over voltage.
NEW KOYNA-KARAD CKT - 2	IntraState	12/11/2023	20:11	13/11/2023	09:29	HT	Handtrip to contrl overvoltage.
LONIKAND 2 - KARJAT CKT - 2	IntraState	13/11/2023	19:23		Continued.	T	tripped on R and Y ph fault
LONIKAND 2 - KARJAT CKT - 1	IntraState	13/11/2023	19:23		Continued.	T	Tripped on R ph to Y ph fault
NEW KOYNA-KARAD CKT - 2	IntraState	13/11/2023	20:29			HT	Handtrip to control overvoltage.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	IntraState	23/10/2023	00:10	13/11/2023	12:58	EO	CHECKING AND TESTING OF TRANSFORMER
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	28/10/2023	22:20			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	28/10/2023	22:27			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	28/10/2023	22:32			PO	1) ICTs Hand tripped for safety purpose during tap period of Katai nakka 2) Removal of Tata Power 220KV Lines passing over Vikhroli Substation
220 KV LINE Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 12/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 13/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	26/10/2023	20:16			HT	Charged from Navsary end only
KALWA - BORIVALI	IntraState	12/11/2023	02:51	12/11/2023	11:13	PO	Replacement of old rusted hardwares at critical crossing locations i.e. at TL no. 17, 18 & 19 (Total 60/60 sets are balance)
BORIVALI - CTRLS CKT	IntraState	12/11/2023	03:15	12/11/2023	09:43	PO	Replacement of old rusted hardwares at critical crossing locations i.e. at TL no. 17, 18 & 19 (Total 60/60 sets are balance)
BUTIBORI-SUNVIJAY	IntraState	12/11/2023	10:57	12/11/2023	11:57	EO	220kV Y-Phase Alstom SF6 Breaker Pole at Sunvijay End.
MAHALAXMI - AMONA	IntraState	12/11/2023	20:08	13/11/2023	07:57	T	Tripped due to overvoltage.
TILLARI - AMONA LINE	IntraState	12/11/2023	20:15	13/11/2023	07:57	T	Tripped due to overvoltage.
NEW KOYNA - PEDAMBE	IntraState	12/11/2023	20:16	12/11/2023	21:33	T	Tripped on back up protection,
ADLABS - PEDAMBE	IntraState	12/11/2023	20:16	12/11/2023	23:40	T	Y ph CT burst at Pedhambe end of Nerle end . so other lines tripped on backup
NERLE - PEDAMBE	IntraState	12/11/2023	20:16			T	Y ph CT burst at Pedhambe end of Nerle line
PEDHAMBE ONI LINE	IntraState	12/11/2023	20:16	13/11/2023	18:18	T	Y ph CT burst at Pedhambe end of Nerle end . so other lines tripped on backup
POPHLI PEDHMBE LINE- 2	IntraState	12/11/2023	20:16	13/11/2023	01:10	T	Y ph CT burst at Pedhambe end of Nerle line . so other lines tripped on backup
JEJURI - BARAMATI	IntraState	13/11/2023	01:25	13/11/2023	01:41	T	Line tripped from Jejuri end only due to bursting of Bph CT of 220KV Kalyani-Baramati Agro line.
KALYANI - BARAMATI AGRO	IntraState	13/11/2023	01:25	13/11/2023	21:25	T	B ph CT burst at Kalyani end of Baramati Agro line
BARAMATI- KALYANI	IntraState	13/11/2023	01:25	13/11/2023	02:49	T	B phase CT burst of Baramati Agro line at Kalyani end.
BOMBAY DYEING - SAHARA	IntraState	13/11/2023	10:51	13/11/2023	17:17	PO	For OPGW installation work from T. No 116 ȳ T. No .126.The condition of existing earth wire is not good in this section . Hence, Shutdown is proposed The condition of existing earth wire is not good in this section .
LAMBOTI - TULJAPUR CKT - 2	IntraState	13/11/2023	12:10	13/11/2023	13:10	EO	TO ATTEND DC LEAKAGE
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132kV 100MVA ICT-3 @ SATARA MIDC-220 KV	IntraState	13/11/2023	10:07	13/11/2023	14:33	PO	1.Diagnostic Testing Work 2.Quarterly Maintenance Work
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
AUXILIARY BUS @ PADGHE	IntraState	14/09/2023	10:32			PO	For making twin bus conductor arrangements of 220kV Aux. Bus in upper section .
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	22/09/2023	07:10			HT	H/T FOR LOAD MANAGEMENT
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 12/Nov/2023

Statement-VII

Position as on 6.30 Hrs of 13/Nov/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
WAGHIVALI - MANKHURD	IntraState	12/11/2023	09:36	12/11/2023	11:00	PO	PROJECT WORK-GUARD WIRE DISMANTALLING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage