

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 12/Dec/2019 THURSDAY**

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	151.760	1529.839	1) Gujrat	4.353	56.030
2) Hydro	7.955	192.553	2) Madhya Pradesh	9.336	117.372
3) Gas	6.293	94.634	3) Chattisgarh	6.390	83.170
<b>Total MSPGCL</b>	<b>166.008</b>	<b>1817.026</b>	4) Maharashtra	130.529	1405.071
B) 1) APLM	70.029	888.163	5) Goa (Amona)	-0.704	-8.492
2) JSWEL	16.199	274.441	<b>Total</b>	<b>149.904</b>	<b>1653.151</b>
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.063	337.677
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	31.768	362.124
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	28.766	362.743
6) Other IPP	14.008	165.916	Include PX	8.097	92.128
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.063	337.677
C) 1) TPCL Thermal	8.784	117.129	Include PX	15.057	125.370
2) TPCL Hydro	5.903	64.095	Standby	0.000	0.000
3) TPCL Gas	2.423	37.489	<b>H) ENERGY CATERED (MUs)</b>		
4) AEML Thermal	10.251	129.248	1) MSEDCL	396.780	4642.325
D) STATE			2) Mumbai Discoms	59.129	710.084
1) Thermal	271.031	3104.736	<b>TOTAL STATE</b>	<b>455.909</b>	<b>5352.409</b>
(A1+C1+C4+(B1-B6))					
2) Hydro	13.858	256.648			
(A2+C2)					
3) Gas	8.716	132.123			
(A3+B7+C3)					
4) Wind	7.310	144.837			
6) SOLAR	5.090	60.915			
<b>TOTAL STATE</b>	<b>306.005</b>	<b>3699.259</b>			

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6730	6727	6638	5691
MSPGCL Hydro	599	385	112	95
MSPGCL Gas	278	247	237	286
MSPGCL Total Generation	7607	7359	6987	6072
Central Sector Receipt	7362	7125	5931	5259
WIND	229	194	383	308
CPP / IPP Thermal	4661	4612	4522	3705
CPP / IPP Gas	0	0	0	0
SOLAR	804	758	0	0
Exchange with Mumbai	-1569	-1509	-1640	-996
<b>MSEDCL DEMAND MET</b>	<b>19094</b>	<b>18539</b>	<b>16183</b>	<b>14348</b>
Load Shedding	0	0	0	0
MSEDCL DEMAND	19094	18539	16183	14348
TPCL GENERATION	949	947	807	421
AEML GENERATION	501	502	373	373
<b>MUMBAI DEMAND</b>	<b>3019</b>	<b>2958</b>	<b>2820</b>	<b>1790</b>
STATE DEMAND MET	22113	21497	19003	16138
<b>STATE DEMAND</b>	<b>22113</b>	<b>21497</b>	<b>19003</b>	<b>16138</b>
Frequency (Hz)	50.04	49.93	50.05	49.97

**FREQUENCY PARTICULARS**

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.26 Hz at 06.02 Hrs	49.73 Hz at 12.40 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation, Maximum, Minimum for 12/Dec/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Koradi</b>				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	12.03	143.54	556	460
Unit 9	11.94	143.12	550	460
Unit 10	10.81	69.79	520	400
<b>Total</b>	<b>34.78</b>	<b>356.45</b>		
<b>Bhusawal</b>				
Unit 3	0.00	0.00	0	0
Unit 4	9.57	84.65	460	360
Unit 5	9.72	96.48	465	360
<b>Total</b>	<b>19.28</b>	<b>181.14</b>		
<b>Parli</b>				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.45	67.01	255	190
Unit 7	5.36	44.21	248	194
Unit 8	5.34	50.86	246	188
<b>Total</b>	<b>16.16</b>	<b>162.08</b>		
<b>Chandrapur</b>				
Unit 3	4.28	50.21	190	164
Unit 4	3.70	40.80	170	130
Unit 5	8.75	105.75	370	347
Unit 6	9.54	125.48	475	360
Unit 7	0.00	0.00	0	0
Unit 8	10.54	125.73	480	360
Unit 9	10.22	124.83	470	360
<b>Total</b>	<b>47.02</b>	<b>572.80</b>		
<b>Paras</b>				
Unit 3	4.21	4.21	220	50
Unit 4	3.50	3.50	220	0
<b>Total</b>	<b>7.72</b>	<b>7.72</b>		
<b>Khaparkheda</b>				
Unit 1	3.86	10.38	185	140
Unit 2	4.06	11.52	180	130
Unit 3	4.21	12.04	200	160
Unit 4	4.20	47.05	197	160
Unit 5	9.89	121.92	485	360
<b>Total</b>	<b>26.22</b>	<b>202.90</b>		
<b>Nasik</b>				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.58	46.76	62	0
<b>Total</b>	<b>0.58</b>	<b>46.76</b>		
<b>Uran</b>				
All Units	6.29	94.63	297	228
<b>Total</b>	<b>6.29</b>	<b>94.63</b>		
<b>PGPL</b>				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
<b>Total</b>	<b>0.00</b>	<b>0.00</b>		
<b>PENCH (MS)</b>				
Pench (MS)	0.06	1.33	24	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Total</b>	<b>0.06</b>	<b>1.33</b>		
<b>Koyna</b>				
Stage 1-2	3.35	56.06	385	25
Stage 4	1.94	90.43	518	0
Stage 3	0.69	30.55	160	0
<b>Total</b>	<b>5.97</b>	<b>177.04</b>		
<b>Hydro</b>				
KDPH	0.44	0.59	19	18
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.39	3.81	80	0
RNGR+BHTSA	0.40	4.46	17	16
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.45	3.23	19	18
GHATGHAR	0.30	3.42	125	0
<b>Total</b>	<b>1.98</b>	<b>15.51</b>		
<b>Wind</b>				
Total	7.31	144.84	0	0
<b>Total</b>	<b>7.31</b>	<b>144.84</b>		
<b>CPP</b>				
APML(Mus)	70.03	888.16	0	0
JSWEL(Mus)	16.20	274.44	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	14.01	165.92	0	0
<b>Total</b>	<b>100.24</b>	<b>1328.52</b>		
<b>SOLAR</b>				
Total	5.09	60.92	0	0
<b>Total</b>	<b>5.09</b>	<b>60.92</b>		
<b>Tata</b>				
Trombay 5	8.78	117.03	473	296
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.35	22.32	75	49
Trombay 7B	1.07	15.16	54	40
Trombay 8	0.00	0.10	0	0
TATA Hydro	5.90	64.10	459	0
<b>Total</b>	<b>17.11</b>	<b>218.71</b>		
<b>AEML</b>				
DTPS U-1&2	10.25	129.25	502	371
<b>Total</b>	<b>10.25</b>	<b>129.25</b>		

* Infirm Power		
Particulars	Daily (Mus)	Monthly

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	151.76	1529.84
MSPGCL Thml+Gas	158.05	1624.47
MSPGCL Hydro	7.96	192.55

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	166.01	1817.03
Koyna 1,2 & 4 Total	5.29	146.49
State Total	306.00	3699.26

# State Load Despatch Center, Airoli (MSETCL)

# Annexure-2

## Hourly Load Data As on 12/Dec/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDING	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5726	275	285	6286	310	3722	0	0	5470	5473	-1344	14447	0	14447	2131	16578	49.97
2	5786	80	295	6161	281	3757	0	0	5370	5381	-1170	14410	0	14410	1970	16380	49.99
3	5779	90	287	6156	322	3761	0	0	5335	5113	-1076	14276	0	14276	1872	16148	50.03
4	5691	95	286	6072	308	3705	0	0	5357	5259	-996	14348	0	14348	1790	16138	49.97
5	5867	300	286	6453	283	3676	0	0	5458	5560	-994	14978	0	14978	1788	16766	50.01
6	6387	315	297	6999	306	3938	0	0	6168	6160	-988	16415	0	16415	1876	18291	50.01
7	6715	353	289	7357	322	4265	0	0	6577	6530	-869	17605	0	17605	2044	19649	50.00
8	6717	958	286	7961	278	4265	0	76	6556	6610	-796	18394	0	18394	2216	20610	49.89
9	6792	699	288	7779	206	4264	0	301	6807	6801	-1011	18340	0	18340	2482	20822	49.99
10	6847	642	283	7772	184	4285	0	561	7004	6963	-1329	18436	0	18436	2788	21224	49.94
11	6830	782	280	7892	178	4596	0	714	7171	7105	-1515	18970	0	18970	2972	21942	50.01
12	6730	599	278	7607	229	4661	0	804	7568	7362	-1569	19094	0	19094	3019	22113	50.04
13	6727	385	247	7359	194	4612	0	758	7350	7125	-1509	18539	0	18539	2958	21497	49.93
14	6656	302	238	7196	213	4636	0	670	7223	7130	-1545	18300	0	18300	2831	21131	49.94
15	6555	525	237	7317	241	4655	0	610	7369	7163	-1561	18425	0	18425	2864	21289	50.00
16	6680	213	238	7131	313	4639	0	395	7459	7149	-1398	18229	0	18229	2885	21114	50.03
17	6636	144	239	7019	269	4515	0	179	7154	6977	-1492	17467	0	17467	2852	20319	50.02
18	6394	293	228	6915	274	4477	0	22	6379	6674	-1580	16782	0	16782	2798	19580	50.03
19	6638	112	237	6987	383	4522	0	0	6066	5931	-1640	16183	0	16183	2820	19003	50.05
20	6274	253	238	6765	377	4380	0	0	5930	5610	-1568	15564	0	15564	2717	18281	50.03
21	5862	228	238	6328	427	3984	0	0	5690	5409	-1417	14731	0	14731	2551	17282	49.98
22	5851	108	238	6197	483	3840	0	0	5869	5399	-1492	14427	0	14427	2408	16835	50.05
23	5821	97	237	6155	446	3576	0	0	5203	5411	-1498	14090	0	14090	2303	16393	50.02
24	5799	107	238	6144	483	3505	0	0	5446	5609	-1411	14330	0	14330	2194	16524	50.03
<b>MUs</b>	<b>151.76</b>	<b>7.95</b>	<b>6.29</b>	<b>166.01</b>	<b>7.31</b>	<b>100.24</b>	<b>0.00</b>	<b>5.09</b>	<b>151.98</b>	<b>149.90</b>	<b>-31.77</b>	<b>396.78</b>	<b>0.00</b>	<b>396.78</b>	<b>59.13</b>	<b>455.91</b>	<b>50.00</b>

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center, Airoli (MSETCL) Statement-VI**  
**Details of Generating Unit Outages/Trippings for 12/Dec/2019**

Position as on 6.30 Hrs of 13/Dec/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
<b>PLANNED OUTAGE</b>								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn On Shaft Seal Water Leakage. Converted to AOH From 1 Nov 2019.	
MSPGCL	Koyna Unit 7	80	31/10/2019	16.30		Continued.	Turbine Vibration(converted to Capital Overhaul for 60 Days from 09.00Hrs DT.01-11-2019)	
MSPGCL	Nasik Unit 4	210	20/11/2019	04.15		Continued.	ID Fan Problem(Converted for Zero Schedule from 05.00hrs DT. 21-11-2019 and Continued for Annual Overhaul From 01.12.2019	
TPC_G	Trombay 8	250	01/12/2019	00.50		Continued.	Annual Overhaul	
MSPGCL	Koyna STG-IV Unit-4	250	06/12/2019	12.00		Continued.	Annual Overhaul	
<b>FORCED OUTAGE</b>								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45	12/12/2019	02.38	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57	13/12/2019	04.45	Under Case 4 Bidding.	
MSPGCL	Paras Unit 3	250	23/10/2019	00.00	12/12/2019	00.05	Zero Schedule	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	09/11/2019	03.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 12/Dec/2019**

Position as on 6.30 Hrs of 13/Dec/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 8	108	30/11/2019	19.14		Continued.	Over Speed Bolt Trip.	
MSPGCL	Uran Unit B0	120	07/12/2019	07:14		Continued.	Gas shortage	
MSPGCL	Uran Unit 7	108	07/12/2019	07:14		Continued.	Gas shortage	
IPP	JSW (J) U1	300	11/12/2019	23.58		Continued.	Governing Valve Rectification Work	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 04.25Hrs DT. 13-12-2019)	
IPP	Adani U-5	660	13/12/2019	20.01		Continued.	Due to APH Bellow Oil Leakage.	

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 12/Dec/2019**

**Statement-VII**

Position as on 6.30 Hrs of 13/Dec/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
<b>765 KV ICT Outages/Trippings</b>							
765/400KV 500MVA SPARE ICT UNIT @ AURANGABAD (EKTUNI)	IntraState	12/12/2019	11.36	12/12/2019	23.21	PO	To Remove The bearing Casting Holding of 400KV Isolator of Spare Ict Unit, TO Be Used as Replacement For Damaged For Bearing Casting Holding of Y Ph Isolator Pole of 400KV Taptitanda Ckt 1.
765/400kv 1500MVA ICT @ Akola-II	IntraState	13/12/2019	09.02	13/12/2019	19.57	PO	CSD Commissioning Activities.
<b>400 KV LINE Outages/Trippings</b>							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	11/12/2019	19.07	12/12/2019	07.03	HT	Over Voltage
Parli(MS)-Parli (PG) I	InterState	12/12/2019	10.25	12/12/2019	23.29	EO	CT Testing Work.
Dabhol Nagothane I	InterState	12/12/2019	10.43		Continued.	PO	RPH CT Leakage Attend Work. (Replacement of faulty string dt:13/12/2019 at 09:40 hrs.)
Padgha - Boisar (PG)	InterState	12/12/2019	15.37	12/12/2019	20.38	PO	Hot Spot Isolator Attending Work.
Dhule Sar'Sarovar I	InterState	12/12/2019	18.07	13/12/2019	08.14	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	13/12/2019	18.46		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	03/12/2019	09.54		Continued.	PO	Construction Work
Koradi-Bhusawal	IntraState	04/12/2019	08.41		Continued.	PO	Restringing of Conductor
Deepnagar - Aurangabad	IntraState	12/12/2019	09.21	12/12/2019	15.58	PO	Replacement of Faulty String & AMC Work.
Lonikand2-Lonikand1 (Intrconector)	IntraState	12/12/2019	12.38	12/12/2019	19.10	PO	Half yearly maintenance work
Kalwa - Talegaon(PG)	IntraState	13/12/2019	03.58	13/12/2019	07.37	PO	Plastic Remove From Tower.
Deepnagar Waluj 1	IntraState	13/12/2019	07.44	13/12/2019	13.01	PO	Replacement Of Faulty String.
Warora-Tirora-li	IntraState	13/12/2019	10.09	13/12/2019	17.51	PO	Maintenance Work.
Chandrapur II - Chandrapur SW Ckt I	IntraState	13/12/2019	11.11	13/12/2019	13.22	EO	For Attending heavy Arcing Sound in Regular Interval At YPH 89 A isolator by Hotline.
<b>400 KV ICT Outages/Trippings</b>							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 315 Mva Ict 1 @Parali (Girwali)	IntraState	10/12/2019	10.27		Continued.	PO	For Replacment Of Y-PH UNIT By Overhauled Unit.
400/220/33kv 315MVA ICT2 @Lonikand	IntraState	12/12/2019	11.31	12/12/2019	17.42	PO	Diagnostic Testing & Maintenance Work.
<b>220 KV LINE Outages/Trippings</b>							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
EKLAHARE (OCR) Nasik Navsari II	InterState	12/12/2019	08.48	12/12/2019	18.41	PO	Insulator Replacement Work
EKLAHARE (OCR) Nasik - Navsari I	InterState	13/12/2019	09.37	13/12/2019	15.41	PO	Replacement Of OLD Disc Insulator.
Aurangabad PG (Chitepimpalgaon)-Chitegaon Ckt-II	InterState	13/12/2019	10.25	13/12/2019	19.18	PO	Routine Maintenance Work & Diagnostic Testing.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Pophali - Pedambe II	IntraState	11/12/2019	22.25	12/12/2019	01.55	PO	Replacement of Burnt Conductor of Y Phase Junction Bay Isolator To 2nd Stage Main Bus Side.
Pophali - Nerale	IntraState	11/12/2019	22.40	12/12/2019	02.35	PO	Replacement of Burnt Conductor of Y Phase Junction Bay Isolator To 2nd Stage Main Bus Side.
Pophali - New Koyna	IntraState	11/12/2019	22.45	12/12/2019	02.27	PO	Replacement of Burnt Conductor of Y Phase Junction Bay Isolator To 2nd Stage Main Bus Side.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 12/Dec/2019**

**Statement-VII**

Position as on 6.30 Hrs of 13/Dec/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Bus Section II @ Pophali	IntraState	11/12/2019	23.00	12/12/2019	02.00	PO	Replacement of Burnt Conductor of Y Phase Junction Bay Isolator To 2nd Stage Main Bus Side.
Siemens - Mahape	IntraState	12/12/2019	08.30	12/12/2019	12.39	PO	As The Clipping of OPGW Cable at LOC No. Lilo 1 Get Slips.
Eklahara-(Ocr)(Nashik)-Navasari I	IntraState	12/12/2019	08.48	12/12/2019	18.41	PO	Replacement of Old Disc Insulator By Procprocelain Long Rod Insulator.
Chandrapur GCR - Warora - I	IntraState	12/12/2019	09.27	12/12/2019	09.35	PO	In View of Ict 2 Outage.
Miraj - Mhaishal	IntraState	12/12/2019	09.30	12/12/2019	14.15	PO	String Replacement Work at Loc No. 35 of TPH.
Phursungi-Parvati	IntraState	12/12/2019	09.36	12/12/2019	16.38	PO	Half yearly maintenance work
Taladge(400)- Mudshingi 2 Line	IntraState	12/12/2019	10.01	12/12/2019	13.08	PO	Relay Testing Work & Annual Maintenance Work.
Jamde-Dondaicha 2	IntraState	12/12/2019	11.05	12/12/2019	13.34	PO	Replacement of Autoreclose Relay Work.
Nanded-Parbhani	IntraState	12/12/2019	11.44	12/12/2019	17.26	HT	Outage On Nanded - Nanded Ckt 2.
Nagothane - ACCIL	IntraState	12/12/2019	11.55	12/12/2019	17.20	PO	Tree Cutting.
Nanded-Nanded(Waghale) II	IntraState	12/12/2019	12.25	12/12/2019	15.12	PO	Diagnostic Testing Work.
Trombay - Mulund	IntraState	12/12/2019	14.44	12/12/2019	16.46	EO	Attending Hot Spot
Nanded-Nanded(Waghale) I	IntraState	12/12/2019	15.23	12/12/2019	17.18	PO	Diagnostic Testing Work.
Kandalgaon - ONGC Panvel	IntraState	12/12/2019	16.20	12/12/2019	18.55	PO	Distance Protection
Butibori - Khaperkheda	IntraState	13/12/2019	05.03		Continued.	T	Distance Protection
Apta - Tambati	IntraState	13/12/2019	07.40	13/12/2019	11.55	PO	Relay Testing Work.
Padghe - Nalasopara	IntraState	13/12/2019	08.31		Continued.	PO	Erection of New Tower.
Vita - Mhaishal	IntraState	13/12/2019	09.37	13/12/2019	16.15	PO	String Replacement Work.
Warora - Hinganghat	IntraState	13/12/2019	10.59	13/12/2019	17.07	PO	Diagnostic Testing Work.
Kolhapur-Bidri	IntraState	13/12/2019	11.19	13/12/2019	17.43	PO	Tan Delta Testing.
Kandalgaon - ONGC Panvel	IntraState	13/12/2019	11.20	13/12/2019	13.17	PO	measuring IR values Of LA.
Chalisingaon - Deepnagar	IntraState	13/12/2019	11.53	13/12/2019	12.12	T	Distance Protection
Koradi-Khaperkheda	IntraState	13/12/2019	12.05	13/12/2019	16.26	PO	Coal Pipe Conveyor Galleries Erection Work.
Raymond - Washala	IntraState	13/12/2019	12.42	13/12/2019	12.50	T	Distance Protection
Kalwa1- Airoli Knowledge Park	IntraState	13/12/2019	14.34	13/12/2019	17.33	PO	Crane Passing Work.
Kandalgaon - Bhira	IntraState	13/12/2019	14.55	13/12/2019	16.55	PO	LA LCM Measurement.
<b>220 KV ICT Outages/Trippings</b>							
220/132 Kv 200 Mva Vijai Ict 1 @Ranjangaon	IntraState	12/12/2019	00.43	12/12/2019	19.45	PO	Repare of OLTC Tap Changer.
220/132 Kv 200 MVA ICT III @Ambazari	IntraState	12/12/2019	10.08	12/12/2019	17.48	PO	CTR Trial.
220/132 Kv 150 Mva Emco Ict 1 @Ambazari	IntraState	13/12/2019	11.04	13/12/2019	15.26	PO	For Taking Trial Of CTR System.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage