

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 13/Jan/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	142.664	1912.729	1) Gujrat	-5.222	-87.447
2) Hydro	11.817	144.015	2) Madhya Pradesh	4.595	73.675
3) Gas	4.336	53.854	3) Chattisgarh	5.680	76.000
Total MSPGCL	158.817	2110.598	4) Maharashtra	130.322	1660.049
B) 1) APML	69.464	896.859	5) Goa (Amona)	-1.177	-18.512
2) JSWEL	13.366	178.294	Total	134.198	1703.765
3) VIPL	0.000	0.000	a) Mumbai Schedule	18.601	279.582
4) RPL(AMT)	26.521	342.735	b) Mumbai Drawl	21.539	301.518
5) SWPGPL	6.139	64.485	c) MSEDCL Bilateral *	56.799	705.514
6) Other IPP	38.714	504.460	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	18.575	279.459
C) 1) TPCL Thermal	9.858	130.038	Include PX	0.000	0.000
2) TPCL Hydro	4.182	53.409	Standby	0.026	0.123
3) TPCL Gas	0.000	9.340	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.729	119.012	1) MSEDCL	431.593	5573.659
D) STATE			2) Mumbai Discoms	44.308	613.316
1) Thermal	315.455	4148.612	3) Other Discoms	8.218	117.235
(A1+C1+C4+(B1-B6))			TOTAL STATE	484.119	6304.210
2) Hydro (A2+C2)	15.999	197.424			
3) Gas (A3+B7+C3)	4.336	63.194			
4) Wind	8.507	111.300			
6) SOLAR	5.624	79.916			
TOTAL STATE	349.921	4600.446			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6722	6761	6472	4814
MSPGCL Hydro	1187	473	427	323
MSPGCL Gas	158	145	235	252
MSPGCL Total Generation	8067	7379	7134	5389
Central Sector Receipt	7751	7261	5012	4757
WIND	160	211	314	256
CPP / IPP Thermal	6984	6836	6904	5544
CPP / IPP Gas	0	0	0	0
SOLAR	708	876	0	0
Exchange with Mumbai	-1183	-1305	-800	-832
MSEDCL DEMAND MET	22119	20911	18190	14780
Load Shedding	0	0	0	0
MSEDCL DEMAND	22119	20911	18190	14780
TPCL GENERATION	759	637	923	395
AEML GENERATION	407	341	487	333
MUMBAI DEMAND	2349	2283	2210	1560
OTHER DISCOM DEMAND	368	347	374	334
STATE DEMAND MET	24836	23541	20774	16674
STATE DEMAND	24836	23541	20774	16674
Frequency (Hz)	50.04	50.01	50.01	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.22 Hz at 06:02 Hrs	49.8 Hz at 09:07 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 13/Jan/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.20	34.72	165	115
Unit 7	0.00	0.00	0	0
Unit 8	13.43	175.74	594	403
Unit 9	13.59	140.66	609	375
Unit 10	11.42	150.20	543	380
Total	41.64	501.32		
Bhusawal				
Unit 3	3.25	32.21	170	115
Unit 4	0.00	100.73	0	0
Unit 5	8.23	108.90	415	285
Total	11.48	241.84		
Parli				
Unit 6	4.27	48.76	230	153
Unit 7	3.47	49.39	184	97
Unit 8	3.99	51.48	204	143
Total	11.73	149.63		
Chandrapur				
Unit 3	3.24	33.20	158	98
Unit 4	3.27	42.99	158	118
Unit 5	7.59	101.02	350	285
Unit 6	7.96	111.34	390	263
Unit 7	2.74	56.75	312	0
Unit 8	9.47	126.96	445	283
Unit 9	9.37	123.55	450	280
Total	43.64	595.81		
Paras				
Unit 3	4.13	55.82	224	136
Unit 4	4.16	54.04	232	137
Total	8.28	109.86		
Khaparkheda				
Unit 1	2.92	29.14	135	110
Unit 2	0.00	0.00	0	0
Unit 3	3.30	45.06	153	123
Unit 4	3.34	43.47	155	124
Unit 5	9.91	124.85	500	280
Total	19.48	242.52		
Nasik				
Unit 3	3.19	35.84	176	107
Unit 4	0.00	18.28	0	0
Unit 5	3.23	17.63	177	116
Total	6.42	71.75		
Uran				
All Units	4.34	53.85	252	144
Total	4.34	53.85		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.18	4.13	32	0
Total	0.18	4.13		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.87	29.87	365	30
Stage 4	1.56	16.80	498	0
Stage 3	0.99	10.64	240	0
Total	4.42	57.30		
Hydro				
KDPH	0.43	1.98	18	18
VTRNA	0.80	5.98	60	0
TILLARI	0.52	6.79	58	0
BHIRA T.R.	0.26	3.27	70	0
SMLHY_PTN	5.38	68.70	234	211
GHATGHAR	0.00	0.00	0	0
Total	7.40	86.72		
Wind				
Total	8.51	111.30	0	0
Total	8.51	111.30		
CPP				
APML(Mus)	69.46	896.86	0	0
JSWEL(Mus)	13.37	178.29	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	26.52	342.74	0	0
SWPGPL-Mus	6.14	64.48	0	0
Other(Mus)	38.71	504.46	0	0
Total	154.20	1986.83		
SOLAR				
Total	5.62	79.92	0	0
Total	5.62	79.92		
Tata				
Trombay 5	6.64	85.18	401	258
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	5.17	0	0
Trombay 7B	0.00	4.17	0	0
Trombay 8	3.22	44.86	169	128
TATA Hydro	4.18	53.41	359	0
Total	14.04	192.79		
AEML				
DTPS U-1&2	8.73	119.01	499	299
Total	8.73	119.01		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	142.66	1912.73	MSPGCL Total	158.82	2110.60
			MSPGCL Thml+Gas	147.00	1966.58	Koyna 1,2 & 4 Total	3.43	46.66
			MSPGCL Hydro	11.82	144.02	State Total	349.92	4600.45

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 13/Jan/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4998	294	161	5453	399	5603	0	0	4881	4705	-702	15151	0	15151	1399	307	16857	50.00
2	5086	288	151	5525	468	5599	0	0	4758	4464	-562	15212	0	15212	1308	282	16802	49.98
3	5253	282	151	5686	500	5583	0	0	4690	4287	-484	15289	0	15289	1253	283	16825	50.00
4	5456	281	162	5899	526	5584	0	0	4743	4214	-513	15440	0	15440	1216	270	16926	49.99
5	5412	282	151	5845	492	5634	0	0	4843	4558	-468	15772	0	15772	1239	289	17300	49.98
6	5657	288	152	6097	472	6253	0	0	4927	4913	-587	16840	0	16840	1337	308	18485	49.96
7	5934	278	161	6373	517	6784	0	1	5113	5007	-638	17713	0	17713	1472	331	19516	50.02
8	6369	498	151	7018	417	7005	0	41	5544	5689	-737	19075	0	19075	1685	358	21118	50.00
9	6589	1289	151	8029	308	6971	0	261	6015	5827	-916	20089	0	20089	1977	391	22457	50.02
10	6675	1326	150	8151	194	7030	0	519	7120	7461	-1064	21921	0	21921	2202	370	24493	49.98
11	6722	1187	158	8067	160	6984	0	708	7862	7751	-1183	22119	0	22119	2349	368	24836	50.04
12	6703	881	146	7730	157	6908	0	795	7702	7772	-1278	21727	0	21727	2357	357	24441	50.06
13	6761	473	145	7379	211	6836	0	876	7227	7261	-1305	20911	0	20911	2283	347	23541	50.01
14	6337	388	144	6869	314	6750	0	814	7076	6756	-1193	19972	0	19972	2144	338	22454	50.05
15	6422	384	145	6951	334	6781	0	710	7001	6635	-1207	19854	0	19854	2123	350	22327	50.02
16	6261	383	150	6794	331	6807	0	560	6827	6520	-1190	19465	0	19465	2102	357	21924	49.96
17	5997	391	206	6594	290	6817	0	282	6070	5985	-1118	18479	0	18479	2099	371	20949	50.00
18	6106	395	241	6742	258	6723	0	57	5395	5532	-986	17948	0	17948	2117	378	20443	50.01
19	6472	427	235	7134	314	6904	0	0	4843	5012	-800	18190	0	18190	2210	374	20774	50.01
20	6452	418	239	7109	404	6942	0	0	5036	4772	-825	18024	0	18024	2190	378	20592	49.99
21	6104	338	239	6681	451	6763	0	0	4851	4106	-944	16696	0	16696	2062	361	19119	49.99
22	5162	365	252	5779	434	5900	0	0	5222	5201	-1013	15937	0	15937	1901	364	18202	50.01
23	4922	358	243	5523	300	5499	0	0	5213	5013	-994	14989	0	14989	1723	352	17064	49.94
24	4814	323	252	5389	256	5544	0	0	4944	4757	-832	14780	0	14780	1560	334	16674	50.00
MUs	142.66	11.82	4.34	158.82	8.51	154.20	0.00	5.62	137.90	134.20	-21.54	431.59	0.00	431.59	44.31	8.22	484.12	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 13/Jan/2022

Position as on 6.30 Hrs of 14/Jan/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	07/01/2022	23:55	13/01/2022	08:01	Condenser tube checking, Inspection of Emergency Governer.	
MSPGCL	Bhusawal Unit 4	500	13/01/2022	00:00		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26	13/01/2022	19:05	No schedule.	
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	04/01/2022	19:40		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	04/01/2022	20:00		Continued.	Gas shortage	
MSPGCL	Nasik Unit 4	210	07/01/2022	22:00		Continued.	CONDENSER TUBE LEAKAGE	
MSPGCL	Uran Unit 5	108	10/01/2022	05:48	13/01/2022	15:36	Gas shortage	
MSPGCL	Koyna Unit 6	80	13/01/2022	05:40		Continued.	heavy oil leakage at bypass valve of spherical valve	
IPP	SWPGL U-2	135	13/01/2022	08:00		Continued.	ID Fan Problem	
MSPGCL	Chandrapur Unit 7	500	13/01/2022	18:36	13/01/2022	22:27	Over Speed Protection optd.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 14/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400KV 500MVA SPARE ICT UNIT @ EKTUNI	IntraState	13/01/2022	10:52	13/01/2022	16:50	PO	"Diagnostic Testing & Routine Maintenance work "(765/400KV 500MVA SPARE ICT UNIT @ EKTUNI)
400 KV TIEBAY Outages/Trippings							
TIE BREAKER (411) OF KORADI CKT 1 AND STATION TF-2 @ NANDGAONPETH	InterState	12/01/2022	05:54			PO	Circuit Breaker SF6 gas pressure getting low in 'B' phase of Tie breaker (411).Leakage point is identified. Hence, rectification of issue is essential. Trials shall be taken after NRV replacement and gas filling work.
400 KV MAINBAY Outages/Trippings							
Main Bay 412 of Chadrapur II ckt 2 @ C'pur Sw.	IntraState	13/01/2022	10:36	13/01/2022	12:44	PO	for Diagnostic testing & allied bay maintenance work
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	21/12/2021	12:35			HT	HAND TRIPPED TO CONTROL LINE LOADING OF 400KV TALEGAON-KALWA AND 400KV TALEGAON - KHARGHAR CKT
KORADI - KHAPERKHEDA CKT - 1	IntraState	10/01/2022	10:38			PO	Retrofitting of Distance Relay I & II under MTAMC Project
NAGOTHANE - DABHOL CKT - 1	IntraState	11/01/2022	08:52	13/01/2022	10:17	PO	Earthwire replacement Work & cold washing work
LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	IntraState	12/01/2022	09:08	13/01/2022	00:57	PO	03 Nos of master trip relay replacement work under MTAMC Project.
NAGOTHANE - DABHOL CKT - 1	IntraState	12/01/2022	11:48			PO	Earthwire replacement Work & cold washing work
BABHALESHWAR - PADGHE CKT-1	IntraState	12/01/2022	21:46	13/01/2022	00:48	T	padghe-z-1,R,2.4kA,153 km BBLR-z-1,R,9.38kA,20.7 km
CHANDRAPUR 2 - WARORA CKT-2	IntraState	13/01/2022	08:58	13/01/2022	18:57	PO	For Conductor & Earthwire H/W tightening work
JAIGAD - NEW KOYNA CKT - 2	IntraState	13/01/2022	10:00	13/01/2022	18:05	PO	Diagnostic testing & Relay testing work & Routine maint. Work
JAIGAD - KARAD CKT - 2	IntraState	13/01/2022	21:21			HT	HT OV
KHADKA - BABLESHWAR	IntraState	13/01/2022	23:045	13/01/2022	23:58	T	TRIPPED ON DIST.PRTN ,Y-PH G/E 7.5KM KM FROM BBLR. 204 KM FROM BHSWL.
PADGHE - NAGOTHANE CKT - 2	IntraState	14/01/2022	00:04	14/01/2022	08:30	HT	H/T For Over Voltage.
400 KV ICT Outages/Trippings							
400/220/33 KV 500 MVA ICT - 1 @ NANDED	IntraState	13/01/2022	12:19	13/01/2022	17:41	PO	Annual Tan Delta Testing of bushing & winding, Bay maintenance and relay testing work.
400 KV BR Outages/Trippings							
400KV 125MVAR BUS REACTOR @ CHANDRAPUR 2	InterState	13/01/2022	10:12	13/01/2022	16:36	PO	For fine tuning of CSD relays in Bay 414 & Bay 415 CBs
220 KV MAINBAY Outages/Trippings							
BUS SECTION - 2 @ TIFIL	IntraState	13/01/2022	08:43	13/01/2022	12:49	PO	220KV main bus PT IR to be taken and Isolator maintenance to be done from agency at TFIPL
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 14/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18			PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
PADGHE - TEMGHAR - 2	IntraState	02/01/2022	23:25			HT	conductor replacement work
TATA BORIVLI MSETCL BORIVLI - 4	IntraState	07/01/2022	11:25			PO	For shifting to New GIS at Tata Borivali
AAREY - MSETCL BORIVALI CKT - 1	IntraState	07/01/2022	11:59			T	differential prot optd,Y=33.29 kA,dist-3.2 km from Borivali
BOISAR II - BOISAR (PG) CKT - 1	IntraState	10/01/2022	09:51			PO	REPLACEMENT OF old CONDUCTOR by HTLS CONDUCTOR
BABHALESHWAR - DEOGAON RANGARI	IntraState	12/01/2022	00:03	13/01/2022	16:45	PO	29A, 29B islaotr servicing and alignment and mchanism box replacment jump opening and reconnection for main bus I and main bus II by hot line unit
HALKARNI-MAHALAXMI LINE	IntraState	13/01/2022	09:13	13/01/2022	17:42	PO	Conversion of SSN To DSN at Loc.262,263 & 274 275 replacement of Polymer at Tap line 2,3 CP
KALWA - TFIPL	IntraState	13/01/2022	09:27	13/01/2022	13:27	PO	Chemical cleaning and jumper nut bolt tightening.
KARAD -MUDSHINGI CKT 2-TAK	IntraState	13/01/2022	10:06	13/01/2022	14:01	PO	For replacement disc insulator string by long rod AF insulator string in foggy region at tower Location no- 92,103,104,106,107,114,117,118, 121,137,141,166 to 169,171,173,174.
PANDHARPUR - KHANAPUR	IntraState	13/01/2022	10:28	13/01/2022	14:00	PO	Conversion of SSN to DSN work & clod line washing work
LONAND-BOTHE	IntraState	13/01/2022	10:48	13/01/2022	13:58	PO	CT tan delta testing & relay testing works
TROMBAY MSETCL TIE - 2	IntraState	13/01/2022	10:57			PO	R/M and CT, CVT Testing work at both ends
BARAMATI - KURKUMBH	IntraState	13/01/2022	11:14	13/01/2022	14:00	PO	DIAGNOSTIC TESTING WORK.
URSE - TALEGAON (AMBI) CKT 1	IntraState	13/01/2022	12:26	13/01/2022	14:15	PO	CB CRM & Timing by Shifting 220kV Talegaon ckt-1 bay on 220kV TBC bay .
NAGOTHANE - WADKHAL (GIS) CKT-1	IntraState	13/01/2022	12:55	13/01/2022	15:29	EO	Replacement of flashover middle phase suspension insulator string at Loc No. 17 (Middle phase).
MAHAPE - TFIPL	IntraState	13/01/2022	13:30	13/01/2022	15:28	PO	Chemical cleaning and jumper nut bolt tightening.
CHINCHWAD 2-CHINCHWAD (INTERCONNECTOR)	IntraState	13/01/2022	17:18	13/01/2022	23:50	EO	Attending Hot Spot at Bph CT P1 Terminal (102°C) on dt 06.12.2021
BABHALESHWAR - UTECH SUGAR	IntraState	13/01/2022	18:28	14/01/2022	01:29	PO	220 Kv Babhaleshwar UTECH Ckt for erection of the 220 kv SPND +3 between loc no 17 and 18 .
BABLESHWAR- ALEPHATA CKT - 1	IntraState	13/01/2022	18:28	13/01/2022	23:00	PO	220 Kv Babhaleshwar Alephata Ckt for erection of the 220 kv SPND +3 between loc no 17 and 18 .

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 13/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 14/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TEMGHAR - KALWA	IntraState	13/01/2022	23:10				As safety precaution for the replacement of CB pole of 220/22 kV, 50MVA PTR-2
CHAKAN - CHINCHWAD 2	IntraState	14/01/2022	00:23	14/01/2022	06:44	PO	Attending Hot Spots at R ph CT (P1 terminal) 165 μ C , R ph CT (P2 terminal) 108 μ C Y ph CT (P2 terminal) 95.4 ,Y ph CB Bottom 100 μ C & Replacement of Y ph LA
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/22 KV 50 MVA PTR 2 @ KALWA	IntraState	12/01/2022	09:17			PO	CB MECHANISM & POLE OUEHVALING
220/132KV 100MVA ICT 1@ PETH	IntraState	13/01/2022	09:30			PO	Oil filtration & oil leakage attending work by replacement of gaskets of bushing, PRV & inspection windows.
220/22 KV 50 MVA PTR 1 @ PAL- DOMBIVALI	IntraState	13/01/2022	10:11	13/01/2022	20:26	PO	Diagnostic & testing work.
220 KV BUSBAR Outages/Trippings							
MAIN BUS-PT @TIFIL	IntraState	13/01/2022	0843	13/01/2022	12:57	PO	220KV main bus PT IR to be taken and Isolator maintenance to be done from agency at TFIPL

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage