

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 13/Jan/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	157.900	1854.767	1) Gujrat	-7.039	-67.203
2) Hydro	10.167	190.986	2) Madhya Pradesh	1.712	48.534
3) Gas	5.833	59.097	3) Chattisgarh	4.960	77.650
Total MSPGCL	173.900	2104.850	4) Maharashtra	165.964	2317.496
B) 1) APLM	50.993	669.200	5) Goa (Amona)	-1.273	-21.376
2) JSWEL	18.954	254.871	Total	164.324	2355.101
3) VIPL	0.000	0.000	a) Mumbai Schedule	21.613	291.024
4) RPL(AMT)	31.140	278.658	b) Mumbai Drawl	25.938	343.281
5) SWPGPL	8.577	101.762	c) MSEDCL Bilateral *	62.515	955.566
6) Other IPP	48.242	607.703	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	21.613	291.024
C) 1) TPCL Thermal	12.824	151.078	Include PX	0.000	0.000
2) TPCL Hydro	4.299	47.150	Standby	0.000	0.000
3) TPCL Gas	1.578	32.525	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.081	115.936	1) MSEDCL	483.612	6172.258
D) STATE			2) Mumbai Discoms	53.720	689.969
1) Thermal	337.711	4033.975	3) Other Discoms	9.703	125.250
(A1+C1+C4+(B1-B6))			TOTAL STATE	547.035	6987.477
2) Hydro	14.466	238.136			
(A2+C2)					
3) Gas	7.411	91.622			
(A3+B7+C3)					
4) Wind	8.913	109.336			
6) SOLAR	14.210	159.308			
TOTAL STATE	382.711	4632.377			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	6919	6882	7058	5557
MSPGCL Hydro	1468	93	507	92
MSPGCL Gas	243	236	236	247
MSPGCL Total Generation	8630	7211	7801	5896
Central Sector Receipt	7804	8298	6234	6570
WIND	329	233	194	465
CPP / IPP Thermal	7277	7084	7151	5676
CPP / IPP Gas	0	0	0	0
SOLAR	1841	2074	0	0
Exchange with Mumbai	-1355	-1397	-961	-833
MSEDCL DEMAND MET	24082	23065	19962	17453
Load Shedding	0	0	0	0
MSEDCL DEMAND	24082	23065	19962	17453
TPCL GENERATION	889	794	1140	495
AEML GENERATION	499	494	477	317
MUMBAI DEMAND	2743	2685	2578	1645
OTHER DISCOM DEMAND	444	438	457	321
STATE DEMAND MET	27269	26188	22997	19419
STATE DEMAND	27269	26188	22997	19419
Frequency (Hz)	49.93	49.98	50.03	49.90

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.37 Hz at 17:03 Hrs	49.49 Hz at 09:11 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 13/Jan/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.44	62.39	215	115
Unit 7	0.00	0.00	0	0
Unit 8	12.73	172.25	552	510
Unit 9	12.51	70.69	550	480
Unit 10	12.67	164.97	600	380
Total	42.34	470.31		
Bhusawal				
Unit 3	3.40	16.44	175	110
Unit 4	10.14	133.42	500	280
Unit 5	9.95	89.77	485	280
Total	23.50	239.63		
Parli				
Unit 6	4.03	56.50	225	140
Unit 7	0.00	13.70	0	0
Unit 8	4.36	51.18	228	144
Total	8.39	121.39		
Chandrapur				
Unit 3	3.58	43.90	165	122
Unit 4	3.25	28.73	148	119
Unit 5	7.07	81.08	310	275
Unit 6	8.30	111.44	400	280
Unit 7	0.00	0.00	0	0
Unit 8	11.21	140.40	498	315
Unit 9	11.04	141.54	496	323
Total	44.45	547.08		
Paras				
Unit 3	4.87	63.41	227	153
Unit 4	5.17	47.94	235	187
Total	10.04	111.36		
Khaparkheda				
Unit 1	2.93	34.60	135	105
Unit 2	3.04	34.46	140	112
Unit 3	3.70	44.07	176	128
Unit 4	3.24	37.04	158	119
Unit 5	9.95	129.05	445	290
Total	22.86	279.22		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.43	43.83	165	118
Unit 5	2.89	41.94	173	0
Total	6.32	85.78		
Uran				
All Units	5.83	59.10	250	234
Total	5.83	59.10		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.28	5.16	40	0
Total	0.28	5.16		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.54	57.33	440	40
Stage 4	3.81	65.55	750	0
Stage 3	1.39	26.39	320	0
Total	7.74	149.26		
Hydro				
KDPH	0.00	3.13	0	0
VTRNA	0.00	0.04	0	0
TILLARI	0.00	4.41	0	0
BHIRA T.R.	0.24	2.80	40	0
SMLHY_PTN	1.27	17.81	59	50
GHATGHAR	0.64	8.37	125	0
Total	2.15	36.56		
Wind				
Total	8.91	109.34	0	0
Total	8.91	109.34		
CPP				
APML(Mus)	50.99	669.20	0	0
JSWEL(Mus)	18.95	254.87	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.14	278.66	0	0
SWPGPL-Mus	8.58	101.76	0	0
Other(Mus)	48.24	607.70	0	0
Total	157.91	1912.19		
SOLAR				
Total	14.21	159.31	0	0
Total	14.21	159.31		
Tata				
Trombay 5	8.44	99.96	479	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.84	18.55	47	0
Trombay 7B	0.74	13.98	41	0
TATA Hydro	4.30	47.15	467	3
Trombay 8	4.38	51.12	237	131
Total	18.70	230.75		
AEML				
DTPS U-1&2	9.08	115.94	499	287
Total	9.08	115.94		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	157.90	1854.77	MSPGCL Total	173.90	2104.85
			MSPGCL Thml+Gas	163.73	1913.86	Koyna 1,2 & 4 Total	6.35	122.88
			MSPGCL Hydro	10.17	190.99	State Total	382.71	4632.38

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 13/Jan/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5781	92	247	6120	383	5670	0	0	6689	6672	-944	17550	0	17550	1771	351	19672	49.98
2	5557	92	247	5896	465	5676	0	0	7098	6570	-833	17453	0	17453	1645	321	19419	49.90
3	5420	92	249	5761	478	5657	0	0	6877	6735	-745	17573	0	17573	1551	313	19437	49.96
4	5637	92	250	5979	516	5655	0	0	6835	6710	-727	17825	0	17825	1531	308	19664	49.99
5	6011	102	250	6363	566	5702	0	0	6918	6728	-743	18292	0	18292	1549	324	20165	49.99
6	6429	148	250	6827	729	6163	0	0	6943	6490	-880	18968	0	18968	1682	361	21011	50.01
7	6664	802	248	7714	770	6916	0	3	6257	6187	-936	20259	0	20259	1907	395	22561	49.98
8	6776	1604	250	8630	695	7172	0	172	6157	6131	-912	21480	0	21480	2092	408	23980	50.00
9	6782	1508	246	8536	551	7203	0	744	6501	6595	-1020	22187	0	22187	2360	422	24969	49.85
10	6817	1420	242	8479	438	7280	0	1336	7054	7261	-1224	23133	0	23133	2606	437	26176	49.68
11	6919	1468	243	8630	329	7277	0	1841	7455	7804	-1355	24082	0	24082	2743	444	27269	49.93
12	6973	616	240	7829	397	7191	0	2020	7665	8039	-1343	23692	0	23692	2751	441	26884	49.89
13	6882	93	236	7211	233	7084	0	2074	7815	8298	-1397	23065	0	23065	2685	438	26188	49.98
14	6953	97	237	7287	264	6691	0	1983	8010	7997	-1545	22257	0	22257	2502	420	25179	50.10
15	6942	92	234	7268	214	6521	0	1762	8174	8154	-1604	21887	0	21887	2496	428	24811	50.04
16	6979	143	236	7358	226	6730	0	1365	7734	7749	-1444	21564	0	21564	2503	420	24487	50.06
17	7104	130	235	7469	280	7086	0	746	6991	7208	-1165	21185	0	21185	2485	439	24109	50.03
18	7044	300	236	7580	193	6936	0	164	6034	6388	-954	19846	0	19846	2562	461	22869	50.07
19	7058	507	236	7801	194	7151	0	0	6082	6234	-961	19962	0	19962	2578	457	22997	50.03
20	7058	369	240	7667	188	7183	0	0	5993	6201	-925	19861	0	19861	2535	453	22849	50.00
21	7004	107	244	7355	201	6834	0	0	5400	5598	-872	18683	0	18683	2569	433	21685	50.03
22	6612	96	245	6953	202	6451	0	0	6011	6089	-1079	18189	0	18189	2362	427	20978	50.02
23	6308	99	246	6653	192	5852	0	0	6263	6128	-1237	17180	0	17180	2200	408	19788	49.92
24	6190	99	246	6535	209	5825	0	0	6399	6357	-1093	17439	0	17439	2055	394	19888	49.96
MUs	157.90	10.17	5.83	173.90	8.91	157.91	0.00	14.21	163.35	164.32	-25.94	483.61	0.00	483.61	53.72	9.70	547.03	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 13/Jan/2023

Position as on 6.30 Hrs of 14/Jan/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
MSPGCL	Parli Unit 7	250	03/01/2023	22:16		Continued.	Annual Overhaul	31/01/2023
IPP	JSW (J) U4	300	04/01/2023	23:45		Continued.	NO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/02/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	20/01/2023
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25		Continued.	Boiler Tube Leakage. Unit on tolling from 22:00Hrs Dtd 09.12.2022	
IPP	SWPGPL U-4	135	28/12/2022	00:00	13/01/2023	03:22	BOTTOM ASH EVACUATION PROBLEM	13/01/2023
IPP	Adani U-1	660	12/01/2023	11:02		Continued.	APH-B Hot PA below leakage.	15/01/2023
MSPGCL	Nasik Unit 5	210	13/01/2023	05:55	13/01/2023	09:15	Low Vaccum	
TPC-G	Trombay 7B	60	13/01/2023	21:10	14/01/2023	18:55	Gas shortage	
TPC-G	Trombay 7A	120	13/01/2023	21:28	14/01/2023	15:04	Gas shortage	
MSPGCL	Parli Unit 8	250	14/01/2023	08:51		Continued.	Lube oil system problem	18/01/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 14/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY - 707 OF EKTUNI CKT - 2 @ AKOLA 2	IntraState	13/01/2023	09:17	13/01/2023	18:29	PO	OEM Inspection of CB
500 KV TBC Outages/Trippings							
POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	13/01/2023	22:45	14/01/2023	02:29	EO	emergency Outage to attend 2 nos Hotspot
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KOLHAPUR - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32		Continued.	HT	For Load Management
KHADKA - BABLESHWAR	IntraState	13/01/2023	08:01	13/01/2023	18:57	PO	Chemical Cleaning of Insulator string and Routine Line maintenance work
CHANDRAPUR-PARLI CKT-3	IntraState	13/01/2023	09:14	13/01/2023	20:11	PO	The ETC work of new CGPISL male 420kV, 50MVA Line Shunt Reactor under progress and will be completed up to 11.01.2023. It is necessary to take protection trials of New Reactor before charging. After completion of proposed works, Line Shunt Reactor will be charged.
CHANDRAPUR 2 - CHD SWITCHING CKT - 2	IntraState	13/01/2023	10:38	13/01/2023	20:21	EO	or checking healthiness of this R-ph CVT and if it is found faulty the same will be replaced by available spare CVT at the earliest.
NEW KOYNA - STAGE IV CKT - 2	IntraState	14/01/2023	18:04	14/01/2023	21:01	T	Tripped on over voltage at Koyna Stage 4 only. Hence H/T at New Koyna end.
400 KV ICT Outages/Trippings							
400/220/33KV SPARE ICT @ KORADI 2	IntraState	27/12/2022	09:20		Continued.	PO	SFRA , DFRA test & tan delta measurement - spare ICT.
400kv Stn. TF No 3 @ C'pur GCR	IntraState	12/01/2023	14:10	13/01/2023	22:41	EO	To attend the closing problem of Y-ph PG-3 Isolator (Aux. Bus Isolator)On dt.- 12/01/2023 at 10:00Hrs, during Isolator operation closing problem of Y-ph PG-3 isolator (Aux. Bus Isolator) is observed and hence, not closing properly. It is very necessary to attend the same on top priority.
400/220/33 KV 500MVA ICT - 1 @ KORADI 2	IntraState	13/01/2023	10:34	13/01/2023	18:44	PO	Diagnostic Testing of ICT and routine bay maintenance work
400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	IntraState	13/01/2023	16:12	13/01/2023	19:41	EO	To be Shifted on 220 KV TBC For attending Hotspot on 29 D Rph 501 MVA ICT-IV LV on 220 KV TBC
400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	IntraState	14/01/2023	14:46	14/01/2023	22:48	EO	For replacement of 220kV Y phase IV bushing due to high Tan-delta value

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 14/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	14/01/2023	15:00	14/01/2023	18:05	PO	To attend oil leakage, oil level is low below 35 deg level, to refill the oil. SFRA test and diagnostic testing work to be carried out.
220 KV MAINBAY Outages/Trippings							
220 KV MAIN BUS II	IntraState	13/01/2023	11:30	13/01/2023	17:20	PO	Erection of 220kv 89A Isolator,BPI, Jumpering of Isolator, TopBus ofnew ICT No.2,
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
VANKUSWADE - KDPH	IntraState	07/01/2023	10:46	14/01/2023	18:00	PO	For Erection & Stringing of In line Multi Circuit tower (Loc No.1 to 7) of new 220kV Karad-Koyana Line and Re stringing of existing 220kV D/C KDPH LILO line.
TROMBAY SALSETTE LINE-2	IntraState	12/01/2023	23:06	13/01/2023	03:50	PO	Shifting to TDS bay 400KVPTL work.
KALWA SALSETTE - 3	IntraState	13/01/2023	02:24	14/01/2023	09:07	T	Tripped on distance protection
BORIVALI - BOISAR II LINE	IntraState	13/01/2023	02:24	13/01/2023	13:21	T	Tripped on distance protection
BELEWADI - MUMEWADI LINE	IntraState	13/01/2023	08:41	13/01/2023	18:05	PO	For Testing and Commissioning of new Control & Relay Panel at 220 KV SubStation,Mumewadi
MHAISHAL - SHEDYAL	IntraState	13/01/2023	09:00	13/01/2023	16:12	PO	Cold line washing Work
NERLE- POPHALI	IntraState	13/01/2023	09:15	13/01/2023	16:55	PO	Outage for replacement of damaged conductor at loc no. 33B ̳ Y ph Nerale side , R ph Pedhambe side Replacement of damaged string loc no ̳ 20A R, Y,B ph , loc no ̳ 19B ̳ Y, B both side
ALKUD - VITA	IntraState	13/01/2023	09:22	13/01/2023	14:21	PO	Quarterly maintenance work & to attend DC leakage from CR Panel
URAN - APTA 2	IntraState	13/01/2023	09:44	13/01/2023	18:10	PO	Insulator String Replacement Work & Diagnostic testing and Bay Maint's work
KOLSHET - KHARBAO	IntraState	13/01/2023	11:00	13/01/2023	22:55	PO	Replacement of CB Auxiliary contact assembly, Annual relay testing work & RMW.
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 2	IntraState	13/01/2023	11:07	13/01/2023	18:25	PO	Erection of 220kv 89A Isolator,BPI, Jumpering of Isolator, TopBus ofnew ICT No.2,
BABLESHWAR-BABLESHWAR(400KV)-II	IntraState	13/01/2023	11:33	13/01/2023	15:20	PO	Replacement of RCC structures of BPIs at 220kV Babhaleshwar Sub-Station End.
AAREY - AEML BORIVALI	IntraState	13/01/2023	16:55	13/01/2023	17:57	T	Distance Protection
KARAD -MUDSHINGI CKT 2-TAK	IntraState	14/01/2023	05:23	14/01/2023	10:48	T	Tripped on Distance protection
MHAISHAL - SHEDYAL	IntraState	14/01/2023	09:01	14/01/2023	17:46	PO	Cold line washing Work
TROMBAY - MULUND	IntraState	14/01/2023	10:03	14/01/2023	14:27	PO	For Diagnostic testing & Bay Maintenance work.
EKLAHARA(OCR)-RAYMOND	IntraState	14/01/2023	10:09	14/01/2023	17:30	PO	To attend Red Hot on 220kV Raymond bay
EKLAHARA(OCR)-RAYMOND	IntraState	14/01/2023	10:09	14/01/2023	17:30	PO	1. Replacement of 220 KV PT 2. Attending red hot on B ph wave trap bottom side by replacement of existing jump along with Nut bolt
TALANDGE - MUDSHINGI CKT - 2	IntraState	14/01/2023	15:36	14/01/2023	23:11	EO	Heavy sparking observed at Yph wave trap
BOISAR - VERSOVA	IntraState	14/01/2023	17:16	14/01/2023	18:33	T	TRIPPED ON DISTANCE PROTECTION

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 14/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
VANKUSWADE - KDPH	IntraState	14/01/2023	18:00			PO	For Erection & Stringing of In line Multi Circuit tower (Loc No.1 to 7) of new 220kV Karad-Koyana Line and Re stringing of existing 220kV D/C KDPH LILO line.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	IntraState	23/12/2022	09:30		Continued.	PO	For TF Diagnostic Testing work , HV CT Tandelta , HV & LV Breaker CRM, Timing and R&M work
220/100 KV 200 MVA ICT 3 @ PADGHE	IntraState	13/01/2023	09:58	13/01/2023	18:13	PO	1. Diagnostic testing work 2. Pending MTAMC work 3. Attending hotspot 4. Isolator alignment and maintenance work.
220/132 KV 200MVA ICT 3@ BALE(SOLAPUR)	IntraState	13/01/2023	10:07	13/01/2023	13:52	PO	Outage is required for Tan delta testing
STATION TRANSFORMER - 4 @ EKLAHARE (GCR)	IntraState	13/01/2023	10:12	13/01/2023	17:14	PO	Diagnostic testing work
220/100 KV 100 MVA ICT 1 @ KANDALGAON	IntraState	13/01/2023	10:26	14/01/2023	01:01	PO	For the work of anticorrosive painting with chemical to 125 MVA 220/100 KV ICT -1
220/132KV 200MVA PTR 1 @ LONAND	IntraState	13/01/2023	11:34	13/01/2023	15:42	PO	1.Diagnostic testing work 2.Quarterly maintenance Work 3.Relay testing Work.
220/100 KV 200 MVA ICT 2 @ KOLSHET	IntraState	13/01/2023	13:05	13/01/2023	14:22	EO	Oil leakages Inspection work to be carried out from top side body of ICT 2 .
220/100 KV 100 MVA ICT 1 @ KANDALGAON	IntraState	14/01/2023	09:20	14/01/2023	18:12	PO	For the work of anticorrosive painting with chemical to 125 MVA 220/100 KV ICT -1
220/132 KV 200 MVA ICT 1 @ RAYMOND	IntraState	14/01/2023	10:31	14/01/2023	18:58	PO	Replacement of 220 KV BUS PT
220/33 KV 50 MVA TF - 1@BELWANDI	IntraState	14/01/2023	11:02	14/01/2023	14:30	PO	DIAGNOSTIC TESTING WORK
220/100 KV 200 MVA ICT 2 @ KOLSHET	IntraState	14/01/2023	11:27	14/01/2023	18:18	EO	Arresting of oil leakages of ICT-2 due to leakage observed from RTD pocket, PRV, Butterfly valve & pipe valve after inspection ICT on dt.13.01.2023 from(13:00 to 14:00Hrs.)
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	14/01/2023	13:53	14/01/2023	19:25	PO	Diagnostic Testing of Bay equipments and attending red hot on ICT bushings & on LV CTs
220/33 KV 50 MVA PTR 2 @ BHENDA	IntraState	14/01/2023	16:29	14/01/2023	21:45	PO	PTR-2 Oil Leakage Attend work from Main Tank top side gasket.
220 KV BUSBAR Outages/Trippings							
MAIN BUS SECTION - 1 @ PIRANGUT	IntraState	12/01/2023	19:00	13/01/2023	03:54	EO	1)Bus strengthning work of existing 220 kV single conductor Bus by twin conductor. 2)TF Bushing and Winding Tan delta measurement. 3) Attending emergency hot spot on CB of Hinjewadi-II line bay at 220kV Pirangut SS.
MAIN BUS - 2 @ URAN	IntraState	13/01/2023	09:59	13/01/2023	17:48	PO	For MAIN BUS 2 insulator string replacement work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 14/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS @ PAWAS	IntraState	13/01/2023	10:35	13/01/2023	16:53	PO	Outage required in 220kV Main Bus sec-II in which following bays are present, 220kV Niwali-Pawas line, 25MVA 220/33kV TF-2, 220kV Finolex ckt -1 bay, 25MVA 220/33kV TF-1 Work: For dismantling of HVCB of 25MVA 220/33kV 25MVA TF-1.
MAIN BUS @ PAWAS	IntraState	14/01/2023	10:37	14/01/2023	12:24	PO	For insulator cleaning of 220kV Main Bus sec-1.
MAIN BUS SECTION - 2 @ PIRANGUT	IntraState	14/01/2023	12:16	14/01/2023	23:28	PO	1)Bus strengthening work of existing 220 kV single conductor Bus by twin conductor. 2)TF Bushing and Winding Tan delta measurement.
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	13/01/2023	12:54	13/01/2023	14:52	EO	Y phase bus isolator to breaker jumper replacement work
110 KV LINE Outages/Trippings							
KHOPOLI - KARANJADE	IntraState	14/01/2023	09:31	14/01/2023	15:45	PO	FOR ATTENDING HOT SPOT AT LOC 300 AND TREE TRIMMING WORK

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage