

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 13/Feb/2021 SATURDAY**

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	141.955	2016.588	1) Gujrat	-0.855	-0.400
2) Hydro	15.528	142.816	2) Madhya Pradesh	7.133	75.216
3) Gas	6.865	84.457	3) Chattisgarh	5.010	69.230
<b>Total MSPGCL</b>	<b>164.348</b>	<b>2243.861</b>	4) Maharashtra	138.922	1711.862
B) 1) APLM	57.349	729.908	5) Goa (Amona)	-0.890	-12.595
2) JSWEL	10.536	157.447	<b>Total</b>	<b>149.320</b>	<b>1843.313</b>
3) VIPL	0.000	0.000	a) Mumbai Schedule	19.408	265.578
4) RPL(AMT)	30.952	360.220	b) Mumbai Drawl	21.584	282.609
5) WPCL	8.610	105.126	c) MSEDCL Bilateral *	31.307	363.946
6) Other IPP	18.253	242.173	Include PX	1.409	-26.517
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	19.408	261.531
C) 1) TPCL Thermal	5.158	123.283	Include PX	6.225	66.726
2) TPCL Hydro	5.712	55.559	Standby	0.000	4.047
3) TPCL Gas	4.385	47.187	<b>H) ENERGY CATERED (MUs)</b>		
4) AEML Thermal	11.132	124.630	1) MSEDCL	432.907	5624.764
D) STATE			2) Mumbai Discoms	47.971	633.270
1) Thermal	283.945	3859.375	<b>TOTAL STATE</b>	<b>480.878</b>	<b>6258.034</b>
(A1+C1+C4+(B1-B6))					
2) Hydro	21.240	198.375			
(A2+C2)					
3) Gas	11.250	131.644			
(A3+B7+C3)					
4) Wind	7.364	122.874			
6) SOLAR	7.759	102.451			
<b>TOTAL STATE</b>	<b>331.558</b>	<b>4414.719</b>			

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6104	6030	5854	5941
MSPGCL Hydro	1162	1178	704	102
MSPGCL Gas	269	287	292	304
MSPGCL Total Generation	7535	7495	6850	6346
Central Sector Receipt	7444	7022	5949	5491
WIND	136	102	227	356
CPP / IPP Thermal	5471	5465	5526	4508
CPP / IPP Gas	0	0	0	0
SOLAR	1086	1131	0	0
Exchange with Mumbai	-1043	-1044	-1015	-924
<b>MSEDCL DEMAND MET</b>	<b>20629</b>	<b>20171</b>	<b>17537</b>	<b>15778</b>
Load Shedding	0	0	0	0
MSEDCL DEMAND	20629	20171	17537	15778
TPCL GENERATION	836	812	844	319
AEML GENERATION	500	501	501	284
<b>MUMBAI DEMAND</b>	<b>2379</b>	<b>2357</b>	<b>2360</b>	<b>1527</b>
STATE DEMAND MET	23008	22528	19897	17304
<b>STATE DEMAND</b>	<b>23008</b>	<b>22528</b>	<b>19897</b>	<b>17304</b>
Frequency (Hz)	49.98	49.97	50.02	50.01

**FREQUENCY PARTICULARS**

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.21 Hz at 06.02 Hrs	49.82 Hz at 12.08 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation, Maximum, Minimum for 13/Feb/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Koradi</b>				
Unit 6	0.00	6.21	0	0
Unit 7	0.00	5.60	0	0
Unit 8	12.28	153.90	550	473
Unit 9	11.39	155.35	500	446
Unit 10	0.00	95.67	0	0
<b>Total</b>	<b>23.67</b>	<b>416.73</b>		
<b>Bhusawal</b>				
Unit 3	0.00	0.00	0	0
Unit 4	11.37	139.84	480	465
Unit 5	11.33	136.42	475	455
<b>Total</b>	<b>22.70</b>	<b>276.26</b>		
<b>Parli</b>				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.44	70.43	250	185
Unit 7	5.51	69.98	249	194
Unit 8	5.69	71.59	250	208
<b>Total</b>	<b>16.64</b>	<b>212.00</b>		
<b>Chandrapur</b>				
Unit 3	3.16	44.92	141	118
Unit 4	3.67	45.30	158	146
Unit 5	0.00	56.32	0	0
Unit 6	9.32	124.39	420	325
Unit 7	10.20	111.26	435	410
Unit 8	8.80	143.61	472	0
Unit 9	11.15	143.54	500	428
<b>Total</b>	<b>46.30</b>	<b>669.34</b>		
<b>Paras</b>				
Unit 3	2.05	64.22	150	0
Unit 4	0.53	63.48	145	0
<b>Total</b>	<b>2.58</b>	<b>127.70</b>		
<b>Khaparkheda</b>				
Unit 1	3.38	42.86	155	130
Unit 2	3.73	47.23	165	135
Unit 3	4.49	56.82	200	160
Unit 4	4.20	52.86	190	145
Unit 5	10.43	69.58	475	410
<b>Total</b>	<b>26.22</b>	<b>269.34</b>		
<b>Nasik</b>				
Unit 3	0.00	0.00	0	0
Unit 4	3.84	45.21	199	126
Unit 5	0.00	0.00	0	0
<b>Total</b>	<b>3.84</b>	<b>45.21</b>		
<b>Uran</b>				
All Units	6.86	84.46	305	258
<b>Total</b>	<b>6.86</b>	<b>84.46</b>		
<b>PGPL</b>				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
<b>Total</b>	<b>0.00</b>	<b>0.00</b>		
<b>PENCH (MS)</b>				
Pench (MS)	0.06	3.64	21	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Total</b>	<b>0.06</b>	<b>3.64</b>		
<b>Koyna</b>				
Stage 1-2	5.20	44.18	565	40
Stage 4	4.50	36.64	815	0
Stage 3	2.11	17.82	240	0
<b>Total</b>	<b>11.82</b>	<b>98.63</b>		
<b>Hydro</b>				
KDPH	0.68	6.64	37	19
VTRNA	0.45	4.63	60	0
TILLARI	0.00	1.06	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.32	2.96	80	0
RNGR+BHTSA	0.36	4.59	16	15
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.55	6.06	23	22
GHATGHAR	1.34	18.25	250	0
<b>Total</b>	<b>3.71</b>	<b>44.18</b>		
<b>Wind</b>				
Total	7.36	122.87	0	0
<b>Total</b>	<b>7.36</b>	<b>122.87</b>		
<b>CPP</b>				
APML(Mus)	57.35	729.91	0	0
JSWEL(Mus)	10.54	157.45	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	30.95	360.22	0	0
WPCL(Mus)	8.61	105.13	0	0
Other(Mus)	18.25	242.17	0	0
<b>Total</b>	<b>125.70</b>	<b>1594.87</b>		
<b>SOLAR</b>				
Total	7.76	102.45	0	0
<b>Total</b>	<b>7.76</b>	<b>102.45</b>		
<b>Tata</b>				
Trombay 5	0.00	62.20	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	29.69	116	115
Trombay 7B	1.61	17.50	68	66
Trombay 8	5.16	61.08	234	137
TATA Hydro	5.71	55.56	435	25
<b>Total</b>	<b>15.26</b>	<b>226.03</b>		
<b>AEML</b>				
DTPS U-1&2	11.13	124.63	502	282
<b>Total</b>	<b>11.13</b>	<b>124.63</b>		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	141.96	2016.59	MSPGCL Total	164.35	2243.86
			MSPGCL Thml+Gas	148.82	2101.04	Koyna 1,2 & 4 Total	9.70	80.82
			MSPGCL Hydro	15.53	142.82	State Total	331.56	4414.72

# State Load Despatch Center, Airoli (MSETCL)

# Annexure-2

## Hourly Load Data As on 13/Feb/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDING	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5807	102	285	6194	351	5015	0	0	5636	5445	-818	16188	0	16188	1730	17918	49.99
2	5845	102	295	6242	388	4864	0	0	5626	5524	-873	16146	0	16146	1607	17752	50.03
3	5941	102	304	6346	356	4508	0	0	5561	5491	-924	15778	0	15778	1527	17304	50.01
4	5924	96	295	6316	483	4595	0	0	5462	5505	-859	16040	0	16040	1460	17500	49.97
5	5776	102	296	6174	586	4767	0	0	5625	5896	-874	16548	0	16548	1476	18024	50.01
6	5867	202	295	6364	571	5089	0	0	5777	5975	-833	17166	0	17166	1567	18732	50.02
7	5791	1062	305	7158	665	5433	0	0	5800	5590	-592	18254	0	18254	1647	19900	49.99
8	5881	1730	296	7908	686	5550	0	133	5777	5719	-500	19496	0	19496	1751	21246	50.05
9	5967	1330	295	7592	490	5547	0	432	6309	6476	-630	19906	0	19906	1939	21846	50.02
10	6146	1282	284	7712	426	5555	0	722	6669	6666	-822	20258	0	20258	2170	22428	50.02
11	6163	1020	281	7464	303	5553	0	938	6977	7122	-976	20404	0	20404	2327	22730	50.02
12	6104	1162	269	7535	136	5471	0	1086	7187	7444	-1043	20629	0	20629	2379	23008	49.98
13	6030	1178	287	7495	102	5465	0	1131	7067	7022	-1044	20171	0	20171	2357	22528	49.97
14	5898	614	258	6770	55	5480	0	1105	7004	7258	-937	19731	0	19731	2236	21967	50.04
15	5892	780	268	6940	51	5456	0	954	7164	7198	-972	19627	0	19627	2236	21863	50.01
16	5894	873	289	7056	84	5465	0	721	7125	7028	-989	19365	0	19365	2243	21608	50.00
17	5879	1090	269	7238	90	5551	0	411	6556	6377	-958	18709	0	18709	2247	20956	50.00
18	5893	653	280	6826	150	5557	0	126	6222	6083	-942	17800	0	17800	2250	20050	50.01
19	5874	480	271	6625	145	5508	0	0	5839	5994	-961	17311	0	17311	2309	19620	50.01
20	5854	704	292	6850	227	5526	0	0	5790	5949	-1015	17537	0	17537	2360	19897	50.02
21	5796	225	282	6303	321	5313	0	0	5854	5735	-1060	16612	0	16612	2235	18847	50.00
22	5809	178	292	6279	313	4910	0	0	5982	5839	-1030	16311	0	16311	2088	18399	49.99
23	5964	178	294	6436	209	4692	0	0	5889	6199	-1001	16535	0	16535	1957	18492	49.97
24	5960	284	283	6527	176	4830	0	0	5796	5785	-931	16387	0	16387	1873	18260	49.99
<b>MUs</b>	<b>141.96</b>	<b>15.53</b>	<b>6.86</b>	<b>164.35</b>	<b>7.36</b>	<b>125.70</b>	<b>0.00</b>	<b>7.76</b>	<b>148.69</b>	<b>149.32</b>	<b>-21.58</b>	<b>432.91</b>	<b>0.00</b>	<b>432.91</b>	<b>47.97</b>	<b>480.88</b>	<b>50.01</b>

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 13/Feb/2021**

Position as on 6.30 Hrs of 14/Feb/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
<b>PLANNED OUTAGE</b>								
IPP	JSW (J) U4	300	28/01/2021	01.34		Continued.	Annual Overhaul	
TPC-G	Trombay 5	500	08/02/2021	00.10		Continued.	Annual Overhaul	
<b>FORCED OUTAGE</b>								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	Economizer Tube Leakage. (Zero Schedule from 18:45hrs of 05.12.2020).	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Nasik Unit 3	210	03/12/2020	06.45		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019).	
IPP	Adani U-5	660	18/01/2021	21.00		Continued.	zero scheduled	
MSPGCL	Koyna Unit 11	80	19/01/2021	10.05		Continued.	Tripped on stator earth fault (will not be available till dt.18.04.21)	
MSPGCL	Bhusawal Unit 3	210	26/01/2021	00.00		Continued.	Zero schedule.	
IPP	JSW (J) U1	300	01/02/2021	18.00		Continued.	Due to turbine vibration high	
MSPGCL	Koradi Unit 6	210	02/02/2021	20.30		Continued.	ZERO Schedule by MSEDCL	
MSPGCL	Koradi Unit 7	210	02/02/2021	20.50		Continued.	ZERO Schedule by MSEDCL	
MSPGCL	Chandrapur Unit 5	500	06/02/2021	20.16	14/02/2021	21.52	Clinker Formation In Boiler.	
MSPGCL	Koradi Unit 10	660	09/02/2021	15.10	14/02/2021	05.01	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit-8	500	12/02/2021	21.21	13/02/2021	01.17	Drum level high.	
MSPGCL	Paras Unit 4	250	13/02/2021	03.54		Continued.	Coal bunker problem.	
MSPGCL	Paras Unit 3	250	13/02/2021	14.06	13/02/2021	22.00	Withdraw due to no bunker level.	
IPP	Dhariwal	300	14/02/2021	00.00	14/02/2021	16.21	ESP problem.	
MSPGCL	Koradi Unit 9	660	14/02/2021	09.22		Continued.	Cooling Water Return line leakage.	

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 13/Feb/2021**

**Statement-VII**

Position as on 6.30 Hrs of 14/Feb/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
<b>400 KV LINE Outages/Trippings</b>							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	12/02/2021	18.21		Continued.	HT	Over Voltage
Chandrapur-II - Warora - I	InterState	13/02/2021	10.08	13/02/2021	17.42	PO	Routine Maintenance Work
Lamboti - Solapur (PG)	InterState	13/02/2021	10.40	13/02/2021	22.43	PO	Line CVT Replacement Work At PG End.
Khadka-Aurangabad (Waluj)	IntraState	12/02/2021	19.59	13/02/2021	08.15	HT	Over Voltage
Babhaleshwar - Padghe-I	IntraState	13/02/2021	13.25	13/02/2021	17.42	T	Distance Protection
Khadka-Aurangabad (Waluj)	IntraState	13/02/2021	22.43	14/02/2021	05.53	HT	Over Voltage
Girwali- Lonikand 2	IntraState	14/02/2021	11.21	14/02/2021	18.38	PO	Line Maintenance work
Khadka-Aurangabad (Waluj)	IntraState	14/02/2021	19.44		Continued.	HT	Over Voltage
Dhule- Bableswhar - I	IntraState	14/02/2021	20.54		Continued.	HT	Over Voltage
<b>400 KV ICT Outages/Trippings</b>							
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/08/2020	09.58		Continued.	PO	Replacement of existing 315 MVA ICT by 3*167 MVA ICT.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	23/09/2020	09.12		Continued.	PO	Augmentation work of 400/220 315MVA ICT-II to 501MVA
400/220kv 105mva 1 Ph Spare Ict @New Koyna	IntraState	13/02/2021	10.15	13/02/2021	16.06	PO	Routine Maintenance Work
400/220 Kv 500 MVA ICT-I @Kalwa	IntraState	14/02/2021	06.21	14/02/2021	07.38	PO	Oil Leakage Arresting From Y-Phase HV Turret By Nut Bolt Tightening.
400/220/33 Kv 600 MVA ICT 4 @Padghe	IntraState	14/02/2021	09.09	14/02/2021	22.24	PO	Attending Oil Leakage
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	14/02/2021	12.05	14/02/2021	15.44	PO	Connection of online DGA Set's outlet To 50 NB Gate Valve of Main Tank & commissioning thereafter for 440/220/33kv ICT-2 & Spare ICT.
400/220/33 kv 105 MVA Spare ICT @Chandrapur GCR	IntraState	14/02/2021	16.08	14/02/2021	17.25	PO	Connection Of Online DGA Sets Outlet To 50 NB gate Valve Of Main Tank.
<b>400 KV BR Outages/Trippings</b>							
80MVAR Bus reactor @Nagothane	IntraState	14/02/2021	20.54		Continued.	EO	Differential protection
<b>220 KV LINE Outages/Trippings</b>							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower Due to Railway Crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower Due to Railway Crossing
Topworth - Kharghar	IntraState	12/02/2021	09.24	13/02/2021	14.49	PO	Replacement of flash over polymer insulator at Loc no. 665 (Cut point) Top - B-phase.(Breaker problem at Topworth From 15.30 hrs
Kharepatan -Pawas Line	IntraState	13/02/2021	08.47	13/02/2021	18.15	PO	For Cold Washing of Insulators Strings At Loc No. 1-82.229-384.
Goregaon Aarey Line 2	IntraState	13/02/2021	09.35	13/02/2021	11.12	PO	Removal Of Foreign Material From Conductor/Insulator/Hardware On VAB 24.29.35.
Infosys - Hinjawadi 1	IntraState	13/02/2021	10.09	13/02/2021	20.10	PO	Annual Testing Work.
Pohali-Nerle	IntraState	13/02/2021	10.55	13/02/2021	18.35	PO	For Replacement Of Damaged Conductor & Fixing PA Rod Of Y-Phase At Loc No.30.
Nerul-Trombay	IntraState	13/02/2021	10.55	13/02/2021	18.28	PO	For OPGW Stringing Work In Between Loc No.03 To Nerul

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 13/Feb/2021**

**Statement-VII**

Position as on 6.30 Hrs of 14/Feb/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							Gantry.
Kharghar - Nerul	IntraState	13/02/2021	10.58	13/02/2021	11.17	PO	For OPGW Stringing Work In Between Loc No 03 Nerul Gantry.
Trombay Salsette 1 Backbay	IntraState	14/02/2021	08.05	14/02/2021	18.05	PO	For Metro-6 Height Raising Work.
220 KV JALKOT - NANDED (KUMBHARGAON) CKT - 2	IntraState	14/02/2021	08.32	14/02/2021	18.52	PO	stringing Work Of 220KV Krishnorr Nande Ckt I.
Phophali Stg I Bus section II	IntraState	14/02/2021	10.40	14/02/2021	22.10	PO	Replacement of 220kv SF6 Breaker pole & main bus Side CT of R-Phase, Replacement of R & Y Ph Stage 2 Side Isolator to Main bus Conductor of 220kv junction Bay.
Kadegaon-Miraj	IntraState	14/02/2021	14.05	14/02/2021	14.16	T	Back up over current.
Talandge(400kv)- Ichalkaranji ckt-2	IntraState	14/02/2021	14.05	14/02/2021	19.35	T	Distance Protection
Alkud Miraj	IntraState	14/02/2021	14.05	14/02/2021	14.30	T	Back up over current.
Talandge(400kv)- Ichalkaranji ckt-1	IntraState	14/02/2021	14.05	14/02/2021	14.22	T	Back up over current.
Miraj - Mhaishal	IntraState	14/02/2021	14.05	14/02/2021	14.44	T	Back up over current.
Miraj-Ichalkaranji I	IntraState	14/02/2021	14.05	14/02/2021	19.51	T	Back up over current.
Vita Alkud	IntraState	14/02/2021	14.05	14/02/2021	14.37	T	Back up over current.
<b>220 KV ICT Outages/Trippings</b>							
220/132 Kv 200mva Kanohar Ict 3 @Bale (Solapur 2)	IntraState	12/02/2021	16.20		Continued.	PO	Outage is required for Oil Filtration work.
220/33kv 100 MVA Transformer 1 @Ghodbunder R/S	IntraState	13/02/2021	08.41	13/02/2021	19.11	PO	33KV AIS To GIS Work(Erection Of Structural Steel For Fabrication Of Cable Support Structure Near NGt 1.)
220/33 Kv 50 Mva Imp Ptr 2 @Sonkar	IntraState	13/02/2021	09.20	13/02/2021	18.17	PO	OSR Relay Replacement Work.& Attending Oil Leakage.
220/33kv 125 MVA T/F-III @ Goregaon	IntraState	13/02/2021	09.53	13/02/2021	14.20	PO	Replacement Of E/S Cum Disconnecter Operating Spindle Alogwith O'ring Of 33KV Sw. No 09(I/C Of 125MVA Tr-3.)
220/132 KV ICT 6 @ Eklahare	IntraState	13/02/2021	11.39	13/02/2021	18.15	PO	Restoration Of Nitrogen Injection System CTR Make by Agency.
Saki : 220 / 110 / 33 250 MVA ICT 2	IntraState	14/02/2021	08.25	14/02/2021	18.05	PO	Routine Maintenance Work & Testing.
<b>132 KV LINE Outages/Trippings</b>							
Padegaon- Waluj 2	IntraState	13/02/2021	10.15	13/02/2021	18.01	PO	Replacement Of Faulty Strings Isolator Maintenance Work.
Kopergaon - Vaijapur	IntraState	13/02/2021	11.05	13/02/2021	13.28	PO	Replacement Of R-Phase Iso-Bus Jumper At 132Kv TSS.
Main Bus @ Kopergaon	IntraState	13/02/2021	11.05	13/02/2021	13.28	PO	For Replacement Of R-Phase Iso-Bus Jumper At 132KV TSS.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage