

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 13/Apr/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	161.303	2125.469	1) Gujrat	-3.957	-56.872
2) Hydro	33.883	471.789	2) Madhya Pradesh	7.927	129.673
3) Gas	6.283	82.853	3) Chattisgarh	3.820	61.460
Total MSPGCL	201.469	2680.111	4) Maharashtra	161.231	2112.574
B) 1) APLM	76.369	983.167	5) Goa (Amona)	-1.521	-22.213
2) JSWEL	20.931	241.988	Total	167.500	2224.622
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.955	381.813
4) RPL(AMT)	31.733	397.873	b) Mumbai Drawl	33.029	421.053
5) SWPGPL	9.430	118.463	c) MSEDCL Bilateral *	55.363	871.849
6) Other IPP	33.730	449.818	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.923	381.704
C) 1) TPCL Thermal	16.521	204.537	Include PX	0.000	0.000
2) TPCL Hydro	5.252	47.321	Standby	0.032	0.108
3) TPCL Gas	3.575	41.927	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.945	151.205	1) MSEDCL	514.965	6833.358
D) STATE			2) Mumbai Discoms	70.322	866.049
1) Thermal (A1+C1+C4+(B1-B6))	361.962	4672.520	3) Other Discoms	8.966	116.885
2) Hydro (A2+C2)	39.135	519.110	TOTAL STATE	594.253	7816.292
3) Gas (A3+B7+C3)	9.858	124.780			
4) Wind	7.704	161.082			
6) SOLAR	8.094	114.172			
TOTAL STATE	426.753	5591.664			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6772	6653	6811	6664
MSPGCL Hydro	1310	1634	1420	1261
MSPGCL Gas	263	169	248	289
MSPGCL Total Generation	8345	8456	8479	8214
Central Sector Receipt	8461	8145	6767	5831
WIND	131	174	449	555
CPP / IPP Thermal	7029	7031	7033	7098
CPP / IPP Gas	0	0	0	0
SOLAR	1142	643	0	0
Exchange with Mumbai	-1854	-1866	-1351	-857
MSEDCL DEMAND MET	22982	22315	21097	20713
Load Shedding	965	2293	510	695
MSEDCL DEMAND	23947	24608	21607	21408
TPCL GENERATION	1013	1158	1222	956
AEML GENERATION	492	480	502	501
MUMBAI DEMAND	3359	3504	3075	2314
OTHER DISCOM DEMAND	403	402	414	259
STATE DEMAND MET	26744	26221	24586	23286
STATE DEMAND	27709	28514	25096	23981
Frequency (Hz)	49.80	49.83	49.90	49.91

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.18 Hz at 18.01 Hrs	49.57 Hz at 16.46 Hrs	49.89	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 13/Apr/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.58	47.61	205	175
Unit 7	0.00	0.00	0	0
Unit 8	14.13	177.42	605	484
Unit 9	13.82	178.41	593	550
Unit 10	0.00	60.94	0	0
Total	32.53	464.38		
Bhusawal				
Unit 3	3.90	22.17	170	155
Unit 4	8.79	118.02	375	325
Unit 5	9.11	122.70	420	370
Total	21.80	262.88		
Parli				
Unit 6	4.36	50.67	192	163
Unit 7	3.91	50.83	202	119
Unit 8	3.26	44.12	139	133
Total	11.53	145.63		
Chandrapur				
Unit 3	4.46	58.09	190	181
Unit 4	4.06	52.52	174	163
Unit 5	7.21	111.05	307	290
Unit 6	6.99	85.46	300	273
Unit 7	8.63	114.64	371	338
Unit 8	11.10	136.97	480	440
Unit 9	10.35	132.19	440	415
Total	52.80	690.92		
Paras				
Unit 3	5.32	69.28	240	187
Unit 4	5.08	65.26	227	176
Total	10.39	134.54		
Khaparkheda				
Unit 1	3.01	41.46	155	100
Unit 2	3.07	42.94	145	105
Unit 3	3.54	50.78	175	129
Unit 4	3.20	49.77	162	115
Unit 5	11.09	140.61	477	435
Total	23.91	325.55		
Nasik				
Unit 3	4.29	48.70	193	166
Unit 4	4.05	52.86	184	152
Unit 5	0.00	0.00	0	0
Total	8.34	101.56		
Uran				
All Units	6.28	82.85	291	163
Total	6.28	82.85		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	1.80	24	0
Total	0.15	1.80		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	8.74	97.37	530	65
Stage 4	12.13	207.03	995	120
Stage 3	4.63	65.32	320	80
Total	25.49	369.72		
Hydro				
KDPH	0.82	11.11	34	34
VTRNA	0.86	9.56	59	0
TILLARI	0.46	5.82	58	0
BHIRA T.R.	0.16	2.18	77	0
SMLHY_PTN	5.66	70.66	253	220
GHATGHAR	0.29	0.93	125	0
Total	8.24	100.27		
Wind				
Total	7.70	161.08	0	0
Total	7.70	161.08		
CPP				
APML(Mus)	76.37	983.17	0	0
JSWEL(Mus)	20.93	241.99	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.73	397.87	0	0
SWPGPL-Mus	9.43	118.46	0	0
Other(Mus)	33.73	449.82	0	0
Total	172.19	2191.31		
SOLAR				
Total	8.09	114.17	0	0
Total	8.09	114.17		
Tata				
Trombay 5	10.89	137.46	480	419
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.17	25.01	114	62
Trombay 7B	1.41	16.92	66	49
TATA Hydro	5.25	47.32	429	43
Trombay 8	5.63	67.07	242	215
Total	25.35	293.78		
AEML				
DTPS U-1&2	11.94	151.20	502	480
Total	11.94	151.20		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	161.30	2125.47	MSPGCL Total	201.47	2680.11
			MSPGCL Thml+Gas	167.59	2208.32	Koyna 1,2 & 4 Total	20.86	304.40
			MSPGCL Hydro	33.88	471.79	State Total	426.75	5591.66

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 13/Apr/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6544	895	274	7713	452	7260	0	0	6248	6260	-1220	20143	956	21099	2827	322	24248	49.78
2	6555	995	286	7836	432	7260	0	0	6098	6167	-1089	20306	922	21228	2615	300	24143	49.82
3	6636	1055	288	7979	532	7259	0	0	5818	6124	-954	20672	691	21363	2436	268	24067	49.93
4	6664	1261	289	8214	555	7229	0	0	5740	5831	-857	20713	695	21408	2314	259	23981	49.91
5	6663	1816	288	8767	471	7241	0	0	5691	5997	-807	21376	843	22219	2255	293	24767	49.84
6	6670	2114	288	9072	388	7214	0	0	5766	5879	-878	21337	846	22183	2324	338	24845	49.79
7	6721	2020	291	9032	244	7251	0	32	5893	6190	-1005	21374	674	22048	2361	370	24779	49.93
8	6760	1654	290	8704	171	7191	0	219	6070	6345	-1091	21160	261	21421	2456	379	24256	50.01
9	6788	1181	277	8246	129	7113	0	512	6692	6930	-1261	21269	641	21910	2733	400	25043	50.02
10	6742	1216	284	8242	151	6999	0	792	7609	7889	-1611	22048	899	22947	3036	414	26397	49.95
11	6776	1238	278	8292	112	7077	0	1041	8035	8202	-1762	22561	944	23505	3273	401	27179	49.96
12	6772	1310	263	8345	131	7160	0	1142	8166	8461	-1854	22982	965	23947	3359	403	27709	49.80
13	6767	1404	267	8438	155	7115	0	1137	8182	8505	-1924	23002	1019	24021	3395	424	27840	49.92
14	6681	1489	204	8374	135	6964	0	1059	8715	8917	-1925	23115	1001	24116	3363	409	27888	49.98
15	6671	1546	163	8380	129	7082	0	946	8200	8279	-1964	22452	1607	24059	3461	400	27920	49.81
16	6653	1634	169	8456	174	7165	0	643	7892	8145	-1866	22315	2293	24608	3504	402	28514	49.83
17	6687	1680	203	8570	216	7140	0	392	7364	7310	-1667	21551	2283	23834	3387	410	27631	49.79
18	6711	878	267	7856	245	7148	0	164	6691	6581	-1458	20119	1724	21843	3236	417	25496	49.92
19	6733	1180	268	8181	308	7172	0	15	6279	6474	-1352	20377	951	21328	3090	421	24839	49.99
20	6811	1420	248	8479	449	7167	0	0	6230	6767	-1351	21097	510	21607	3075	414	25096	49.90
21	6837	1196	269	8302	529	7201	0	0	6197	6459	-1297	20786	223	21009	3002	408	24419	49.99
22	6857	1489	279	8625	670	7232	0	0	6262	6694	-1247	21584	0	21584	2927	390	24901	49.91
23	6815	1590	270	8675	509	7268	0	0	6342	6884	-1254	21706	0	21706	2922	376	25004	49.80
24	6789	1622	280	8691	417	7285	0	0	6392	6210	-1335	20921	11	20932	2971	347	24250	49.89
MUs	161.30	33.88	6.28	201.47	7.70	172.19	0.00	8.09	162.57	167.50	-33.03	514.96	20.96	535.92	70.32	8.97	615.21	49.89

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 13/Apr/2022

Position as on 6.30 Hrs of 14/Apr/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Nasik Unit 5	210	22/03/2022	23:40		Continued.	Coal Shortage	
MSPGCL	Koradi Unit-10	660	07/04/2022	08:08		Continued.	Condenser Cleaning work.	
MSPGCL	Uran Unit 6	108	12/04/2022	17:29	13/04/2022	13:57	Gas shortage	
MSPGCL	Uran Unit 8	108	13/04/2022	13:49		Continued.	Bearing vibration high	
MSPGCL	Uran Unit B0	120	13/04/2022	13:49		Continued.	Bearing vibration high	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 13/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 14/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Tripping							
TIE BAY (705) OF ICT - 2 & BUS REACTOR @ KORADI 3	IntraState	14/04/2022	09:10	14/04/2022	18:19	PO	Annual Maintenance of Bay equipment
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	13/04/2022	23:12	14/04/2022	01:24	EO	Attending CT OIL LEAKAGE at pole-2 base filter Z21- Z21 Y-ph
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	14/04/2022	05:02	14/04/2022	07:50	T	Tripped on Line Fault
400 KV TIEBAY Outages/Tripping							
TIE BAY-402 OF GT-10 @ KORADI-2	IntraState	13/04/2022	10:40	13/04/2022	14:58	PO	Diagnostic testing of CT & CB at bay 402
400 KV MAINBAY Outages/Tripping							
MAIN BAY (419) OF FUTURE CKT - 1 @ WARORA	IntraState	13/04/2022	09:04	13/04/2022	13:50	PO	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work.
400 KV LINE Outages/Tripping							
DHULE - SSNNL CKT - 2	InterState	13/04/2022	07:54	13/04/2022	15:34	T	Tripped on DP
KOLHAPUR - KOLHAPUR (PG) CKT - 2	InterState	13/04/2022	19:30	13/04/2022	23:31	EO	To attend CT oil leakage
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	29/03/2022	13:28			T	HT FOR LOAD MANAGEMENT
NAGOTHANE - DABHOL CKT - 2	IntraState	14/04/2022	00:52	14/04/2022	01:27	T	Distance Protection
NAGOTHANE - DABHOL CKT - 2	IntraState	14/04/2022	09:59	14/04/2022	18:56	PO	Cold washing work
LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	IntraState	14/04/2022	16:51	14/04/2022	20:26	PO	Half Yearly Bay Maintenance & DT work
400 KV ICT Outages/Tripping							
400/220KV 105 MVA SPARE ICT @ KARAD	IntraState	23/03/2022	10:14			EO	Spare ICT -1 will be taken into service through RRS in place of ICT-I R ph unit due to rising trend of various gases in ICT-I R ph unit
400 KV BR Outages/Tripping							
125 MVar BUS REACTOR @ TALANDGE	IntraState	13/04/2022	09:46	13/04/2022	18:07	PO	1. MOG of conservator tank replacement work. 2. QM Work 3. Bushing & Winding C & Tan delta testing work
220 KV TBC Outages/Tripping							
BUS COUPLER @ NAGOTHANE	IntraState	13/04/2022	11:42		Continued.	PO	CT tan delta testing
TBC @ AAREY	IntraState	14/04/2022	09:12	14/04/2022	18:26	PO	Annual maintenance work on 589C side isolator during outage of Bay-5 i.e 125MVA TR 2
220 KV LINE Outages/Tripping							
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	12/04/2022	18:36	13/04/2022	06:40	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY.
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
KANDALGAON - SONA ALLOYS	IntraState	12/04/2022	18:32	13/04/2022	06:10	EO	Damaged conductor to be attended at Loc.No.2B,15B,43B,46B,48B and other line maintenance work.
BHUGAON - WARDHA (PG)	IntraState	12/04/2022	19:15	13/04/2022	05:09	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY.
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 1	IntraState	12/04/2022	19:18	13/04/2022	06:35	HT	H/T FOR HIGH O/D AT LOW FREQUENCY
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 1	IntraState	12/04/2022	19:19	13/04/2022	05:13	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY.
WALUJ - CHITEGAON I	IntraState	12/04/2022	21:45	13/04/2022	06:09	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY.
OSMANABAD - PARLY (PG)	IntraState	12/04/2022	22:15	13/04/2022	05:04	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 13/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 14/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY - ANTOP HILL CKT - 1	IntraState	13/04/2022	00:05	13/04/2022	04:13	PO	for LA replacement work.
LAMBOTI - VAIRAG	IntraState	13/04/2022	00:46	13/04/2022	01:17	T	TRIPPED ON DIST.PROTN.
TALOJA II - OCIL 2	IntraState	13/04/2022	07:58	13/04/2022	18:04	PO	220kV SF6 Circuit Breakers & Isolator maintenance
KARAD -MUDSHINGI CKT- 4	IntraState	13/04/2022	10:49	13/04/2022	17:19	PO	Replacement of TSR-I.Fixing of new TSR-II & relay Testing work.Quarterly Maint. Work
HAMIDWADA - MUMEWADI	IntraState	13/04/2022	11:03	14/04/2022	14:45	PO	For Overhauling of 245 KV CGL make Circuit Breaker & maintenance work.
URAN - ONGC URAN	IntraState	13/04/2022	11:53	13/04/2022	14:26	T	tripped in DP
TROMBAY - KALWA	IntraState	13/04/2022	13:04	13/04/2022	19:51	PO	Bunching work at Loc No. 723 & 62
TROMBAY (M) - CHEMBUR CKT - 3	IntraState	13/04/2022	13:25			PO	Bunching work at Loc No. 723 & 62
SOUTH SOLAPUR (KUMBHARI) - SOLAPUR (PG) CKT - 1	IntraState	13/04/2022	14:37	13/04/2022	16:24	HT	Heavy CT oil Leakage
LAMBOTI - SOLAPUR 2(BALE) CKT - 1	IntraState	13/04/2022	14:37	13/04/2022	16:24	EO	To attend oil leakage from R phase CT
NEW KOYNA - NIWALI	IntraState	14/04/2022	08:42	14/04/2022	18:20	PO	For cold washing of insulator strings from Loc no 01 to 53(Niwali LILO Line), 56 to 195.
TROMBAY - MULUND	IntraState	14/04/2022	09:00			PO	Erection of tower at Loc No.72
LAMBOTI - KARKAMB	IntraState	14/04/2022	15:28	14/04/2022	15:50	T	Tripped on Distance protection
NEW KOYNA - NIWALI	IntraState	14/04/2022	19:25		Continued.	T	Tripped on Distance protection
NEW KOYNA - NIWALI	IntraState	14/04/2022	22:00		Continued.	PO	For cold washing of insulator strings from Loc no 01 to 53(Niwali LILO Line), 56 to 195.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Diferrential protection and Declare faulty
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	01/03/2022	18:17			T	Differential Protection
220 / 110 / 33kV 315 MVA ICT 6 @ CARNAC	IntraState	03/04/2022	11:00			PO	FOR SHIFTING ON NEW 110 KV GIS
220/132 KV 100 MVA ICT 1 @ SOUTH SOLAPUR	IntraState	13/04/2022	11:08	13/04/2022	14:50	PO	An outage is required for Quarterly Maintenance
220/33KV 50MVA PTR 2 @ KATHAPUR	IntraState	13/04/2022	17:50	13/04/2022	20:05	PO	Attending hot spot and routine maintenance.
220/100 KV 200 MVA ICT 2 @ TROMBAY	IntraState	13/04/2022	18:04	13/04/2022	21:55	T	Tripped on Buccholze relay
220/33KV 50MVA PTR 1 @ KATHAPUR	IntraState	13/04/2022	20:15	13/04/2022	22:30	PO	Attending hot spot and routine maintenance.
220/33kV 125 MVA TF 2 @ AAREY	IntraState	14/04/2022	09:12	14/04/2022	18:25	PO	1. Annual maintenance work on Bay-5 equipments, Transformer 2 & NGT-2. 2. Calibration of OTI/ WTI meter 3. For attending observation of TR -2 N2FF system nonworking issue.
BUS COUPLER @ LONIKAND	IntraState	14/04/2022	20:35		Continued.	PO	Back up relay & Master trip relay replacement work under MTAMC Project.
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 14/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
KALWA KALYAN	IntraState	13/04/2022	06:40	13/04/2022	13:27	PO	for attending to hot spot at loc 127-128

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage