

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 13/May/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	171.784	2144.002	1) Gujrat	-8.787	-75.686
2) Hydro	23.715	247.948	2) Madhya Pradesh	1.386	75.254
3) Gas	6.505	96.465	3) Chattisgarh	3.080	48.520
Total MSPGCL	202.004	2488.415	4) Maharashtra	183.342	2484.930
B) 1) APML	65.411	877.568	5) Goa (Amona)	-1.250	-19.954
2) JSWEL	20.237	255.294	Total	177.771	2513.064
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.928	448.850
4) RPL(AMT)	24.877	375.709	b) Mumbai Drawl	36.077	482.734
5) SWPGPL	5.376	104.433	c) MSEDCL Bilateral *	72.819	957.717
6) Other IPP	18.923	292.030	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.904	448.799
C) 1) TPCL Thermal	13.959	188.063	Include PX	0.000	0.000
2) TPCL Hydro	5.386	48.513	Standby	0.024	0.051
3) TPCL Gas	3.311	45.009	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.855	147.481	1) MSEDCL	506.562	6782.836
D) STATE			2) Mumbai Discoms	69.588	911.793
1) Thermal	331.422	4384.580	3) Other Discoms	9.694	121.943
(A1+C1+C4+(B1-B6))			TOTAL STATE	585.844	7816.572
2) Hydro (A2+C2)	29.101	296.461			
3) Gas (A3+B7+C3)	9.816	141.474			
4) Wind	30.137	362.491			
6) SOLAR	7.597	118.509			
TOTAL STATE	408.073	5303.515			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	6941	7376	7342	7083
MSPGCL Hydro	592	1476	1831	466
MSPGCL Gas	257	232	224	290
MSPGCL Total Generation	7790	9084	9397	7838
Central Sector Receipt	8978	8444	6616	6805
WIND	831	930	1227	1897
CPP / IPP Thermal	5423	5408	5560	5885
CPP / IPP Gas	0	0	0	0
SOLAR	1017	671	0	0
Exchange with Mumbai	-1943	-1849	-1472	-1217
MSEDCL DEMAND MET	21661	22261	20876	20892
Load Shedding	0	0	0	0
MSEDCL DEMAND	21661	22261	20876	20892
TPCL GENERATION	955	1100	1097	672
AEML GENERATION	499	496	498	322
MUMBAI DEMAND	3397	3445	3067	2211
OTHER DISCOM DEMAND	434	427	453	317
STATE DEMAND MET	25493	26133	24395	23420
STATE DEMAND	25493	26133	24395	23420
Frequency (Hz)	49.98	49.97	49.98	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.2 Hz at 08:02 Hrs	49.81 Hz at 16:14 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 13/May/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.82	52.85	170	145
Unit 7	0.00	0.00	0	0
Unit 8	13.16	173.95	576	436
Unit 9	12.84	158.40	559	461
Unit 10	12.89	170.30	570	500
Total	42.71	555.50		
Bhusawal				
Unit 3	3.18	40.95	155	120
Unit 4	8.67	83.43	425	280
Unit 5	7.92	112.28	400	280
Total	19.78	236.66		
Parli				
Unit 6	3.39	40.02	235	0
Unit 7	2.76	49.70	119	112
Unit 8	2.90	30.44	130	116
Total	9.05	120.15		
Chandrapur				
Unit 3	3.36	47.68	151	123
Unit 4	3.26	47.47	146	126
Unit 5	8.59	109.96	370	325
Unit 6	9.50	95.18	410	370
Unit 7	8.24	116.66	376	314
Unit 8	11.03	120.03	473	450
Unit 9	10.00	130.11	439	396
Total	53.99	667.09		
Paras				
Unit 3	4.84	51.80	219	145
Unit 4	4.81	55.61	220	144
Total	9.65	107.41		
Khaparkheda				
Unit 1	2.84	36.19	135	105
Unit 2	3.62	46.13	155	130
Unit 3	4.21	39.94	184	152
Unit 4	3.34	44.86	150	129
Unit 5	11.09	144.75	480	425
Total	25.10	311.86		
Nasik				
Unit 3	3.85	50.64	181	121
Unit 4	3.87	50.34	180	134
Unit 5	3.79	44.35	185	114
Total	11.51	145.33		
Uran				
All Units	6.50	96.46	423	219
Total	6.50	96.46		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.03	1.50	22	0
Total	0.03	1.50		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.84	53.18	540	40
Stage 4	8.05	65.87	865	0
Stage 3	2.75	26.60	240	80
Total	15.64	145.65		
Hydro				
KDPH	0.68	5.58	29	29
VTRNA	0.83	10.90	60	0
TILLARI	0.20	7.13	58	0
BHIRA T.R.	0.32	1.99	80	0
SMLHY_PTN	5.82	69.65	259	219
GHATGHAR	0.21	5.55	106	0
Total	8.05	100.80		
Wind				
Total	30.14	362.49	0	0
Total	30.14	362.49		
CPP				
APML(Mus)	65.41	877.57	0	0
JSWEL(Mus)	20.24	255.29	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.88	375.71	0	0
SWPGPL-Mus	5.38	104.43	0	0
Other(Mus)	18.92	292.03	0	0
Total	134.82	1905.03		
SOLAR				
Total	7.60	118.51	0	0
Total	7.60	118.51		
Tata				
Trombay 5	9.32	123.86	432	279
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.98	27.18	113	49
Trombay 7B	1.33	17.83	66	41
TATA Hydro	5.39	48.51	411	43
Trombay 8	4.64	64.20	227	131
Total	22.66	281.58		
AEML				
DTPS U-1&2	10.86	147.48	501	303
Total	10.86	147.48		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	171.78	2144.00	MSPGCL Total	202.00	2488.42
			MSPGCL Thml+Gas	178.29	2240.47	Koyna 1,2 & 4 Total	12.88	119.05
			MSPGCL Hydro	23.72	247.95	State Total	408.07	5303.52

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 13/May/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	7359	794	423	8576	1457	6019	0	0	6851	6742	-1291	21136	0	21136	2783	367	24286	50.00
2	7359	852	354	8564	1424	5951	0	0	6864	6644	-1128	21119	0	21119	2583	336	24038	49.97
3	7224	1050	269	8544	1632	5898	0	0	6629	6488	-1153	21102	0	21102	2407	307	23816	49.98
4	7118	780	270	8168	1809	5901	0	0	6653	6452	-1121	20899	0	20899	2283	310	23492	49.98
5	7083	466	290	7838	1897	5885	0	0	6837	6805	-1217	20892	0	20892	2211	317	23420	50.02
6	7087	598	270	7954	1739	5871	0	0	6914	7113	-1256	21062	0	21062	2233	360	23654	49.99
7	7080	1076	269	8426	1430	5818	0	45	6852	6821	-1274	20882	0	20882	2233	384	23498	50.03
8	6833	946	270	8050	1082	5629	0	191	7146	7509	-1367	20668	0	20668	2329	426	23423	50.04
9	6688	1186	269	8144	1010	5497	0	464	7364	7165	-1390	20460	0	20460	2597	429	23486	50.05
10	6775	820	270	7866	1064	5733	0	734	8083	7852	-1746	21061	0	21061	3036	441	24539	50.05
11	6538	648	278	7464	909	5329	0	904	9006	9048	-1920	21291	0	21291	3286	442	25020	50.03
12	6941	592	257	7790	831	5423	0	1017	9122	8978	-1943	21661	0	21661	3397	434	25493	49.98
13	7083	522	267	7872	930	5849	0	1049	8796	8458	-1944	21789	0	21789	3394	425	25608	50.01
14	6850	502	268	7620	832	5396	0	968	9018	9069	-1908	21543	0	21543	3329	434	25306	50.02
15	7189	908	267	8364	829	5156	0	884	8849	9058	-1937	21934	0	21934	3408	421	25763	50.00
16	7376	1476	232	9084	930	5408	0	671	8434	8444	-1849	22261	0	22261	3445	427	26133	49.97
17	7356	1338	230	8924	907	5419	0	431	8040	8041	-1746	21532	0	21532	3378	444	25355	49.98
18	7362	954	219	8536	983	5428	0	196	7626	7598	-1622	20681	0	20681	3257	437	24375	50.02
19	7326	748	220	8294	1191	5461	0	42	7156	7051	-1474	20130	0	20130	3086	435	23652	50.01
20	7342	1831	224	9397	1227	5560	0	0	6414	6616	-1472	20876	0	20876	3067	453	24395	49.98
21	7351	1893	270	9514	1299	5557	0	0	6198	6061	-1428	20554	0	20554	2995	449	23998	50.01
22	7441	1032	269	8742	1434	5487	0	0	6803	6714	-1267	20682	0	20682	2927	428	24038	50.02
23	7504	1402	280	9186	1563	5547	0	0	6563	6522	-1327	21085	0	21085	2937	406	24428	50.01
24	7519	1298	270	9086	1728	5602	0	0	6968	6521	-1297	21261	0	21261	2987	379	24628	50.01
MUs	171.78	23.72	6.51	202.00	30.14	134.82	0.00	7.60	179.19	177.77	-36.08	506.56	0.00	506.56	69.59	9.69	585.84	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 13/May/2022

Position as on 6.30 Hrs of 14/May/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	03/05/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
IPP	SWPGPL U-3	135	09/05/2022	09:30	13/05/2022	19:51	due to Boiler SSC chain broken problem	13/05/2022
IPP	RPL(AMT) U-1	270	11/05/2022	21:00		Continued.	Coal Shortage	
IPP	SWPGPL U-2	135	13/05/2022	00:33	13/05/2022	06:23	GV problem	
MSPGCL	Uran Unit B0	120	13/05/2022	01:34		Continued.	excitation fault	
MSPGCL	Uran Unit 8	108	13/05/2022	01:34		Continued.	excitation fault	
MSPGCL	Parli Unit 6	250	13/05/2022	07:29	13/05/2022	11:45	Furnace Pressure High	
IPP	Adani U-2	660	13/05/2022	14:24		Continued.	Leakage Work.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/May/2022

Statement-VII

Position as on 6.30 Hrs of 14/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY (708) of KORADI - 3 CKT - 2 & EKTUNI CKT - 2 @ AKOLA 2	IntraState	13/05/2022	10:29	13/05/2022	15:47	PO	Circuit Breaker SF6 gas analysis
765 KV MAINBAY Outages/Trippings							
MAIN BAY (709) OF KORADI 3 CKT- 2 @ AKOLA 2	IntraState	14/05/2022	09:09			PO	Circuit Breaker SF6 gas analysis
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	14/05/2022	09:47			PO	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	30/04/2022	11:21			HT	HT for Load Management
JAIGAD - KARAD CKT - 2	IntraState	09/05/2022	10:45			PO	BAY MAINTENANCE WORK AT MSETCL KARAD
PARLI-SOLAPUR (LAMBOTI)	IntraState	12/05/2022	19:34	13/05/2022	08:21	T	TRIPPED ON DIST.PROTECTION
JEJURI- KOYNA STAGE-IV	IntraState	12/05/2022	23:06	13/05/2022	05:29	EO	400KV Circuit Breaker- Oil leakage through blocking ram, hence blocking ram bypass work for all phases.
KALWA - KHARGHAR	IntraState	12/05/2022	23:30	13/05/2022	06:09	EO	Hot spot attending work and Coldline washing of 400kV Kalwa Bay equipments
AKOLA-NANDGAONPETH (RPL- AMT)	IntraState	13/05/2022	06:29	13/05/2022	20:10	PO	String replacement work will be carried out on 400 kV Akola- Nandgaonpeth line. Also work of tightening of Spacers cum Vibration Dampers, providing of corona ring & arcing horn will be carried out.
NEW KOYNA-KARAD CKT - 1	IntraState	13/05/2022	09:37	13/05/2022	16:11	PO	Hot spot attending work at loc 89 and PID faulty insulator replacement work
MAIN BUS - 2 @ LAMBOTI	IntraState	13/05/2022	17:34	13/05/2022	21:50	EO	For removing broken post Insulator at Earth Switch of 400 KV Main Bus -II (R ph)
MAIN BUS - 2 @ LAMBOTI	IntraState	13/05/2022	17:34	13/05/2022	21:50	HT	for removing broken post Insulator at Earth Switch of 400 KV Main Bus -II
KHARGHAR - TALEGAON (PG)	IntraState	14/05/2022	00:26	14/05/2022	05:16	EO	Chemical cleaning of insulators in the fog prone region, and damaged insulator strings replacement at loc no.10
AKOLA - KHADKA (BHUSAWAL)	IntraState	14/05/2022	06:32			PO	Work of strings replacement of total 04 strings detected faulty in PID testing are to be replaced by availing outage 400 kV Akola- Khadka (Bhusawal) line. Also other works like spacers fixing, providing of corona ring.
NEW KOYNA - DABHOL CKT - 2	IntraState	14/05/2022	11:48			PO	Cold washing work, Diagnostic testing & Relay testing work & Routine maint. Work
400 KV ICT Outages/Trippings							
400/220kv 500MVA ICT-2 @ TAPTITANDA	IntraState	13/05/2022	07:12	13/05/2022	14:15	PO	Pre Monsoon Maintenance Work
400/220/33 KV 500 MVA ICT - 3 @ JEJURI	IntraState	13/05/2022	21:15	14/05/2022	05:43	EO	urgent need to test the ICT-III B phase Unit in view of increasing trend of fault gas.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 13/May/2022

Statement-VII

Position as on 6.30 Hrs of 14/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
SHIVAJINAGAR-MALEGAON	IntraState	13/05/2022	03:48	13/05/2022	08:58	HT	R-ph Wave trap Jump open
APTA - TAMBATI	IntraState	13/05/2022	06:22	13/05/2022	10:29	PO	Replacement of damaged jumper Y phase CT to CB & Attending oil leakage of B phase CT
KALWA - MULUND 2	IntraState	13/05/2022	06:44	13/05/2022	09:31	PO	LA Y Ph replacement work due to high LCM value.
MUDSHINGI - CHIKODI	IntraState	13/05/2022	06:59	13/05/2022	15:57	T	Distance Protection
PADGHE - KAMBA 1	IntraState	13/05/2022	09:40	13/05/2022	13:12	PO	CT Tan Delta & CRM and Hot spot attending work.
VANKUSWADE - AJINKYATARA	IntraState	13/05/2022	10:55	13/05/2022	19:45	PO	Insulator replacement work, cold line washing of insulators and suspension clamp work
CHEMBUR (AEML) - NERUL (M)	IntraState	13/05/2022	11:17	13/05/2022	16:28	PO	Insulator cleaning work at various location.
GHATGHAR - BAPGAON	IntraState	13/05/2022	13:24	13/05/2022	13:24	PO	220 kV B Phase LA replacement work at Ghatghar SS, R&M works at Bapgaon SS
BOMBAY DYEING - SAHARA	IntraState	13/05/2022	14:06	13/05/2022	23:32	EO	1)Replacement of F/O Strings in view of AR operation on dt.13.05.2022. 2)Cold washing of insulators from Loc.115 to 125
SATANA - GANGAPUR	IntraState	13/05/2022	15:21	13/05/2022	17:24	PO	Outage proposal for attending the red hot which found in thermo vision camera & Quarterly maint.Work at satana End.
BABLESHWAR-BABLESHWAR(400KV)-I	IntraState	13/05/2022	17:15	13/05/2022	18:29	PO	Bay equipment maintenance work and TAN DELTA Testing of line CTs
KANDALGAON - KOYNA (POPHALI)	IntraState	14/05/2022	05:20	14/05/2022	10:35	PO	For replacement of damaged tower during flood at Chiplun at Loc. No. 56 of 220kV New Koyana ĳ Lote & 220kV Pophali ĳ Kandalgaon D/C Line.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	14/05/2022	05:41	14/05/2022	06:42	T	TRIPPED ON DIST.PROTECTION
NEW KOYNA - LOTEPARSHURAM	IntraState	14/05/2022	06:13	14/05/2022	10:04	PO	For replacement of damaged tower (during flood at Chiplun) at Loc. No. 56 of 220kV New Koyana ĳ Lote & 220kV Pophali ĳ Kandalgaon D/C Line.
URAN - SEZ JNPT	IntraState	14/05/2022	09:45			PO	"1) Replacement of B Phase Stub Bus Horizontal Insulator String. 2) Diagnostic Testing & R&M Works."
NAGAR BELWANDI CKT 2	IntraState	14/05/2022	10:40	14/05/2022	11:20	EO	For attending Hot Spot on B-Ph CT (160 Degrees)
BOMBAY DYEING - SAHARA	IntraState	14/05/2022	11:18			EO	1)Replacement of polymer insulator by longrod insulator Loc.146-147 2) Cold line washing loc.130-140, Loc.90-100
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	IntraState	13/05/2022	06:42	13/05/2022	13:05	PO	198kV R phase LA erection, Hot spot attending and R&M work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/May/2022

Statement-VII

Position as on 6.30 Hrs of 14/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22 KV 50 MVA PTR 1	IntraState	13/05/2022	09:01	13/05/2022	17:30	PO	for Replacement of damaged LV Cable Termination
220/132 KV 200 MVA ICT 1 @ MALEGAON	IntraState	13/05/2022	09:46			HT	smoke observed through 132KV I.C 1 B ph CT
220/132 KV 200 MVA ICT 1 @ MALEGAON	IntraState	13/05/2022	09:46	13/05/2022	22:45	EO	During switchyard inspection smoke observed through 132KV I.C 1 B ph CT. I/C 1 HT immediately. CT Sec wiring found burnt. An Emergency Outage required for 132 Kv Incomer-Ist B-phase CT replacement work.
220/132 KV 150 MVA PTR NO 7	IntraState	13/05/2022	10:22	13/05/2022	18:29	PO	For CT Replacement of R,Y phase and air cell leakage & refitting attending work
220/33 KV 50MVA PTR NO 1 @ ALEPHATA	IntraState	13/05/2022	11:47	13/05/2022	15:02	PO	For Diagnostic testing work & general maintenance work
220/33 KV 50 MVA PTR NO 3 @ ALEPHATA	IntraState	13/05/2022	15:07	13/05/2022	19:53	PO	For Diagnostic testing work & general maintenance work (Red Hot spot attending)
220/33 KV 50 MVA PTR 2 @ SONKAR	IntraState	14/05/2022	06:04			PO	Premonsoon maintenance, LA Meggering, RM work Earthing pit renovation, hot spot attending work.
220/22 KV 50 MVA PTR 3 @ MAHAPE	IntraState	14/05/2022	08:18			PO	1) 50 MVA T/F-III Premonsoon maintenance work. 2) 50 MVA T/F-III Diagnostic testing work & bay maintenance work. 3) Erection & commissioning of advanced TF oil cooling / heat exchanger system as per MSETCL.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	14/05/2022	08:32			PO	Attending oil leakage and R/M
220/132KV 200MVA ICT 6 @ EKLAHARE (GCR)	IntraState	14/05/2022	09:32			PO	Oil Leakage arrest work and diagnosis of testing work.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shifting these lines on new Multicircuit Towers between Darave to Vashi.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/May/2022

Statement-VII

Position as on 6.30 Hrs of 14/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage