

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 13/Jun/2015 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	106.196	1544.401	1) Gujrat	4.219	19.170
2) Hydro	6.625	146.526	2) Madhya Pradesh	13.984	183.668
3) Gas	3.292	74.722	3) Chattisgarh	4.560	54.650
Total MSPGCL	116.113	1765.649	4) Maharashtra Net	88.124	1295.021
B) 1) APMIL	52.940	736.530	5) Goa	-6.280	-88.488
2) JSWEL	15.108	209.362	6) TAPS 1&2 Injection	3.060	23.291
3) VIPL	9.526	144.158	7) RGPPL Injection	0.000	0.000
4) RPL(AMT)	4.540	66.970	8) Pench (MS)	0.000	1.154
5) WPCL	7.705	89.140	9) Pench (Excess)	0.000	-0.751
6) Other IPP	4.860	71.248	Total	107.667	1486.561
C) 1) TPCL Thermal	13.422	209.393	a) Mumbai Schedule	21.851	358.149
2) TPCL Hydro	2.352	46.027	b) Mumbai Drawl	28.321	397.779
3) TPCL Gas	2.573	34.352	c) MSEDCL Bilateral *	29.718	395.448
4) R-INFRA Thermal	9.805	153.986	Include PX	-0.426	1.182
D) STATE			d) Mumbai Bilateral *	21.851	358.149
1) Thermal	224.102	3225.188	Include PX	0.819	26.811
(A1+C1+C4+(B1-B6))			Include Standby	0.000	0.000
2) Hydro	8.977	192.553	H) ENERGY CATERED (MUs)		
3) Gas	5.865	109.074	1) MSEDCL	307.263	4381.506
4) Wind	16.173	195.592	2) Mumbai Discoms	56.473	841.527
6) SOLAR	0.952	13.324	TOTAL STATE	363.736	5223.033
TOTAL STATE	256.069	3735.731			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	4703	4710	4166	4582
MSPGCL Hydro	498	201	736	201
MSPGCL Gas	133	133	127	134
MSPGCL Total Generation	5334	5044	5029	4917
Central Sector Receipt	4804	4710	4597	3946
WIND	441	606	960	295
CPP / IPP	4223	4218	3953	3703
SOLAR	111	124	0	0
Exchange with Mumbai	-1182	-1195	-1327	-934
MSEDCL DEMAND MET	13731	13507	13212	11927
Load Shedding	44	44	39	44
MSEDCL DEMAND	13775	13551	13251	11971
TPCL GENERATION	1027	1011	820	627
R-INFRA GENERATION	514	509	381	380
MUMBAI DEMAND	2723	2715	2528	1941
STATE DEMAND MET	16454	16222	15740	13868
STATE DEMAND	16498	16266	15779	13912
Frequency (Hz)	50.03	49.98	49.90	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.49 Hz at 15.02 Hrs	49.72 Hz at 20.13 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 13/Jun/2015

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	3.14	30.28	142	119
Unit 6	0.00	0.00	0	0
Unit 7	3.64	15.07	160	130
Total	6.78	45.35		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	3.98	4.57	170	160
Unit 4	5.66	132.15	395	0
Unit 5	9.14	98.64	400	360
Total	18.76	235.37		
Parli				
Unit 3	3.50	45.12	160	132
Unit 4	0.00	0.00	0	0
Unit 5	3.53	46.37	149	143
Unit 6	4.65	62.74	203	187
Unit 7	4.65	65.20	204	191
Total	16.33	219.43		
Chandrapur				
Unit 1	0.00	0.00	0	0
Unit 2	3.32	40.73	145	130
Unit 3	4.01	55.34	177	149
Unit 4	3.95	54.46	176	160
Unit 5	8.98	121.85	380	360
Unit 6	0.00	84.60	0	0
Unit 7	6.64	80.77	315	237
Total	26.89	437.76		
Paras				
Unit 3	5.04	65.36	237	144
Unit 4	5.00	68.68	234	193
Total	10.04	134.04		
Khaparkheda				
Unit 1	3.86	42.72	170	155
Unit 2	3.73	46.11	165	135
Unit 3	3.90	52.20	172	152
Unit 4	3.86	49.79	166	155
Unit 5	0.00	105.83	0	0
Total	15.36	296.66		
Nasik				
Unit 3	4.46	60.74	195	180
Unit 4	3.17	55.48	148	0
Unit 5	4.40	59.55	188	176
Total	12.03	175.78		
Uran				
All Units	3.29	74.72	178	127
Total	3.29	74.72		
PENCH (MS)				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Pench (MS)	0.00	1.15	0	0
Total	0.00	1.15		
Koyna				
Stage 1-2	2.64	49.60	475	40
Stage 4	0.51	42.10	200	0
Stage 3	1.00	20.47	160	0
Total	4.14	112.17		
Hydro				
KDPH	0.34	3.52	14	14
VTRNA	0.00	8.82	0	0
TILLARI	0.00	1.93	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.13	2.50	80	0
RNGR+BHTSA	0.21	2.40	9	8
BHANDARDRA	0.00	0.63	0	0
ELDARY	0.00	1.04	0	0
SMLHY_PTN	0.28	2.21	20	9
GHATGHAR	1.53	11.32	250	0
Total	2.48	34.36		
Wind				
Total	16.17	195.59	0	0
Total	16.17	195.59		
CPP				
APML(Mus)	52.94	736.53	0	0
JSWEL(Mus)	15.11	209.36	0	0
VIPL(Mus)	9.53	144.16	0	0
RPLAMT(Mus)	4.54	66.97	0	0
WPCL(Mus)	7.70	89.14	0	0
Other(Mus)	4.86	71.25	0	0
Total	94.68	1317.41		
SOLAR				
Total	0.95	13.32	0	0
Total	0.95	13.32		
Tata				
Trombay 5	8.33	127.84	483	315
Trombay 6	0.00	13.80	0	0
Trombay 7A	1.43	19.23	60	59
Trombay 7B	1.14	15.12	48	46
Trombay 8	5.10	67.75	250	197
TATA Hydro	2.35	46.03	300	0
Total	18.35	289.77		
R-INFRA				
1-2	9.80	153.99	514	378
Total	9.80	153.99		

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	106.20	1544.40
MSPGCL Thml+Gas	109.49	1619.12

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Hydro	6.62	146.53
MSPGCL Total	116.11	1765.65

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
Koyna 1,2 & 4 Total	3.14	91.70
State Total	256.07	3735.73

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 13/Jun/2015

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	4503	176	133	4812	710	4144	0	4168	4734	-1430	12970	62	13032	2454	15486	49.95
2	4501	101	132	4734	581	4268	0	4130	4092	-1230	12445	44	12489	2237	14726	49.96
3	4573	76	133	4782	451	4241	0	4106	4135	-1089	12520	44	12564	2099	14663	49.97
4	4583	71	133	4787	303	3825	0	4000	4252	-988	12179	44	12223	1995	14218	49.60
5	4582	201	134	4917	295	3703	0	3907	3946	-934	11927	44	11971	1941	13912	49.99
6	4591	226	134	4951	280	3753	0	4020	4113	-950	12147	45	12192	1954	14146	50.04
7	4585	77	133	4795	370	3711	4	4109	4253	-876	12257	45	12302	1883	14185	49.99
8	4583	297	133	5013	247	3731	15	4092	4318	-920	12404	45	12449	1938	14387	50.04
9	4602	237	134	4973	250	3915	30	4322	4542	-828	12882	48	12930	2132	15062	50.08
10	4661	271	134	5066	309	4129	74	4459	4872	-1049	13401	48	13449	2426	15875	50.00
11	4675	522	134	5331	403	4224	110	4464	4772	-1167	13673	46	13719	2686	16405	50.02
12	4703	498	133	5334	441	4223	111	4569	4804	-1182	13731	44	13775	2723	16498	50.03
13	4710	201	133	5044	606	4218	124	4576	4710	-1195	13507	44	13551	2715	16266	49.98
14	4674	94	132	4900	768	4169	138	4539	4404	-1279	13100	39	13139	2581	15720	50.15
15	4552	82	134	4768	983	4105	131	4469	4711	-1351	13347	39	13386	2560	15946	50.20
16	4211	72	131	4414	1189	3894	92	4459	4929	-1392	13126	39	13165	2551	15716	50.24
17	4163	78	131	4372	1482	3601	69	4242	4573	-1400	12697	39	12736	2512	15248	50.12
18	4114	93	131	4338	1491	3388	45	3669	3879	-1398	11743	39	11782	2477	14259	50.09
19	4104	266	128	4498	1207	3429	8	2828	4171	-1291	12022	39	12061	2426	14487	50.02
20	4123	748	128	4999	1032	3579	1	3993	4659	-1206	13064	39	13103	2517	15620	49.88
21	4166	736	127	5029	960	3953	0	4320	4597	-1327	13212	39	13251	2528	15779	49.90
22	4103	531	162	4796	757	4151	0	4259	4457	-1277	12884	39	12923	2445	15368	49.98
23	3989	488	178	4655	572	4144	0	4277	4817	-1276	12912	39	12951	2369	15320	49.95
24	4145	483	177	4805	486	4181	0	4279	4927	-1286	13113	39	13152	2324	15476	49.99
MUs	106.20	6.63	3.29	116.11	16.17	94.68	0.95	100.26	107.67	-28.32	307.26	1.03	308.29	56.47	364.77	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 13/Jun/2015

Position as on 6.30 Hrs of 14/Jun/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CENT.SECTOR	Tarapur 1	160	12/10/2014	22:39		Continued.	Refuelling work	
MSPGCL	Parli Unit 4	210	13/04/2015	11.27		Continued.	Turbine vibration high. Continued to AOH w.e.f.01.05.2015	
IPP	Adani U-1	660	01/06/2015	01.48		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 6	500	09/06/2015	23.58		Continued.	COH	
FORCED OUTAGE								
RGPPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPPL	Dabhol 3A	230	06/06/2013	08.28		Continued.	Gas Shortage	
RGPPL	Dabhol 2A	230	06/06/2013	09.10		Continued.	Gas Shortage	
RGPPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
RGPPL	Dabhol 2X	290	15/07/2013	15.09		Continued.	Gas Shortage	
RGPPL	Dabhol 2B	230	08/08/2013	15.03		Continued.	Gas Shortage	
RGPPL	Dabhol 3X	290	29/12/2013	05.47		Continued.	Gas Shortage	
RGPPL	Dabhol 3B	230	29/12/2013	06.14		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No schedule	
MSPGCL	Chandrapur Unit 1	210	28/08/2014	07:15		Continued.	Economic Shutdown.	
MSPGCL	Bhusawal Unit 2	210	13/09/2014	12.43		Continued.	Economic shutdown	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Chandrapur Unit-8	500	29/03/2015	18.26		Continued.	Withdrawn	
MSPGCL	Koradi Unit-8	660	30/03/2015	20.22		Continued.	BLR Tripped.	
MSPGCL	Uran Unit 6	108	01/04/2015	16.35		Continued.	Gas shortage	
IPP	RPL(AMT) U-4	270	03/04/2015	11.42		Continued.	Boiler feed Pump problem.	
IPP	RPL(AMT) U-5	270	03/04/2015	14.22		Continued.	turbine Shaft Vibration high.	
IPP	RPL(AMT) U-3	270	05/04/2015	22.01		Continued.	Governor AVR Problem.	
MSPGCL	Uran Unit 7	108	17/04/2015	00.07		Continued.	Gas turbine problem	
IPP	JSW (J) U1	300	14/05/2015	19.16		Continued.	Turbine Bearing Problem	
IPP	RPL(AMT) U-2	270	01/06/2015	06.53		Continued.	Coal bunkering problem	
TPC-G	Trombay 6	500	05/06/2015	05.59		Continued.	Economic Shutdown.	
MSPGCL	Koyna STG- IV Unit - 1	250	09/06/2015	14.22		Continued.	Excitation major problem.	
MSPGCL	Uran Unit 5	108	11/06/2015	00.11		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	11/06/2015	00.12	14/06/2015	01.35	Gas shortage	
MSPGCL	Khaparkheda Unit 5	500	11/06/2015	14.17	14/06/2015	16.00	Boiler Tube Leakage	
MSPGCL	Bhusawal Unit 4	500	13/06/2015	14.50	14/06/2015	05.52	due to jerk of tripping of 400kv deepnagar-a'bad line	
MSPGCL	Nasik Unit 4	210	13/06/2015	22.05		Continued.	Boiler Validity extension work	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 13/Jun/2015

Position as on 6.30 Hrs of 14/Jun/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
TPC-G	Trombay 7A	120	14/06/2015	02.04	14/06/2015	06.43	due to brusting of breaker	
TPC-G	Trombay 7B	60	14/06/2015	02.04	14/06/2015	08.45	due to brusting of breaker	
MSPGCL	Parli Unit 3	210	14/06/2015	12.58		Continued.	Coal Shortage	
MSPGCL	Uran Unit B0	120	14/06/2015	14.48		Continued.	Compresor Surge Protection Operated.	
MSPGCL	Uran Unit 8	108	14/06/2015	14.48		Continued.	Compresor Surge Protection Operated.	
MSPGCL	Bhusawal Unit 4	500	14/06/2015	21.14	14/06/2015	22.25	To Take A'bad-Bsl Line in Service.	
MSPGCL	Chandrapur Unit 2	210	14/06/2015	21.35		Continued.	UAT Supply Fail.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jun/2015

Statement-VII

Position as on 6.30 Hrs of 14/Jun/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Wardha(PG)-Aurangabad(PG)- II	InterState	22/05/2015	16.44		Continued.	HT	To Control ICT Loading.
Wardha PG - Aurangabad PG IV	InterState	11/06/2015	11.34		Continued.	HT	Over Voltage
400 KV LINE Outages/Trippings							
Wardha (PG)-Warora II	InterState	20/05/2015	02.39		Continued.	T	Breaker Accumulator Oil Leakage
Dhule Sar'Sarovar I	InterState	10/06/2015	18.16	13/06/2015	09.56	HT	Over Voltage
Kolhapur Mapusa I	InterState	12/06/2015	16.15	13/06/2015	09.29	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	13/06/2015	05.09		Continued.	T	DT Received at Dhule
Chandrapur Bhadravati II	InterState	13/06/2015	08.53	13/06/2015	17.16	PO	Replacement work
Talegaon(Pg) Padgha	InterState	13/06/2015	09.04	13/06/2015	16.26	PO	Annual Maintenance Work
Kolhapur Mapusa II	InterState	13/06/2015	16.26	14/06/2015	09.41	HT	Over Voltage
Lamboti - Solapur (PG)	InterState	14/06/2015	15.26		Continued.	T	Distance Protection
Kolhapur Mapusa II	InterState	14/06/2015	15.52		Continued.	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt I	IntraState	07/04/2015	00.27		Continued.	T	"R" Phase Metering CT Burst.
Akola II - Taptitanda	IntraState	20/05/2015	08.59		Continued.	HT	Ckt I and Ckt 2 new charged to control BBLSR ICT loading.
New Koyna - Dabhol-I	IntraState	08/06/2015	10.05		Continued.	PO	Outage (RFC 16.07Hrs)
Bhusawal-Aurangabad	IntraState	11/06/2015	17.26		Continued.	HT	Over Voltage
Babhaleshwar-Taptitanda ckt-II	IntraState	12/06/2015	16.20		Continued.	HT	Over Voltage
karad -kolhapur-II	IntraState	12/06/2015	16.37	13/06/2015	09.34	HT	Over Voltage
Karad - Jaigad - II	IntraState	12/06/2015	17.18	13/06/2015	10.03	HT	Over Voltage
Babhaleshwar - Padghe-I	IntraState	12/06/2015	23.32	13/06/2015	07.22	PO	To attend Hot Spot
Lonikand I - Koyna stage-IV	IntraState	13/06/2015	01.11	13/06/2015	06.49	HT	Over Voltage
Bus Coupler @ Kharghar	IntraState	13/06/2015	09.46	14/06/2015	19.54	PO	erection of pg isolator for a bus
karad -kolhapur-I	IntraState	13/06/2015	13.33		Continued.	HT	Over Voltage
Karad-Jaigad - I	IntraState	13/06/2015	16.04		Continued.	HT	Over Voltage
Chandrapur-Parali III	IntraState	13/06/2015	18.10	13/06/2015	21.18	T	Over Voltage
Padghe - Talegaon (PG)	IntraState	14/06/2015	13.30	14/06/2015	14.09	PO	A/R Auto to Non Auto for OPGW.
Lonikand I - Koyna stage-IV	IntraState	14/06/2015	17.26		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/132 Kv 200 Mva Ict 2 @Khadka	IntraState	11/06/2015	12.57		Continued.	PO	R Phase Jumper Reconnection
400/220/33 Kv 315 Mva ICT I @Akola	IntraState	12/06/2015	11.07	13/06/2015	19.43	PO	Routine Maintenance Work
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	13/06/2015	06.30	13/06/2015	08.52	T	premansoon maintance work
400/220/33 Kv 315 Mva ICT II @Chandrapur	IntraState	13/06/2015	10.06	13/06/2015	19.50	PO	Replacement work
400/220/33 Kv 315 Mva ICT I @Akola	IntraState	13/06/2015	20.57	13/06/2015	21.18	T	ct burst lv side
400/220 Kv 600 MVA ICT-IV @Padghe	IntraState	14/06/2015	09.26	14/06/2015	12.56	PO	P.M.Work.
400/220/33 Kv 315 Mva Ict- 2 @Kharghar	IntraState	14/06/2015	15.36	14/06/2015	16.58	PO	Premonsoon Work.
400/220/33 Kv 500 Mva Ict 3 @Girwali	IntraState	14/06/2015	16.24		Continued.	T	Due to LV Side PRV Operated.
220 KV LINE Outages/Trippings							
Sahara-Urse	IntraState	03/03/2015	11.06		Continued.	PO	Tower erection work (90Days)
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jun/2015

Statement-VII

Position as on 6.30 Hrs of 14/Jun/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
Padghe - Jambhul 2	IntraState	09/06/2015	11.13		Continued.	PO	Shifted on TBC,Bus isolator maint.
Chandrapur GCR - Cpur Rly Tss 2	IntraState	12/06/2015	10.38		Continued.	PO	Isolator Maint.work
Jamde-Dondaicha 1	IntraState	12/06/2015	16.00		Continued.	T	R Phase Conductor Snapped
Nanded - Parli Ext. Ckt I	IntraState	12/06/2015	16.46		Continued.	T	Distance Protection
Badnera-Akola I	IntraState	13/06/2015	00.08	13/06/2015	00.50	T	Bus Bar Prot.Operated at Akola
Badnera-Akola li	IntraState	13/06/2015	00.08	13/06/2015	00.57	T	Bus Bar Prot.Operated at Akola
Akola-Paras Ckt No-I	IntraState	13/06/2015	00.08	13/06/2015	00.45	T	Bus Bar Prot.Operated at Akola
Balapur-Akola li	IntraState	13/06/2015	00.08	13/06/2015	00.35	T	Bus Bar Prot.Operated at Akola
Balapur-Akola I	IntraState	13/06/2015	00.08	13/06/2015	00.30	T	Bus Bar Prot.Operated at Akola
Akola-Paras Ckt No-li	IntraState	13/06/2015	00.08	13/06/2015	00.55	T	Bus Bar Prot.Operated at Akola
Magar Patta City- Serum	IntraState	13/06/2015	09.21	13/06/2015	16.18	PO	Half yearly maintenance work
Karad-Nerle	IntraState	13/06/2015	11.18	13/06/2015	14.00	PO	Replacement work
Kharghar Trombay	IntraState	13/06/2015	23.32	14/06/2015	00.08	T	Distance Protection
Trombay Dharavi 6	IntraState	14/06/2015	02.04	14/06/2015	02.17	T	bus bar operated at trombay end
Trombay Dharavi 5	IntraState	14/06/2015	02.04	14/06/2015	09.34	T	bus bar operated at trombay end
Trombay Salsette 1 Backbay	IntraState	14/06/2015	02.04	14/06/2015	09.33	T	bus bar operated at trombay end
Trombay Carnac 6	IntraState	14/06/2015	02.04	14/06/2015	03.39	T	bus bar operated at trombay end
Bableshtar- Alephata	IntraState	14/06/2015	08.20	14/06/2015	15.56	HT	To Control BBLR ICT Loading.
Padgha - Temghar I	IntraState	14/06/2015	09.17	14/06/2015	13.00	HT	Padgha ICT-4 Outage.
Padgha-Temghar-II	IntraState	14/06/2015	09.18	14/06/2015	13.00	HT	Padgha ICT-4 Outage.
Kharghar Trombay	IntraState	14/06/2015	12.43	14/06/2015	13.01	PO	Bird Nest Eemoval from loc.699
Sonkhar - Trombay	IntraState	14/06/2015	13.02	14/06/2015	13.05	PO	Bird Nest Eemoval from loc.699
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Internal Fault
220/132Kv 200MVA ICT-I @ Akola	IntraState	13/06/2015	00.08	13/06/2015	00.43	T	Bus Bar Prot.Operated at Akola
220/132 Kv 200 Mva Vijai Ict 1 @Eklahre (Gcr)	IntraState	13/06/2015	09.36		Continued.	PO	p.m.work
220/132 Kv 200 Mva Cgl Ict 1 @Raymond (Nasik 2)	IntraState	13/06/2015	10.09	13/06/2015	16.06	PO	Attending Hot Spot
220/100 Kv 100 Mva Emco Ict 1 @Tambati	IntraState	13/06/2015	15.06	13/06/2015	15.46	PO	Annual Maintenance Work
220/100 Kv 100 Mva Cgl Ict 2 @Tambati	IntraState	13/06/2015	15.48	13/06/2015	16.23	PO	Annual Maintenance Work
132 KV LINE Outages/Trippings							
Dondaicha- Shahada	IntraState	07/06/2015	21.08		Continued.	T	L A Brust @ Shahada.
Akola-Paras Ckt-I	IntraState	12/06/2015	16.32	13/06/2015	01.18	T	Distance Protection
Chikhli-Dhad	IntraState	13/06/2015	00.08	13/06/2015	00.33	T	Load Trimming Scheme operated at Chikhali
Chikhali-Deulgaon Mahi	IntraState	13/06/2015	00.08	13/06/2015	00.33	T	Load Trimming Scheme operated at Chikhali
Nandurbar - Visarwadi	IntraState	13/06/2015	03.10		Continued.	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage