

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 13/Jun/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	160.808	2022.049	1) Gujrat	2.681	-34.249
2) Hydro	6.517	210.347	2) Madhya Pradesh	4.932	75.842
3) Gas	4.555	63.967	3) Chattisgarh	3.290	39.650
Total MSPGCL	171.880	2296.363	4) Maharashtra	204.297	2781.149
B) 1) APLM	67.203	856.692	5) Goa (Amona)	-1.329	-18.505
2) JSWEL	22.244	313.975	Total	213.871	2843.887
3) VIPL	0.000	0.000	a) Mumbai Schedule	44.033	563.104
4) RPL(AMT)	25.042	395.324	b) Mumbai Drawl	48.326	621.063
5) SWPGPL	10.710	135.348	c) MSEDCL Bilateral *	126.618	1438.887
6) Other IPP	7.170	58.378	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	44.033	562.917
C) 1) TPCL Thermal	12.950	164.940	Include PX	0.000	0.000
2) TPCL Hydro	5.563	70.355	Standby	0.000	0.187
3) TPCL Gas	1.648	25.895	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.556	116.818	1) MSEDCL	526.612	6760.020
D) STATE			2) Mumbai Discoms	78.043	999.071
1) Thermal	315.683	4063.524	3) Other Discoms	10.566	138.780
(A1+C1+C4+(B1-B6))			TOTAL STATE	615.221	7897.871
2) Hydro (A2+C2)	12.080	280.702			
3) Gas (A3+B7+C3)	6.203	89.862			
4) Wind	50.942	410.732			
6) SOLAR	16.442	209.164			
TOTAL STATE	401.350	5053.984			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	6512	6828	6851	6790
MSPGCL Hydro	234	150	234	218
MSPGCL Gas	180	174	190	203
MSPGCL Total Generation	6926	7152	7274	7212
Central Sector Receipt	9176	9265	7152	9546
WIND	2370	2339	2574	1525
CPP / IPP Thermal	4685	5541	6241	5701
CPP / IPP Gas	0	0	0	0
SOLAR	2179	1415	0	0
Exchange with Mumbai	-2559	-2469	-1646	-1607
MSEDCL DEMAND MET	22289	22778	21151	22015
Load Shedding	0	0	0	0
MSEDCL DEMAND	22289	22778	21151	22015
TPCL GENERATION	681	923	1116	699
AEML GENERATION	482	476	488	306
MUMBAI DEMAND	3722	3868	3250	2612
OTHER DISCOM DEMAND	487	465	445	362
STATE DEMAND MET	26498	27110	24846	24988
STATE DEMAND	26498	27110	24846	24988
Frequency (Hz)	50.03	49.95	50.03	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.32 Hz at 18.02 Hrs	49.72 Hz at 22.36 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 13/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.43	60.56	195	155
Unit 8	13.74	102.14	605	540
Unit 9	14.16	88.84	604	572
Unit 10	12.68	168.39	540	500
Total	45.01	419.94		
Bhusawal				
Unit 3	0.24	28.97	90	0
Unit 4	10.35	128.93	455	390
Unit 5	11.11	139.09	490	425
Total	21.70	296.99		
Parli				
Unit 6	4.86	60.67	249	146
Unit 7	4.69	61.79	245	148
Unit 8	3.45	54.06	155	138
Total	13.00	176.52		
Chandrapur				
Unit 3	2.97	36.94	155	101
Unit 4	0.00	39.36	0	0
Unit 5	0.00	0.00	0	0
Unit 6	9.06	98.14	405	305
Unit 7	9.81	122.36	431	320
Unit 8	10.56	140.25	471	338
Unit 9	10.49	144.72	485	350
Total	42.89	581.78		
Paras				
Unit 3	4.98	64.58	222	154
Unit 4	0.00	54.79	0	0
Total	4.98	119.36		
Khaparkheda				
Unit 1	2.98	38.20	140	100
Unit 2	2.86	38.12	130	113
Unit 3	4.12	43.04	183	142
Unit 4	4.24	52.84	190	155
Unit 5	11.18	141.14	470	465
Total	25.39	313.33		
Nasik				
Unit 3	0.00	10.09	0	0
Unit 4	3.88	52.52	174	130
Unit 5	3.96	51.53	178	156
Total	7.84	114.13		
Uran				
All Units	4.56	63.97	205	171
Total	4.56	63.97		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.07	1.15	21	0
Total	0.07	1.15		
Koyna				
Stage 1-2	1.94	50.01	370	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	81.22	0	0
Stage 3	0.41	30.01	80	0
Total	2.35	161.23		
Hydro				
KDPH	0.20	4.44	9	9
VTRNA	1.03	14.51	61	0
TILLARI	0.00	1.04	0	0
BHIRA T.R.	0.28	4.55	77	0
SMLHY_PTN	2.51	23.15	109	100
GHATGHAR	0.08	0.27	72	0
Total	4.10	47.97		
Wind				
Total	50.94	410.73	0	0
Total	50.94	410.73		
CPP				
APML(Mus)	67.20	856.69	0	0
JSWEL(Mus)	22.24	313.98	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.04	395.32	0	0
SWPGPL-Mus	10.71	135.35	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.31	28.79	270	183
Other(Mus)	1.86	29.59	0	0
Total	132.37	1759.72		
SOLAR				
Total	16.44	209.16	0	0
Total	16.44	209.16		
Tata				
Trombay 5	8.45	107.97	425	269
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.88	14.05	45	12
Trombay 7B	0.76	11.84	36	4
TATA Hydro	5.56	70.36	413	63
Trombay 8	4.50	56.97	230	130
Total	20.16	261.19		
AEML				
DTPS U-1&2	9.56	116.82	488	289
Total	9.56	116.82		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	160.81	2022.05	MSPGCL Total	171.88	2296.36
			MSPGCL Thml+Gas	165.36	2086.02	Koyna 1,2 & 4 Total	1.94	131.23
			MSPGCL Hydro	6.52	210.35	State Total	401.35	5053.98

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 13/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7008	548	202	7758	1390	6252	0	0	8553	9065	-1713	22345	0	0	22345	3217	406	25968	49.99
2	6950	362	203	7514	1358	6198	0	0	9442	9556	-1582	22675	0	0	22675	3006	370	26050	49.99
3	6980	224	203	7406	1523	6087	0	0	9265	9228	-1526	22375	0	0	22375	2812	344	25530	49.99
4	6913	216	205	7334	1681	6017	0	0	9197	9010	-1559	22142	0	0	22142	2681	340	25164	50.01
5	6790	218	203	7212	1525	5701	0	0	9763	9546	-1607	22015	0	0	22015	2612	362	24988	50.00
6	6819	228	205	7252	1437	6025	0	2	9444	9779	-1598	22494	0	0	22494	2607	403	25504	50.01
7	6806	236	204	7246	1455	5861	0	167	9604	9612	-1743	22156	0	0	22156	2582	441	25180	50.00
8	6752	313	203	7268	1832	5748	0	630	8939	9062	-1874	22200	0	0	22200	2707	467	25373	50.10
9	6487	244	186	6916	2289	4991	0	1224	9043	9101	-2137	21889	0	0	21889	3010	495	25394	50.09
10	6238	282	185	6706	2447	4457	0	1708	9152	9607	-2302	22130	0	0	22130	3343	493	25966	50.01
11	6459	286	182	6928	2423	4689	0	2058	8945	9018	-2477	22143	0	0	22143	3602	495	26240	50.17
12	6512	234	180	6926	2370	4685	0	2179	9042	9176	-2559	22289	0	0	22289	3722	487	26498	50.03
13	6190	232	181	6602	2325	4486	0	2003	9686	9496	-2489	21962	0	0	21962	3717	461	26140	50.07
14	6090	230	174	6494	2350	4197	0	1877	9936	10048	-2379	22102	0	0	22102	3707	485	26294	50.13
15	6673	192	171	7036	2438	4594	0	1733	9368	9759	-2477	22626	0	0	22626	3816	457	26900	50.00
16	6828	150	174	7152	2339	5541	0	1415	9451	9265	-2469	22778	0	0	22778	3868	465	27110	49.95
17	6653	212	177	7042	2524	5263	0	912	9176	9243	-2392	22150	0	0	22150	3774	442	26366	49.99
18	6778	210	177	7166	2685	5713	0	446	8410	8084	-2226	21405	0	0	21405	3618	462	25486	50.01
19	6622	250	184	7056	2572	5353	0	88	8376	7886	-2295	20204	0	0	20204	3377	456	24036	50.06
20	6705	268	182	7154	2613	5601	0	0	8261	8125	-2011	21023	0	0	21023	3307	460	24790	50.01
21	6851	234	190	7274	2574	6241	0	0	7360	7152	-1646	21151	0	0	21151	3250	445	24846	50.03
22	6826	228	189	7244	2542	6123	0	0	7746	7378	-1699	21137	0	0	21137	3166	450	24754	50.02
23	6901	346	197	7444	2169	6244	0	0	7573	7959	-1776	21588	0	0	21588	3239	451	25279	49.92
24	6977	578	198	7753	2081	6302	0	0	7635	7716	-1790	21633	0	0	21633	3303	429	25365	49.95
MUs	160.81	6.52	4.55	171.88	50.94	132.37	0.00	16.44	213.37	213.87	-48.33	526.61	0.00	0.00	526.61	78.04	10.57	615.22	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 13/Jun/2023

Position as on 6.30 Hrs of 14/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Nasik Unit 3	210	08/06/2023	11:40		Continued.	Tolling Agreement with IEPL synchronised at 9:19 Hrs	
MSPGCL	Paras Unit 4	250	11/06/2023	13:46		Continued.	Boiler Tube Leakage	14/06/2023
MSPGCL	Chandrapur Unit 4	210	11/06/2023	18:51		Continued.	SUSPECTED BTL AT AB-4 ELEVATION	13/06/2023
MSPGCL	Bhusawal Unit 3	210	13/06/2023	03:15		Continued.	ID Fan Problem	15/06/2023
MSPGCL	Chandrapur Unit 6	500	14/06/2023	04:25	14/06/2023	09:24	Stator Earth Fault	15/06/2023
MSPGCL	Chandrapur Unit 6	500	14/06/2023	09:25	14/06/2023	10:48	Drum level low	
MSPGCL	Chandrapur Unit 7	500	14/06/2023	11:48		Continued.	Air heater problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 14/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	13/06/2023	00:30	14/06/2023	05:42	EO	Emergency Shutdown of HVDC Pole 1 for premonsoon maintenance work.
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	14/06/2023	00:30	14/06/2023	05:42	HT	Emergency Shutdown of HVDC Pole 1 for premonsoon maintenance work.
400 KV LR Outages/Trippings							
400 KV KARAD - SOLAPUR (PG) LR	IntraState	05/06/2023	10:58			PO	Overhauling of 400 kV CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
LONIKAND I - TALEGAON (PGCIL)	InterState	12/06/2023	09:54			PO	400kV CB O/H work by shifting on TBC and 29-A PG Isolator mechanim box replacement and trials
DHULE - KHANDWA CKT - 1	InterState	13/06/2023	09:08			PO	MTAMC Project work Main-I Dist Protn, REF & Master trip relay Gr-A &B replacement work
KHADKA- DEEPNAGAR CKT 2	IntraState	25/05/2023	10:02				Servicing &overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.
PADGHE - NAGOTHANE CKT - 2	IntraState	08/06/2023	13:08	13/06/2023	18:37	PO	Work of shifting/height raising of various EHV (220/110KV) transmission lines infringing in Samruddhi crossing . 1) Erection of 5 no. of Monopple 2) Stringing of 6.nos. of spans between location nos. 310-313
TBC 2 @ CHANDRAPUR	IntraState	12/06/2023	08:48			PO	Replacement of problematic old BHEL make 400kV quad break CB of TBC-2 bay with new siemens ltd make 400kV Quad CB.
JEJURI - KARAD	IntraState	12/06/2023	20:10			PO	Overhauling of 400 kv CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad
220KV CHANDRAPUR MIDC-CHANDRAPUR 2(400KV) CKT	IntraState	13/06/2023	07:29	13/06/2023	14:11	PO	Replacement of Broken Disc Insulator
220 KV CHANDRAPUR 2 - TADALI CKT	IntraState	13/06/2023	07:39	13/06/2023	13:53	PO	To attend damaged/ broken strand of conductor
JAIGAD - KARAD CKT - 1	IntraState	13/06/2023	09:08	13/06/2023	13:35	PO	BAY EQUIPMENT WASHING
PADGHE - NAGOTHANE CKT - 1	IntraState	13/06/2023	09:45	13/06/2023	10:13	T	bus 1 and bus -2 tripped at 400kv nagothane s/stn
NAGOTHANE - DABHOL CKT - 2	IntraState	13/06/2023	09:45	14/06/2023	12:57	T	bus 1 and bus -2 tripped at 400kv nagothane s/stn
NAGOTHANE - DABHOL CKT - 1	IntraState	13/06/2023	09:45	13/06/2023	11:47	T	bus 1 and bus -2 tripped at 400kv nagothane s/stn
NAGOTHANE - DABHOL CKT - 1	IntraState	13/06/2023	11:49	14/06/2023	13:50	HT	LINE H/T DUE TO HEAVY SPARKING ON Y PHASE CT AT NAGOTHANE END
PARLI - KUMBHARGAON(NANDED) CKT - 2	IntraState	14/06/2023	12:17			PO	(1) Distance relay testing work. (2) Bay maintenance work. (3) Hardware tightning and fitting work.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	14/06/2023	12:55			HT	TO CONTROL LINE LOADING
KHADKA - BABLESHWAR	IntraState	14/06/2023	13:14			PO	For routine bay maintenance works.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 13/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 14/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV ICT Outages/Tripping							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	IntraState	12/06/2023	21:28	13/06/2023	23:59	EO	To attend hotspot of 400 kv Bushing -B ph (Temp 160 °C)
400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	IntraState	13/06/2023	09:45	13/06/2023	18:45	T	bus 1 and bus -2 tripped at 400kv nagothane s/stn
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	13/06/2023	09:45	13/06/2023	10:36	T	bus 1 and bus -2 tripped at 400kv nagothane s/stn
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	13/06/2023	09:45	13/06/2023	10:20	T	bus 1 and bus -2 tripped at 400kv nagothane s/stn
400/220/33 KV 167 MVA SPARE ICT @ WALUJ	IntraState	13/06/2023	11:50	13/06/2023	18:14	PO	Installation of SCADA interfacing control box of CTR fire fighting system panel.
220 KV MAINBAY Outages/Tripping							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
BUS COUPLER @ SOUTH SOLAPUR	IntraState	14/06/2023	11:32	14/06/2023	13:05	PO	Outage is required for Quarterly Maintenance
220 KV LINE Outages/Tripping							
BALE - SOLAPUR (PG)	InterState	13/06/2023	11:40	13/06/2023	13:05	T	220kv Bale Pgcl(solapur) line tripped due to the DT send, LBB operated.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AAREY - AEML SAKI CKT - 1	IntraState	28/05/2023	17:23	13/06/2023	14:36	T	Tripped on Differential protection.
ABHIJEET-WARDHA-1	IntraState	13/06/2023	08:14	13/06/2023	12:14	PO	Testing work
PEDHAMBE ONI LINE	IntraState	13/06/2023	08:20	13/06/2023	13:20	PO	For cold washing of insulator strings & other maintenance work.
PEDHAMBE ONI LINE	IntraState	13/06/2023	08:20	13/06/2023	13:20	PO	Pre-monsoon maintenance activities to be done.
PARANDA - OSMANABAD	IntraState	13/06/2023	08:29	13/06/2023	15:41	PO	Quarterly Maintenance work
KALMESHWAR-PANDHURNA	IntraState	13/06/2023	08:45	13/06/2023	19:11	PO	FOR LINE MAINTENANCE WORK
LOTEPARSHURAM- DASTURI LINE	IntraState	13/06/2023	11:06	13/06/2023	16:45	T	Tripped on Distance Protection.
PANDHARPUR - MALINAGAR	IntraState	13/06/2023	16:36	13/06/2023	20:40	PO	Outage is required for Date:- 12.06.2023; Cold line cleaning loc no. 1 to 30 Date:- 13.06.2023; Cold line cleaning loc no. 31 to 61 Date:- 14.06.2023; Cold line cleaning loc no. 62 to 118 For changing /replacement of faulty string at loc no LILO portion 60, 64, 67. Date:- 15.06.2023; Cold line cleaning LILO loc no. 1 to 30 Date:- 16.06.2023; Cold line cleaning LILO loc no. 31 to 60 Date:- 17.06.2023; Cold line cleaning LILO loc no. 61 to 62
BORIVALI - TARAPUR	IntraState	13/06/2023	17:27	14/06/2023	13:14	T	Tripped on Distance Protection.
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	IntraState	14/06/2023	03:52	14/06/2023	04:15	T	Tripped from Nagar end only
GOREGAON - VERSOVA CKT - 2	IntraState	14/06/2023	09:45			EO	Attending the hotspots on line.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 14/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAHALAXMI - AMONA	IntraState	14/06/2023	10:37	14/06/2023	16:54	PO	Maintenance work. For cold washing of 220 kV line bay equipments, Maintenance & alignments of all isolators, Maintenance of all Bay Equipments at 220kV Mahalaxmi SS.
BHUGAON - WARDHA (PG)	IntraState	14/06/2023	10:40			PO	For Amp of Line Bay
PANDHARPUR - MALINAGAR	IntraState	14/06/2023	10:46			PO	Outage is required for Date:- 12.06.2023; Cold line cleaning loc no. 1 to 30 Date:- 13.06.2023; Cold line cleaning loc no. 31 to 61 Date:- 14.06.2023; Cold line cleaning loc no. 62 to 118 For changing /replacement of faulty string at loc no LILO portion 60, 64, 67. Date:- 15.06.2023; Cold line cleaning LILO loc no. 1 to 30 Date:- 16.06.2023; Cold line cleaning LILO loc no. 31 to 60 Date:- 17.06.2023; Cold line cleaning LILO loc no. 61 to 62
OSMANABAD - SOLAPUR (BALE)	IntraState	14/06/2023	10:48			PO	Outage is required for High tan delta CT replacement work
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132KV 100MVA ICT 1 @ SATARA MIDC	IntraState	13/06/2023	09:03	13/06/2023	16:41	PO	Replacement work of LV CTs & testing of LTS scheme on HV Back up relay of 100MVA ICT-1
220/33KV 50MVA PTR 1 @ MIRAJ	IntraState	13/06/2023	11:45	13/06/2023	17:19	PO	For replacing chipped support insulator stack of TF HV side isolator
220/33 kV 50 MVA PTR 1 @ VIRAJ	IntraState	13/06/2023	17:54	13/06/2023	20:03	T	Tripped due to R-ph LA Burst LV
220/132 KV 200 MVA PTR NO 5 @ PARVATI	IntraState	14/06/2023	10:51	14/06/2023	15:15	EO	For safety purpose to replace 132 kV PT 01
220/132KV 200MVA ICT 2 @ PANDHARPUR	IntraState	14/06/2023	11:51	14/06/2023	15:53	PO	Outage is required for Auxillary Protection trails Testing
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	14/06/2023	16:52			PO	Outage is required for Auxillary Protection trails Testing
220 KV BUSBAR Outages/Trippings							
220KV PT-1 of BUS-1@ MULUND	IntraState	13/06/2023	08:15	13/06/2023	16:04	PO	PRE MANSOON ACTIVITY work & PAINTING WORK.
220KV PT-2 of BUS-1@ MULUND	IntraState	13/06/2023	16:10	13/06/2023	19:08	PO	PRE MANSOON ACTIVITY work & PAINTING WORK.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
KANHAN-MANSAR	IntraState	14/06/2023	10:50	14/06/2023	13:02	PO	Routine Maint. Work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALYAN KALWA SALSETTE 1	IntraState	12/06/2023	21:17	13/06/2023	00:05	EO	Removal of hanging object at loc.48
KALWA KALYAN	IntraState	13/06/2023	00:13	13/06/2023	06:23	PO	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 14/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BHIRA (T) - DAVDI	IntraState	14/06/2023	06:54	14/06/2023	12:12	PO	Lightning spikes installation

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage