

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 13/Jun/2024 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	147.456	2025.860	1) Gujrat	0.874	9.032
2) Hydro	6.280	118.147	2) Madhya Pradesh	0.806	16.298
3) Gas	5.491	88.654	3) Chattisgarh	1.070	29.420
Total MSPGCL	159.227	2232.661	4) Maharashtra	180.329	2541.015
B) 1) APML	41.680	740.120	5) Goa (Amona)	-1.699	-27.106
2) JSWEL	20.420	334.482	Total	181.380	2568.659
3) VIPL	0.000	0.000	a) Mumbai Schedule	42.725	578.012
4) RPL(AMT)	31.511	387.116	b) Mumbai Drawl	45.839	609.146
5) SWPGPL	12.190	158.359	c) MSEDCL Bilateral *	76.045	1119.696
6) Other IPP	15.270	194.738	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	42.725	577.960
C) 1) TPCL Thermal	12.662	167.392	Include PX	0.000	0.000
2) TPCL Hydro	5.434	73.686	Standby	0.000	0.053
3) TPCL Gas	4.128	53.226	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.481	122.933	1) MSEDCL	449.768	6304.393
D) STATE			2) Mumbai Discoms	77.544	1026.380
1) Thermal	290.670	4131.000	3) Other Discoms	11.817	151.311
(A1+C1+C4+(B1-B6))			TOTAL STATE	539.129	7482.084
2) Hydro	11.714	191.833			
(A2+C2)					
3) Gas	9.619	141.880			
(A3+B7+C3)					
4) Wind	29.936	254.183			
6) SOLAR	15.810	194.532			
TOTAL STATE	357.749	4913.428			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	5491	5834	6894	6507
MSPGCL Hydro	118	117	383	196
MSPGCL Gas	140	283	289	143
MSPGCL Total Generation	5749	6234	7566	6846
Central Sector Receipt	8233	8361	7535	6932
WIND	1233	1101	1755	1269
CPP / IPP Thermal	4518	4584	5425	4877
CPP / IPP Gas	0	0	0	0
SOLAR	1650	1726	0	0
Exchange with Mumbai	-2312	-2388	-1890	-1414
MSEDCL DEMAND MET	18540	19105	19878	18100
Load Shedding	0	0	0	0
MSEDCL DEMAND	18540	19105	19878	18100
TPCL GENERATION	724	959	998	730
AEML GENERATION	303	428	407	390
MUMBAI DEMAND	3339	3775	3295	2534
OTHER DISCOM DEMAND	531	513	513	410
STATE DEMAND MET	22410	23393	23686	21044
STATE DEMAND	22410	23393	23686	21044
Frequency (Hz)	50.03	50.03	49.98	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 08.43 Hrs	49.88 Hz at 19.20 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 13/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.14	53.40	190	131
Unit 8	13.34	177.32	614	390
Unit 9	13.34	148.84	605	362
Unit 10	12.64	166.05	566	440
Total	43.47	545.62		
Bhusawal				
Unit 3	0.00	20.50	0	0
Unit 4	9.63	132.70	495	280
Unit 5	9.10	122.24	485	280
Total	18.73	275.45		
Parli				
Unit 6	0.00	34.93	0	0
Unit 7	0.00	26.47	0	0
Unit 8	0.00	38.18	0	0
Total	0.00	99.58		
Chandrapur				
Unit 3	3.14	46.41	154	110
Unit 4	3.38	47.17	165	125
Unit 5	8.01	82.30	425	275
Unit 6	7.68	65.44	435	270
Unit 7	8.35	116.24	470	285
Unit 8	8.79	127.58	450	273
Unit 9	10.35	108.70	500	290
Total	49.70	593.84		
Paras				
Unit 3	4.61	59.24	231	148
Unit 4	0.00	7.43	0	0
Total	4.61	66.67		
Khaparkheda				
Unit 1	3.08	46.18	160	100
Unit 2	3.30	53.93	164	103
Unit 3	3.52	40.44	168	129
Unit 4	3.80	55.08	187	128
Unit 5	10.53	142.49	485	355
Total	24.23	338.11		
Nasik				
Unit 3	3.41	44.12	157	127
Unit 4	0.00	19.19	0	0
Unit 5	3.31	43.28	164	115
Total	6.72	106.59		
Uran				
All Units	5.49	88.65	291	139
Total	5.49	88.65		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	1.42	0	0
Total	0.00	1.42		
Koyna				
Stage 1-2	2.34	37.45	405	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.30	29.19	178	0
Stage 3	0.94	16.24	240	0
Total	3.58	82.87		
Hydro				
KDPH	0.00	2.96	0	0
VTRNA	0.79	8.62	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.73	21.75	80	63
GHATGHAR	0.18	1.95	110	0
Total	2.70	35.27		
Wind				
Total	29.94	254.18	0	0
Total	29.94	254.18		
CPP				
APML(Mus)	41.68	740.12	0	0
JSWEL(Mus)	20.42	334.48	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.51	387.12	0	0
SWPGPL-Mus	12.19	158.36	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.73	74.71	269	194
Other(Mus)	3.54	56.39	0	0
JPL	6.01	63.63	273	233
Total	121.07	1814.82		
SOLAR				
Total	15.81	194.53	0	0
Total	15.81	194.53		
Tata				
Trombay 5	8.47	111.26	429	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	33.37	108	108
Trombay 7B	1.54	19.86	64	64
TATA Hydro	5.43	73.69	352	57
Trombay 8	4.19	56.13	226	130
Total	22.22	294.30		
AEML				
DTPS U-1&2	9.48	122.93	502	284
Total	9.48	122.93		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	147.46	2025.86	MSPGCL Total	159.23	2232.66
			MSPGCL Thml+Gas	152.95	2114.51	Koyna 1,2 & 4 Total	2.65	66.64
			MSPGCL Hydro	6.28	118.15	State Total	357.75	4913.43

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 13/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6824	406	291	7521	1356	5773	0	0	7054	6075	-1600	18678	0	0	18678	3211	447	22336	50.00
2	6445	348	290	7083	1303	5144	0	0	6913	6521	-1414	18206	0	0	18206	2955	431	21592	49.97
3	6225	192	269	6686	1347	4850	0	0	6993	6767	-1250	17974	0	0	17974	2772	426	21172	50.01
4	6518	166	144	6828	1368	4849	0	0	6894	6857	-1395	18106	0	0	18106	2610	401	21117	50.01
5	6507	196	143	6846	1269	4877	0	0	6918	6932	-1414	18100	0	0	18100	2534	410	21044	50.00
6	6688	530	141	7359	1213	5055	0	0	7058	7189	-1346	19037	0	0	19037	2537	433	22007	49.99
7	6932	198	142	7272	1232	5711	0	163	7409	6943	-1387	19462	0	0	19462	2571	472	22505	49.99
8	6230	109	141	6480	1072	5092	0	603	8185	7879	-1809	18824	0	0	18824	2738	493	22055	50.02
9	5942	113	139	6194	1280	4579	0	1116	8207	8205	-2127	18724	0	0	18724	3066	523	22313	50.09
10	5491	118	140	5749	1233	4518	0	1650	8281	8233	-2312	18540	0	0	18540	3339	531	22410	50.03
11	5107	121	141	5369	916	4509	0	1971	8566	8261	-2368	18134	0	0	18134	3596	524	22254	49.98
12	4871	126	153	5150	752	4489	0	2083	8719	8655	-2460	18133	0	0	18133	3713	536	22382	49.97
13	4895	317	205	5417	673	4520	0	1906	8749	8609	-2487	18112	0	0	18112	3726	526	22364	49.96
14	5019	197	278	5494	699	4487	0	1745	8676	8535	-2384	18062	0	0	18062	3683	514	22259	49.98
15	5834	117	283	6234	1101	4584	0	1726	8615	8361	-2388	19105	0	0	19105	3775	513	23393	50.03
16	5826	124	284	6234	1603	4524	0	1424	8695	7852	-2420	18679	0	0	18679	3827	538	23044	50.01
17	5284	132	284	5700	1859	4540	0	956	8783	8599	-2377	18734	0	0	18734	3739	543	23016	50.06
18	5787	178	286	6251	1672	4701	0	414	8624	8228	-2329	18411	0	0	18411	3561	526	22498	50.01
19	6347	237	286	6870	1698	4981	0	53	8165	7894	-2088	18869	0	0	18869	3377	539	22785	49.98
20	6894	383	289	7566	1755	5425	0	0	7906	7535	-1890	19878	0	0	19878	3295	513	23686	49.98
21	6895	438	291	7624	1441	5766	0	0	7396	7239	-1778	19767	0	0	19767	3225	525	23517	50.01
22	6956	359	290	7605	1146	5836	0	0	6842	6926	-1631	19395	0	0	19395	3188	487	23070	50.02
23	7000	655	290	7945	998	6056	0	0	6439	6678	-1571	19614	0	0	19614	3236	492	23342	50.01
24	6939	520	291	7750	950	6205	0	0	6776	6407	-1614	19224	0	0	19224	3270	474	22968	50.02
MUs	147.46	6.28	5.49	159.23	29.94	121.07	0.00	15.81	186.86	181.38	-45.84	449.77	0.00	0.00	449.77	77.54	11.82	539.13	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 13/Jun/2024

Position as on 6.30 Hrs of 14/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Paras Unit 4	250	05/06/2024	03:59		Continued.	Fire in GT	16/06/2024
MSPGCL	Nasik Unit 4	210	06/06/2024	19:18		Continued.	ID Fan Problem(Under Tolling from 23.00Hrs DT.06-06-2024)	
MSPGCL	Uran Unit 8	108	13/06/2024	02:58	13/06/2024	11:17	attending B2 Boiler Super Heater vent leakage	13/06/2024
Total Capacity MSPGCL		813						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1133						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	05/06/2024	17:00		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	06/06/2024	17:40		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Parli Unit 7	250	08/06/2024	21:00		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 6	250	08/06/2024	21:13		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 8	250	09/06/2024	20:50		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	12/06/2024	16:15		Continued.	Zero schedule given by LM Cell Discom due to drop in demand	
Total Capacity MSPGCL		1176						
IPP								
IPP	Adani U-4	660	10/06/2024	16:16		Continued.	ZERO SCHEDULE BY MSEDCL	
Total Capacity IPP		660						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		1836						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 13/Jun/2024

Position as on 6.30 Hrs of 14/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 14/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400KV 1500 MVA ICT-1 @ TIRORA	IntraState	13/06/2024	15:30	13/06/2024	19:20	PO	CT OIL SAMPLE COLLECTION FOR DGA
400 KV TIEBAY Outages/Trippings							
TIE BAY 418 OF ICT-1 @ LONIKAND 2	IntraState	13/06/2024	06:18	13/06/2024	18:31	PO	Diagnostic testing and Pre Monsoon Maintenance
400 KV MAINBAY Outages/Trippings							
400KV 125MVAR BUS REACTOR MAIN BAY(420) @ 400KV DEEPNAGAR	IntraState	13/06/2024	09:48	13/06/2024	18:40	PO	For the instalment of external cooling fans to enhance cooling in 400 kV, 125 MVAR, Bus Shunt Reactor.
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
DEEPNAGAR - THAPTI TANDA	IntraState	13/06/2024	06:22	13/06/2024	09:29	PO	Replacement of R- Phase suspension type string insulator at location No. 90 due to flash over observed due to lightning and AR successful operated at both end on 07.06.2024.
JEJURI - KARAD	IntraState	13/06/2024	08:49	13/06/2024	13:14	PO	For diagnostic testing work
PADGHE - NAGOTHANE CKT - 2	IntraState	13/06/2024	13:44	13/06/2024	19:45	PO	For string replacement work
LONIKAND I - KOYNA STAGE-IV	IntraState	13/06/2024	14:22	13/06/2024	21:31	PO	Diagnostic testing & Relay testing work , Routine maint. Work
CHANDRAPUR-PARLI CKT-3	IntraState	14/06/2024	08:19			PO	1.Measurement of tandelta of Bushing of 50MVar Line shunt Reactor. 2.Premonsoon maintenance work of Reactor. 3. Maintenance and alignment of Isolators. 4. Bay routine maintenance work.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	IntraState	12/06/2024	08:36	13/06/2024	20:58	PO	1.MEASUREMENT OF TANDELTA OF BUSHING & WINDING. 2.MEASUREMENT OF TANDELTA & CAPACITANCE OF CT. 3.PREMONSOON MAINTENANCE WORK OF ICT. 4. BAY ROUTINE MAINTENANCE WORK
MAIN BAY (419) OF 400/220/33kV 500MVA ICT-I @ LONIKAND 2	IntraState	13/06/2024	06:18	13/06/2024	18:31	PO	Diagnostic testing and Pre Monsoon Maintenance

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 14/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	13/06/2024	10:11			PO	For work in vicinity for erection of scaffolding for installation of LA�s on 220KV Bays at KVTL Vikhroli (These Bays used for feeding 220/110kV, 250MVA, ICT-1 & ICT-2 of TPC Vikhroli).
400220kV 167MVA SPARE ICT @ DEEPNAGAR	IntraState	13/06/2024	17:06	13/06/2024	18:31	PO	FOR REPLACEMENT OF NITROGEN GAS CYLINDER DUE TO LOW N2 PRESSURE ALARM APPEARS ON CTR NIFPS CUBICLE
400/220/20 KV 300 MVA ICT - 1 @ KORADI	IntraState	14/06/2024	09:41			PO	For premonsson maintenance works
400 KV BR Outages/Trippings							
80 MVAR BUS REACTOR @ PADGHE	IntraState	12/06/2024	10:10	13/06/2024	18:30	PO	1) Relay replacement work of Reactor 2) Bay maint work 3) Replacement of 29C bus PG isolator
MAIN BAY 415 OF BUS REACTOR 2@ TIRORA	IntraState	13/06/2024	09:53	13/06/2024	11:40	PO	CT OIL SAMPLE COLLECTION FOR DGA
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
40MVA 220/6.6 KV STN T/F 3	IntraState	13/06/2024	10:07	13/06/2024	19:04	PO	DIAGNOSTIC MEASUREMENT WORK TO BE CARRIED OUT (CB CRM, TIMING & CT TAN DELTA & CAPACITANCE MEAS . WORK)
220 KV LINE Outages/Trippings							
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220KV GIS DCHI - COLOURCHEM	IntraState	31/05/2024	04:30			PO	For de-stringing & stringing of old circuit at new tower Loc. No. 6.
NTT - KALWA	IntraState	05/06/2024	00:20			PO	For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kv GIS S/tn M/s NTT Global DC NAV2 Pvt Ltd.
EKLAHARE (OCR) - PADGHE	IntraState	10/06/2024	08:42			HT	H/T for load management
TIFIL - KALWA	IntraState	13/06/2024	08:55			PO	For making 220kV Pawane-TIFIL line LILO for M/s NXTRA Data Ltd for the proposed 220kV GIS S/stn.
GOREGAON - VERSOVA CKT - 1	IntraState	13/06/2024	09:32	13/06/2024	11:32	PO	Pre-monsoon Maintenance work
KANHAN-UMRED 1	IntraState	13/06/2024	10:12	13/06/2024	13:19	PO	FOR DIAGNOSTIC TESTING WORK AND ALLIED MAINTENANCE WORK.
PHALTAN MIDC - CSSK BHAVANI NAGAR	IntraState	13/06/2024	10:45	13/06/2024	17:22	PO	1.Cable Replacement Work 2.Quarterly Maintenance Work 3.Relay Testing Work
NAGOTHANE - POSCO	IntraState	13/06/2024	10:45	13/06/2024	14:56	PO	Outage tree cutting work & Other line maintenance work.
NERLE - DASGAON	IntraState	13/06/2024	10:48	13/06/2024	15:24	PO	For checking remote operation through new SAS of 220kv line & Bus Section CB
ABHIJEET-WARDHA-II	IntraState	13/06/2024	10:52	13/06/2024	20:58	PO	RETROFITTING OF DISTANCE RELAY OF 220KV ABHIJEET-WARDHA-2 CKT. (GE MAKE) DUE TO MALFUNTIONING OF RELAY.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 14/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV WALUJ(400KV) - CHITEGAON CKT	IntraState	13/06/2024	11:13	13/06/2024	14:57	PO	DIAGNOSTIC TESTING AND ROUTINE MAINTENANCE WORK.
GOREGAON - VERSOVA CKT - 2	IntraState	13/06/2024	11:51	13/06/2024	16:25	PO	Pre-monsoon Maintenance work
PARGAON(KATHAPUR)- LONIKAND	IntraState	13/06/2024	17:22	14/06/2024	00:19	PO	Loc No 306 Bph, 321 Rph, 322 Bph flashover string replacement work.
TALEGAON (AMBI)-TALEGAON (PG) CKT 1	IntraState	13/06/2024	23:43	14/06/2024	06:24	PO	Cold line washing of insulators.
ADLABS - PEDAMBE	IntraState	14/06/2024	06:50			PO	Outage tree cutting work at Loc.No.262-263,293-294,397-398 & Other line Maint. Works
WASHALA - GHATGHAR	IntraState	14/06/2024	08:16			PO	1)Emergency Tree cutting maintenance work and 2) Emergency Tree monsoon maintenance work
220 KV ICT Outages/Trippings							
220/33kv 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/132KV 200MVA ICT 3 @ PANDHARPUR	IntraState	12/06/2024	10:50			PO	Outage is required for Pre Monsoon maintenance
220/132 KV 200MVA ICT NO 1 @ THEUR	IntraState	13/06/2024	06:15	13/06/2024	15:52	PO	OLTC overhauling work
220/100 KV 100 MVA ICT 2 @ KANDALGAON	IntraState	13/06/2024	09:45	13/06/2024	11:08	PO	100 MVA 220/100 Kv ICT No:02 Premonsoon activites /Dignostic testing
220/132kv 200MVA ICT-2 @ KOPARGAON	IntraState	13/06/2024	11:42	13/06/2024	14:20	PO	For TCIV valve of NIFPS (Nitrogen fire protection system) maintenance.
220/100 KV 100 MVA ICT 1 @ JAMBHUL	IntraState	13/06/2024	11:46			PO	Nitrogen Injection Pipeline reinstallation/ replacement work by M/s. CTR.
220/132 KV 200MVA ICT NO 2 @ THEUR	IntraState	14/06/2024	06:15			PO	OLTC overhauling work
220/100 KV 200 MVA ICT 1 @ PAL-DOMBIVALI	IntraState	14/06/2024	09:28			PO	Replacement of HV Back up relay.
220 KV BUSBAR Outages/Trippings							
TBC @220 KV NERUL	IntraState	14/06/2024	09:01			PO	Pre-Monsoon Maintenance CB CRM Timing Auxiliary isolator maintenance work
132 KV LINE Outages/Trippings							
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.
PADEGAON- WALUJ 1	IntraState	13/06/2024	08:05	13/06/2024	12:45	T	AT P E=R PH, IF=2.3KA, D=66METER
DEEPNAGAR- NIMBHORA	IntraState	13/06/2024	10:53	13/06/2024	14:14	T	D/P B-E Z1 30KM 3.3KA
110 KV LINE Outages/Trippings							
TATA AMBERNATH MSETCL NERAL	IntraState	13/06/2024	06:04	13/06/2024	07:50	PO	Bird nest removal at loc. 176,177,178,180,181,183,184,185,186
BHIVPURI - AMBERNATH CKT - 1	IntraState	13/06/2024	08:04	13/06/2024	09:20	PO	Bird nest removal at loc. 166,173,175,182
TATA BHIVPURI MSETCL NERAL	IntraState	13/06/2024	09:51	13/06/2024	16:42	PO	110 KV BN line TBS GOD Stuck defect attaining work
TATA BHIVPURI MSETCL NERAL	IntraState	14/06/2024	06:05			PO	R/M of TBS GOD and Testing

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage