

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 13/Jul/2018 FRIDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 82.998         | 1341.328        | 1) Gujrat                      | -7.999         | -63.992         |
| 2) Hydro            | 5.771          | 56.638          | 2) Madhya Pradesh              | 6.032          | 135.027         |
| 3) Gas              | 7.212          | 112.046         | 3) Chattisgarh                 | 5.790          | 69.230          |
| <b>Total MSPGCL</b> | <b>95.981</b>  | <b>1510.012</b> | 4) Maharashtra                 | 96.860         | 1216.541        |
| B) 1) APMIL         | 62.953         | 772.225         | 5) Goa (Amona)                 | -0.286         | -5.764          |
| 2) JSWEL            | 17.904         | 229.129         | <b>Total</b>                   | <b>100.397</b> | <b>1351.042</b> |
| 3) VIPL             | 6.387          | 83.192          | a) Mumbai Schedule             | 22.230         | 284.749         |
| 4) RPL(AMT)         | 0.000          | 116.383         | b) Mumbai Drawl                | 27.355         | 356.844         |
| 5) SWPGPL           | 2.678          | 32.272          | c) MSEDCL Bilateral *          | 11.394         | 207.709         |
| 6) Other IPP        | 7.855          | 89.577          | Include PX                     | -15.201        | -144.133        |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 22.230         | 284.749         |
| C) 1) TPCL Thermal  | 13.021         | 125.342         | Include PX                     | 5.457          | 76.586          |
| 2) TPCL Hydro       | 5.828          | 73.852          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 3.841          | 50.000          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 9.468          | 130.999         | 1) MSEDCL                      | 323.629        | 4481.656        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 59.513         | 737.031         |
| 1) Thermal          | 203.264        | 2920.447        | 3) Other Discoms               |                |                 |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>383.142</b> | <b>5218.687</b> |
| 2) Hydro            | 11.599         | 130.490         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 11.053         | 162.046         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 53.410         | 607.242         |                                |                |                 |
| 6) SOLAR            | 3.419          | 47.426          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>282.745</b> | <b>3867.651</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 10 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 3446                      | 3335                  | 3512                      | 3468                      |
| MSPGCL Hydro               | 244                       | 383                   | 305                       | 109                       |
| MSPGCL Gas                 | 353                       | 351                   | 234                       | 359                       |
| MSPGCL Total Generation    | 4043                      | 4069                  | 4051                      | 3936                      |
| Central Sector Receipt     | 5151                      | 4046                  | 4962                      | 3082                      |
| WIND                       | 2296                      | 2624                  | 1906                      | 2175                      |
| CPP / IPP Thermal          | 4297                      | 3869                  | 4300                      | 3743                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 347                       | 468                   | 0                         | 0                         |
| Exchange with Mumbai       | -1460                     | -1618                 | -1116                     | -755                      |
| <b>MSEDCL DEMAND MET</b>   | <b>14674</b>              | <b>13458</b>          | <b>14103</b>              | <b>12181</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 14674                     | 13458                 | 14103                     | 12181                     |
| TPCL GENERATION            | 1019                      | 1047                  | 1203                      | 625                       |
| AEML GENERATION            | 376                       | 377                   | 409                       | 375                       |
| <b>MUMBAI DEMAND</b>       | <b>2855</b>               | <b>3042</b>           | <b>2728</b>               | <b>1755</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>0</b>                  | <b>0</b>              | <b>0</b>                  | <b>0</b>                  |
| STATE DEMAND MET           | 17529                     | 16500                 | 16831                     | 13936                     |
| <b>STATE DEMAND</b>        | <b>17529</b>              | <b>16500</b>          | <b>16831</b>              | <b>13936</b>              |
| Frequency (Hz)             | 50.04                     | 49.99                 | 49.86                     | 49.98                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.14 Hz at 09.54 Hrs | 49.74 Hz at 19.53 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 13/Jul/2018

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| Unit 9             | 7.20         | 113.54        | 339      | 266      |
| Unit 10            | 6.22         | 106.59        | 321      | 100      |
| <b>Total</b>       | <b>13.41</b> | <b>220.13</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 8.62         | 120.44        | 400      | 335      |
| Unit 5             | 8.56         | 119.19        | 400      | 325      |
| <b>Total</b>       | <b>17.18</b> | <b>239.64</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 3.68         | 52.67         | 167      | 142      |
| <b>Total</b>       | <b>3.68</b>  | <b>52.67</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 7.28         | 115.29        | 320      | 285      |
| Unit 6             | 7.64         | 120.01        | 330      | 298      |
| Unit 7             | 5.92         | 114.10        | 290      | 207      |
| Unit 8             | 7.47         | 125.96        | 440      | 243      |
| Unit 9             | 0.00         | 4.95          | 0        | 0        |
| <b>Total</b>       | <b>28.31</b> | <b>480.31</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 3.50         | 51.58         | 158      | 129      |
| Unit 4             | 3.48         | 49.71         | 152      | 130      |
| <b>Total</b>       | <b>6.99</b>  | <b>101.29</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.35         | 35.72         | 105      | 75       |
| Unit 2             | 3.42         | 45.58         | 150      | 105      |
| Unit 3             | 3.72         | 47.56         | 161      | 140      |
| Unit 4             | 0.00         | 26.04         | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>9.50</b>  | <b>154.90</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.93         | 50.26         | 183      | 159      |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 42.12         | 0        | 0        |
| <b>Total</b>       | <b>3.93</b>  | <b>92.38</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 7.21         | 112.05        | 373      | 225      |
| <b>Total</b>       | <b>7.21</b>  | <b>112.05</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.22         | 1.78          | 44       | 0        |
| <b>Total</b>       | <b>0.22</b>  | <b>1.78</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation   |                |          |          |
|-----------------|--------------|----------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 1.34         | 21.95          | 110      | 40       |
| Stage 4         | 0.00         | 1.42           | 0        | 0        |
| Stage 3         | 2.13         | 17.41          | 160      | 0        |
| <b>Total</b>    | <b>3.46</b>  | <b>40.78</b>   |          |          |
| <b>Hydro</b>    |              |                |          |          |
| KDPH            | 0.00         | 0.00           | 0        | 0        |
| VTRNA           | 0.20         | 1.21           | 59       | 0        |
| TILLARI         | 1.14         | 1.56           | 60       | 0        |
| BHIRA T.R.      | 0.40         | 5.37           | 40       | 0        |
| SMLHY_PTN       | 0.27         | 2.23           | 19       | 9        |
| GHATGHAR        | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>    | <b>2.02</b>  | <b>10.38</b>   |          |          |
| <b>Wind</b>     |              |                |          |          |
| Total           | 53.41        | 607.24         | 0        | 0        |
| <b>Total</b>    | <b>53.41</b> | <b>607.24</b>  |          |          |
| <b>CPP</b>      |              |                |          |          |
| APML(Mus)       | 62.95        | 772.22         | 0        | 0        |
| JSWEL(Mus)      | 17.90        | 229.13         | 0        | 0        |
| VIPL(Mus)       | 6.39         | 83.19          | 0        | 0        |
| RPLAMT(Mus)     | 0.00         | 116.38         | 0        | 0        |
| WPCL(Mus)       | 2.68         | 32.27          | 0        | 0        |
| Other(Mus)      | 7.86         | 89.58          | 0        | 0        |
| <b>Total</b>    | <b>97.78</b> | <b>1322.78</b> |          |          |
| <b>SOLAR</b>    |              |                |          |          |
| Total           | 3.42         | 47.43          | 0        | 0        |
| <b>Total</b>    | <b>3.42</b>  | <b>47.43</b>   |          |          |
| <b>Tata</b>     |              |                |          |          |
| Trombay 5       | 7.81         | 57.90          | 455      | 291      |
| Trombay 6       | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A      | 2.38         | 31.05          | 119      | 62       |
| Trombay 7B      | 1.46         | 18.95          | 67       | 48       |
| TATA Hydro      | 5.83         | 73.85          | 443      | 3        |
| Trombay 8       | 5.21         | 67.45          | 232      | 210      |
| <b>Total</b>    | <b>22.69</b> | <b>249.19</b>  |          |          |
| <b>R-INFRA</b>  |              |                |          |          |
| DTPS U-1&2      | 9.47         | 131.00         | 504      | 373      |
| <b>Total</b>    | <b>9.47</b>  | <b>131.00</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 83.00       | 1341.33       | MSPGCL Total        | 95.98       | 1510.01       |
|                |             |         | MSPGCL Thml+Gas | 90.21       | 1453.37       | Koyna 1,2 & 4 Total | 1.34        | 23.37         |
|                |             |         | MSPGCL Hydro    | 5.77        | 56.64         | State Total         | 282.74      | 3867.65       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 13/Jul/2018

### Annexure-2

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | LOAD<br>SHED<br>DING | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAN<br>D | OTHER<br>DISCOM<br>DEMAN<br>D | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|-------|-------|-----------|------|-------|-------------|-------------|----------------------|------------------------|----------------------|-------------------------------|----------------------|-------------------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |       |       | THM       | GAS  |       |             |             |                      |                        |                      |                               |                      |                               |                 |               |
| 1                  | 3443        | 115  | 346  | 3904  | 2240  | 3937      | 0    | 0     | 3571        | 3492        | -964                 | 12609                  | 0                    | 12609                         | 2089                 |                               | 14698           | 49.95         |
| 2                  | 3446        | 110  | 348  | 3904  | 2256  | 3865      | 0    | 0     | 3362        | 3250        | -895                 | 12380                  | 0                    | 12380                         | 1924                 |                               | 14304           | 49.98         |
| 3                  | 3397        | 115  | 349  | 3861  | 2262  | 3837      | 0    | 0     | 3397        | 3071        | -805                 | 12226                  | 0                    | 12226                         | 1816                 |                               | 14042           | 50.02         |
| 4                  | 3468        | 109  | 359  | 3936  | 2175  | 3743      | 0    | 0     | 3197        | 3082        | -755                 | 12181                  | 0                    | 12181                         | 1755                 |                               | 13936           | 49.98         |
| 5                  | 3545        | 109  | 350  | 4004  | 2101  | 3719      | 0    | 0     | 3414        | 3548        | -743                 | 12629                  | 0                    | 12629                         | 1743                 |                               | 14372           | 49.96         |
| 6                  | 3536        | 144  | 352  | 4032  | 2003  | 3950      | 0    | 0     | 4136        | 4484        | -844                 | 13625                  | 0                    | 13625                         | 1846                 |                               | 15471           | 49.92         |
| 7                  | 3781        | 251  | 353  | 4385  | 1859  | 4225      | 0    | 14    | 5031        | 4887        | -794                 | 14576                  | 0                    | 14576                         | 2010                 |                               | 16586           | 49.99         |
| 8                  | 3717        | 257  | 373  | 4347  | 1942  | 4274      | 0    | 100   | 5300        | 5430        | -984                 | 15109                  | 0                    | 15109                         | 2202                 |                               | 17311           | 49.97         |
| 9                  | 3492        | 221  | 353  | 4066  | 2265  | 4299      | 0    | 215   | 5342        | 5312        | -1373                | 14784                  | 0                    | 14784                         | 2531                 |                               | 17315           | 50.02         |
| 10                 | 3446        | 244  | 353  | 4043  | 2296  | 4297      | 0    | 347   | 5400        | 5151        | -1460                | 14674                  | 0                    | 14674                         | 2855                 |                               | 17529           | 50.04         |
| 11                 | 3378        | 309  | 352  | 4039  | 2330  | 4253      | 0    | 421   | 4989        | 4749        | -1687                | 14105                  | 0                    | 14105                         | 3054                 |                               | 17159           | 50.02         |
| 12                 | 3376        | 378  | 359  | 4113  | 2616  | 4203      | 0    | 488   | 4781        | 4105        | -1694                | 13831                  | 0                    | 13831                         | 3113                 |                               | 16944           | 50.01         |
| 13                 | 3335        | 383  | 351  | 4069  | 2624  | 3869      | 0    | 468   | 4383        | 4046        | -1618                | 13458                  | 0                    | 13458                         | 3042                 |                               | 16500           | 49.99         |
| 14                 | 3353        | 378  | 324  | 4055  | 2565  | 3843      | 0    | 365   | 3957        | 3949        | -1457                | 13320                  | 0                    | 13320                         | 2896                 |                               | 16216           | 50.04         |
| 15                 | 3360        | 406  | 240  | 4006  | 2616  | 3822      | 0    | 335   | 3887        | 3868        | -1441                | 13206                  | 0                    | 13206                         | 2901                 |                               | 16107           | 49.97         |
| 16                 | 3387        | 309  | 230  | 3926  | 2694  | 3847      | 0    | 324   | 3577        | 3522        | -1430                | 12883                  | 0                    | 12883                         | 2885                 |                               | 15768           | 50.01         |
| 17                 | 3374        | 314  | 228  | 3916  | 2715  | 3892      | 0    | 209   | 3460        | 3675        | -1369                | 13038                  | 0                    | 13038                         | 2836                 |                               | 15874           | 49.95         |
| 18                 | 3352        | 367  | 228  | 3947  | 2585  | 4077      | 0    | 115   | 3398        | 3753        | -1316                | 13161                  | 0                    | 13161                         | 2795                 |                               | 15956           | 50.00         |
| 19                 | 3322        | 355  | 225  | 3902  | 2426  | 4238      | 0    | 18    | 4254        | 4389        | -1302                | 13671                  | 0                    | 13671                         | 2760                 |                               | 16431           | 49.89         |
| 20                 | 3512        | 305  | 234  | 4051  | 1906  | 4300      | 0    | 0     | 4787        | 4962        | -1116                | 14103                  | 0                    | 14103                         | 2728                 |                               | 16831           | 49.86         |
| 21                 | 3576        | 196  | 226  | 3998  | 1723  | 4309      | 0    | 0     | 4855        | 4879        | -888                 | 14021                  | 0                    | 14021                         | 2644                 |                               | 16665           | 49.92         |
| 22                 | 3555        | 180  | 226  | 3961  | 1738  | 4345      | 0    | 0     | 4566        | 4593        | -752                 | 13885                  | 0                    | 13885                         | 2507                 |                               | 16392           | 49.98         |
| 23                 | 3503        | 115  | 227  | 3845  | 1753  | 4326      | 0    | 0     | 4358        | 4275        | -833                 | 13366                  | 0                    | 13366                         | 2349                 |                               | 15715           | 49.97         |
| 24                 | 3344        | 101  | 226  | 3671  | 1720  | 4307      | 0    | 0     | 3693        | 3926        | -835                 | 12789                  | 0                    | 12789                         | 2232                 |                               | 15021           | 49.98         |
| MUs                | 83.00       | 5.77 | 7.21 | 95.98 | 53.41 | 97.78     | 0.00 | 3.42  | 101.09      | 100.40      | -27.36               | 323.63                 | 0.00                 | 323.63                        | 59.51                |                               | 383.14          | 49.98         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 13/Jul/2018**

**Position as on 6.30 Hrs of 14/Jul/2018**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                           | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                            |               |
| MSPGCL                | Koradi Unit 6           | 210      | 09/07/2015   | 00.00        |            | Continued. | EE R&M LE Work                                                             |               |
| MSPGCL                | Koyna STG-IV Unit-4     | 250      | 12/06/2018   | 09.40        |            | Continued. | Annual Overhaul                                                            |               |
| MSPGCL                | Khaparkhedha Unit 5     | 500      | 20/06/2018   | 05.14        |            | Continued. | Annual Overhaul                                                            |               |
| MSPGCL                | Parli Unit 6            | 250      | 24/06/2018   | 18.02        |            | Continued. | Zero Schedule(Converted for Capital overhaul from 00.00Hrs Dt. 23/07/2018) |               |
| MSPGCL                | Koradi Unit 8           | 660      | 29/06/2018   | 13.27        |            | Continued. | Converted to APH from 19/07/2018                                           |               |
| MSPGCL                | Chandrapur Unit 9       | 500      | 01/07/2018   | 11.35        |            | Continued. | Annual Overhaul                                                            |               |
| IPP                   | JSW (J) U3              | 300      | 09/07/2018   | 00.42        |            | Continued. | Annual Overhaul                                                            |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                            |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |            | Continued. | Economic shutdown                                                          |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                    | 25/06/2022    |
| IPP                   | SWPGPL U-2              | 135      | 29/02/2016   | 21.46        |            | Continued. | No PPA                                                                     |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                          |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                          |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                       |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                       |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 03/12/2017   | 01.35        |            | Continued. | Water Shortage                                                             |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 03/12/2017   | 14.17        |            | Continued. | Water Shortage                                                             |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 14/04/2018   | 23.45        |            | Continued. | Stator Earth Fault                                                         |               |
| IPP                   | RPL(AMT) U-1            | 270      | 01/05/2018   | 00.00        |            | Continued. | Coal Shortage( Zero schedule on 30.06.2018)                                |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 21/05/2018   | 18.46        |            | Continued. | Coal Swapping IEPL                                                         |               |
| MSPGCL                | Nasik Unit 4            | 210      | 01/06/2018   | 00.53        |            | Continued. | Dharwal Inter Change                                                       |               |
| MSPGCL                | Uran Unit 6             | 108      | 09/06/2018   | 11.50        |            | Continued. | GT winding short.                                                          |               |
| IPP                   | SWPGPL U-4              | 135      | 10/06/2018   | 00.01        |            | Continued. | Maintenance work                                                           |               |
| IPP                   | VIPL U-1                | 300      | 11/06/2018   | 00.30        |            | Continued. | Coal Shortage                                                              |               |
| MSPGCL                | Koradi Unit 7           | 210      | 11/06/2018   | 22.10        |            | Continued. | Coal Shortage                                                              |               |
| MSPGCL                | Parli Unit 7            | 250      | 17/06/2018   | 08.32        |            | Continued. | ZERO SCHEDULE                                                              |               |
| IPP                   | RPL(AMT) U-4            | 270      | 22/06/2018   | 17.31        |            | Continued. | Bottom Ash Problem.                                                        |               |
| IPP                   | RPL(AMT) U-3            | 270      | 26/06/2018   | 00.01        |            | Continued. | Zero Schedule                                                              |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 29/06/2018   | 01.12        |            | Continued. | Stator Earth Fault                                                         |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 29/06/2018   | 01:12        |            | Continued. | Stator Earth Fault                                                         |               |
| IPP                   | IEPL Unit 1             | 270      | 11/07/2018   | 13.00        |            | Continued. | poor coal receipt.                                                         |               |
| MSPGCL                | Khaparkhedha Unit 4     | 210      | 11/07/2018   | 16.27        | 14/07/2018 | 12.49      | Furnace Pressure High                                                      |               |
| MSPGCL                | Nasik Unit 5            | 210      | 12/07/2018   | 00.00        |            | Continued. | ZERO SCHEDULE.                                                             |               |
| IPP                   | RPL(AMT) U-2            | 270      | 12/07/2018   | 00.00        |            | Continued. | ZERO SCHEDULE.                                                             |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 13/Jul/2018**

**Position as on 6.30 Hrs of 14/Jul/2018**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                          | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|-------------------------------------------|---------------|
| IPP                | RPL(AMT) U-5            | 270      | 12/07/2018   | 01.28        |            | Continued. | ZERO SCHEDULE.                            |               |
| MSPGCL             | Uran Unit 7             | 108      | 13/07/2018   | 13.52        |            | Continued. | Rain Hood Installation work               |               |
| IPP                | Dhariwal                | 300      | 13/07/2018   | 23.59        |            | Continued. | Critical coal stock                       |               |
| MSPGCL             | Uran Unit 8             | 108      | 14/07/2018   | 01.21        |            | Continued. | Rain Hood Installation work               |               |
| MSPGCL             | Uran Unit B0            | 120      | 14/07/2018   | 01.21        |            | Continued. | Rain Hood Installation work               |               |
| MSPGCL             | Khaparkheda Unit 4      | 210      | 14/07/2018   | 13.23        | 14/07/2018 | 15.23      | M.S.Temp.Low                              |               |
| MSPGCL             | Chandrapur Unit 8       | 500      | 14/07/2018   | 15.32        | 14/07/2018 | 23.05      | UAT TARIPPED<br>INCOMMING SUPPLY<br>FAILS |               |

