

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 13/Jul/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	112.928	1582.192	1) Gujrat	-9.549	-125.305
2) Hydro	8.201	133.530	2) Madhya Pradesh	3.475	56.745
3) Gas	3.227	55.789	3) Chattisgarh	4.320	48.790
Total MSPGCL	124.356	1771.511	4) Maharashtra	118.085	1887.009
B) 1) APLM	39.863	591.909	5) Goa (Amona)	-2.278	-18.624
2) JSWEL	9.057	178.416	Total	114.053	1848.615
3) VIPL	0.000	0.000	a) Mumbai Schedule	40.840	446.646
4) RPL(AMT)	22.020	261.862	b) Mumbai Drawl	38.996	473.588
5) SWPGPL	7.646	101.112	c) MSEDCL Bilateral *	77.496	1015.595
6) Other IPP	5.914	93.717	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	40.840	444.603
C) 1) TPCL Thermal	10.258	121.269	Include PX	0.000	0.000
2) TPCL Hydro	5.097	41.726	Standby	0.000	2.044
3) TPCL Gas	0.000	6.389	H) ENERGY CATERED (MUs)		
4) AEML Thermal	3.980	119.409	1) MSEDCL	349.747	4996.850
D) STATE			2) Mumbai Discoms	58.332	762.382
1) Thermal	211.666	3049.886	3) Other Discoms	8.312	114.445
(A1+C1+C4+(B1-B6))			TOTAL STATE	416.391	5873.677
2) Hydro	13.298	175.256			
3) Gas	3.227	62.178			
4) Wind	71.520	662.562			
6) SOLAR	2.626	75.179			
TOTAL STATE	302.337	4025.061			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 9 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5299	4343	5045	4405
MSPGCL Hydro	377	365	347	327
MSPGCL Gas	139	129	129	139
MSPGCL Total Generation	5815	4837	5521	4871
Central Sector Receipt	5487	5698	4658	3531
WIND	2815	2876	3168	2869
CPP / IPP Thermal	4446	3041	4520	3117
CPP / IPP Gas	0	0	0	0
SOLAR	107	370	0	0
Exchange with Mumbai	-1835	-1989	-1718	-1075
MSEDCL DEMAND MET	16466	14480	15775	13038
Load Shedding	0	0	0	0
MSEDCL DEMAND	16466	14480	15775	13038
TPCL GENERATION	517	770	772	599
AEML GENERATION	159	165	160	167
MUMBAI DEMAND	2511	2924	2650	1841
OTHER DISCOM DEMAND	369	353	374	275
STATE DEMAND MET	19346	17757	18799	15154
STATE DEMAND	19346	17757	18799	15154
Frequency (Hz)	50.05	50.02	49.99	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.16 Hz at 13.01 Hrs	49.76 Hz at 11.43 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 13/Jul/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.56	29.71	130	55
Unit 7	0.00	0.00	0	0
Unit 8	0.00	43.27	0	0
Unit 9	10.22	62.12	480	332
Unit 10	10.71	144.98	515	370
Total	23.49	280.08		
Bhusawal				
Unit 3	2.78	38.00	125	90
Unit 4	7.94	112.30	425	275
Unit 5	7.86	101.04	415	280
Total	18.59	251.33		
Parli				
Unit 6	3.87	61.07	200	149
Unit 7	0.09	45.58	33	0
Unit 8	3.62	6.17	197	127
Total	7.58	112.82		
Chandrapur				
Unit 3	0.00	20.97	0	0
Unit 4	2.18	31.22	101	83
Unit 5	6.78	92.64	300	235
Unit 6	5.57	82.03	260	195
Unit 7	0.00	0.00	0	0
Unit 8	7.97	125.68	370	278
Unit 9	8.83	127.08	440	285
Total	31.33	479.62		
Paras				
Unit 3	3.54	52.23	177	132
Unit 4	3.59	51.39	172	135
Total	7.13	103.61		
Khaparkheda				
Unit 1	3.12	36.63	140	120
Unit 2	3.25	38.65	155	120
Unit 3	3.66	39.15	183	131
Unit 4	2.32	2.32	130	27
Unit 5	8.56	123.55	445	270
Total	20.90	240.29		
Nasik				
Unit 3	2.34	44.02	121	62
Unit 4	1.56	38.50	80	48
Unit 5	0.00	31.92	0	0
Total	3.90	114.44		
Uran				
All Units	3.23	55.79	140	128
Total	3.23	55.79		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.03	1.52	27	0
Total	0.03	1.52		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	0.72	24.88	45	0
Stage 4	0.00	8.04	0	0
Stage 3	1.15	16.70	80	0
Total	1.86	49.62		
Hydro				
KDPH	0.11	0.76	14	0
VTRNA	0.77	7.62	60	0
TILLARI	0.35	4.42	58	0
BHIRA T.R.	0.46	4.37	60	0
SMLHY_PTN	4.61	65.22	212	173
GHATGHAR	0.00	0.00	0	0
Total	6.30	82.39		
Wind				
Total	71.52	662.56	0	0
Total	71.52	662.56		
CPP				
APML(Mus)	39.86	591.91	0	0
JSWEL(Mus)	9.06	178.42	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	22.02	261.86	0	0
SWPGPL-Mus	7.65	101.11	0	0
Other(Mus)	5.91	93.72	0	0
Total	84.50	1227.02		
SOLAR				
Total	2.63	75.18	0	0
Total	2.63	75.18		
Tata				
Trombay 5	6.66	69.68	370	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	3.82	0	0
Trombay 7B	0.00	2.57	0	0
TATA Hydro	5.10	41.73	336	115
Trombay 8	3.60	51.59	224	133
Total	15.36	169.38		
AEMIL				
DTPS U-1&2	3.98	119.41	222	152
Total	3.98	119.41		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	112.93	1582.19	MSPGCL Total	124.36	1771.51
			MSPGCL Thml+Gas	116.16	1637.98	Koyna 1,2 & 4 Total	0.72	32.92
			MSPGCL Hydro	8.20	133.53	State Total	302.34	4025.06

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 13/Jul/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4420	390	128	4938	3275	3508	0	0	3585	3466	-1219	13638	0	13638	2124	330	16092	50.02
2	4336	348	139	4823	3115	3373	0	0	3542	3264	-1164	13106	0	13106	1991	305	15402	50.01
3	4401	324	128	4853	2941	3208	0	0	3544	3703	-1100	13319	0	13319	1897	286	15502	50.00
4	4405	327	139	4871	2869	3117	0	0	3606	3531	-1075	13038	0	13038	1841	275	15154	50.03
5	4509	332	129	4970	2935	3349	0	0	3677	3954	-1065	13869	0	13869	1829	274	15972	50.02
6	4568	347	139	5054	2944	3497	0	0	4683	4414	-1223	14365	0	14365	1924	321	16610	49.95
7	4891	361	129	5381	2714	3520	0	11	5113	5668	-1370	15586	0	15586	2068	338	17992	49.93
8	5235	340	139	5714	2853	3811	0	53	5429	5705	-1587	16185	0	16185	2253	364	18802	50.00
9	5299	377	139	5815	2815	4446	0	107	5555	5487	-1835	16466	0	16466	2511	369	19346	50.05
10	5111	410	139	5660	2786	3931	0	209	6416	6058	-2082	16200	0	16200	2758	362	19320	50.02
11	4990	406	139	5535	2740	3361	0	248	6409	6292	-2211	15591	0	15591	2910	374	18875	50.03
12	4660	357	139	5156	2791	3250	0	362	6603	6085	-2165	15114	0	15114	2955	365	18434	49.95
13	4343	365	129	4837	2876	3041	0	370	6297	5698	-1989	14480	0	14480	2924	353	17757	50.02
14	4144	370	129	4643	2585	2878	0	403	5867	5613	-1872	13902	0	13902	2786	348	17036	50.06
15	4253	298	139	4690	2946	2944	0	327	5329	5227	-1957	13818	0	13818	2750	359	16927	50.01
16	4490	314	129	4933	3075	3100	0	295	5314	4867	-1868	14042	0	14042	2706	360	17108	50.01
17	4407	314	139	4860	2955	3019	0	146	5215	5383	-1866	14144	0	14144	2678	353	17175	49.98
18	4975	284	129	5388	2909	3364	0	89	4855	5104	-1855	14622	0	14622	2677	377	17676	50.03
19	4942	323	139	5404	3051	4189	0	6	5162	5027	-1842	15451	0	15451	2651	384	18486	50.03
20	5045	347	129	5521	3168	4520	0	0	4879	4658	-1718	15775	0	15775	2650	374	18799	49.99
21	5087	312	140	5539	3127	4214	0	0	4542	4075	-1577	15013	0	15013	2557	365	17935	49.97
22	5062	312	130	5504	3357	3782	0	0	3837	3962	-1543	14681	0	14681	2423	381	17485	49.99
23	4954	282	129	5365	3423	3726	0	0	3352	3172	-1472	13864	0	13864	2300	350	16514	49.98
24	4401	361	140	4902	3270	3352	0	0	3563	3640	-1341	13480	0	13480	2168	343	15991	50.02
MUs	112.93	8.20	3.23	124.36	71.52	84.50	0.00	2.63	116.37	114.05	-39.00	349.75	0.00	349.75	58.33	8.31	416.39	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 13/Jul/2022

Position as on 6.30 Hrs of 14/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkhedha Unit 4	210	05/06/2022	00:07	13/07/2022	00:31	Annual Overhaul	20/07/2022
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Annual Overhaul	17/07/2022
MSPGCL	Koyana Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
IPP	Adani U-2	660	25/06/2022	04:18		Continued.	Annual Overhaul	22/07/2022
MSPGCL	Koradi Unit 8	660	04/07/2022	21:55		Continued.	Annual Overhaul	10/08/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/07/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
MSPGCL	Ghatghar Unit-2	125	18/06/2022	10:00		Continued.	for Hydraulic Intake Gate Work	15/07/2022
MSPGCL	Uran Unit B0	120	24/06/2022	06:28		Continued.	Excitation channel fault(Converted to Gas Shortage from 26-06-22)	
MSPGCL	Uran Unit 8	108	24/06/2022	15:33		Continued.	Gas shortage	
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vabration high	15/07/2022
IPP	SWPGPL U-1	135	04/07/2022	02:38		Continued.	PA Fan problem	15/07/2022
MSPGCL	Uran Unit 6	108	06/07/2022	17:51		Continued.	Gas shortage	
MSPGCL	Koyana STG-IV Unit-1	250	06/07/2022	18:30		Continued.	Governor problem	16/07/2022
TPC-G	Trombay 7A	120	07/07/2022	01:09		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	07/07/2022	01:21		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 3	210	09/07/2022	11:58		Continued.	Furnace Pressure High	16/07/2022
MSPGCL	Nasik Unit 5	210	11/07/2022	17:00		Continued.	WET COAL	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 13/Jul/2022

Position as on 6.30 Hrs of 14/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Parli Unit 7	250	11/07/2022	22:03	13/07/2022	19:37	Boiler Tube Leakage	14/07/2022
AEML	AEML Unit 2	250	13/07/2022	00:38		Continued.	Coal Shortage	
IPP	JSW (J) U2	300	13/07/2022	09:35	14/07/2022	03:45	CW Duct leakage.	
MSPGCL	Koyana Unit 6	80	13/07/2022	12:07	13/07/2022	14:35	BUS SEC-2 TRIPPED AT POPHALI AND BUS SEC-1 IS UNDER EMERGENCY OUTAGE	
MSPGCL	Koyana Unit 5	80	13/07/2022	12:07	13/07/2022	14:50	BUS SEC-2 TRIPPED AT POPHALI AND BUS SEC-1 IS UNDER EMERGENCY OUTAGE	
MSPGCL	Koyana Unit 8	80	13/07/2022	12:07	13/07/2022	14:25	BUS SEC-2 TRIPPED AT POPHALI AND BUS SEC-1 IS UNDER EMERGENCY OUTAGE	
MSPGCL	Koyana Unit 7	80	13/07/2022	12:07	13/07/2022	14:38	BUS SEC-2 TRIPPED AT POPHALI AND BUS SEC-1 IS UNDER EMERGENCY OUTAGE	
MSPGCL	Parli Unit 7	250	13/07/2022	19:55	13/07/2022	21:02	Flame Failure	
MSPGCL	Bhusawal Unit 5	500	14/07/2022	01:48	14/07/2022	09:05	both ID fans off	14/07/2022
MSPGCL	Chandrapur Unit 5	500	14/07/2022	02:03	14/07/2022	15:16	UAT-5C TRIP ON EARTH FAULT.	15/07/2022
MSPGCL	Parli Unit 8	250	14/07/2022	02:05	14/07/2022	07:18	Generator Protection operated	15/07/2022
IPP	SWPGPL U-3	135	14/07/2022	14:58		Continued.	FD Fan Problem.	17/07/2022
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 13/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 14/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Tripping							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (431) OF 167 MVA SPARE ICT @ KORADI II	IntraState	16/06/2022	11:23			PO	1) Premonsoon maintenance work & 2) Routine Bay Maintenance.
400 KV LINE Outages/Tripping							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	30/06/2022	07:24			HT	H/T FOR CONTROLLING LINE LOADING
KHADKA-AURANGABAD (WALUJ)	IntraState	10/07/2022	17:30			HT	To control OV
MAIN BUS - 2 @ LAMBOTI	IntraState	13/07/2022	11:22	13/07/2022	18:42	PO	Routine Maintenance work
MAIN BUS - 2 @ KORADI 2	IntraState	13/07/2022	11:58	13/07/2022	22:04	PO	Bus isolator alignment work required for charging of 125MVar Reactor at 400kv Koradi II SS & separate proposal with required documents for charging of reactor on same day is to be submitted.
400 KV ICT Outages/Tripping							
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	13/07/2022	15:29	13/07/2022	19:41	T	OLTC Bucholz Trip & WTI Trip
220 KV TBC Outages/Tripping							
BUS COUPLER @ CARNAC	IntraState	13/07/2022	14:37	13/07/2022	16:33	EO	INVESTIGATION OF TRIPPING. BREAKER TRIPPED IN MORNING
220 KV MAINBAY Outages/Tripping							
AIS 220KV BUS COUPLER @ GHODBUNDER	IntraState	14/07/2022	09:39	14/07/2022	11:10	PO	Pre monsoon Maintenance
220 KV LINE Outages/Tripping							
NALASOPARA - BOISAR PG	InterState	14/07/2022	06:06	14/07/2022	17:47	T	Tripped on Distance Protection.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kv GCR-BBLR-2 line on 220kv TBC bay.
TATA BORIVLI MSETCL BORIVLI - 5	IntraState	11/07/2022	09:29	14/07/2022	00:31	PO	Relay replacement at MSETCL Bor Project work.
ADLABS - PEDAMBE	IntraState	12/07/2022	18:11	13/07/2022	17:01	T	TRIPPED ON D/P
EKLAHARE (OCR) - PADGHE	IntraState	12/07/2022	18:59	13/07/2022	03:12	HT	H/T FOR NASIK(GCR)-BBLR LINE LOADING
POPHALI - KDPH	IntraState	12/07/2022	23:30	14/07/2022	00:35	T	TRIPPED ON DIST.PROTECTION
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	13/07/2022	07:49	13/07/2022	17:46	T	TRIPPED ON DIST.PROTECTION
NEW KOYNA - NIWALI	IntraState	13/07/2022	10:17	13/07/2022	14:14	T	TRIPPED ON DIST.PROTECTION
TILLARI - AMONA LINE	IntraState	13/07/2022	11:21	13/07/2022	18:06	PO	Annual maintenance work
NEW KOYNA - POPHALI	IntraState	13/07/2022	12:07	13/07/2022	17:45	T	BUS SEC-2 TRIPPED AT POPHALI AND BUS SEC-1 IS UNDER EMERGENCY OUTAGE
NERLE- POPHALI	IntraState	13/07/2022	12:07	13/07/2022	14:48	T	BUS SEC-2 TRIPPED AT POPHALI AND BUS SEC-1 IS UNDER EMERGENCY OUTAGE
MAIN BUS SECTION - 2 @ PEDAMBE	IntraState	13/07/2022	12:07	13/07/2022	13:30	T	BUS SEC-2 TRIPPED AT POPHALI AND BUS SEC-1 IS UNDER EMERGENCY OUTAGE
MAIN BUS SECTION - 2 @ POPHALI	IntraState	13/07/2022	12:07	13/07/2022	13:30	T	BUS SEC-2 TRIPPED AT POPHALI AND BUS SEC-1 IS UNDER EMERGENCY OUTAGE

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 14/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS SECTION - 1 @ POPHALI	IntraState	13/07/2022	12:07	13/07/2022	23:10	EO	An emergency outage required on Main bus section -I for attending PPL-KDPH line Y & B phase broken jumper conductor, broken wave trap from 09:00 hrs. of date 13.07.2022 to 18:00 hrs. of date 13.07.2022 . During this outage period 220kV PPL-KANDALGAON line, 220kV PPL-PEDAMBE-I , Generating units 1,2,3,4 (each of 70 MW total 280 MW) will not be available.
POPHLI PEDHMBE LINE- 2	IntraState	13/07/2022	12:07	13/07/2022	13:15	T	BUS SEC-2 TRIPPED AT POPHALI AND BUS SEC-1 IS UNDER EMERGENCY OUTAGE
THEUR-JEJURI	IntraState	13/07/2022	16:11	13/07/2022	20:38	EO	RELAY TESTING WORK
NEW KOYNA - POPHALI	IntraState	13/07/2022	19:45	13/07/2022	17:45	HT	HT due to Conductor Strand open at Pophali end
TROMBAY - SALSETTE CKT - 1	IntraState	14/07/2022	00:55	14/07/2022	06:24	PO	METRO-4 WORK-ERECTION OF 46 A TOWER
TROMBAY SALSETTE LINE-2	IntraState	14/07/2022	01:05	14/07/2022	06:24	PO	METRO-4 WORK-ERECTION OF 46 A TOWER
BORIVALI - CTRLS CKT	IntraState	14/07/2022	03:22	14/07/2022	10:25	T	Tripped on Distance Protection.
NERLE - PEDAMBE	IntraState	14/07/2022	05:23	14/07/2022	15:44	T	Conductor snapping CT to isolator at Pedhambhe end
NERLE- POPHALI	IntraState	14/07/2022	08:43	14/07/2022	15:44	T	Y ph CB pole burst at Nerle end
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	14/07/2022	09:32			HT	HT from Navsary end for load management purpose
VANKUSWADE - AJINKYATARA	IntraState	14/07/2022	11:12	14/07/2022	15:28	PO	Replacement of flashover disc insulator strings at Loc No.78Y Ph
KARAD - NERLE	IntraState	14/07/2022	12:03	14/07/2022	12:20	T	Tripped at Nerle end due to bus fault at Nerle ss
IPCL - SPCL	IntraState	14/07/2022	21:43			T	tripped on DT
TROMBAY - SALSETTE CKT - 1	IntraState	14/07/2022	23:18		Continued.	PO	METRO-4 WORK-ERECTION OF 46 A TOWER
TROMBAY SALSETTE LINE-2	IntraState	14/07/2022	23:25		Continued.	PO	METRO-4 WORK-ERECTION OF 46 A TOWER
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200MVA ICT NO 1 @ THEUR	IntraState	14/07/2022	09:03	14/07/2022	18:02	PO	ICT1 LV Bay & Stub bus strengthning work
220/22 KV 50 MVA PTR 2 @ LONIKAND	IntraState	14/07/2022	11:20	14/07/2022	16:38	PO	Annual Relay Testing
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 14/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage