

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 13/Jul/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	132.630	1786.574	1) Gujrat	4.413	4.576
2) Hydro	11.990	92.857	2) Madhya Pradesh	7.511	72.820
3) Gas	0.208	0.208	3) Chattisgarh	0.880	29.410
Total MSPGCL	144.828	1879.639	4) Maharashtra	168.223	2124.206
B) 1) APML	70.383	803.790	5) Goa (Amona)	-1.002	-13.713
2) JSWEL	21.142	253.723	Total	180.025	2217.299
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.924	476.048
4) RPL(AMT)	18.862	300.733	b) Mumbai Drawl	37.859	522.540
5) SWPGPL	9.006	114.122	c) MSEDCL Bilateral *	88.284	1151.521
6) Other IPP	6.388	83.719	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.924	475.198
C) 1) TPCL Thermal	12.212	77.972	Include PX	0.000	0.000
2) TPCL Hydro	5.421	66.079	Standby	0.000	0.851
3) TPCL Gas	2.971	48.000	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.066	117.155	1) MSEDCL	445.102	5674.246
D) STATE			2) Mumbai Discoms	69.529	831.748
1) Thermal	281.689	3537.788	3) Other Discoms	9.993	127.985
(A1+C1+C4+(B1-B6))			TOTAL STATE	524.624	6633.979
2) Hydro (A2+C2)	17.411	158.936			
3) Gas (A3+B7+C3)	3.179	48.208			
4) Wind	29.925	530.720			
6) SOLAR	12.395	141.026			
TOTAL STATE	344.599	4416.678			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5410	5553	5638	5467
MSPGCL Hydro	717	277	1228	390
MSPGCL Gas	0	0	22	0
MSPGCL Total Generation	6127	5830	6888	5857
Central Sector Receipt	9056	8478	7250	6126
WIND	1343	1158	1536	1042
CPP / IPP Thermal	4763	4738	5581	5384
CPP / IPP Gas	0	0	0	0
SOLAR	1382	1654	0	0
Exchange with Mumbai	-2305	-2272	-1394	-1195
MSEDCL DEMAND MET	19897	19139	19411	16887
Load Shedding	0	0	135	0
MSEDCL DEMAND	19897	19139	19546	16887
TPCL GENERATION	612	697	1201	636
AEML GENERATION	494	451	500	355
MUMBAI DEMAND	3411	3420	3095	2186
OTHER DISCOM DEMAND	469	447	450	327
STATE DEMAND MET	23777	23006	22956	19400
STATE DEMAND	23777	23006	23091	19400
Frequency (Hz)	50.05	50.00	50.03	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 14.01 Hrs	49.72 Hz at 05.44 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 13/Jul/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.70	49.14	170	130
Unit 8	12.44	158.76	581	475
Unit 9	12.41	155.02	553	487
Unit 10	0.00	111.14	0	0
Total	28.56	474.05		
Bhusawal				
Unit 3	3.02	36.56	135	115
Unit 4	9.27	125.30	415	360
Unit 5	9.96	130.66	475	360
Total	22.24	292.53		
Parli				
Unit 6	1.11	12.42	240	0
Unit 7	0.44	0.44	137	0
Unit 8	0.00	0.00	0	0
Total	1.54	12.86		
Chandrapur				
Unit 3	3.25	43.29	151	115
Unit 4	3.30	42.42	148	129
Unit 5	0.00	0.00	0	0
Unit 6	7.32	102.58	335	280
Unit 7	7.83	103.03	350	303
Unit 8	10.08	128.14	437	400
Unit 9	10.86	133.62	489	400
Total	42.64	553.09		
Paras				
Unit 3	4.71	45.87	214	156
Unit 4	4.30	60.67	192	156
Total	9.00	106.53		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	2.34	32.93	132	60
Unit 3	4.04	50.36	178	158
Unit 4	3.82	43.02	175	143
Unit 5	10.36	130.13	458	395
Total	20.57	256.44		
Nasik				
Unit 3	4.08	33.68	183	142
Unit 4	4.00	45.05	173	143
Unit 5	0.00	12.33	0	0
Total	8.08	91.07		
Uran				
All Units	0.21	0.21	87	0
Total	0.21	0.21		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.18	0.26	27	0
Total	0.18	0.26		
Koyna				
Stage 1-2	3.68	28.59	425	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	3.14	5.94	506	0
Stage 3	1.66	11.87	240	0
Total	8.48	46.40		
Hydro				
KDPH	0.00	0.14	0	0
VTRNA	0.00	0.64	0	0
TILLARI	0.00	1.16	0	0
BHIRA T.R.	0.42	5.78	80	0
SMLHY_PTN	2.74	35.22	117	112
GHATGHAR	0.18	3.26	125	0
Total	3.34	46.20		
Wind				
Total	29.92	530.72	0	0
Total	29.92	530.72		
CPP				
APML(Mus)	70.38	803.79	0	0
JSWEL(Mus)	21.14	253.72	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	18.86	300.73	0	0
SWPGPL-Mus	9.01	114.12	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.39	66.47	270	199
Other(Mus)	1.00	17.25	0	0
Total	125.78	1556.09		
SOLAR				
Total	12.40	141.03	0	0
Total	12.40	141.03		
Tata				
Trombay 5	7.81	28.50	410	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.76	29.54	108	39
Trombay 7B	1.21	18.46	65	36
TATA Hydro	5.42	66.08	418	60
Trombay 8	4.40	49.47	224	130
Total	20.60	192.05		
AEML				
DTPS U-1&2	11.07	117.16	500	333
Total	11.07	117.16		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	132.63	1786.57	MSPGCL Total	144.83	1879.64
			MSPGCL Thml+Gas	132.84	1786.78	Koyna 1,2 & 4 Total	6.81	34.54
			MSPGCL Hydro	11.99	92.86	State Total	344.60	4416.68

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 13/Jul/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5478	371	0	5849	954	5494	0	0	6536	6338	-1160	17116	0	0	17116	2652	359	20127	50.04
2	5445	196	0	5641	882	5446	0	0	6777	6358	-1156	16824	0	0	16824	2427	347	19598	49.99
3	5444	260	0	5704	978	5398	0	0	6687	6465	-1197	17026	0	0	17026	2266	322	19614	49.96
4	5467	390	0	5857	1042	5384	0	0	6600	6126	-1195	16887	0	0	16887	2186	327	19400	49.97
5	5413	154	0	5567	1062	5424	0	0	6907	6631	-1054	17285	0	0	17285	2219	345	19849	49.97
6	5441	214	0	5655	1026	5418	0	0	8029	7673	-1083	18321	0	0	18321	2270	368	20959	49.86
7	5479	1055	0	6534	962	5447	0	130	8110	8200	-1221	19661	0	0	19661	2384	391	22436	49.94
8	5490	697	0	6187	904	5422	0	457	8829	8841	-1377	20020	0	0	20020	2572	414	23006	50.02
9	5506	267	0	5773	1313	5226	0	959	9074	8588	-1803	19592	0	0	19592	2911	464	22967	50.03
10	5441	398	0	5839	1492	4913	0	1239	9094	8761	-2142	19623	0	1	19623	3217	479	23319	50.01
11	5410	717	0	6127	1343	4763	0	1382	8974	9056	-2305	19897	0	4	19897	3411	469	23777	50.05
12	5503	229	0	5732	1203	5087	0	1551	8931	8640	-2301	19457	0	1	19457	3469	455	23381	49.99
13	5553	277	0	5830	1158	4738	0	1654	8745	8478	-2272	19139	0	0	19139	3420	447	23006	50.00
14	5462	298	0	5760	1133	4527	0	1479	8596	8201	-2139	18563	0	0	18563	3286	398	22247	50.05
15	5537	279	0	5816	1555	4987	0	1283	8500	7704	-1839	19091	0	0	19091	3318	415	22824	50.06
16	5359	268	0	5627	1558	4783	0	1032	8708	8043	-1800	18809	0	0	18809	3320	434	22563	50.00
17	5403	228	0	5631	1514	4844	0	791	8396	7984	-1822	18482	0	0	18482	3277	460	22219	49.98
18	5495	236	0	5731	1612	5197	0	360	8029	7868	-1904	18396	0	0	18396	3195	468	22059	50.00
19	5548	602	0	6150	1512	5446	0	78	7924	7564	-1714	18571	0	0	18571	3098	465	22134	50.01
20	5638	1228	22	6888	1536	5581	0	0	7169	7250	-1394	19411	135	36	19546	3095	450	23091	50.03
21	5678	1387	87	7152	1300	5581	0	0	6741	6533	-1317	18809	360	94	19169	2999	440	22608	50.04
22	5747	1120	87	6954	1354	5578	0	0	6540	6235	-1243	18447	157	83	18604	2893	431	21928	50.04
23	5811	823	12	6646	1244	5552	0	0	6505	6252	-1227	18035	0	0	18035	2837	432	21304	50.03
24	5882	296	0	6178	1288	5545	0	0	6478	6236	-1194	17640	0	0	17640	2807	413	20860	50.04
MUs	132.63	11.99	0.21	144.83	29.93	125.78	0.00	12.39	186.88	180.02	-37.86	445.10	0.65	0.22	445.75	69.53	9.99	525.28	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)ELR done due to overloading of 132 kV MIDC to Sonewadi and 132kV satana-dindori line.2)ELR done due to State overdrawal.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 13/Jul/2023

Position as on 6.30 Hrs of 14/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
MSPGCL	Parli Unit 8	250	18/06/2023	23:55		Continued.	Annual Overhaul	15/07/2023
MSPGCL	Khaparkheda Unit 1	210	30/06/2023	00:18		Continued.	Annual Overhaul	24/07/2023
IPP	JSW (J) U3	300	07/07/2023	09:06		Continued.	Annual Overhaul	08/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhual.	
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	24/07/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57	13/07/2023	19:34	No Schedule	
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	25/07/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	25/07/2023
MSPGCL	Uran Unit 7	108	24/06/2023	19:03		Continued.	No Schedule	
MSPGCL	Parli Unit 7	250	29/06/2023	14:31	13/07/2023	17:27	On Zero Schedule	
IPP	SWPGPL U-1	135	02/07/2023	02:54		Continued.	PA Fan problem	14/07/2023
MSPGCL	Nasik Unit 5	210	04/07/2023	18:00		Continued.	Generator Swapping : nashik Unit-3 sync 16:35 Hrs and tolling agreement with IEPL	
MSPGCL	Parli Unit 6	250	07/07/2023	21:45	13/07/2023	16:38	ZERO SCHEDULE	
IPP	RPL(AMT) U-5	270	10/07/2023	08:55		Continued.	Bottom Ash Problem.	14/07/2023

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 13/Jul/2023

Position as on 6.30 Hrs of 14/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	13/07/2023	22:16		Continued.	No Schedule	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 14/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400KV 1500 MVA ICT-2 @ KORADI 3	IntraState	13/07/2023	12:19	13/07/2023	15:40	PO	DGA test of Metering Current Transformer
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV MAINBAY Outages/Trippings							
GTR - 5 @ CHANDRAPUR	IntraState	06/07/2023	08:38			PO	1. Maintenance and alignment work of Bus-1, Bus-2 Aus. Bus And HCB Isolator. 2. Maintenance of CB, CT and Synch CVT.
SPARE LINE-1 BAY (401) @ TAPTITANDA	IntraState	11/07/2023	09:42	13/07/2023	15:51	PO	Circuit Breaker Overhauling work by M/s CGL
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
KOLHAPUR - SOLAPUR (PG) CKT - 2	InterState	13/07/2023	19:04	14/07/2023	06:17	T	Tripped on distance protection
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	13/07/2023	08:03			HT	H/T Due to load management.
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	13/07/2023	11:13	13/07/2023	16:26	PO	(1) Main-1 distance relay testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work
DABHOL - NEW KOYNA CKT - 1	IntraState	13/07/2023	11:48	13/07/2023	19:09	PO	Rectification of line and bay isolator and earth switch operational issues.
KORADI - KHAPERKHEDA CKT - 2	IntraState	14/07/2023	07:47			PO	Faulty string replaement work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315MVA ICT - 2 @ CHAKAN	IntraState	13/07/2023	10:37	13/07/2023	20:08	PO	Attending oil leakages Routine Maintenance and DT.
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	13/07/2023	11:23			PO	Mechanism overhauling work of IV Bay Circuit Breaker
400/220/20 KV 500MVA ICT - 1 @ KALWA	IntraState	14/07/2023	14:44	14/07/2023	16:34	EO	For replacement of damaged jumper on urgent basis
400 KV BUSBAR Outages/Trippings							
400KV MAIN BUS 2 @ 400KV DEEPNAGAR	IntraState	13/07/2023	10:46	13/07/2023	14:30	PO	For cable termination, wiring, testing & configuration of new Station TF (STN-6A) and Generating TF GT-6 bay in existing 400 kV Bus-II Busbar Panel in r/o 660 MW Unit.
220 KV MAINBAY Outages/Trippings							
220 KV BUS SECTION - 2	IntraState	13/07/2023	08:56	13/07/2023	17:21	PO	Diagnostic testing and Routine bay maintenance work.
220 KV LINE Outages/Trippings							
NARANGWADI - SOLAPUR PG CKT - 1	InterState	13/07/2023	08:47	13/07/2023	18:05	PO	Line terminal equipments AMP at 765kV Solapur Substation
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 14/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
DAHANU - VERSOVA	IntraState	10/07/2023	10:24			PO	Shifting of Lines on Newly constructed Towers for NHRCL Project Total Towers (04 nos) - SS 220, 223, 224 & 225 1. Bunching of lines will be done on Tower no 82. 2. Post bunching existing configuration of line will be changed as 220 kV Dahanu - Boisar Line.
BOISAR - VERSOVA	IntraState	10/07/2023	10:27			PO	Shifting of Lines on Newly constructed Towers for NHRCL Project. Total Towers (04 nos) - SS 220, 223, 224 & 225 1. Bunching of lines will be done on Tower no 82. 2. Post bunching existing configuration of line will be changed as 220 kV Dahanu - Boisar Line.
VITA - HIWARWADI	IntraState	13/07/2023	10:33	13/07/2023	17:34	PO	Cold washing of insulator strings
KARAD - VITA CKT- 1	IntraState	13/07/2023	10:33	13/07/2023	17:34	PO	Cold washing work of insulator strings
LONAND-PHALTAN MIDC	IntraState	13/07/2023	10:40	13/07/2023	14:45	PO	TBC Wiring & Testing Work
NAGOTHANE - SPCL	IntraState	13/07/2023	11:11	13/07/2023	13:11	PO	For relay testing work
BABLESHWAR- ALEPHATA CKT - 1	IntraState	13/07/2023	11:31	13/07/2023	21:09	PO	220 KvBabhaleshwarAlephataCktfor attending the damage conductor at various cut point locations found in monkey patrolling of the line. 83 Y phAlephataside, 82 B phAlephata side, 74 R Y B ph BBLR side, 98 R ph alephata side . 124 R ph BBLR side , 131 R Y B PH ALEphata side . 172 Y ph Alephata SIDE ,
220 KV PARLI -U-8 - PARBHANI CKT	IntraState	13/07/2023	11:40	13/07/2023	15:00	EO	Y phase flashover string replacement work.
DONDAICHA- SHAHADA	IntraState	13/07/2023	15:00	13/07/2023	18:30	PO	Line 1, Commissioning and charging work.
KANDALGAON - KOYNA (POPHALI)	IntraState	13/07/2023	19:26	14/07/2023	04:25	T	Tripped on distance protection
VITA - HIWARWADI	IntraState	14/07/2023	09:34			PO	Cold washing of insulator strings
KARAD - VITA CKT- 1	IntraState	14/07/2023	09:34			PO	Cold washing work of insulator strings
PADGHE - KAMBA 2	IntraState	14/07/2023	10:10			PO	For replacement of broken Jumper conductor of Y Phase CT to Stub Bus
PHURSUNGI-PARVATI	IntraState	14/07/2023	10:31	14/07/2023	17:03	EO	Bay is to be shifted on TBC for CB Y ph pole replacement work due to higher CRM value without affecting any load
WALCHANDNAGAR-LONI DEOKAR	IntraState	14/07/2023	14:40	14/07/2023	15:57	EO	Outage required to removed trapped kite thread Y phase insulator string at location no. 52
KHARGHAR - SONKHAR	IntraState	14/07/2023	17:06	14/07/2023	19:32	EO	To replace damaged R & B ph Cable bushing clamp at cable termination bay near loc. No. 1
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 14/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/110 kV 200 MVA ICT 1 @ MUDSHINGI	IntraState	14/07/2023	10:28	14/07/2023	17:05	EO	For TAMS system wiring & testing work
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage