

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 13/Sep/2018 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	106.060	1314.365	1) Gujrat	4.798	21.693
2) Hydro	7.838	177.696	2) Madhya Pradesh	18.371	204.386
3) Gas	2.491	36.090	3) Chattisgarh	5.240	65.310
Total MSPGCL	116.389	1528.151	4) Maharashtra Net	131.758	1538.562
B) 1) APML	58.870	680.560	5) Goa (Amona)	-0.220	-5.434
2) JSWEL	18.535	217.577	Total	159.947	1824.517
3) VIPL	14.478	187.398	a) Mumbai Schedule	18.249	297.044
4) RPL(AMT)	31.140	375.873	b) Mumbai Drawl	18.540	297.898
5) WPCL	3.926	40.183	c) MSEDCL Bilateral *	58.231	506.467
6) PGPL	0.000	0.000	Include PX	44.059	232.174
7) Other IPP	6.925	86.204	d) Mumbai Bilateral *	18.249	297.044
C) 1) TPCL Thermal	16.226	195.574	Include PX	-0.504	28.483
2) TPCL Hydro	1.894	59.567	Include Standby	0.000	0.000
3) TPCL Gas	4.368	56.326	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	11.554	140.512	1) MSEDCL	413.500	5050.052
D) STATE			2) Mumbai Discoms	52.582	749.874
1) Thermal	267.714	3238.246	TOTAL STATE	466.082	5799.926
(A1+C1+C4+(B1-B6))					
2) Hydro	9.732	237.263			
(A2+C2)					
3) Gas	6.859	92.416			
(A3+B6+C3)					
4) Wind	16.406	341.740			
6) SOLAR	5.424	65.747			
TOTAL STATE	306.135	3975.412			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	4412	4250	4610	4746
MSPGCL Hydro	611	722	275	186
MSPGCL Gas	101	100	104	105
MSPGCL Total Generation	5124	5072	4989	5037
Central Sector Receipt	7846	7780	4895	4677
WIND	227	285	1148	909
CPP / IPP Thermal	5514	5548	5676	5723
CPP / IPP Gas	0	0	0	0
SOLAR	710	731	0	0
Exchange with Mumbai	-1039	-950	-694	-681
MSEDCL DEMAND MET	18382	18466	16014	15665
Load Shedding	0	0	0	0
MSEDCL DEMAND	18382	18466	16014	15665
TPCL GENERATION	846	873	1323	1163
R-INFRA GENERATION	485	500	460	500
MUMBAI DEMAND	2370	2323	2477	2344
STATE DEMAND MET	20752	20789	18491	18009
STATE DEMAND	20752	20789	18491	18009
Frequency (Hz)	49.92	50.01	49.95	49.91

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.14 Hz at 16.02 Hrs	49.72 Hz at 22.11 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 13/Sep/2018

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.15	0	0
Unit 7	0.00	0.00	0	0
Unit 8	4.58	88.96	301	69
Unit 9	0.00	38.80	0	0
Unit 10	5.07	57.48	330	0
Total	9.66	185.38		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	11.04	129.42	485	450
Total	11.04	129.42		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	14.31	0	0
Unit 7	4.80	69.93	216	176
Unit 8	4.84	67.98	229	181
Total	9.64	152.22		
Chandrapur				
Unit 3	4.09	50.06	181	141
Unit 4	4.21	50.84	182	168
Unit 5	0.00	55.84	0	0
Unit 6	6.45	108.58	290	245
Unit 7	9.43	29.30	423	367
Unit 8	9.69	62.96	442	336
Unit 9	8.84	110.69	412	302
Total	42.71	468.27		
Paras				
Unit 3	4.45	54.47	249	155
Unit 4	4.57	56.35	221	178
Total	9.02	110.82		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	27.37	0	0
Unit 3	3.15	47.77	180	0
Unit 4	3.32	13.44	145	130
Unit 5	9.27	113.16	425	350
Total	15.74	201.74		
Nasik				
Unit 3	4.28	54.43	190	156
Unit 4	3.97	5.94	176	154
Unit 5	0.00	6.13	0	0
Total	8.26	66.51		
Uran				
All Units	2.49	36.09	107	100
Total	2.49	36.09		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.02	0.95	12	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.02	0.95		
Koyna				
Stage 1-2	2.70	44.14	325	40
Stage 4	2.90	69.64	419	0
Stage 3	1.70	26.66	160	0
Total	7.30	140.44		
Hydro				
KDPH	0.00	7.24	0	0
VTRNA	0.00	5.00	0	0
TILLARI	0.00	5.98	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.29	4.57	73	0
RNGR+BHTSA	0.18	3.27	15	0
BHANDARDRA	0.00	2.57	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.08	6.10	13	0
GHATGHAR	0.00	2.53	0	0
Total	0.54	37.25		
Wind				
Total	16.41	341.74	0	0
Total	16.41	341.74		
CPP				
APML(Mus)	58.87	680.56	0	0
JSWEL(Mus)	18.54	217.58	0	0
VIPL(Mus)	14.48	187.40	0	0
RPLAMT(Mus)	31.14	375.87	0	0
WPCL(Mus)	3.93	40.18	0	0
Other(Mus)	6.92	86.20	0	0
Total	133.87	1587.80		
SOLAR				
Total	5.42	65.75	0	0
Total	5.42	65.75		
Tata				
Trombay 5	10.89	128.36	482	313
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.76	35.57	116	114
Trombay 7B	1.61	20.75	68	66
Trombay 8	5.34	67.21	239	200
TATA Hydro	1.89	59.57	436	0
Total	22.49	311.47		
R-INFRA				
DTPS U-1&2	11.55	140.51	502	376
Total	11.55	140.51		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	106.06	1314.36	MSPGCL Total	116.39	1528.15
			MSPGCL Thml+Gas	108.55	1350.46	Koyna 1,2 & 4 Total	5.60	113.78
			MSPGCL Hydro	7.84	177.70	State Total	306.14	3975.41

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 13/Sep/2018

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4319	568	105	4992	861	5607	0	0	6299	6257	-811	16906	0	16906	2205	19111	49.87
2	4291	465	106	4862	891	5596	0	0	6074	6295	-673	16971	0	16971	2051	19022	49.92
3	4251	297	106	4654	836	5590	0	0	5929	6135	-550	16665	0	16665	1933	18598	49.95
4	4222	165	107	4494	843	5596	0	0	5912	6223	-487	16669	0	16669	1861	18530	49.99
5	4179	506	106	4791	736	5593	0	0	6182	6316	-476	16960	0	16960	1844	18804	49.95
6	4204	678	107	4989	643	5592	0	0	6783	7139	-548	17815	0	17815	1919	19734	49.94
7	4276	389	107	4772	498	5602	0	24	8048	8021	-578	18339	0	18339	1953	20292	49.98
8	4347	331	107	4785	355	5600	0	186	8086	8330	-640	18616	0	18616	2022	20638	50.00
9	4331	192	105	4628	316	5573	0	404	8135	8116	-918	18119	0	18119	2133	20252	49.99
10	4386	174	104	4664	219	5465	0	573	7865	7734	-1169	17486	0	17486	2250	19736	50.00
11	4403	420	102	4925	191	5365	0	625	7588	8092	-1193	18005	0	18005	2343	20348	49.94
12	4412	611	101	5124	227	5514	0	710	7842	7846	-1039	18382	0	18382	2370	20752	49.92
13	4250	722	100	5072	285	5548	0	731	7590	7780	-950	18466	0	18466	2323	20789	50.01
14	4319	592	100	5011	359	5540	0	669	7449	7834	-852	18561	0	18561	2228	20789	49.96
15	4322	382	100	4804	492	5550	0	585	7596	7656	-858	18229	0	18229	2227	20456	49.94
16	4417	136	101	4654	589	5503	0	504	7602	7696	-888	18058	0	18058	2255	20313	49.94
17	4460	68	101	4629	842	5536	0	301	7188	7518	-864	17962	0	17962	2226	20188	49.99
18	4581	61	103	4745	1023	5520	0	108	6507	5980	-861	16515	0	16515	2231	18746	50.04
19	4593	132	102	4827	1256	5540	0	4	5018	4853	-816	15664	0	15664	2284	17948	49.95
20	4610	275	104	4989	1148	5676	0	0	4675	4895	-694	16014	0	16014	2477	18491	49.95
21	4633	103	103	4839	1118	5715	0	0	4527	4656	-678	15650	0	15650	2434	18084	49.96
22	4718	41	104	4863	996	5734	0	0	4486	4671	-656	15608	0	15608	2386	17994	49.95
23	4746	186	105	5037	909	5723	0	0	4656	4677	-681	15665	0	15665	2344	18009	49.91
24	4790	344	105	5239	773	5594	0	0	4780	5227	-660	16173	0	16173	2283	18456	49.91
MUs	106.06	7.84	2.49	116.39	16.41	133.87	0.00	5.42	156.82	159.95	-18.54	413.50	0.00	413.50	52.58	466.08	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 13/Sep/2018

Position as on 6.30 Hrs of 14/Sep/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U2	300	28/07/2018	13.48	13/09/2018	06.30	Annual Overhaul	
MSPGCL	Bhusawal Unit 4	500	10/08/2018	01.02		Continued.	Capital Overhaul	
IPP	Adani U-3	660	03/09/2018	05.02		Continued.	Capital overhaul	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Bhusawal Unit 3	210	21/05/2018	18.46		Continued.	Coal Swapping IEPL	
MSPGCL	Ghatghar Unit-2	125	29/06/2018	01.12		Continued.	Stator Earth Fault	
MSPGCL	Ghatghar Unit-2	125	29/06/2018	01:12		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
MSPGCL	Koradi Unit 7	210	03/08/2018	15.54		Continued.	Poor Coal Receipt.	
MSPGCL	Khaparkheda Unit 1	210	11/08/2018	23.57		Continued.	Poor coal Receipt	
MSPGCL	Uran Unit A0	120	27/08/2018	02:06		Continued.	Generator protection	
MSPGCL	Uran Unit 5	108	27/08/2018	03.31	14/09/2018	01.21	Due to A0 Trip.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Koradi Unit 9	660	04/09/2018	12.48		Continued.	Poor Coal Receipt	
MSPGCL	Chandrapur Unit 5	500	07/09/2018	11.24	14/09/2018	11.15	poor coal.	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn due to B0 & U-7	
MSPGCL	Koradi Unit 6	210	09/09/2018	05.52		Continued.	Inspection of Boiler Tubes by R & M Team.	
MSPGCL	Khaparkheda Unit 2	210	10/09/2018	02.35		Continued.	Poor Coal Receipt.	
MSPGCL	Nasik Unit 5	210	11/09/2018	18.45		Continued.	Coal Swapping with DIL	
MSPGCL	Parli Unit 6	250	12/09/2018	06.57		Continued.	Poor Coal receipt	
MSPGCL	Koradi Unit 10	660	13/09/2018	03.39	13/09/2018	05.25	Flame Failure	
MSPGCL	Khaparkheda Unit 3	210	13/09/2018	12.32	13/09/2018	15.23	Drum level High.	
IPP	JSW (J) U2	300	13/09/2018	13.50	14/09/2018	02.18	turbine balancing.	
MSPGCL	Uran Unit 5	108	14/09/2018	06.17	14/09/2018	16.06	Generator protection	
MSPGCL	Chandrapur Unit 6	500	14/09/2018	23.58		Continued.	Clinker Removed	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 13/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 14/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	13/09/2018	22.00	14/09/2018	03.39	PO	oil top up in smoothing reactor & connector transformer. 14/Sep/2018 REC 03.39.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kv Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar I	InterState	12/09/2018	18.26	13/09/2018	10.54	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	13/09/2018	17.53	14/09/2018	06.21	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	14/09/2018	16.45		Continued.	HT	for charging.
Dhule - Bableshwar - li	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Dhule- Bableshwar - I	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Khadka-Aurangabad (Waluj)	IntraState	12/09/2018	19.14	13/09/2018	06.00	HT	Over Voltage
Karad - Jaigad - II	IntraState	13/09/2018	17.13	14/09/2018	09.16	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	13/09/2018	17.59	14/09/2018	06.07	HT	Over Voltage
Akola-Bhusawal(khadka) bay 410	IntraState	14/09/2018	00.07	14/09/2018	13.38	EO	hot spot R PHASE isolator clamp.
Bhusawal-Aurangabad	IntraState	14/09/2018	20.07		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220kv 315 MVA ICT-III@Padgha	IntraState	14/09/2018	09.50	14/09/2018	18.50	PO	Testing Work
400/220 KV 500MVA ICT-IV @ Babhaleshwar	IntraState	14/09/2018	14.20	14/09/2018	17.01	T	Bucholz relay same time LTS operated.
400/220/33 Kv 500 MVA ICT-III @Girwali	IntraState	14/09/2018	19.50	14/09/2018	23.30	EO	Attending Hot Spot
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Nasik Navsari II	InterState	13/09/2018	14.08	13/09/2018	16.14	EO	B PHASE bus isolator hot spot attending work at navsari end.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching Of Conductor at Loc No.86 Disconnecting Of jumper at Loc No.86 to 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To control line loading.
Kalwa 52B Interconnector CB	IntraState	19/08/2018	18.25		Continued.	HT	Taken In Service To Control Load Of Temghar Ckt At Kalwa 1 S/5 In Lieu Of 220kv Bus Outage At Padgha.
Nerul-Trombay	IntraState	31/08/2018	22.04		Continued.	PO	Conductor Replacement
JATH SHEDYAL	IntraState	05/09/2018	20.34	14/09/2018	23.29	HT	Over Voltage
Dhule-Chalisagaon	IntraState	13/09/2018	06.18	13/09/2018	09.12	HT	for controlling dhule ict o/l.
Eklahara(Gcr)(Nasik)- Bableshwar-I	IntraState	13/09/2018	06.49	13/09/2018	13.13	T	Distance Protection
Kalwa - Borivali	IntraState	13/09/2018	08.35	13/09/2018	11.10	EO	Attending Hot Spot
Dondaicha- Shahada	IntraState	13/09/2018	15.02	13/09/2018	15.23	T	Distance Protection
Dhule-Chalisagaon	IntraState	14/09/2018	05.35	14/09/2018	08.12	HT	to control ict overloading.
Gadchandur - Virur-li	IntraState	14/09/2018	06.35	14/09/2018	08.45	T	sparking on bus isolator.
Uran - Apta III	IntraState	14/09/2018	10.24	14/09/2018	14.06	PO	bus post insulator replacement.
Miraj - Mhaishal	IntraState	14/09/2018	10.50	14/09/2018	13.40	HT	for load management.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 14/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Aurangabad (Waluj)-Bhenda	IntraState	14/09/2018	10.52	14/09/2018	15.15	PO	Routine Maintenance Work
Mahindra Vehicle-Bridgestone	IntraState	14/09/2018	11.00	14/09/2018	19.27	PO	Routine Maintenance Work
Padegaon-Sawangi	IntraState	14/09/2018	11.07	14/09/2018	13.06	EO	Attending Hot Spot
Miraj-Ichalkaranji I	IntraState	14/09/2018	11.30	14/09/2018	17.39	PO	Routine Maintenance Work
Nashik-Padgha	IntraState	14/09/2018	11.44	14/09/2018	14.35	PO	insulator replacement.
chandrapur-Tadali	IntraState	14/09/2018	12.45	14/09/2018	15.43	PO	CB AND LINE ISO.
Badnera-Akola li	IntraState	14/09/2018	12.45	14/09/2018	17.30	PO	Line Maintenance work
Uran - Kharghar I	IntraState	14/09/2018	14.16	14/09/2018	20.28	PO	Routine Maintenance Work
Bableshwar -Ahamadnagar-I	IntraState	14/09/2018	14.20	14/09/2018	14.38	T	LTS operated due to tripping of ict 4.
Bableshwar Ahamadnagar-li	IntraState	14/09/2018	14.20	14/09/2018	14.39	T	LTS operated due to tripping of ict 4.
Bableshwar-Alephata ckt I	IntraState	14/09/2018	14.20	14/09/2018	15.40	T	LTS operated due to tripping of ict 4.
Malegaon-Satana	IntraState	14/09/2018	14.55	14/09/2018	15.36	PO	line signature test.
Malegaon-Sayne	IntraState	14/09/2018	15.54	14/09/2018	17.14	PO	line signature test.
220 KV ICT Outages/Trippings							
220/132 Kv 200 Mva Vijay Ict 2 @Chalisgaon	IntraState	14/09/2018	09.18	14/09/2018	12.34	PO	Routine Maintenance Work
220/22 Kv 50 Mva T&R Ptr 1 @Anandnagar	IntraState	14/09/2018	10.15	14/09/2018	12.25	PO	hot spot on LV jumper.
220/132 Kv 200 Mva Cgl Ict 1 @Boisar-li	IntraState	14/09/2018	11.16	14/09/2018	13.50	PO	Routine Maintenance Work
220/132 Kv 200 Mva Vijay Ict 1 @Chalisgaon	IntraState	14/09/2018	13.33	14/09/2018	19.17	PO	Routine Maintenance Work
132 KV LINE Outages/Trippings							
Kaulewada-Gondia-li	IntraState	14/09/2018	04.22	14/09/2018	04.40	T	Distance Protection
Elichpur - Hingoli	IntraState	14/09/2018	07.29	14/09/2018	08.10	T	overloading.
Waghala (Nanded2) - Tamsa	IntraState	14/09/2018	12.07	14/09/2018	12.31	T	Distance Protection
Amravati - Tiwasa	IntraState	14/09/2018	13.57	14/09/2018	14.24	T	132KV OLD BUS SECTION BUS BAR PROTN OPTD.
Ambazari-Amravati	IntraState	14/09/2018	13.57	14/09/2018	20.10	T	132KV OLD BUS SECTION BUS BAR PROTN OPTD.
Ahamadnagar - Ashti	IntraState	14/09/2018	14.19	14/09/2018	14.39	T	Distance Protection
Raimoha - Pathardi	IntraState	14/09/2018	14.35	14/09/2018	19.35	T	Distance Protection
Gondia-Amgaon li	IntraState	14/09/2018	23.18		Continued.	T	Amgaon CKT Y PH CT Burst And Caught Fire.
Gondia-Amgaon 1	IntraState	14/09/2018	23.18		Continued.	T	Amgaon CKT Y PH CT Caught Fire.
Kaulewada-Gondia-li	IntraState	14/09/2018	23.18		Continued.	T	At Amgaon Y PH CT Burst And Caught Fire.
Kaulewada-Gondia-I	IntraState	14/09/2018	23.18		Continued.	T	At Amgaon Y PH CT Burst And Caught Fire.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage