

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 13/Sep/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	132.472	1730.668	1) Gujrat	1.683	43.157
2) Hydro	14.558	191.494	2) Madhya Pradesh	2.625	22.316
3) Gas	3.469	72.024	3) Chattisgarh	3.980	38.120
Total MSPGCL	150.499	1994.186	4) Maharashtra	186.965	2453.673
B) 1) APLM	69.731	756.621	5) Goa (Amona)	-1.798	-22.830
2) JSWEL	24.808	329.225	Total	193.455	2534.436
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.344	436.183
4) RPL(AMT)	25.425	328.522	b) Mumbai Drawl	40.814	491.845
5) SWPGPL	11.900	153.552	c) MSEDCL Bilateral *	90.876	1285.065
6) Other IPP	5.967	81.889	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.344	436.119
C) 1) TPCL Thermal	12.905	164.938	Include PX	0.000	0.000
2) TPCL Hydro	4.179	49.954	Standby	0.000	0.064
3) TPCL Gas	2.126	27.422	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.345	126.452	1) MSEDCL	477.453	6164.067
D) STATE			2) Mumbai Discoms	70.369	860.612
1) Thermal	293.553	3671.867	3) Other Discoms	10.408	134.670
(A1+C1+C4+(B1-B6))			TOTAL STATE	558.230	7159.349
2) Hydro	18.737	241.448			
(A2+C2)					
3) Gas	5.595	99.446			
(A3+B7+C3)					
4) Wind	33.746	461.444			
6) SOLAR	13.144	150.707			
TOTAL STATE	364.775	4624.912			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5234	5567	5716	5360
MSPGCL Hydro	366	210	1444	218
MSPGCL Gas	132	141	143	138
MSPGCL Total Generation	5732	5918	7303	5716
Central Sector Receipt	9604	9194	8267	7236
WIND	1634	1247	1340	1595
CPP / IPP Thermal	4849	5960	6170	5335
CPP / IPP Gas	0	0	0	0
SOLAR	1643	1249	0	0
Exchange with Mumbai	-2102	-2319	-1500	-1305
MSEDCL DEMAND MET	20898	20796	21115	18230
Load Shedding	0	0	0	0
MSEDCL DEMAND	20898	20796	21115	18230
TPCL GENERATION	850	682	1220	516
AEML GENERATION	491	391	499	326
MUMBAI DEMAND	3443	3392	3219	2147
OTHER DISCOM DEMAND	462	453	465	347
STATE DEMAND MET	24803	24641	24799	20724
STATE DEMAND	24803	24641	24799	20724
Frequency (Hz)	49.98	50.00	49.87	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.22 Hz at 18.02 Hrs	49.76 Hz at 19.27 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 13/Sep/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.24	43.65	165	110
Unit 8	14.18	160.21	635	530
Unit 9	12.34	140.97	552	438
Unit 10	0.00	0.00	0	0
Total	29.75	344.83		
Bhusawal				
Unit 3	2.88	34.06	135	90
Unit 4	8.72	119.59	440	320
Unit 5	8.62	116.40	420	305
Total	20.22	270.06		
Parli				
Unit 6	4.63	56.92	214	151
Unit 7	4.30	47.28	234	108
Unit 8	3.87	52.49	174	137
Total	12.80	156.69		
Chandrapur				
Unit 3	2.86	42.63	149	83
Unit 4	2.89	12.47	127	114
Unit 5	0.00	0.00	0	0
Unit 6	7.64	77.90	350	225
Unit 7	6.78	83.73	309	252
Unit 8	10.08	122.16	453	373
Unit 9	0.00	114.86	0	0
Total	30.26	453.76		
Paras				
Unit 3	4.71	57.77	211	168
Unit 4	4.73	60.83	213	175
Total	9.44	118.61		
Khaparkheda				
Unit 1	2.90	36.00	140	90
Unit 2	1.58	22.39	84	0
Unit 3	3.71	44.36	177	128
Unit 4	3.32	41.83	153	123
Unit 5	10.21	131.48	455	370
Total	21.71	276.06		
Nasik				
Unit 3	3.72	42.54	165	146
Unit 4	3.08	40.51	151	34
Unit 5	1.49	27.61	135	0
Total	8.30	110.66		
Uran				
All Units	3.47	72.02	232	132
Total	3.47	72.02		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.07	9.21	47	44
Total	1.07	9.21		
Koyna				
Stage 1-2	2.70	37.76	345	30

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	4.77	60.16	750	0
Stage 3	1.81	23.19	216	0
Total	9.28	121.11		
Hydro				
KDPH	0.00	4.48	0	0
VTRNA	0.00	0.49	0	0
TILLARI	0.24	0.24	60	0
BHIRA T.R.	0.30	4.54	80	0
SMLHY_PTN	3.24	47.69	143	121
GHATGHAR	0.43	3.73	125	0
Total	4.20	61.17		
Wind				
Total	33.75	461.44	0	0
Total	33.75	461.44		
CPP				
APML(Mus)	69.73	756.62	0	0
JSWEL(Mus)	24.81	329.22	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.42	328.52	0	0
SWPGPL-Mus	11.90	153.55	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.56	73.76	259	185
Other(Mus)	0.41	8.13	0	0
Total	137.83	1649.81		
SOLAR				
Total	13.14	150.71	0	0
Total	13.14	150.71		
Tata				
Trombay 5	8.47	108.16	453	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.18	15.14	89	38
Trombay 7B	0.95	12.28	58	33
TATA Hydro	4.18	49.95	391	28
Trombay 8	4.44	56.78	229	131
Total	19.21	242.31		
AEML				
DTPS U-1&2	10.34	126.45	500	320
Total	10.34	126.45		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	132.47	1730.67	MSPGCL Total	150.50	1994.19
			MSPGCL Thml+Gas	135.94	1802.69	Koyna 1,2 & 4 Total	7.47	97.92
			MSPGCL Hydro	14.56	191.49	State Total	364.78	4624.91

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 13/Sep/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5315	271	136	5722	1496	5970	0	0	6754	6848	-1269	18361	0	0	18361	2597	406	21364	49.99
2	5335	220	138	5693	1545	5857	0	0	7161	6796	-1389	18106	0	0	18106	2385	396	20887	49.98
3	5313	228	136	5677	1588	5608	0	0	7306	7234	-1360	18396	0	0	18396	2232	351	20979	49.99
4	5360	218	138	5716	1595	5335	0	0	7364	7236	-1305	18230	0	0	18230	2147	347	20724	49.98
5	5491	229	136	5856	1574	5757	0	0	7219	7145	-1294	18683	0	0	18683	2132	355	21170	49.98
6	5560	503	139	6202	1462	5987	0	0	7567	7580	-1239	19618	0	0	19618	2230	374	22222	50.00
7	5498	1360	137	6995	1392	5978	0	77	7698	7688	-1174	20549	0	0	20549	2399	407	23355	49.92
8	5593	1218	136	6947	1212	5951	0	452	7989	8508	-1340	21298	0	0	21298	2603	432	24333	50.03
9	5664	399	137	6200	1538	5844	0	975	8970	8829	-2038	20890	0	0	20890	2927	458	24275	49.99
10	5581	306	134	6021	1726	5488	0	1347	9290	9081	-2318	20891	0	2	20891	3236	454	24581	49.99
11	5234	366	132	5732	1634	4849	0	1643	9767	9604	-2102	20898	0	4	20898	3443	462	24803	49.98
12	5338	521	136	5995	1435	4585	0	1663	9776	9679	-2316	20584	0	2	20584	3471	457	24512	49.95
13	5542	296	183	6021	1119	4994	0	1643	9310	9090	-2336	20074	0	0	20074	3407	457	23938	49.99
14	5612	240	232	6084	1041	5217	0	1639	8917	8948	-2203	20269	0	1	20269	3283	457	24009	49.98
15	5689	207	139	6035	1180	5698	0	1484	9032	8847	-2260	20544	0	2	20544	3343	440	24327	49.96
16	5567	210	141	5918	1247	5960	0	1249	9236	9194	-2319	20796	0	3	20796	3392	453	24641	50.00
17	5605	291	142	6038	1300	5817	0	696	9036	8714	-2071	20025	0	0	20025	3396	469	23890	49.96
18	5609	900	143	6652	1378	6104	0	257	8159	8013	-1859	20064	0	0	20064	3322	481	23867	50.00
19	5622	1448	143	7213	1401	6116	0	19	7947	7887	-1567	20586	0	0	20586	3277	483	24346	49.98
20	5716	1444	143	7303	1340	6170	0	0	8327	8267	-1500	21115	0	0	21115	3219	465	24799	49.87
21	5617	1307	143	7067	1334	6111	0	0	7423	7430	-1429	20046	0	0	20046	3107	467	23620	49.88
22	5553	1051	141	6745	1381	6104	0	0	7199	7224	-1405	19586	0	0	19586	3008	463	23057	50.03
23	5573	861	142	6576	1452	6152	0	0	6865	6811	-1386	19155	0	0	19155	2944	450	22549	50.03
24	5485	464	142	6091	1376	6179	0	0	6783	6802	-1335	18691	0	0	18691	2869	422	21982	50.02
MUs	132.47	14.56	3.47	150.50	33.75	137.83	0.00	13.14	195.10	193.45	-40.81	477.45	0.00	0.01	477.45	70.37	10.41	558.23	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)132KV MIDC to Sonewadi line over load 506 A/106.00MW.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 13/Sep/2023

Position as on 6.30 Hrs of 14/Sep/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault(converted to Capital overhaul from 00.00Hrs DT.27-07-2023)	20/09/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	Annual Overhaul	18/09/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/09/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
MSPGCL	Koyna Unit 7	80	13/08/2023	09:00		Continued.	Spherical Valve maintenance	20/09/2023
IPP	RPL(AMT) U-4	270	22/08/2023	18:46		Continued.	Generator Stator Earth Fault	01/10/2023
MSPGCL	Uran Unit 6	108	02/09/2023	07:16		Continued.	Gas shortage	
MSPGCL	Uran Unit 7	108	09/09/2023	00:03	13/09/2023	11:10	Gas shortage	
MSPGCL	Nasik Unit 5	210	09/09/2023	01:24	13/09/2023	11:15	Boiler Tube Leakage	13/09/2023
MSPGCL	Chandrapur Unit 9	500	12/09/2023	16:00		Continued.	Boiler Tube Leakage	14/09/2023
MSPGCL	Uran Unit 8	108	13/09/2023	14:03		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 2	210	13/09/2023	20:17	14/09/2023	00:31	Oil Gun Failure	
MSPGCL	Khaparkheda Unit 1	210	14/09/2023	01:30	14/09/2023	03:33	Furnace Pressure High	14/09/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 14/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LR Outages/Trippings							
POLE-2 BASE AC FILTER Z1-Z2(200MVAR) @ PADGHE HVDC	IntraState	13/09/2023	09:45	13/09/2023	10:34	T	Tripped due to bird fault.
400 KV TIEBAY Outages/Trippings							
TIE BAY 418 OF YELWAN CKT - 2 @ AKOLA	IntraState	13/09/2023	13:17	13/09/2023	15:03	T	IT WAS FOUND THAT THE SPARE ICT BUS ISOLATOR (40189A) CAME IN INDUCTION ZONE
400 KV MAINBAY Outages/Trippings							
MAIN BAY (406) OF LINE- 3 @ KORADI 3	IntraState	13/09/2023	09:26	13/09/2023	16:16	PO	Annual Maintenance of CB at Koradi-III SS.
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
PADGHE - TARAPUR CKT - 1	InterState	12/09/2023	09:11	13/09/2023	18:47	PO	Outage requested by NPCIL for implementing single pole auto reclosure lead follower scheme in view of bullet train diversion works./ Pls approve from 11 to 13 Sept as discussed
400 KV AKOLA - AURANGABAD(PG) CKT -1	InterState	13/09/2023	13:17	13/09/2023	16:02	T	Tripped due to Isolator came in Induction zone of main bus-2
400 KV AKOLA - AURANGABAD(PG) CKT -2	InterState	13/09/2023	13:17	13/09/2023	16:04	T	Tripped due to Isolator came in Induction zone of main bus-2
AKOLA - WARDHA(PG) CKT - 2	InterState	13/09/2023	13:17	13/09/2023	14:53	T	Tripped due to Isolator came in Induction zone of main bus-2
AKOLA - WARDHA(PG) CKT - 1	InterState	13/09/2023	13:17	13/09/2023	14:50	T	Tripped due to Isolator came in Induction zone of main bus-2
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of 2Y2 phase Protection CT Of NTPP I (RPL 1)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	09/09/2023	22:51			HT	H/T For load Management.
KHADKA- DEEPNAGAR CKT 2	IntraState	14/09/2023	08:41			PO	For breaker mechanism overhauling work by agency
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	05/09/2023	09:21			PO	1.Replacement of HV CB under LES Scheme.2.A & B Bus PG isolator Maintenance Work.3.ICT HV Side will be in service through TBC.
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	13/09/2023	10:47	13/09/2023	19:15	PO	Rapid Restortion Scheme(RRS) Work
167 MVA SPARE ICT @ TALANDGE	IntraState	13/09/2023	10:54	13/09/2023	17:02	PO	Quarterly Maintenance work
105 MVA SPARE ICT @ AKOLA	IntraState	13/09/2023	11:06	13/09/2023	22:08	PO	Diagnostic testing Tandelta of CT & Isolator maintenance work by agency in r/o Bimco Hyderabad
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	13/09/2023	11:53	13/09/2023	17:58	PO	RRS SCHEME TESTING WORK BY TAKING OUT ONE UNIT AND CONNECT SPARE UNIT AND RESTORE AFTER TESTING WORK.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	13/09/2023	13:17	13/09/2023	14:22	T	Tripped due to Isolator came in Induction zone of main bus-2
400/220/33 KV 315MVA ICT - 1 @ AKOLA	IntraState	13/09/2023	13:17	13/09/2023	14:18	T	Tripped due to Isolator came in Induction zone of main bus-2
220 KV MAINBAY Outages/Trippings							
220 KV BUS COUPLER	IntraState	13/09/2023	08:35	13/09/2023	12:00	PO	CB CRM, TAN

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 14/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV LINE Outages/Trippings							
AAREY - MSETCL BORIVALI CKT - 2	IntraState	15/08/2023	06:02			T	Tripped on Distance Protection
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
EKLAHARE (OCR) - PADGHE	IntraState	09/09/2023	16:45			HT	HT for Load Management
URAN - APTA CKT - 1	IntraState	11/09/2023	11:50	13/09/2023	13:50	PO	Shifting on 220 KV TBC for Breaker Mechanism Overhauling Work by Agency.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	12/09/2023	09:38			HT	H/T for load management
PANDHARPUR - KHANAPUR	IntraState	13/09/2023	09:13	13/09/2023	13:28	PO	1.Broken String Replacement Work at Loc No.209 B Ph 2.Flashover Sting replacement Work at Loc No.213 R Ph 3.Nut Bolt replacement Work at Loc No.240 Y & B Ph
KHAREPATAN -PAWAS LINE	IntraState	13/09/2023	10:27	13/09/2023	11:54	PO	220kV Pawas-Kharepatan Line Bay HVCT Tan Delta Testing work.
PADGHE - JINDAL	IntraState	13/09/2023	10:54	13/09/2023	14:41	PO	1. Hot spot attending work on R Ph wave trap 2. Replacement of Y-Ph Wave Trap
THEUR-PHURSUNGI CKT I	IntraState	13/09/2023	11:08	13/09/2023	14:21	PO	Half yearly maintenance work
CHAKAN PH II - VOLKSWAGEN	IntraState	13/09/2023	11:25	13/09/2023	15:21	PO	SCADA Trial and Commissioning work
TILLARI - AMONA LINE	IntraState	13/09/2023	12:27	13/09/2023	17:29	PO	Maintenance work
BABLESHWAR AHAMADNAGAR-II	IntraState	13/09/2023	13:44	13/09/2023	17:47	PO	CC and CT tan delta testing
PEDAMBE-KALAMBANI(TSS)	IntraState	13/09/2023	14:40	13/09/2023	21:35	PO	For erection of new tower against rusted tower in lote (P) MIDC Area at loc no .92, 94, 95, 96, 97, 98, 99 , 100, 101
ADLABS - PEDAMBE	IntraState	13/09/2023	14:55	13/09/2023	19:34	PO	For erection of new tower against rusted tower in lote (P) MIDC Area at loc no .92, 94, 95, 96, 97, 98, 99, 100, 101
LAMBOTI - VAIRAG	IntraState	13/09/2023	17:32	13/09/2023	20:00	PO	FOR Motorized Isolator alignment work of 89 D isolator & Earth switch by OEM representative.
LAMBOTI - VAIRAG	IntraState	13/09/2023	17:32	13/09/2023	20:00	PO	Outage is required for Quarterly Maintenance
AUXILARY BUS @ VAIRAG	IntraState	13/09/2023	17:32	13/09/2023	20:00	PO	Outage is required for Quarterly Maintenance
MAIN BUS @ VAIRAG	IntraState	13/09/2023	17:32	13/09/2023	20:00	PO	Outage is required for Quarterly Maintenance
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 150MVA ICT - 1 @ MALINAGAR	IntraState	13/09/2023	09:08	13/09/2023	20:25	PO	Outage is required for OLTC OVERHAULLING WORK
220/132 KV 200MVA ICT 2 @ JALNA	IntraState	13/09/2023	11:48	13/09/2023	16:24	PO	DIAGONISIS TESTING OF ICT
220/33 KV 50 MVA PTR 1 @ BOISAR-II	IntraState	13/09/2023	21:38			HT	Problem arise during tap changing operation , Tap was not getting changed ,When tried manually it was found jammed. Hence HT from HV & LV Both .
220 KV BUSBAR Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 13/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 14/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
MAIN BUS SECTION - 2 @ URSE	IntraState	13/09/2023	13:12	13/09/2023	16:00	PO	Testing work of 220kV PT-2(CVT) bay at 220kV Urse SS.
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	13/09/2023	17:04			HT	H/T AT PENCH END SYSTEM CONSTRAINT
KANHAN-MANSAR	IntraState	13/09/2023	11:16	13/09/2023	16:59	PO	Routine Maint. Work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
BHIRA (T) - KHOPOLI 2	IntraState	13/09/2023	09:48	13/09/2023	15:15	PO	OPGW stringing in between 172 & 237

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage