

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 13/Oct/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	112.535	1547.278	1) Gujrat	11.356	135.415
2) Hydro	8.412	103.102	2) Madhya Pradesh	8.377	94.202
3) Gas	2.185	29.140	3) Chattisgarh	5.490	71.950
Total MSPGCL	123.132	1679.520	4) Maharashtra	154.574	2147.063
B) 1) APMIL	60.082	639.389	5) Goa (Amona)	-1.264	-16.664
2) JSWEL	15.019	214.272	Total	178.533	2431.966
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.530	425.899
4) RPL(AMT)	23.434	299.003	b) Mumbai Drawl	38.059	474.039
5) SWPGPL	7.788	92.569	c) MSEDCL Bilateral *	64.136	871.898
6) Other IPP	7.943	97.313	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.525	425.888
C) 1) TPCL Thermal	5.210	129.212	Include PX	0.000	0.000
2) TPCL Hydro	8.807	53.004	Standby	0.005	0.012
3) TPCL Gas	2.096	30.702	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.495	123.892	1) MSEDCL	386.096	5134.591
D) STATE			2) Mumbai Discoms	65.667	810.825
1) Thermal	243.506	3142.928	3) Other Discoms	9.298	119.558
(A1+C1+C4+(B1-B6))			TOTAL STATE	461.061	6064.974
2) Hydro	17.219	156.106			
3) Gas	4.281	59.842			
4) Wind	7.773	152.003			
6) SOLAR	9.749	122.153			
TOTAL STATE	282.528	3633.032			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4595	4840	5035	4633
MSPGCL Hydro	209	472	1444	182
MSPGCL Gas	91	91	90	92
MSPGCL Total Generation	4895	5403	6569	4907
Central Sector Receipt	8357	7685	7445	6226
WIND	237	239	580	221
CPP / IPP Thermal	4751	4982	5797	4660
CPP / IPP Gas	0	0	0	0
SOLAR	1074	95	0	0
Exchange with Mumbai	-1914	-1861	-1816	-920
MSEDCL DEMAND MET	16968	16119	18146	14792
Load Shedding	0	0	0	0
MSEDCL DEMAND	16968	16119	18146	14792
TPCL GENERATION	695	684	699	638
AEML GENERATION	493	491	468	476
MUMBAI DEMAND	3102	3036	2983	2034
OTHER DISCOM DEMAND	432	424	429	302
STATE DEMAND MET	20502	19579	21558	17128
STATE DEMAND	20502	19579	21558	17128
Frequency (Hz)	50.04	49.98	50.02	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 13.04 Hrs	49.77 Hz at 17.57 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 13/Oct/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.84	13.77	190	125
Unit 7	0.00	0.00	0	0
Unit 8	0.00	123.66	0	0
Unit 9	0.00	37.66	0	0
Unit 10	8.76	127.73	390	351
Total	12.60	302.82		
Bhusawal				
Unit 3	2.86	28.08	140	110
Unit 4	7.58	104.33	385	270
Unit 5	8.88	105.96	445	280
Total	19.32	238.36		
Parli				
Unit 6	4.36	52.16	230	147
Unit 7	3.74	52.11	173	130
Unit 8	0.12	31.38	80	0
Total	8.22	135.64		
Chandrapur				
Unit 3	3.07	39.13	145	122
Unit 4	2.86	34.10	135	103
Unit 5	6.60	87.73	320	235
Unit 6	7.03	95.49	350	222
Unit 7	7.04	97.29	320	277
Unit 8	7.78	13.62	421	274
Unit 9	8.41	111.30	439	280
Total	42.79	478.67		
Paras				
Unit 3	4.55	50.16	214	135
Unit 4	0.00	0.00	0	0
Total	4.55	50.16		
Khaparkheda				
Unit 1	2.70	37.33	130	90
Unit 2	2.57	36.84	125	90
Unit 3	3.18	45.38	147	120
Unit 4	3.10	41.83	150	108
Unit 5	7.64	104.18	425	270
Total	19.18	265.56		
Nasik				
Unit 3	0.00	25.32	0	0
Unit 4	2.97	40.50	148	110
Unit 5	2.89	10.25	149	103
Total	5.87	76.07		
Uran				
All Units	2.18	29.14	93	88
Total	2.18	29.14		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.59	7.71	25	24
Total	0.59	7.71		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.38	27.04	515	40
Stage 4	1.48	22.30	754	0
Stage 3	0.97	12.32	240	0
Total	4.84	61.66		
Hydro				
KDPH	0.14	3.02	18	0
VTRNA	0.00	1.82	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.38	3.42	80	0
SMLHY_PTN	2.46	23.23	107	99
GHATGHAR	0.00	2.22	0	0
Total	2.98	33.73		
Wind				
Total	7.77	152.00	0	0
Total	7.77	152.00		
CPP				
APML(Mus)	60.08	639.39	0	0
JSWEL(Mus)	15.02	214.27	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	23.43	299.00	0	0
SWPGPL-Mus	7.79	92.57	0	0
Other(Mus)	7.94	97.31	0	0
Total	114.27	1342.55		
SOLAR				
Total	9.75	122.15	0	0
Total	9.75	122.15		
Tata				
Trombay 5	0.00	80.46	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.12	17.07	68	35
Trombay 7B	0.97	13.64	52	33
TATA Hydro	8.81	53.00	408	292
Trombay 8	5.21	48.75	234	168
Total	16.11	212.92		
AEMIL				
DTPS U-1&2	11.50	123.89	499	413
Total	11.50	123.89		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	112.54	1547.28	MSPGCL Total	123.13	1679.52
			MSPGCL Thml+Gas	114.72	1576.42	Koyna 1,2 & 4 Total	3.87	49.34
			MSPGCL Hydro	8.41	103.10	State Total	282.53	3633.03

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 13/Oct/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4772	187	92	5051	187	4584	0	0	6865	6480	-1165	14775	0	14775	2404	362	17541	50.01
2	4600	182	92	4874	210	4559	0	0	6643	6374	-1043	14653	0	14653	2228	321	17202	50.03
3	4445	182	92	4719	203	4567	0	0	6393	6506	-968	14735	0	14735	2107	292	17134	50.00
4	4633	182	92	4907	221	4660	0	0	6409	6226	-920	14792	0	14792	2034	302	17128	50.00
5	4707	187	93	4987	227	4740	0	0	6598	6766	-912	15483	0	15483	2043	325	17851	50.01
6	5127	367	92	5586	254	4912	0	0	6775	7146	-991	16559	0	16559	2134	348	19041	50.03
7	5207	292	92	5591	263	5128	0	28	7827	7961	-1134	17466	0	17466	2277	371	20114	50.02
8	5084	187	92	5363	227	5342	0	292	8360	8294	-1314	17816	0	17816	2475	388	20679	50.05
9	4906	205	92	5203	198	4840	0	653	8328	8272	-1627	17106	0	17106	2793	433	20332	50.02
10	4595	209	91	4895	237	4751	0	1074	8731	8357	-1914	16968	0	16968	3102	432	20502	50.04
11	4314	219	90	4623	257	4312	0	1292	8848	8804	-2161	16697	0	16697	3316	430	20443	50.00
12	4343	236	88	4667	135	4167	0	1451	7966	8034	-2250	15783	0	15783	3381	421	19585	49.99
13	4273	192	91	4556	132	4163	0	1446	7656	7651	-2189	15350	0	15350	3337	409	19096	50.05
14	4235	177	90	4502	120	4004	0	1272	7431	7811	-2061	15233	0	15233	3215	415	18863	50.10
15	4432	312	90	4834	184	3896	0	1018	7628	7879	-1933	15489	0	15489	3100	389	18978	49.95
16	4548	172	91	4811	227	4552	0	723	7740	7440	-1948	15397	0	15397	3062	408	18867	49.95
17	4378	167	91	4636	214	4749	0	403	8100	8166	-1870	15892	0	15892	3041	406	19339	49.97
18	4840	472	91	5403	239	4982	0	95	7906	7685	-1861	16119	0	16119	3036	424	19579	49.98
19	5084	1633	91	6808	377	5667	0	2	7204	7344	-1870	17909	0	17909	3058	419	21386	49.97
20	5035	1444	90	6569	580	5797	0	0	7306	7445	-1816	18146	0	18146	2983	429	21558	50.02
21	4941	354	90	5385	654	5403	0	0	7892	7355	-1672	16706	0	16706	2830	419	19955	50.03
22	4737	331	90	5158	682	4845	0	0	7203	7311	-1532	16065	0	16065	2667	399	19131	50.00
23	4752	330	91	5173	933	4820	0	0	6699	6634	-1477	15695	0	15695	2558	388	18641	49.97
24	4547	193	91	4831	812	4826	0	0	6373	6592	-1431	15263	0	15263	2486	367	18116	50.00
MUs	112.53	8.41	2.18	123.13	7.77	114.27	0.00	9.75	178.88	178.53	-38.06	386.10	0.00	386.10	65.67	9.30	461.06	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 13/Oct/2022

Position as on 6.30 Hrs of 14/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	22/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/10/2022
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	12/10/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	27/09/2022	17:11		Continued.	Gas shortage	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High	12/10/2022
MSPGCL	Nasik Unit 3	210	08/10/2022	20:05		Continued.	PA FAN 3B motor replacement work Unit # 3 Nashik is under tolling from 08:00 hrs of 10/10/2022 & is available (as PA FAN 3B work is completed)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	18/10/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	18/10/2022
MSPGCL	Koradi Unit 9	660	10/10/2022	07:43		Continued.	Boiler Tube Leakage	13/10/2022
MSPGCL	Parli Unit 8	250	11/10/2022	00:01	13/10/2022	22:08	Boiler Tube Leakage	14/10/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
IPP	IEPL Unit 1	270	11/10/2022	22:09	13/10/2022	02:12	Generator Protection operated	
TPC-G	Trombay 5	500	12/10/2022	03:34	14/10/2022	07:00	Economizer Tube Leakage.	14/10/2022
MSPGCL	Koradi Unit 8	660	12/10/2022	18:53		Continued.	Boiler Tube Leakage	16/10/2022
MSPGCL	Parli Unit 7	250	14/10/2022	04:24		Continued.	Boiler Tube Leakage	17/10/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 14/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BREAKER (411) OF KORADI CKT 1 AND STATION TF-2 @ NANDGAONPETH	InterState	13/10/2022	11:42			EO	SF6 Gas Replenishment in Tie breaker (411) due to low SF6 Gas Alarm is coming intermittently and Density Monitor level is showing near alarm value.
TIE BAY (402) OF KALA CKT - 2 @ KUDUS	IntraState	13/10/2022	12:32	13/10/2022	17:24	PO	Annual Maintenance of bays equipment & Diagnostics Testing Work
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (409) OF AKOLA-1 CKT-1 @ AKOLA 2	IntraState	13/10/2022	10:08	13/10/2022	18:55	PO	Annual Maintenance of Bay Equipment
MAIN BAY (403) OF FUTURE LINE @ KUDUS	IntraState	13/10/2022	12:32	13/10/2022	17:26	PO	Annual Maintenance of bays equipment & Diagnostics Testing Work
400 KV LINE Outages/Trippings							
KARAD - LONIKAND I	IntraState	10/10/2022	09:28			PO	1. Errection of 315A & 316 in line tower. 2. Loc no. 315 to 315A S/C stringing. 3. Loc no. 315A to 33(D/C LILO tower) stringing. 4. Loc No. 316 to 33(D/C LILO tower) stringing. 5. Dismantling of existing in line tower at loc no 316.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	11/10/2022	08:52			HT	H/T FOR LOAD MANAGEMENT
JAIGAD - KARAD CKT - 2	IntraState	12/10/2022	04:09	13/10/2022	10:11	HT	Overvoltage
PARLI-SOLAPUR (LAMBOTI)	IntraState	12/10/2022	21:07	13/10/2022	15:14	T	TRIPPED ON DISTANCE PROTECTION
PADGHE - KALWA CKT - 1	IntraState	13/10/2022	00:19	13/10/2022	04:21	EO	For 1) Attending Hot spot on Y ph CT lineside Temp 113 deg 2) C bus Bph BPI clamp 158 deg 3) Rph CB B bus side 104deg 4) Rph B bus PG isolator jaw 134deg 5) C bud Yph PG isolator 89deg
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	13/10/2022	05:53	13/10/2022	18:52		Disc Insulator string Replacement by Long Rod Porcelain string
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	13/10/2022	07:20	13/10/2022	16:45	PO	Replacement of Disc Insulator Strings by Long Rod Porcelain strings
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	13/10/2022	11:57	13/10/2022	17:11	PO	Tan-d of 408 & 409 CT's, Routine relay testing & bay maintenance works
JAIGAD - KARAD CKT - 2	IntraState	14/10/2022	00:23			HT	H/T DUE TO O/V
AKOLA - KHADKA (BHUSAWAL)	IntraState	14/10/2022	06:01			PO	For reconnection of B ph isolator arm after repairing/ brazing and fabrication of its jaw
KORADI II - KORADI III CKT - 2	IntraState	14/10/2022	07:04			PO	Refixing or tightening of missing/loose nublts as required on various line hardwares observed during the patrolling
400 KV ICT Outages/Trippings							
400/220/33 KV 500 MVA ICT - 2 @ JEJURI	IntraState	13/10/2022	10	13/10/2022	19:41	PO	Annual bay Maintenance and Testing Work.
220 KV MAINBAY Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 13/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 14/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
METERING BAY (CONSUMER) - 2 @ SERUM	IntraState	13/10/2022	10:18	13/10/2022	17:45	PO	Line differential relay retrofitting work and Main bus isolator maintenance work
220 KV LINE Outages/Trippings							
BOISAR - VERSOVA	IntraState	06/10/2022	08:15			PO	Bunching of lines at location no.SS 82 to facilitate the following project work: NHSRCL project: Relocation of existing Tr. Towers and lines at Vasai area - Tower no SS 221 & SS 223. DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	06/10/2022	08:22			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:NHSRCL project: Relocation of existing Tr. Towers and lines at Vasai area - Tower no SS 221 & SS 223.DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
EKLAHARE (OCR) - PADGHE	IntraState	08/10/2022	22:52			HT	For load management
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	13/10/2022	08:21	13/10/2022	22:08	HT	H/T FOR LOAD MANAGEMENT
ADLABS - PEDAMBE	IntraState	13/10/2022	08:52	13/10/2022	18:35	PO	for attending red hot spot between Y-phase CT to line side isolator jumper near isolator clamp & bay R/M work.
TALANDGE - SAWANTWADI	IntraState	13/10/2022	09:14	13/10/2022	17:33	PO	Chemical cleaning of insulator string from loc.No.1-25 & 260-275
BABLESHWAR -BHENDA	IntraState	13/10/2022	09:23	13/10/2022	11:52	EO	Flashover string replacement loc 30 R ph
MAGAR PATTI CITY- SERUM	IntraState	13/10/2022	10:17	13/10/2022	20:51	PO	Line differential relay retrofitting work main bus isolator maintenance work.
HALF MAIN BUS - 1 @ SERUM	IntraState	13/10/2022	10:18	13/10/2022	17:45	PO	Line differential relay retro fitting work and main bus isolator maintenance work.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	13/10/2022	10:34	13/10/2022	13:35	EO	Attending red hot of ;29D 29C side B phase (146 deg);Wave trap R phase (105 deg) and (80 deg).
BOMBAY DYEING - SAHARA	IntraState	13/10/2022	12:14	13/10/2022	17:16	T	Tripped on distance protection
BABHALESHWAR - DEOGAON RANGARI	IntraState	13/10/2022	12:19	13/10/2022	17:00	EO	Flashover string replacement loc 30 R ph
BOISAR II - TARAPUR	IntraState	13/10/2022	12:48	13/10/2022	17:50	PO	Replacement of Rusted Hardware work under scheme at Loc No.28 To 50
BOISAR II - TARAPUR	IntraState	13/10/2022	12:48	13/10/2022	17:50	PO	Bay Maintenance works.
NERLE- POPHALI	IntraState	13/10/2022	16:11	13/10/2022	18:50	T	Tripped on distance protection
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 13/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 14/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33KV 50MVA PTR -2 @ KURKUMBH	IntraState	13/10/2022	09:00	13/10/2022	16:27	PO	Attending transformer oil leakage.
PT BAY NO.1 @ SERUM	IntraState	13/10/2022	10:18	13/10/2022	17:45	PO	Line differential relay retrofitting work and Main bus isolator maintenance work
220/22 KV 50 MVA PTR 2 @ MAHAD	IntraState	13/10/2022	10:19	13/10/2022	12:58	PO	Hotspot attending work& diagnostic testing work..
220/100 KV 200 MVA ICT 1 @ KOLSHET	IntraState	13/10/2022	10:40	13/10/2022	18:15	PO	1) ICT-1 DM Box replacement work & Diverter mechanism maintenance work. 2) Diagnostic Testing Work 3) CTR Maintenance work 4) Bay maintenance work 5) RMW
220/22 KV 50 MVA PTR 3 @ RANJANGAON	IntraState	13/10/2022	11:44	13/10/2022	15:11	PO	For Attending Hot spot & General bay maintenance
220/110 kV 200 MVA ICT 2 @ MUDSHINGI	IntraState	13/10/2022	13:40	13/10/2022	17:55	T	Tripped on OSR
220/22KV 50MVA PTR 2 @ RANJANGAON	IntraState	13/10/2022	15:45	13/10/2022	17:26	PO	For Attending Hot spot & General bay maintenance
220/33KV 50MVA PTR 1 @ KURKUMBH	IntraState	13/10/2022	16:30	13/10/2022	21:21	PO	Attending transformer oil leakage from inspection windows on top plate.
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	14/10/2022	03:44			T	TRIPPED ON DISTANCE PROTECTION
DHARANI - NEPANAGAR	InterState	14/10/2022	04:35	14/10/2022	05:08	T	TRIPPED ON DISTANCE PROTECTION
KANHAN-PENCH	IntraState	14/10/2022	03:44	14/10/2022	04:44	T	TRIPPED ON DISTANCE PROTECTION
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage