

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 14/Jan/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	140.319	2053.048	1) Gujrat	-0.843	-88.290
2) Hydro	10.893	154.908	2) Madhya Pradesh	3.451	77.126
3) Gas	5.609	59.463	3) Chattisgarh	5.010	81.010
Total MSPGCL	156.821	2267.419	4) Maharashtra	131.436	1791.485
B) 1) APLM	68.461	965.320	5) Goa (Amona)	-1.166	-19.678
2) JSWEL	14.824	193.118	Total	137.888	1841.653
3) VIPL	0.000	0.000	a) Mumbai Schedule	20.262	299.844
4) RPL(AMT)	25.218	367.953	b) Mumbai Drawl	22.490	324.008
5) SWPGPL	5.980	70.465	c) MSEDCL Bilateral *	56.416	761.929
6) Other IPP	37.579	542.039	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	20.262	299.722
C) 1) TPCL Thermal	9.398	139.436	Include PX	0.000	0.000
2) TPCL Hydro	4.127	57.536	Standby	0.000	0.123
3) TPCL Gas	0.000	9.340	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.757	127.769	1) MSEDCL	424.931	5996.945
D) STATE			2) Mumbai Discoms	44.772	658.088
1) Thermal	310.536	4459.148	3) Other Discoms	8.206	127.086
(A1+C1+C4+(B1-B6))			TOTAL STATE	477.909	6782.119
2) Hydro (A2+C2)	15.020	212.444			
3) Gas (A3+B7+C3)	5.609	68.803			
4) Wind	3.635	114.935			
6) SOLAR	5.221	85.137			
TOTAL STATE	340.021	4940.467			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6328	6031	5961	4940
MSPGCL Hydro	980	499	474	310
MSPGCL Gas	243	232	226	246
MSPGCL Total Generation	7551	6762	6661	5496
Central Sector Receipt	8337	7918	5271	4496
WIND	115	88	72	279
CPP / IPP Thermal	6887	6809	6659	5492
CPP / IPP Gas	0	0	0	0
SOLAR	692	789	4	0
Exchange with Mumbai	-1185	-1292	-1106	-866
MSEDCL DEMAND MET	22033	20734	17177	14576
Load Shedding	0	0	0	0
MSEDCL DEMAND	22033	20734	17177	14576
TPCL GENERATION	707	641	752	386
AEML GENERATION	493	426	310	324
MUMBAI DEMAND	2385	2359	2168	1576
OTHER DISCOM DEMAND	364	340	384	321
STATE DEMAND MET	24782	23433	19729	16473
STATE DEMAND	24782	23433	19729	16473
Frequency (Hz)	49.99	50.04	49.92	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 13:02 Hrs	49.75 Hz at 09:33 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 14/Jan/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.31	38.04	170	120
Unit 7	0.00	0.00	0	0
Unit 8	12.42	188.16	619	412
Unit 9	11.94	152.59	561	410
Unit 10	10.88	161.07	535	390
Total	38.54	539.86		
Bhusawal				
Unit 3	3.05	35.26	150	115
Unit 4	0.00	100.73	0	0
Unit 5	8.08	116.99	410	280
Total	11.14	252.98		
Parli				
Unit 6	4.05	52.81	220	147
Unit 7	3.46	52.85	198	115
Unit 8	3.98	55.47	224	143
Total	11.50	161.13		
Chandrapur				
Unit 3	3.37	36.57	164	118
Unit 4	3.25	46.24	159	120
Unit 5	7.68	108.70	360	283
Unit 6	7.93	119.27	390	282
Unit 7	5.40	62.15	310	0
Unit 8	9.45	136.40	447	282
Unit 9	9.15	132.70	455	275
Total	46.22	642.03		
Paras				
Unit 3	4.45	60.27	240	141
Unit 4	2.76	56.80	230	0
Total	7.21	117.07		
Khaparkheda				
Unit 1	3.04	32.17	140	115
Unit 2	0.00	0.00	0	0
Unit 3	3.65	48.71	190	126
Unit 4	3.54	47.00	188	119
Unit 5	9.26	134.12	460	280
Total	19.48	262.00		
Nasik				
Unit 3	3.16	38.99	169	120
Unit 4	0.00	18.28	0	0
Unit 5	3.07	20.70	171	114
Total	6.23	77.98		
Uran				
All Units	5.61	59.46	255	163
Total	5.61	59.46		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	4.19	25	0
Total	0.06	4.19		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.84	31.70	240	30
Stage 4	0.92	17.71	400	0
Stage 3	0.64	11.28	160	0
Total	3.39	60.69		
Hydro				
KDPH	0.43	2.41	18	18
VTRNA	0.70	6.69	60	0
TILLARI	0.52	7.31	58	0
BHIRA T.R.	0.24	3.51	57	0
SMLHY_PTN	5.60	74.30	255	216
GHATGHAR	0.00	0.00	0	0
Total	7.50	94.22		
Wind				
Total	3.64	114.94	0	0
Total	3.64	114.94		
CPP				
APML(Mus)	68.46	965.32	0	0
JSWEL(Mus)	14.82	193.12	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.22	367.95	0	0
SWPGPL-Mus	5.98	70.46	0	0
Other(Mus)	37.58	542.04	0	0
Total	152.06	2138.90		
SOLAR				
Total	5.22	85.14	0	0
Total	5.22	85.14		
Tata				
Trombay 5	6.29	91.47	280	255
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	5.17	0	0
Trombay 7B	0.00	4.17	0	0
Trombay 8	3.11	47.97	131	126
TATA Hydro	4.13	57.54	364	0
Total	13.52	206.31		
AEMIL				
DTPS U-1&2	8.76	127.77	493	310
Total	8.76	127.77		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	140.32	2053.05	MSPGCL Total	156.82	2267.42
			MSPGCL Thml+Gas	145.93	2112.51	Koyna 1,2 & 4 Total	2.75	49.42
			MSPGCL Hydro	10.89	154.91	State Total	340.02	4940.47

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 14/Jan/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4995	282	244	5521	274	5618	0	0	4748	4662	-702	15051	0	15051	1439	322	16812	49.98
2	4986	274	244	5504	221	5593	0	0	4744	4613	-634	15015	0	15015	1350	282	16647	49.99
3	5165	277	255	5697	247	5593	0	0	4717	4691	-568	15388	0	15388	1287	272	16947	49.99
4	5411	283	243	5937	173	5579	0	0	4713	4645	-542	15520	0	15520	1265	272	17057	49.98
5	5697	279	244	6220	192	5620	0	0	4834	4757	-563	15925	0	15925	1289	301	17515	49.98
6	5791	278	254	6323	186	6338	0	0	4976	4896	-642	16771	0	16771	1383	330	18484	49.92
7	6131	359	244	6734	208	6789	0	0	5130	5226	-702	17897	0	17897	1505	358	19760	49.98
8	6573	700	243	7516	185	6908	0	45	5357	5693	-716	19270	0	19270	1706	361	21337	50.01
9	6728	971	253	7952	124	6884	0	202	6325	6204	-912	20075	0	20075	2013	379	22467	49.99
10	6703	792	244	7739	95	7335	0	416	7506	7261	-1039	21436	0	21436	2246	371	24053	49.88
11	6328	980	243	7551	115	6887	0	692	8263	8337	-1185	22033	0	22033	2385	364	24782	49.99
12	6266	556	249	7071	98	6817	0	777	8539	8482	-1272	21608	0	21608	2405	365	24378	50.05
13	6031	499	232	6762	88	6809	0	789	8036	7918	-1292	20734	0	20734	2359	340	23433	50.04
14	6415	433	230	7078	84	6813	0	705	7045	6874	-1209	20011	0	20011	2188	333	22533	50.09
15	6141	404	233	6778	86	6682	0	671	7295	6939	-1208	19610	0	19610	2137	338	22085	50.00
16	5860	401	233	6494	79	6781	0	529	7190	6749	-1186	19093	0	19093	2101	353	21547	49.96
17	6301	404	164	6869	116	6716	0	307	6093	5476	-1127	17996	0	17996	2078	361	20435	49.98
18	5885	408	163	6456	59	6039	0	85	5545	5587	-1023	16818	0	16818	2089	385	19292	50.02
19	5961	474	226	6661	72	6659	0	4	5356	5271	-1106	17177	0	17177	2168	384	19729	49.92
20	6137	415	226	6778	91	6796	0	0	4903	4475	-1021	16732	0	16732	2150	387	19269	49.99
21	5664	352	227	6243	158	6263	0	0	5032	4663	-957	16015	0	16015	2033	355	18403	49.97
22	5128	452	237	5817	199	5532	0	0	5031	5052	-1025	15234	0	15234	1899	341	17474	50.00
23	5082	310	232	5624	206	5519	0	0	4880	4921	-993	14946	0	14946	1721	331	16998	50.01
24	4940	310	246	5496	279	5492	0	0	4848	4496	-866	14576	0	14576	1576	321	16473	50.02
MUs	140.32	10.89	5.61	156.82	3.64	152.06	0.00	5.22	141.11	137.89	-22.49	424.93	0.00	424.93	44.77	8.21	477.91	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 14/Jan/2022

Position as on 6.30 Hrs of 15/Jan/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Bhusawal Unit 4	500	13/01/2022	00:00		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	04/01/2022	19:40		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	04/01/2022	20:00		Continued.	Gas shortage	
MSPGCL	Nasik Unit 4	210	07/01/2022	22:00		Continued.	CONDENSER TUBE LEAKAGE	
MSPGCL	Koyna Unit 6	80	13/01/2022	05:40	14/01/2022	20:20	heavy oil leakage at bypass valve of spherical valve	
IPP	SWPGL U-2	135	13/01/2022	08:00		Continued.	ID Fan Problem	
MSPGCL	Chandrapur Unit 7	500	14/01/2022	09:51	14/01/2022	13:09	TURBINE OVERSPEED.	
MSPGCL	Paras Unit 4	250	14/01/2022	15:05		Continued.	Furnace Pressure High	
MSPGCL	Uran Unit 5	108	14/01/2022	16:15	14/01/2022	17:27	FOR BACK CHARGING ACTIVITY.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 15/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BREAKER (411) OF KORADI CKT 1 AND STATION TF-2 @ NANDGAONPETH	InterState	12/01/2022	05:54			PO	Circuit Breaker SF6 gas pressure getting low in 'B' phase of Tie breaker (411).Leakage point is identified. Hence, rectification of issue is essential. Trials shall be taken after NRV replacement and gas filling work.
400 KV LINE Outages/Trippings							
PADGHA - BOISAR (PG)	InterState	15/01/2022	04:01			T	TRIPPED ON OVER VOLTAGE
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	21/12/2021	12:35			HT	HAND TRIPPED TO CONTROL LINE LOADING OF 400KV TALEGAON-KALWA AND 400KV TALEGAON - KHARGHAR CKT
400 KV WALUJ (400 KV) - BABHALESHWAR CKT	IntraState	04/01/2022	15:46			PO	Height raising work of 400kv Waluj-Babhleshwar line atLoc No. 239 to 240 crossing to Samruddhi Highway i.e. 1. Dismantling of loc No. 239,240,241 (all DA+01) 2. Erection of new towers at loc No.239, 240,241 (All DD+9) 3. Restraining between Loc No. 237 to 242
KORADI - KHAPERKHEDA CKT - 1	IntraState	10/01/2022	10:38	14/01/2022	19:28	PO	Retrofitting of Distance Relay I & II under MTAMC Project
JAIGAD - KARAD CKT - 2	IntraState	13/01/2022	21:21	14/01/2022	09:25	HT	HT OV
PADGHE - NAGOTHANE CKT - 2	IntraState	14/01/2022	00:04	14/01/2022	08:30	HT	H/T For Over Voltage.
LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	IntraState	14/01/2022	09:13	14/01/2022	21:50	PO	03 Nos of Master Trip replay replacement work under MTAMC Project.
AKOLA - KHADKA (BHUSAWAL)	IntraState	14/01/2022	12:51	14/01/2022	17:20	EO	For reconnection of R -ph IPS tube from Auxiliary PG isolator to Line isolator along with R-ph line isolator assembly.
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	14/01/2022	16:21	14/01/2022	19:36	EO	for replacement of NRV of main and standby Compressor of Main Bay CB 412 due to air leakage through Non return valve
JAIGAD - KARAD CKT - 1	IntraState	14/01/2022	20:19			HT	H/T For Overvoltage.
PADGHE - KALWA CKT - 1	IntraState	15/01/2022	04:01	15/01/2022	07:35	T	TRIPPED ON OVER VOLTAGE
220 KV LINE Outages/Trippings							
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18			PO	1) 220kv PGCIL (Boisar)- Borivali line tapping will be done to 220kv Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kv D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kv PadghaNalasopara- Vasai Tap line and 220kv Kamba Vasai Line between location no 8 to 14.
PADGHE - TEMGHAR - 2	IntraState	02/01/2022	23:25			HT	conductor replacement work
TATA BORIVLI MSETCL BORIVLI - 4	IntraState	07/01/2022	11:25			PO	For shifting to New GIS at Tata Borivali

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 15/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
AAREY - MSETCL BORIVALI CKT - 1	IntraState	07/01/2022	11:59			T	differential prot optd,Y=33.29 kA,dist-3.2 km from Borivali
BOISAR II - BOISAR (PG) CKT - 1	IntraState	10/01/2022	09:51			PO	REPLACEMENT OF old CONDUCTOR by HTLS CONDUCTOR
TROMBAY MSETCL TIE - 2	IntraState	13/01/2022	10:57	14/01/2022	20:40	PO	R/M and CT, CVT Testing work at both ends
BABHALESHWAR - UTECH SUGAR	IntraState	13/01/2022	18:28	14/01/2022	01:29	PO	220 Kv Babhaleshwar UTECH Ckt for erection of the 220 kv SPND +3 between loc no 17 and 18 .
TEMGHAR - KALWA	IntraState	13/01/2022	23:10				As safety precaution for the replacement of CB pole of 220/22 kV, 50MVA PTR-2
CHAKAN - CHINCHWAD 2	IntraState	14/01/2022	00:23	14/01/2022	06:44	PO	Attending Hot Spots at R ph CT (P1 terminal) 165 μ C , R ph CT (P2 terminal) 108 μ C Y ph CT (P2 terminal) 95.4 ,Y ph CB Bottom 100 μ C & Replacement of Y ph LA
CHALISGAON -BABHALESHWAR	IntraState	14/01/2022	09:06	14/01/2022	13:01	EO	While monkey petrolling found R Ph. disc flashover at loc.52 string String replacement work with New
JEJURI-PHURSUNGI 2	IntraState	14/01/2022	09:25	14/01/2022	15:17	PO	Replacement of 03 nos. of High tan delta value CTs with new Mehru make CTs
MALEGAON - SAYNE	IntraState	14/01/2022	10:11	14/01/2022	13:48	PO	For Diagnostic testin work
ADLABS - PEDAMBE	IntraState	14/01/2022	10:25	14/01/2022	19:17	PO	BT tower nut bolt tightening work and other line maint work
MUMEWADI -HALKARNI 1 LINE	IntraState	14/01/2022	10:33	14/01/2022	17:54	PO	For conversion of SSN To DSN at loc. No. 143, 225,226
GT - 3 @ EKLARE (GCR)	IntraState	14/01/2022	11:48			EO	. Shifting of 220kV GT-3 on TBC (in view to attend air leakage from moisture release valve of the 220kV GT-3 Own Circuit Breaker) will be carried out on Dt.14.01.2022 @ 11:30Hrs.
MALINAGAR - TEMBHURNI	IntraState	14/01/2022	13:11	14/01/2022	16:11	PO	Outage is required for For Attending hot Spot
AAREY - AEML BORIVALI	IntraState	14/01/2022	16:15	14/01/2022	17:23	T	Kite Fault
PADGHE - NALASOPARA - VASAI (T)	IntraState	14/01/2022	17:35	14/01/2022	19:44	T	Zone 1 R-Y ph
BABHALESHWAR - UTECH SUGAR	IntraState	14/01/2022	18:21	15/01/2022	02:25	PO	29D & 29C isolator servicing and alignment
TROMBAY SALSETTE LINE-2	IntraState	14/01/2022	23:29	15/01/2022	06:23	PO	FOR METRO-4 WORK
LONAND-BOTHE	IntraState	15/01/2022	00:57	15/01/2022	01:24	T	TRIPPED ON DIST.PRTN
HALKARNI-MAHALAXMI LINE	IntraState	15/01/2022	09:26			PO	Replacement faulty polymer insulator at location No.2 & 3
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/22 KV 50 MVA PTR 2 @ KALWA	IntraState	12/01/2022	09:17	14/01/2022	17:50	PO	CB MECHANISM & POLE OUERHAVLING
220/132KV 100MVA ICT 1@ PETH	IntraState	13/01/2022	09:30			PO	Oil filtration & oil leakage attending work by replacement of gaskets of bushing, PRV & inspection windows.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 14/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 15/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22 KV 50 MVA PTR 1 @ MAHAPE	IntraState	14/01/2022	09:04	14/01/2022	17:41	PO	Yes. 22KV feeders on T/F-I will be diverted on T/F-II, T/F-IV & T/F-III operating in parallel during the outage period. Load of some 22KV feeders will be diverted on other MSETCL sub-station in consent with MSEDCL company/Torrent Power Ltd Company.
220/22-22 KV 50 MVA PTR 3 @ ANANDNAGAR	IntraState	14/01/2022	10:00	14/01/2022	17:25	PO	Attending oil leakage from Transformer bushing and HV CB test of CRM, Timing & IR
220/110 kV 200 MVA ICT 2 @ MUDSHINGI	IntraState	14/01/2022	10:05	14/01/2022	18:45	PO	Quarterly maint. Work
220/22 KV 50 MVA PTR 3 @ KAMBA	IntraState	14/01/2022	12:32	14/01/2022	16:00	EO	Hot spot attending work on R PH HV CT palm
220/110 kV 200 MVA ICT 3 @ MUDSHINGI	IntraState	15/01/2022	09:15			PO	Quarterly maint. Work & replacement of damaged /obsolete parts & testing of CTR system by agency
132 KV LINE Outages/Trippings							
KANHAN-PENCH	IntraState	15/01/2022	09:19			EO	Outage required for replacement Flashed over string at various locations

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage