

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 14/Mar/2016 MONDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 97.534         | 1396.493        | 1) Gujrat                      | -3.666         | -43.115         |
| 2) Hydro            | 6.658          | 103.070         | 2) Madhya Pradesh              | 10.723         | 153.145         |
| 3) Gas              | 11.086         | 149.792         | 3) Chattisgarh                 | 7.160          | 89.620          |
| <b>Total MSPGCL</b> | <b>115.278</b> | <b>1649.355</b> | 4) Maharashtra Net             | 89.368         | 1214.401        |
| B) 1) APML          | 62.107         | 846.381         | 5) Goa (Amona)                 | -0.580         | -9.640          |
| 2) JSWEL            | 27.765         | 356.276         | 6) TAPS 1&2 Injection          | 3.658          | 51.019          |
| 3) VIPL             | 12.523         | 170.304         | 7) RGPPL Injection             | 11.632         | 159.405         |
| 4) RPL(AMT)         | 14.807         | 224.127         | 8) Pench (MS)                  | 0.239          | 2.084           |
| 5) WPCL             | 4.506          | 54.931          | 9) Pench (Excess)              | -0.239         | -2.084          |
| 6) Other IPP        | 8.194          | 117.328         | <b>Total</b>                   | <b>118.056</b> | <b>1612.751</b> |
| C) 1) TPCL Thermal  | 15.334         | 182.387         | a) Mumbai Schedule             | 21.332         | 279.093         |
| 2) TPCL Hydro       | 3.333          | 45.301          | b) Mumbai Drawl                | 22.858         | 340.083         |
| 3) TPCL Gas         | 4.327          | 58.127          | c) MSEDCL Bilateral *          | 35.505         | 422.381         |
| 4) R-INFRA Thermal  | 10.397         | 155.226         | Include PX                     | 0.980          | -14.771         |
| <b>D) STATE</b>     |                |                 | d) Mumbai Bilateral *          | 21.332         | 279.093         |
| 1) Thermal          | 253.167        | 3503.453        | Include PX                     | 3.205          | 37.540          |
| (A1+C1+C4+(B1-B6))  |                |                 | Include Standby                | 0.000          | 0.000           |
| 2) Hydro            | 9.991          | 148.371         | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 3) Gas              | 15.413         | 207.919         | 1) MSEDCL                      | 350.514        | 4829.023        |
| 4) Wind             | 8.648          | 119.604         | 2) Mumbai Discoms              | 56.249         | 781.111         |
| 6) SOLAR            | 1.488          | 18.049          | <b>TOTAL STATE</b>             | <b>406.763</b> | <b>5610.134</b> |
| <b>TOTAL STATE</b>  | <b>288.707</b> | <b>3997.396</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 15 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4568                      | 4365                  | 3534                      | 3948                      |
| MSPGCL Hydro             | 933                       | 209                   | 675                       | 118                       |
| MSPGCL Gas               | 456                       | 438                   | 451                       | 475                       |
| MSPGCL Total Generation  | 5957                      | 5012                  | 4660                      | 4541                      |
| Central Sector Receipt   | 5021                      | 6335                  | 5603                      | 3452                      |
| WIND                     | 108                       | 282                   | 267                       | 576                       |
| CPP / IPP                | 5602                      | 5641                  | 5670                      | 4879                      |
| SOLAR                    | 176                       | 171                   | 0                         | 0                         |
| Exchange with Mumbai     | -1198                     | -1283                 | -1005                     | -533                      |
| <b>MSEDCL DEMAND MET</b> | <b>15666</b>              | <b>16158</b>          | <b>15195</b>              | <b>12915</b>              |
| Load Shedding            | 3                         | 3                     | 3                         | 3                         |
| MSEDCL DEMAND            | 15669                     | 16161                 | 15198                     | 12918                     |
| TPCL GENERATION          | 1138                      | 1091                  | 1252                      | 697                       |
| R-INFRA GENERATION       | 513                       | 408                   | 405                       | 402                       |
| <b>MUMBAI DEMAND</b>     | <b>2849</b>               | <b>2782</b>           | <b>2662</b>               | <b>1632</b>               |
| STATE DEMAND MET         | 18515                     | 18940                 | 17857                     | 14547                     |
| <b>STATE DEMAND</b>      | <b>18518</b>              | <b>18943</b>          | <b>17860</b>              | <b>14550</b>              |
| Frequency (Hz)           | 49.97                     | 49.95                 | 49.93                     | 49.99                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.17 Hz at 07.01 Hrs | 49.69 Hz at 19.11 Hrs | 49.97         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 14/Mar/2016

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 4.01          | 0        | 0        |
| Unit 8             | 0.00         | 79.53         | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>83.54</b>  |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 2             | 4.12         | 38.22         | 185      | 160      |
| Unit 3             | 4.08         | 47.12         | 180      | 165      |
| Unit 4             | 5.07         | 8.74          | 365      | 0        |
| Unit 5             | 9.55         | 126.38        | 510      | 350      |
| <b>Total</b>       | <b>22.82</b> | <b>220.46</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 2.40         | 59.48         | 198      | 0        |
| Unit 4             | 4.32         | 59.62         | 199      | 163      |
| Unit 5             | 9.98         | 139.17        | 460      | 360      |
| Unit 6             | 0.00         | 40.63         | 0        | 0        |
| Unit 7             | 6.92         | 132.98        | 450      | 0        |
| <b>Total</b>       | <b>23.63</b> | <b>431.87</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.66         | 61.41         | 258      | 203      |
| Unit 4             | 5.77         | 39.63         | 260      | 195      |
| <b>Total</b>       | <b>11.43</b> | <b>101.04</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.84         | 54.77         | 175      | 150      |
| Unit 2             | 3.98         | 56.37         | 180      | 160      |
| Unit 3             | 4.06         | 44.80         | 190      | 160      |
| Unit 4             | 4.08         | 59.15         | 198      | 158      |
| Unit 5             | 9.79         | 146.67        | 500      | 368      |
| <b>Total</b>       | <b>25.75</b> | <b>361.76</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 43.98         | 0        | 0        |
| Unit 4             | 4.11         | 56.59         | 196      | 157      |
| Unit 5             | 4.22         | 54.45         | 199      | 161      |
| <b>Total</b>       | <b>8.33</b>  | <b>155.02</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 11.09        | 149.79        | 478      | 437      |
| <b>Total</b>       | <b>11.09</b> | <b>149.79</b> |          |          |

| Generating unit   | Generation    |                |          |          |
|-------------------|---------------|----------------|----------|----------|
|                   | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>PENCH (MS)</b> |               |                |          |          |
| Pench (MS)        | 0.24          | 2.08           | 40       | 0        |
| <b>Total</b>      | <b>0.24</b>   | <b>2.08</b>    |          |          |
| <b>Koyna</b>      |               |                |          |          |
| Stage 1-2         | 2.18          | 42.95          | 415      | 40       |
| Stage 4           | 0.88          | 19.63          | 494      | 0        |
| Stage 3           | 0.64          | 12.44          | 80       | 0        |
| <b>Total</b>      | <b>3.70</b>   | <b>75.03</b>   |          |          |
| <b>Hydro</b>      |               |                |          |          |
| KDPH              | 0.65          | 5.36           | 27       | 26       |
| VTRNA             | 0.00          | 0.00           | 0        | 0        |
| TILLARI           | 0.25          | 1.84           | 61       | 0        |
| BHTGR/VEER        | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.        | 0.04          | 2.92           | 37       | 0        |
| RNGR+BHTSA        | 0.23          | 2.80           | 11       | 0        |
| BHANDARDRA        | 0.00          | 0.00           | 0        | 0        |
| ELDARY            | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN         | 0.97          | 12.68          | 41       | 40       |
| GHATGHAR          | 0.83          | 2.44           | 125      | 0        |
| <b>Total</b>      | <b>2.96</b>   | <b>28.04</b>   |          |          |
| <b>Wind</b>       |               |                |          |          |
| Total             | 8.65          | 119.60         | 0        | 0        |
| <b>Total</b>      | <b>8.65</b>   | <b>119.60</b>  |          |          |
| <b>CPP</b>        |               |                |          |          |
| APML(Mus)         | 62.11         | 846.38         | 0        | 0        |
| JSWEL(Mus)        | 27.76         | 356.28         | 0        | 0        |
| VIPL(Mus)         | 12.52         | 170.30         | 0        | 0        |
| RPLAMT(Mus)       | 14.81         | 224.13         | 0        | 0        |
| WPCL(Mus)         | 4.51          | 54.93          | 0        | 0        |
| Other(Mus)        | 8.19          | 117.33         | 0        | 0        |
| <b>Total</b>      | <b>129.90</b> | <b>1769.35</b> |          |          |
| <b>SOLAR</b>      |               |                |          |          |
| Total             | 1.49          | 18.05          | 0        | 0        |
| <b>Total</b>      | <b>1.49</b>   | <b>18.05</b>   |          |          |
| <b>Tata</b>       |               |                |          |          |
| Trombay 5         | 9.89          | 130.60         | 489      | 315      |
| Trombay 6         | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A        | 2.73          | 36.28          | 115      | 113      |
| Trombay 7B        | 1.60          | 21.85          | 67       | 66       |
| Trombay 8         | 5.44          | 51.79          | 246      | 200      |
| TATA Hydro        | 3.33          | 45.30          | 360      | 0        |
| <b>Total</b>      | <b>22.99</b>  | <b>285.82</b>  |          |          |
| <b>R-INFRA</b>    |               |                |          |          |
| 1-2               | 10.40         | 155.23         | 518      | 402      |
| <b>Total</b>      | <b>10.40</b>  | <b>155.23</b>  |          |          |

|                     |              |      |          |      |
|---------------------|--------------|------|----------|------|
| <b>Infirm Power</b> | Chandrapur 8 | 0.00 | Koradi 9 | 5.57 |
|---------------------|--------------|------|----------|------|

| Summary         |             |               |
|-----------------|-------------|---------------|
| Particulars     | Daily (Mus) | Monthly (Mus) |
| MSPGCL Thermal  | 97.53       | 1396.49       |
| MSPGCL Thml+Gas | 108.62      | 1546.28       |

| Summary      |             |               |
|--------------|-------------|---------------|
| Particulars  | Daily (Mus) | Monthly (Mus) |
| MSPGCL Hydro | 6.66        | 103.07        |
| MSPGCL Total | 115.28      | 1649.36       |

| Summary             |             |               |
|---------------------|-------------|---------------|
| Particulars         | Daily (Mus) | Monthly (Mus) |
| Koyna 1,2 & 4 Total | 3.06        | 62.58         |
| State Total         | 288.71      | 3997.40       |

**State Load Despatch Center,Airoli (MSETCL)**  
**Hourly Load Data As on 14/Mar/2016**

**Annexure-2**

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |       | TOTAL  | WIND | CPP /<br>IPP | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|-------|--------|------|--------------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS   |        |      |              |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4024        | 121  | 466   | 4611   | 558  | 4688         | 0     | 4998        | 4364        | -849                 | 13372                 | 3                    | 13375                     | 1949             | 15324           | 49.99         |
| 2                  | 3937        | 117  | 477   | 4531   | 646  | 4551         | 0     | 4992        | 4266        | -682                 | 13312                 | 3                    | 13315                     | 1780             | 15095           | 49.96         |
| 3                  | 4017        | 123  | 466   | 4606   | 649  | 4667         | 0     | 4548        | 3986        | -588                 | 13320                 | 3                    | 13323                     | 1688             | 15011           | 49.99         |
| 4                  | 3948        | 118  | 475   | 4541   | 576  | 4879         | 0     | 4005        | 3452        | -533                 | 12915                 | 3                    | 12918                     | 1632             | 14550           | 49.99         |
| 5                  | 4158        | 133  | 478   | 4769   | 556  | 4892         | 0     | 4136        | 3679        | -519                 | 13377                 | 3                    | 13380                     | 1622             | 15002           | 49.99         |
| 6                  | 3775        | 133  | 475   | 4383   | 547  | 4900         | 0     | 5083        | 4655        | -632                 | 13853                 | 3                    | 13856                     | 1732             | 15588           | 49.97         |
| 7                  | 4172        | 123  | 473   | 4768   | 530  | 5381         | 1     | 5220        | 4608        | -668                 | 14620                 | 3                    | 14623                     | 1861             | 16484           | 49.99         |
| 8                  | 4469        | 128  | 478   | 5075   | 418  | 5788         | 25    | 5496        | 4623        | -646                 | 15283                 | 3                    | 15286                     | 2060             | 17346           | 50.02         |
| 9                  | 4394        | 128  | 466   | 4988   | 268  | 5811         | 92    | 5778        | 4723        | -881                 | 15001                 | 3                    | 15004                     | 2313             | 17317           | 49.95         |
| 10                 | 4387        | 616  | 469   | 5472   | 231  | 5667         | 142   | 5132        | 5211        | -1005                | 15718                 | 3                    | 15721                     | 2602             | 18323           | 49.95         |
| 11                 | 4568        | 933  | 456   | 5957   | 108  | 5602         | 176   | 5564        | 5021        | -1198                | 15666                 | 3                    | 15669                     | 2849             | 18518           | 49.97         |
| 12                 | 4602        | 667  | 453   | 5722   | 62   | 5629         | 189   | 5765        | 5168        | -1234                | 15536                 | 3                    | 15539                     | 2915             | 18454           | 49.97         |
| 13                 | 4600        | 365  | 447   | 5412   | 73   | 5733         | 206   | 5741        | 4790        | -1115                | 15099                 | 3                    | 15102                     | 2903             | 18005           | 49.93         |
| 14                 | 4592        | 321  | 446   | 5359   | 163  | 5760         | 201   | 5528        | 5653        | -1084                | 16052                 | 3                    | 16055                     | 2795             | 18850           | 50.04         |
| 15                 | 4365        | 209  | 438   | 5012   | 282  | 5641         | 171   | 5568        | 6335        | -1283                | 16158                 | 3                    | 16161                     | 2782             | 18943           | 49.95         |
| 16                 | 4340        | 204  | 437   | 4981   | 398  | 5681         | 142   | 5641        | 5807        | -1234                | 15775                 | 3                    | 15778                     | 2800             | 18578           | 49.93         |
| 17                 | 4099        | 119  | 445   | 4663   | 391  | 5474         | 101   | 5593        | 5428        | -1265                | 14792                 | 3                    | 14795                     | 2771             | 17566           | 49.89         |
| 18                 | 3916        | 411  | 462   | 4789   | 393  | 5423         | 38    | 4488        | 4679        | -1306                | 14016                 | 3                    | 14019                     | 2695             | 16714           | 49.95         |
| 19                 | 3730        | 337  | 459   | 4526   | 284  | 5670         | 4     | 4596        | 4359        | -1096                | 13747                 | 3                    | 13750                     | 2620             | 16370           | 49.91         |
| 20                 | 3534        | 675  | 451   | 4660   | 267  | 5670         | 0     | 5516        | 5603        | -1005                | 15195                 | 3                    | 15198                     | 2662             | 17860           | 49.93         |
| 21                 | 3517        | 283  | 461   | 4261   | 391  | 5679         | 0     | 5463        | 5634        | -949                 | 15016                 | 3                    | 15019                     | 2523             | 17542           | 49.99         |
| 22                 | 3534        | 113  | 474   | 4121   | 332  | 5688         | 0     | 5384        | 5104        | -1003                | 14242                 | 3                    | 14245                     | 2341             | 16586           | 50.02         |
| 23                 | 3428        | 108  | 464   | 4000   | 287  | 5539         | 0     | 5317        | 5422        | -1092                | 14156                 | 3                    | 14159                     | 2232             | 16391           | 49.98         |
| 24                 | 3428        | 173  | 470   | 4071   | 238  | 5489         | 0     | 5184        | 5486        | -991                 | 14293                 | 3                    | 14296                     | 2122             | 16418           | 49.94         |
| MUs                | 97.53       | 6.66 | 11.09 | 115.28 | 8.65 | 129.90       | 1.49  | 124.74      | 118.06      | -22.86               | 350.51                | 0.07                 | 350.59                    | 56.25            | 406.84          | 49.97         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 14/Mar/2016**

**Position as on 6.30 Hrs of 15/Mar/2016**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                          | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                           |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |            | Continued. | Economic shutdown,(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016) |               |
| CENT.SECTOR           | Tarapur 2               | 160      | 10/09/2015   | 12.55        |            | Continued. | Refuelling work                                                           |               |
| MSPGCL                | Koyna Unit 10           | 80       | 29/12/2015   | 08:00        |            | Continued. | Annual Overhaul                                                           |               |
| MSPGCL                | Khaparkhedha Unit 5     | 500      | 15/03/2016   | 01.12        |            | Continued. | Annual Overhaul                                                           |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                           |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |            | Continued. | Gas Shortage.                                                             |               |
| RGPL                  | Dabhol 3A               | 230      | 06/06/2013   | 08.28        |            | Continued. | Gas Shortage                                                              |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |            | Continued. | Gas Shortage                                                              |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |            | Continued. | Gas Shortage                                                              |               |
| IPP                   | Dhariwal                | 300      | 28/05/2014   | 02.27        |            | Continued. | No schedule                                                               |               |
| MSPGCL                | Chandrapur Unit 1       | 210      | 28/08/2014   | 07:15        |            | Continued. | Economic Shutdown.                                                        |               |
| MSPGCL                | Koradi Unit 6           | 210      | 20/03/2015   | 01.02        |            | Continued. | Economic shutdown                                                         |               |
| MSPGCL                | Parli Unit 3            | 210      | 14/06/2015   | 12.58        |            | Continued. | Water Shortage                                                            |               |
| MSPGCL                | Parli Unit 6            | 250      | 25/06/2015   | 15.03        |            | Continued. | Water Shortage                                                            |               |
| MSPGCL                | Parli Unit 4            | 210      | 05/07/2015   | 18.45        |            | Continued. | Water Shortage                                                            |               |
| MSPGCL                | Parli Unit 5            | 210      | 06/07/2015   | 14.55        |            | Continued. | Water Shortage.                                                           |               |
| MSPGCL                | Parli Unit 7            | 250      | 08/07/2015   | 12.08        |            | Continued. | Water Shortage                                                            |               |
| MSPGCL                | Chandrapur Unit-8       | 500      | 10/11/2015   | 12.10        |            | Continued. | Drum level low                                                            |               |
| RGPL                  | Dabhol 3B               | 230      | 07/01/2016   | 17:51        |            | Continued. | Change Over.                                                              |               |
| MSPGCL                | Chandrapur Unit 2       | 210      | 12/01/2016   | 04.47        |            | Continued. | Boiler Tube Leakage                                                       |               |
| RGPL                  | Dabhol 3X               | 290      | 03/02/2016   | 15:36        |            | Continued. | Change Over                                                               |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 15/02/2016   | 00.00        |            | Continued. | Attending Water valve Leakage.                                            |               |
| IPP                   | RPL(AMT) U-2            | 270      | 16/02/2016   | 01.14        | 14/03/2016 | 06.43      | Due to Zero Schedule Given by MSEDCL.                                     |               |
| IPP                   | RPL(AMT) U-3            | 270      | 16/02/2016   | 01.17        |            | Continued. | Due to Zero Schedule Given by MSEDCL.                                     |               |
| CPP                   | WPCL U-1                | 135      | 16/02/2016   | 17.09        |            | Continued. | Change Over , No Schedule                                                 |               |
| MSPGCL                | Koradi Unit 5           | 200      | 18/02/2016   | 11.21        |            | Continued. | MSEDCL Zero Shedule.                                                      |               |
| IPP                   | WPCL U-2                | 135      | 29/02/2016   | 21.46        |            | Continued. | Change over against Unit III                                              |               |
| MSPGCL                | Koradi Unit 7           | 210      | 01/03/2016   | 23.55        |            | Continued. | Zero Schedule Given by MSEDCL.                                            |               |
| MSPGCL                | Uran Unit 8             | 108      | 04/03/2016   | 22.55        |            | Continued. | Gas shortage                                                              |               |
| MSPGCL                | Chandrapur Unit 6       | 500      | 05/03/2016   | 10.15        |            | Continued. | Turbine bearing Vabration high                                            |               |
| IPP                   | Adani U-3               | 660      | 09/03/2016   | 18.07        | 14/03/2016 | 01.29      | Hydrogen cooler inlet valve flange leakage.                               |               |
| MSPGCL                | Koradi Unit-8           | 660      | 10/03/2016   | 12.30        |            | Continued. | Ash Evecuation Problem.                                                   |               |
| MSPGCL                | Koyna Unit 9            | 80       | 10/03/2016   | 14.55        |            | Continued. | GT buchhloz Alaram                                                        |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 14/Mar/2016**

Position as on 6.30 Hrs of 15/Mar/2016

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage               | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------------|---------------|
|                    |                         |          |              |              |            |            | problem                        |               |
| MSPGCL             | Nasik Unit 3            | 210      | 11/03/2016   | 12.32        |            | Continued. | Boiler Tube Leakage            |               |
| MSPGCL             | Koyna Unit 11           | 80       | 11/03/2016   | 13.53        |            | Continued. | stator earth fault             |               |
| MSPGCL             | Bhusawal Unit 4         | 500      | 14/03/2016   | 04.48        | 14/03/2016 | 13.09      | Electrical fault               |               |
| IPP                | RPL(AMT) U-4            | 270      | 14/03/2016   | 09.42        | 14/03/2016 | 11.36      | P A Fan Problem.               |               |
| MSPGCL             | Chandrapur Unit 3       | 210      | 14/03/2016   | 13.32        |            | Continued. | Suspected Boiler Tube Leakage. |               |
| MSPGCL             | Chandrapur Unit 7       | 500      | 14/03/2016   | 17.14        | 15/03/2016 | 04.24      | Aux.Board Tripped.             |               |
| MSPGCL             | Koradi Unit 9           | 660      | 14/03/2016   | 19.35        | 15/03/2016 | 00.34      | Metal Temp.High.               |               |
| MSPGCL             | Koradi Unit 9           | 660      | 15/03/2016   | 06.54        |            | Continued. | Tripped.                       |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 14/Mar/2016**

**Statement-VII**

**Position as on 6.30 Hrs of 15/Mar/2016**

| Name of Line                            | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                    |
|-----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                     |
| Dhule Sar'Sarovar I                     | InterState                | 12/03/2016   | 17.44        | 15/03/2016 | 06.17      | HT          | Over Voltage                                                                                                        |
| Kolhapur Solapur (PG) II                | InterState                | 13/03/2016   | 16.39        | 14/03/2016 | 06.40      | HT          | Over Voltage                                                                                                        |
| Akola Wardha li                         | InterState                | 14/03/2016   | 11.30        | 14/03/2016 | 14.55      | PO          | For Meter Calibration Work,Line Work Permit.                                                                        |
| Akola Aurangabad(PG) I                  | InterState                | 14/03/2016   | 13.13        | 14/03/2016 | 18.26      | PO          | Annual Maintenance Work                                                                                             |
| Kolhapur Solapur(PG) I                  | InterState                | 14/03/2016   | 16.47        | 15/03/2016 | 06.05      | HT          | Over Voltage                                                                                                        |
| Akola II - Taptitanda ckt-II            | IntraState                | 31/12/2015   | 18.16        |            | Continued. | HT          | Change over(outage taken on 2/3/2016 at 10.34hrs for commissioning of 765KV Ektuni S/Stn)                           |
| Babhaleshwar-Taptitanda ckt-II          | IntraState                | 11/02/2016   | 18.40        |            | Continued. | HT          | CHANGE OVER                                                                                                         |
| Bhusawal-Aurangabad                     | IntraState                | 26/02/2016   | 17.08        | 14/03/2016 | 12.06      | HT          | Over Voltage                                                                                                        |
| karad -kolhapur-II                      | IntraState                | 13/03/2016   | 14.01        | 14/03/2016 | 11.04      | HT          | Over Voltage                                                                                                        |
| Karad - Jaigad - II                     | IntraState                | 13/03/2016   | 16.05        | 14/03/2016 | 11.08      | HT          | Over Voltage                                                                                                        |
| Dhule - Bableswhar - li                 | IntraState                | 14/03/2016   | 09.25        | 14/03/2016 | 17.45      | PO          | Providing Conductor Sleeve.                                                                                         |
| Taptitanda Waluj                        | IntraState                | 14/03/2016   | 13.08        | 14/03/2016 | 18.26      | PO          | To Attend Hot Spot on Y Ph.                                                                                         |
| karad -kolhapur-I                       | IntraState                | 14/03/2016   | 16.03        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Karad - Jaigad - II                     | IntraState                | 14/03/2016   | 16.05        |            | Continued. | HT          | Over Voltage                                                                                                        |
| <b>400 KV ICT Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                     |
| 400/220/33 Kv 500 MVA ICT-I @Lonikand 2 | IntraState                | 14/03/2016   | 12.38        | 14/03/2016 | 14.15      | PO          | Shifted on TBC.                                                                                                     |
| <b>220 KV LINE Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                     |
| Hingoli- Girawali                       | InterState                | 14/02/2016   | 12.37        |            | Continued. | HT          | To Improve Voltage @ Hingoli.                                                                                       |
| Chandrapur GCR - Warora - I             | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Chandrapur GCR - Wani                   | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Kalwa - Borivali                        | IntraState                | 10/01/2016   | 09:15        |            | Continued. | PO          | Tower Erection Work.                                                                                                |
| GIS Bhandup - Borivali                  | IntraState                | 11/01/2016   | 07.42        |            | Continued. | PO          | Tower Erection Work.                                                                                                |
| Padghe - Vasai                          | IntraState                | 24/01/2016   | 08.32        |            | Continued. | PO          | For Formation of Temp. Padgha-Borivali (Charge upto 51/1).                                                          |
| Bableswhar- Alephata                    | IntraState                | 03/02/2016   | 06.28        |            | Continued. | HT          | controlling bblsr ICT Overloading                                                                                   |
| Bableswhar- Ranjangaon                  | IntraState                | 03/02/2016   | 07.12        |            | Continued. | HT          | controlling bblsr ICT Overloading                                                                                   |
| Wadkhal - Ipcl 1                        | IntraState                | 09/03/2016   | 08.55        |            | Continued. | PO          | Conductor Stringing Work.                                                                                           |
| Chakan-Chinchwad                        | IntraState                | 13/03/2016   | 20.35        | 14/03/2016 | 04.28      | PO          | Conductor stringing work                                                                                            |
| Telco- Chinchwad                        | IntraState                | 13/03/2016   | 20.38        | 14/03/2016 | 04.29      | PO          | Conductor stringing work                                                                                            |
| Kalwa - Airoli Knowledge Park           | IntraState                | 14/03/2016   | 07.31        | 14/03/2016 | 20.10      | PO          | Creek Side Bus Outage.                                                                                              |
| Loteparshuram- Dasturi Line             | IntraState                | 14/03/2016   | 10.15        | 14/03/2016 | 15.00      | PO          | Red Hot Attending Work of CT Y Phase.                                                                               |
| Chinchwad-Hinjewadi I                   | IntraState                | 14/03/2016   | 20.09        | 15/03/2016 | 05.27      | HT          | For Chinchwad Outage.                                                                                               |
| Chakan-Chinchwad                        | IntraState                | 14/03/2016   | 20.19        | 15/03/2016 | 05.17      | PO          | Tower Erection Work.                                                                                                |
| Telco- Chinchwad                        | IntraState                | 14/03/2016   | 20.21        | 15/03/2016 | 05.18      | HT          | For Chinchwad Outage.                                                                                               |
| Flagship-Nandedcity                     | IntraState                | 15/03/2016   | 05.26        |            | Continued. | HT          | For Chinchwad Outage.                                                                                               |
| <b>220 KV ICT Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                     |
| 220/100 Kv 200 MVA ICT III @Borivali    | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Failed on internal Fault(Now repaired and ready for commissioning)                                                  |
| 220/100 kv 200 MVA ICT-II @Kalwa        | IntraState                | 14/03/2016   | 07.24        | 14/03/2016 | 19.46      | PO          | Creek Side Bus Outage.                                                                                              |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**