

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 14/Mar/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	169.334	2148.352	1) Gujrat	-9.079	-96.538
2) Hydro	19.758	268.158	2) Madhya Pradesh	7.874	133.395
3) Gas	3.631	49.728	3) Chattisgarh	4.230	78.740
Total MSPGCL	192.723	2466.238	4) Maharashtra	159.806	2295.969
B) 1) APLM	75.385	1049.834	5) Goa (Amona)	-1.540	-17.343
2) JSWEL	21.377	278.159	Total	161.291	2394.223
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.594	384.431
4) RPL(AMT)	25.863	351.880	b) Mumbai Drawl	32.947	418.038
5) SWPGPL	5.622	80.460	c) MSEDCL Bilateral *	66.929	1464.912
6) Other IPP	40.313	559.490	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.594	384.431
C) 1) TPCL Thermal	14.420	180.084	Include PX	0.000	5.604
2) TPCL Hydro	6.388	62.784	Standby	0.000	0.000
3) TPCL Gas	2.078	11.389	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.053	132.953	1) MSEDCL	498.792	6869.189
D) STATE			2) Mumbai Discoms	63.886	805.249
1) Thermal	360.367	4781.212	3) Other Discoms	8.806	122.037
(A1+C1+C4+(B1-B6))			TOTAL STATE	571.484	7796.475
2) Hydro (A2+C2)	26.146	330.942			
3) Gas (A3+B7+C3)	5.709	61.117			
4) Wind	9.135	122.202			
6) SOLAR	8.836	106.778			
TOTAL STATE	410.193	5402.251			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	7117	7213	7056	6890
MSPGCL Hydro	1256	861	1489	343
MSPGCL Gas	134	133	196	152
MSPGCL Total Generation	8507	8207	8741	7385
Central Sector Receipt	7598	7991	6314	5807
WIND	257	163	266	780
CPP / IPP Thermal	7112	7054	7230	6752
CPP / IPP Gas	0	0	0	0
SOLAR	1165	1174	0	0
Exchange with Mumbai	-1489	-1612	-1434	-1173
MSEDCL DEMAND MET	22758	22597	20725	19262
Load Shedding	0	0	0	0
MSEDCL DEMAND	22758	22597	20725	19262
TPCL GENERATION	1149	1172	1171	488
AEML GENERATION	500	274	250	481
MUMBAI DEMAND	3138	3058	2855	2142
OTHER DISCOM DEMAND	391	380	391	290
STATE DEMAND MET	26288	26035	23972	21693
STATE DEMAND	26288	26035	23972	21693
Frequency (Hz)	50.00	50.00	49.93	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.18 Hz at 06:01 Hrs	49.71 Hz at 13:50 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 14/Mar/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.18	58.96	180	135
Unit 7	0.00	0.00	0	0
Unit 8	13.95	189.41	601	551
Unit 9	13.87	185.98	600	560
Unit 10	11.58	139.54	510	450
Total	43.58	573.89		
Bhusawal				
Unit 3	3.26	35.97	150	120
Unit 4	9.19	121.56	485	310
Unit 5	0.00	16.69	0	0
Total	12.44	174.22		
Parli				
Unit 6	5.38	63.07	250	150
Unit 7	5.32	61.34	249	144
Unit 8	3.86	45.19	176	145
Total	14.56	169.59		
Chandrapur				
Unit 3	0.00	44.44	0	0
Unit 4	4.10	54.88	176	156
Unit 5	8.85	100.24	395	345
Unit 6	9.80	49.66	420	396
Unit 7	9.86	124.88	427	387
Unit 8	10.90	100.13	466	421
Unit 9	10.94	143.18	465	448
Total	54.45	617.43		
Paras				
Unit 3	5.28	75.74	252	176
Unit 4	5.49	75.59	250	196
Total	10.77	151.33		
Khaparkheda				
Unit 1	3.43	46.97	155	125
Unit 2	3.61	49.04	160	140
Unit 3	4.49	58.68	194	153
Unit 4	4.18	55.61	183	160
Unit 5	10.68	147.16	460	430
Total	26.38	357.46		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.88	56.59	193	119
Unit 5	3.27	47.83	157	119
Total	7.15	104.42		
Uran				
All Units	3.63	49.73	218	120
Total	3.63	49.73		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.09	2.75	40	0
Total	0.09	2.75		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	5.97	59.90	500	40
Stage 4	3.78	79.81	750	0
Stage 3	2.11	30.02	160	0
Total	11.86	169.73		
Hydro				
KDPH	0.86	9.31	36	36
VTRNA	0.00	0.00	0	0
TILLARI	0.23	0.99	58	0
BHIRA T.R.	0.28	3.44	80	0
SMLHY_PTN	6.43	81.95	278	256
GHATGHAR	0.00	0.00	0	0
Total	7.81	95.68		
Wind				
Total	9.14	122.20	0	0
Total	9.14	122.20		
CPP				
APML(Mus)	75.38	1049.83	0	0
JSWEL(Mus)	21.38	278.16	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.86	351.88	0	0
SWPGPL-Mus	5.62	80.46	0	0
Other(Mus)	40.31	559.49	0	0
Total	168.56	2319.82		
SOLAR				
Total	8.84	106.78	0	0
Total	8.84	106.78		
Tata				
Trombay 5	9.58	123.65	464	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.13	6.96	103	41
Trombay 7B	0.95	4.43	64	37
TATA Hydro	6.39	62.78	456	0
Trombay 8	4.84	56.43	240	132
Total	22.89	254.26		
AEML				
DTPS U-1&2	8.05	132.95	501	0
Total	8.05	132.95		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	169.33	2148.35	MSPGCL Total	192.72	2466.24
			MSPGCL Thml+Gas	172.96	2198.08	Koyna 1,2 & 4 Total	9.75	139.71
			MSPGCL Hydro	19.76	268.16	State Total	410.19	5402.25

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 14/Mar/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6809	352	141	7302	758	6845	0	0	6547	6121	-1417	19297	0	19297	2425	312	22034	50.01
2	6791	347	142	7280	753	6582	0	0	6399	6178	-1299	19221	0	19221	2260	272	21754	50.01
3	6890	343	152	7385	780	6752	0	0	5876	5807	-1173	19262	0	19262	2142	290	21693	50.02
4	6946	346	143	7435	750	6908	0	0	5662	5687	-1084	19397	0	19397	2045	299	21741	50.02
5	7110	349	142	7601	723	6910	0	0	5799	5787	-1013	19695	0	19695	1999	312	22007	50.03
6	7139	505	144	7788	694	7003	0	0	5927	6274	-882	20550	0	20550	2062	327	22939	50.01
7	7163	1224	154	8541	636	7079	0	8	5878	6043	-818	21111	0	21111	2158	378	23647	50.01
8	7208	1592	144	8944	514	7124	0	186	5922	5918	-841	21459	0	21459	2268	386	24113	50.02
9	7242	944	142	8328	314	7112	0	531	6497	6350	-1066	21171	0	21171	2539	398	24108	50.03
10	7221	766	148	8135	251	7107	0	866	7221	7272	-1349	21877	0	21877	2836	405	25118	49.97
11	7174	1244	136	8554	246	7109	0	1031	7715	7671	-1518	22691	0	22691	3054	401	26147	49.92
12	7117	1256	134	8507	257	7112	0	1165	7895	7598	-1489	22758	0	22758	3138	391	26288	50.00
13	7213	861	133	8207	163	7054	0	1174	8093	7991	-1612	22597	0	22597	3058	380	26035	50.00
14	6989	930	120	8039	146	6899	0	1152	8198	7845	-1782	21916	0	21916	2975	383	25274	49.90
15	6932	874	130	7936	124	6839	0	1105	8571	8630	-1899	22356	0	22356	3090	379	25825	49.87
16	7086	947	131	8164	159	7006	0	843	8324	8296	-1932	22134	0	22134	3177	402	25713	49.91
17	7044	1127	133	8304	189	7067	0	556	7490	7251	-1732	21234	0	21234	3149	401	24784	49.94
18	7073	901	135	8109	246	7072	0	207	6980	6884	-1592	20509	0	20509	3022	416	23948	49.97
19	7017	787	161	7965	296	7171	0	12	6452	6127	-1453	19701	0	19701	2886	416	23004	49.93
20	7056	1489	196	8741	266	7230	0	0	6383	6314	-1434	20725	0	20725	2855	391	23972	49.93
21	7058	690	197	7945	224	7223	0	0	6301	6235	-1378	19843	0	19843	2740	405	22989	49.98
22	7004	442	213	7659	232	7215	0	0	6311	6197	-1403	19523	0	19523	2666	377	22566	49.98
23	6991	649	218	7858	182	7106	0	0	6252	6351	-1389	19763	0	19763	2660	345	22768	49.97
24	7061	793	142	7996	232	7036	0	0	6595	6464	-1392	19999	0	19999	2682	337	23018	49.99
MUs	169.33	19.76	3.63	192.72	9.14	168.56	0.00	8.84	163.29	161.29	-32.95	498.79	0.00	498.79	63.89	8.81	571.48	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 14/Mar/2022

Position as on 6.30 Hrs of 15/Mar/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Nasik Unit 3	210	26/01/2022	20:26		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U4	300	14/02/2022	16:08	14/03/2022	11:43	No Schedule	
MSPGCL	Ghatghar Unit-1	125	17/02/2022	21:55		Continued.	SFC HEAVY FAULT	
MSPGCL	Uran Unit A0	120	21/02/2022	21:57		Continued.	Gas shortage	
IPP	SWPGPL U-4	135	25/02/2022	16:47		Continued.	Turbine Vibration	
MSPGCL	Bhusawal Unit 5	500	03/03/2022	06:05	15/03/2022	11:20	Flame Failure	
IPP	RPL(AMT) U-1	270	07/03/2022	02:39		Continued.	Generator Protection operated	
MSPGCL	Uran Unit 6	108	10/03/2022	18:07	14/03/2022	18:08	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	11/03/2022	01:25		Continued.	TRIPPED ON SFC HEAVY FAULT WHILE TAKING ON PUMPING MODE.(PUMPING TRIAL CARRIED OUT SUCCESSFULLY FROM 20:35HRS TO 22:35HRS DT.10/03/22)	
MSPGCL	Chandrapur Unit 3	210	11/03/2022	08:43		Continued.	WITHDRAWN FOR ATTENDING HPCV-I STEAM LEAKAGE WORK	
IPP	SWPGPL U-2	135	11/03/2022	16:30	14/03/2022	03:10	Condenser inlet line leakage.	
MSPGCL	Uran Unit 5	108	14/03/2022	00:00		Continued.	Gas shortage	
AEML	AEML Unit 2	250	14/03/2022	12:32	14/03/2022	15:36	Due to tripping of all 220 kV lines at dahanu.	
AEML	AEML Unit 1	250	14/03/2022	12:32		Continued.	Due to tripping of all 220 kV lines at dahanu.	
MSPGCL	Paras Unit 4	250	15/03/2022	00:31	15/03/2022	03:10	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 14/Mar/2022

Position as on 6.30 Hrs of 15/Mar/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 3	210	15/03/2022	03:27		Continued.	Boiler Tube Leakage	
MSPGCL	Bhusawal Unit 3	210	15/03/2022	19:38		Continued.	Coal Shortage	
MSPGCL	Parli Unit 7	250	15/03/2022	23:10		Continued.	Furnace Pressure High	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 14/Mar/2022

Statement-VII

Position as on 6.30 Hrs of 15/Mar/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	12/03/2022	15:01			T	Pole-2 tripped at Padghe end. Black smoke observed near pole 2, B phase converter transformer's 3A bushing - turret. Fire looked external and it was extinguished in 10-15 minutes using fire tenders and fire hydrant
400 KV LINE Outages/Tripping							
PADGHE - BOISAR (PG)	InterState	14/03/2022	15:32	14/03/2022	18:10	T	TRIPPED ON DIST.PROTN.
TIRORA - WARORA CKT - 1	IntraState	13/03/2022	21:27	14/03/2022	00:04	EO	Today on dt.13.03.2022 @ 06:41 hrs VT fail optd alarm observed on SCADA, after checking CVT voltage we found voltage drop in R-ph of 400KV Tirora & Warora Line -1 at Warora end.
AKOLA - KHADKA (BHUSAWAL)	IntraState	13/03/2022	22:14	14/03/2022	18:26	T	R-ph Wavetrap caught fire at Khadka
400 KV ICT Outages/Tripping							
400/220/33KV 500 MVA ICT - 1 @ KUDUS	IntraState	08/03/2022	06:01	15/03/2022	23:03	T	Buccholsz Relay Optd.
400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	IntraState	14/03/2022	16:23	14/03/2022	17:08	PO	For dew point measurement of SF6 C.B
400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	IntraState	14/03/2022	17:15	14/03/2022	18:00	PO	For dew point measurement of SF6 C.B
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	15/03/2022	10:59	15/03/2022	17:18	PO	For attending oil leakage from ICT & general routine maintenance. Isolator alignment
400/220/33KV 315MVA ICT - 3 @ LONIKAND	IntraState	15/03/2022	18:44	15/03/2022	19:57	EO	For attending the Hot spot at Bph 29D isolator (CT side) LV side(220kV side). Hot spot temp-210 DC.
220 KV TIEBAY Outages/Tripping							
BUS SECTION BREAKER @ SHIRSUPHAL	IntraState	15/03/2022	12:12	15/03/2022	21:25	PO	DIAGNOSTIC TESTING & RELAY TESTING WORK
220 KV MAINBAY Outages/Tripping							
BUS COUPLER @ LAMBOTI	IntraState	15/03/2022	13:04	15/03/2022	14:28	PO	For dew point measurement of SF6 CB
MAIN BUS @ SAWANTWADI	IntraState	15/03/2022	15:55	15/03/2022	17:24	PO	220kV Main & allied bay equipments maintenance.
220 KV LINE Outages/Tripping							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	CABLE FAULT
MUDSHINGI - CHIKODI	IntraState	07/03/2022	10:22			PO	For SSN to DSN insulator string conversion at tower location no M/C-13,14,15 220kv CB overhauling work by agency
TROMBAY - MULUND	IntraState	14/03/2022	06:20	14/03/2022	06:39	EO	To attend sparking at Y-phase of Loc no 72 in BARC area.
MHAISHAL- JATH	IntraState	14/03/2022	09:23	14/03/2022	12:35	PO	1. 220kV bay line isolator Quat. maintenance 2. Hot Spot attend
220KV MALEGAON - DHULE	IntraState	14/03/2022	11:05	14/03/2022	13:53	T	TRIPPED ON DIST.PROTN.
LAMBOTI - TULJAPUR CKT - 1	IntraState	14/03/2022	11:40	14/03/2022	12:37	PO	For dew point measurement of SF6 C.B
DAHANU - GHODBUNDER CKT - 1	IntraState	14/03/2022	12:10	14/03/2022	15:38	T	TRIPPED ON DIST.PROTN.
DAHANU - GHODBUNDER CKT - 2	IntraState	14/03/2022	12:30	14/03/2022	15:23	T	TRIPPED ON DIST.PROTN.
BOISAR II - VIRAJ	IntraState	14/03/2022	12:31	14/03/2022	12:55	T	TRIPPED ON DIST.PROTN.
DAHANU - VIRAJ	IntraState	14/03/2022	12:32	14/03/2022	17:05	T	TRIPPED ON DIST.PROTN.
DAHANU - VERSOVA	IntraState	14/03/2022	12:35	14/03/2022	12:35	T	TRIPPED ON DIST.PROTN.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/Mar/2022

Statement-VII

Position as on 6.30 Hrs of 15/Mar/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KANDALGAON - ONGC PANVEL	IntraState	14/03/2022	12:49	14/03/2022	14:58	T	TRIPPED ON DIST.PROTN.
LAMBOTI - TULJAPUR CKT - 2	IntraState	14/03/2022	13:29	14/03/2022	14:50	PO	For dew point measurement of SF6 C.B
LAMBOTI - VAIRAG	IntraState	14/03/2022	14:58	14/03/2022	15:53	PO	For dew point measure of SF6 of C.B
KANDALGAON - ONGC PANVEL	IntraState	14/03/2022	15:10	14/03/2022	19:20	T	TRIPPED ON DIST.PROTN.
TROMBAY - MULUND	IntraState	15/03/2022	05:44	15/03/2022	09:19	EO	For attending sparking at Yph of 72 no location inside BARC
LAMBOTI - SOLAPUR 2(BALE) CKT - 1	IntraState	15/03/2022	10:25	15/03/2022	11:13	PO	For dew point measurement of SF6 CB
KARAD -MUDSHINGI CKT- 4	IntraState	15/03/2022	10:47	15/03/2022	13:47	PO	Replacement of Yph trip ckt coil & for replacement of TSR relays
LAMBOTI - KARKAMB	IntraState	15/03/2022	11:21	15/03/2022	12:09	PO	For dew point measurement of Sf6 gas of CB
LAMBOTI - PANDHARPUR	IntraState	15/03/2022	12:17	15/03/2022	12:56	PO	For dew point measurement of SF6 gas
BIDRI - SAWANTWADI	IntraState	15/03/2022	12:22	15/03/2022	14:29	T	TRIPPED ON DIST.PROTN
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	15/03/2022	12:49	15/03/2022	18:32	PO	For safety purpose due to OPGW stringing work on 220kV Navsari-Atul line and Navsari-Ambheta line.
OSMANABAD - BARSHI	IntraState	15/03/2022	14:12	15/03/2022	16:48	PO	Quarterly bay maintenance and Annual relay testing work
PUSAD - WARDHA (PG)	IntraState	15/03/2022	16:04	15/03/2022	17:13	T	Distance Protection
LONIKAND 2 - BHOSARI	IntraState	15/03/2022	16:13	15/03/2022	18:00	EO	To attend the hot spot at R phase, loc 07 MSJ. (Mid Span Joint) temp is 100 degree.
THEUR-JEJURI	IntraState	15/03/2022	20:10	15/03/2022	21:37	T	Distance Protection Operated.
BOMBAY DYEING - SAHARA	IntraState	15/03/2022	22:20		Continued.	EO	Emergency work of replacement of Y ph bus isolator jumper
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Differential protection and Declare faulty
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	01/03/2022	18:17			T	Differential Protection
220/33kV 50MVA TF-3 @ 5 STAR MIDC	IntraState	14/03/2022	10:17	14/03/2022	15:50	PO	for CB testing of 33 KV Feeders and quarterly maintenance work.
220/33KV 50MVA PTR 3 @ WATHAR	IntraState	14/03/2022	10:50	14/03/2022	15:11	PO	Quarterly Maintenance work .
110 KV LINE Outages/Trippings							
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

