

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 14/Mar/2023 TUESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 162.366        | 2297.368        | 1) Gujrat                      | 3.382          | 42.372          |
| 2) Hydro            | 26.903         | 148.114         | 2) Madhya Pradesh              | 8.769          | 66.905          |
| 3) Gas              | 4.440          | 58.905          | 3) Chattisgarh                 | 4.430          | 55.930          |
| <b>Total MSPGCL</b> | <b>193.709</b> | <b>2504.387</b> | 4) Maharashtra                 | 180.219        | 2318.883        |
| B) 1) APLM          | 58.605         | 938.763         | 5) Goa (Amona)                 | -2.183         | -22.687         |
| 2) JSWEL            | 26.764         | 355.124         | <b>Total</b>                   | <b>194.617</b> | <b>2461.403</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 33.503         | 432.236         |
| 4) RPL(AMT)         | 31.181         | 420.175         | b) Mumbai Drawl                | 40.102         | 512.587         |
| 5) SWPGPL           | 10.350         | 141.535         | c) MSEDCL Bilateral *          | 83.083         | 1198.602        |
| 6) Other IPP        | 38.556         | 582.272         | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 33.503         | 432.236         |
| C) 1) TPCL Thermal  | 10.660         | 151.963         | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 3.980          | 38.784          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 3.265          | 37.291          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 11.508         | 154.860         | 1) MSEDCL                      | 521.277        | 7094.979        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 69.515         | 895.485         |
| 1) Thermal          | 349.990        | 5042.060        | 3) Other Discoms               | 10.455         | 140.893         |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>601.247</b> | <b>8131.357</b> |
| 2) Hydro (A2+C2)    | 30.883         | 186.898         |                                |                |                 |
| 3) Gas (A3+B7+C3)   | 7.705          | 96.196          |                                |                |                 |
| 4) Wind             | 6.019          | 155.414         |                                |                |                 |
| 6) SOLAR            | 12.033         | 189.386         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>406.630</b> | <b>5669.954</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 6781                      | 6820                  | 6761                      | 6815                      |
| MSPGCL Hydro               | 1008                      | 698                   | 1957                      | 566                       |
| MSPGCL Gas                 | 181                       | 176                   | 188                       | 191                       |
| MSPGCL Total Generation    | 7970                      | 7694                  | 8906                      | 7572                      |
| Central Sector Receipt     | 9868                      | 9812                  | 7339                      | 7051                      |
| WIND                       | 147                       | 89                    | 234                       | 332                       |
| CPP / IPP Thermal          | 6848                      | 6810                  | 6938                      | 6937                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 1722                      | 1806                  | 0                         | 0                         |
| Exchange with Mumbai       | -2066                     | -2071                 | -1443                     | -1401                     |
| <b>MSEDCL DEMAND MET</b>   | <b>24020</b>              | <b>23667</b>          | <b>21489</b>              | <b>20150</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 24020                     | 23667                 | 21489                     | 20150                     |
| TPCL GENERATION            | 789                       | 773                   | 1145                      | 515                       |
| AEML GENERATION            | 486                       | 490                   | 499                       | 469                       |
| <b>MUMBAI DEMAND</b>       | <b>3341</b>               | <b>3334</b>           | <b>3087</b>               | <b>2385</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>469</b>                | <b>473</b>            | <b>485</b>                | <b>341</b>                |
| STATE DEMAND MET           | 27830                     | 27474                 | 25061                     | 22876                     |
| <b>STATE DEMAND</b>        | <b>27830</b>              | <b>27474</b>          | <b>25061</b>              | <b>22876</b>              |
| Frequency (Hz)             | 50.00                     | 50.01                 | 50.05                     | 49.99                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.        | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|----------------------|-----------------------|---------------|---------------------|
| 50.4 Hz at 18.03 Hrs | 49.82 Hz at 15.57 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 14/Mar/2023

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 4.42         | 64.06         | 205      | 175      |
| Unit 8             | 10.55        | 183.30        | 457      | 359      |
| Unit 9             | 14.39        | 188.26        | 610      | 575      |
| Unit 10            | 0.00         | 102.93        | 0        | 0        |
| <b>Total</b>       | <b>29.36</b> | <b>538.55</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.38         | 46.76         | 150      | 125      |
| Unit 4             | 11.14        | 137.00        | 490      | 445      |
| Unit 5             | 11.82        | 145.47        | 500      | 455      |
| <b>Total</b>       | <b>26.34</b> | <b>329.24</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 5.93         | 66.88         | 250      | 236      |
| Unit 7             | 5.68         | 65.55         | 248      | 173      |
| Unit 8             | 3.55         | 48.29         | 180      | 111      |
| <b>Total</b>       | <b>15.16</b> | <b>180.72</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.90         | 50.85         | 170      | 130      |
| Unit 4             | 3.46         | 45.60         | 146      | 142      |
| Unit 5             | 9.53         | 55.22         | 405      | 385      |
| Unit 6             | 9.00         | 119.74        | 405      | 309      |
| Unit 7             | 9.68         | 119.11        | 425      | 343      |
| Unit 8             | 11.80        | 152.15        | 500      | 476      |
| Unit 9             | 0.00         | 138.88        | 0        | 0        |
| <b>Total</b>       | <b>47.37</b> | <b>681.55</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.08         | 69.12         | 239      | 161      |
| Unit 4             | 5.53         | 74.23         | 238      | 213      |
| <b>Total</b>       | <b>10.61</b> | <b>143.35</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.78         | 38.75         | 120      | 110      |
| Unit 2             | 2.72         | 43.13         | 125      | 100      |
| Unit 3             | 4.27         | 49.02         | 186      | 172      |
| Unit 4             | 4.47         | 55.46         | 192      | 169      |
| Unit 5             | 11.70        | 146.04        | 500      | 480      |
| <b>Total</b>       | <b>25.94</b> | <b>332.40</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.97          | 0        | 0        |
| Unit 4             | 3.79         | 40.92         | 176      | 135      |
| Unit 5             | 3.81         | 49.68         | 172      | 141      |
| <b>Total</b>       | <b>7.60</b>  | <b>91.57</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 4.44         | 58.90         | 193      | 169      |
| <b>Total</b>       | <b>4.44</b>  | <b>58.90</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.13         | 1.79          | 37       | 0        |
| <b>Total</b>       | <b>0.13</b>  | <b>1.79</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 6.33         | 36.00         | 490      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 11.69         | 35.03          | 1005     | 0        |
| Stage 3         | 3.78          | 15.34          | 320      | 0        |
| <b>Total</b>    | <b>21.81</b>  | <b>86.37</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.86          | 11.65          | 36       | 36       |
| VTRNA           | 1.18          | 14.68          | 61       | 0        |
| TILLARI         | 0.46          | 2.70           | 58       | 0        |
| BHIRA T.R.      | 0.14          | 1.79           | 40       | 0        |
| SMLHY_PTN       | 2.32          | 29.13          | 105      | 91       |
| GHATGHAR        | 0.00          | 0.00           | 0        | 0        |
| <b>Total</b>    | <b>4.96</b>   | <b>59.95</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 6.02          | 155.41         | 0        | 0        |
| <b>Total</b>    | <b>6.02</b>   | <b>155.41</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 58.60         | 938.76         | 0        | 0        |
| JSWEL(Mus)      | 26.76         | 355.12         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 31.18         | 420.18         | 0        | 0        |
| SWPGPL-Mus      | 10.35         | 141.54         | 0        | 0        |
| Dhariwal        | 6.12          | 83.88          | 271      | 241      |
| IEPL            | 5.01          | 70.87          | 269      | 196      |
| Other(Mus)      | 27.42         | 427.52         | 0        | 0        |
| <b>Total</b>    | <b>165.46</b> | <b>2437.87</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 12.03         | 189.39         | 0        | 0        |
| <b>Total</b>    | <b>12.03</b>  | <b>189.39</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 7.19          | 100.54         | 405      | 267      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 1.96          | 21.88          | 109      | 43       |
| Trombay 7B      | 1.30          | 15.41          | 65       | 38       |
| TATA Hydro      | 3.98          | 38.78          | 360      | 7        |
| Trombay 8       | 3.47          | 51.42          | 208      | 130      |
| <b>Total</b>    | <b>17.90</b>  | <b>228.04</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 11.51         | 154.86         | 499      | 424      |
| <b>Total</b>    | <b>11.51</b>  | <b>154.86</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 162.37      | 2297.37       | MSPGCL Total        | 193.71      | 2504.39       |
|                |             |         | MSPGCL Thml+Gas | 166.81      | 2356.27       | Koyna 1,2 & 4 Total | 18.02       | 71.03         |
|                |             |         | MSPGCL Hydro    | 26.90       | 148.11        | State Total         | 406.63      | 5669.95       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 14/Mar/2023

### Annexure-2

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | LOAD<br>SHED<br>DING | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAN<br>D | OTHER<br>DISCOM<br>DEMAN<br>D | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|------------------------|----------------------|-------------------------------|----------------------|-------------------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |      | THM       | GAS  |       |             |             |                      |                        |                      |                               |                      |                               |                 |               |
| 1                  | 6799        | 594   | 190  | 7583   | 632  | 7079      | 0    | 0     | 7110        | 6985        | -1623                | 20268                  | 0                    | 20268                         | 2772                 | 388                           | 23428           | 49.97         |
| 2                  | 6818        | 501   | 190  | 7509   | 400  | 6961      | 0    | 0     | 7121        | 7183        | -1496                | 20198                  | 0                    | 20198                         | 2546                 | 359                           | 23103           | 49.98         |
| 3                  | 6815        | 566   | 191  | 7572   | 332  | 6937      | 0    | 0     | 7010        | 7051        | -1401                | 20150                  | 0                    | 20150                         | 2385                 | 341                           | 22876           | 49.99         |
| 4                  | 6817        | 532   | 192  | 7541   | 312  | 6930      | 0    | 0     | 7005        | 7232        | -1288                | 20384                  | 0                    | 20384                         | 2284                 | 343                           | 23011           | 49.99         |
| 5                  | 6709        | 977   | 192  | 7878   | 293  | 6922      | 0    | 0     | 6993        | 6917        | -1256                | 20398                  | 0                    | 20398                         | 2241                 | 356                           | 22995           | 49.97         |
| 6                  | 6769        | 1562  | 192  | 8523   | 345  | 7042      | 0    | 0     | 6719        | 6806        | -1169                | 21160                  | 0                    | 21160                         | 2291                 | 387                           | 23838           | 50.00         |
| 7                  | 6864        | 1924  | 189  | 8977   | 400  | 7072      | 0    | 12    | 7131        | 7115        | -1147                | 22031                  | 0                    | 22031                         | 2370                 | 398                           | 24799           | 50.00         |
| 8                  | 6876        | 1942  | 191  | 9009   | 469  | 7018      | 0    | 235   | 7244        | 7542        | -1270                | 22570                  | 0                    | 22570                         | 2489                 | 433                           | 25492           | 50.03         |
| 9                  | 6893        | 1168  | 193  | 8254   | 286  | 6883      | 0    | 672   | 7868        | 8268        | -1456                | 22451                  | 0                    | 22451                         | 2743                 | 456                           | 25650           | 50.02         |
| 10                 | 6872        | 995   | 187  | 8054   | 311  | 6932      | 0    | 1140  | 8531        | 8745        | -1763                | 22948                  | 0                    | 22948                         | 3033                 | 471                           | 26452           | 49.98         |
| 11                 | 6801        | 1025  | 183  | 8009   | 242  | 6908      | 0    | 1589  | 9253        | 9467        | -1993                | 23753                  | 0                    | 23753                         | 3256                 | 469                           | 27478           | 50.02         |
| 12                 | 6781        | 1008  | 181  | 7970   | 147  | 6848      | 0    | 1722  | 9678        | 9868        | -2066                | 24020                  | 0                    | 24020                         | 3341                 | 469                           | 27830           | 50.00         |
| 13                 | 6820        | 698   | 176  | 7694   | 89   | 6810      | 0    | 1806  | 9703        | 9812        | -2071                | 23667                  | 0                    | 23667                         | 3334                 | 473                           | 27474           | 50.01         |
| 14                 | 6730        | 287   | 169  | 7186   | 80   | 6776      | 0    | 1655  | 9836        | 10099       | -2165                | 23172                  | 0                    | 23172                         | 3266                 | 459                           | 26897           | 50.00         |
| 15                 | 6778        | 534   | 172  | 7484   | 71   | 6775      | 0    | 1312  | 9920        | 10382       | -2157                | 23395                  | 0                    | 23395                         | 3387                 | 472                           | 27254           | 49.97         |
| 16                 | 6708        | 1078  | 178  | 7964   | 58   | 6765      | 0    | 1080  | 9575        | 9667        | -2184                | 22866                  | 0                    | 22866                         | 3443                 | 484                           | 26793           | 49.91         |
| 17                 | 6699        | 1586  | 174  | 8459   | 98   | 6698      | 0    | 593   | 8598        | 8860        | -1985                | 22243                  | 0                    | 22243                         | 3380                 | 480                           | 26103           | 49.98         |
| 18                 | 6687        | 1924  | 176  | 8787   | 110  | 6688      | 0    | 211   | 8068        | 8322        | -1842                | 21780                  | 0                    | 21780                         | 3243                 | 496                           | 25519           | 50.02         |
| 19                 | 6738        | 1585  | 181  | 8504   | 197  | 6846      | 0    | 6     | 7636        | 7656        | -1678                | 21044                  | 0                    | 21044                         | 3136                 | 487                           | 24667           | 50.07         |
| 20                 | 6761        | 1957  | 188  | 8906   | 234  | 6938      | 0    | 0     | 7116        | 7339        | -1443                | 21489                  | 0                    | 21489                         | 3087                 | 485                           | 25061           | 50.05         |
| 21                 | 6712        | 1165  | 188  | 8065   | 233  | 6980      | 0    | 0     | 7282        | 7342        | -1656                | 20517                  | 0                    | 20517                         | 2949                 | 447                           | 23913           | 50.04         |
| 22                 | 6696        | 787   | 188  | 7671   | 235  | 6858      | 0    | 0     | 7343        | 7265        | -1663                | 19914                  | 0                    | 19914                         | 2857                 | 452                           | 23223           | 50.03         |
| 23                 | 6634        | 1157  | 190  | 7981   | 227  | 6927      | 0    | 0     | 7202        | 7371        | -1640                | 20432                  | 0                    | 20432                         | 2839                 | 434                           | 23705           | 50.00         |
| 24                 | 6589        | 1351  | 189  | 8129   | 218  | 6863      | 0    | 0     | 7336        | 7323        | -1690                | 20427                  | 0                    | 20427                         | 2843                 | 416                           | 23686           | 49.99         |
| MUs                | 162.37      | 26.90 | 4.44 | 193.71 | 6.02 | 165.46    | 0.00 | 12.03 | 191.28      | 194.62      | -40.10               | 521.28                 | 0.00                 | 521.28                        | 69.51                | 10.46                         | 601.25          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 14/Mar/2023**

**Position as on 6.30 Hrs of 15/Mar/2023**

| Generating Company   | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|----------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>FORCED OUTAGE</b> |                         |          |              |              |           |            |                                                                                                                                                         |               |
| PGPL                 | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| PGPL                 | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| IPP                  | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                  | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| CENT.SECTOR          | Tarapur 1               | 160      | 08/01/2020   | 10:37        |           | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 31/03/2023    |
| MSPGCL               | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |           | Continued. | Turbine Blade Failure                                                                                                                                   | 07/04/2023    |
| CENT.SECTOR          | Tarapur 2               | 160      | 13/07/2020   | 04:38        |           | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 31/03/2023    |
| MSPGCL               | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |           | Continued. | Retired (04/08/2021 At 00.00)                                                                                                                           |               |
| MSPGCL               | Ghatghar Unit-1         | 125      | 20/04/2022   | 00:35        |           | Continued. | Stator Earth Fault                                                                                                                                      | 31/07/2023    |
| MSPGCL               | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |           | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 30/05/2023    |
| MSPGCL               | Uran Unit 5             | 108      | 12/11/2022   | 13:23        |           | Continued. | Gas shortage                                                                                                                                            |               |
| MSPGCL               | Ghatghar Unit-2         | 125      | 08/02/2023   | 07:02        |           | Continued. | Stator Earth Fault                                                                                                                                      | 30/04/2023    |
| MSPGCL               | Koradi Unit-10          | 660      | 09/03/2023   | 11:11        |           | Continued. | Boiler Tube Leakage                                                                                                                                     | 15/03/2023    |
| MSPGCL               | Nasik Unit 3            | 210      | 10/03/2023   | 15:22        |           | Continued. | Axial shift high                                                                                                                                        | 17/03/2023    |
| MSPGCL               | Uran Unit B0            | 120      | 11/03/2023   | 09:02        |           | Continued. | Bearing vibration high                                                                                                                                  | 25/03/2023    |
| IPP                  | Adani U-2               | 660      | 12/03/2023   | 18:02        |           | Continued. | turbine left hand side MS drain leakage                                                                                                                 | 15/03/2023    |
| MSPGCL               | Chandrapur Unit 9       | 500      | 13/03/2023   | 18:08        |           | Continued. | Boiler Tube Leakage                                                                                                                                     | 17/03/2023    |
| MSPGCL               | Koyna STG-IV Unit-1     | 250      | 15/03/2023   | 00:30        |           | Continued. | Tripped on Governor fault                                                                                                                               |               |
| MSPGCL               | Koradi Unit 8           | 660      | 15/03/2023   | 02:06        |           | Continued. | Boiler Tube Leakage                                                                                                                                     | 18/03/2023    |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 14/Mar/2023**

**Statement-VII**

Position as on 6.30 Hrs of 15/Mar/2023

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                         |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                          |
| CHANDRAPUR - PADGHE HVDC POLE 1          | IntraState                | 15/03/2023   | 23:40        | 15/03/2023 | 07:26      | EO          | For attending oil leakage Tie CT-B-Ph (WA-W4-T1)                                                                                                                                                         |
| <b>400 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                          |
| PADGHE - NAGOTHANE CKT - 1               | IntraState                | 09/03/2023   | 09:30        |            |            | PO          | CB replacement work                                                                                                                                                                                      |
| BABHALESHWAR - PADGHE CKT-1              | IntraState                | 13/03/2023   | 09:02        | 14/03/2023 | 22:48      | PO          | PG maintenance work;CB timing and DCRM                                                                                                                                                                   |
| NAGOTHANE - DABHOL CKT - 2               | IntraState                | 14/03/2023   | 10:21        | 14/03/2023 | 17:38      | PO          | Over voltage Relay replacement work                                                                                                                                                                      |
| KARAD - TALANDGE CKT - 1                 | IntraState                | 14/03/2023   | 10:45        | 14/03/2023 | 20:15      | PO          | PID Faulty disc insulator replacement work & Cold line washing work                                                                                                                                      |
| <b>400 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                          |
| STATION TF No 3 @ CHANDRAPUR GCR         | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                           |
| 400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR | IntraState                | 13/03/2023   | 10:38        | 14/03/2023 | 00:47      | PO          | 1. OLTC oil filtration work.<br>2. C Bus isolator OH work                                                                                                                                                |
| 400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI  | IntraState                | 14/03/2023   | 09:56        | 14/03/2023 | 18:47      | PO          | For ICT Painting work                                                                                                                                                                                    |
| <b>400 KV BR Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                          |
| 400KV 125MVAR BUS REACTOR @ CHANDRAPUR 2 | InterState                | 14/03/2023   | 09:42        | 14/03/2023 | 21:01      | PO          | Diagnostic testing and allied bay maintenance work                                                                                                                                                       |
| <b>220 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                          |
| EKLAHARE (OCR) - NAVASARI CKT - 1        | IntraState                | 10/02/2023   | 09:45        |            |            | PO          | Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)                                                                                                           |
| EKLAHARE (OCR) - PADGHE                  | IntraState                | 05/03/2023   | 08:55        |            |            | HT          | For load management                                                                                                                                                                                      |
| CTRLS - NET MAGIC GIS                    | IntraState                | 07/03/2023   | 12:43        |            |            | T           | Distance Protection.                                                                                                                                                                                     |
| VERSOVA - GHODBUNDER                     | IntraState                | 13/03/2023   | 09:50        | 14/03/2023 | 16:37      | PO          | Annul maintenance of circuit Breaker.                                                                                                                                                                    |
| EKLAHARA(GCR)(NASIK)-BABLESHWAR 1        | IntraState                | 13/03/2023   | 23:21        | 14/03/2023 | 05:42      | EO          | Replacement of 220KV BBLR - Nashik -1 line Distance relay on immediately basis. line will be in service                                                                                                  |
| SATANA - GANGAPUR                        | IntraState                | 14/03/2023   | 01:51        | 14/03/2023 | 02:49      | T           | Distance Protection                                                                                                                                                                                      |
| SHIVAJINAGAR - GANGAPUR                  | IntraState                | 14/03/2023   | 01:52        | 14/03/2023 | 02:48      | T           | Distance Protection                                                                                                                                                                                      |
| GANGAPUR-VALVE                           | IntraState                | 14/03/2023   | 01:52        | 14/03/2023 | 02:49      | T           | Distance Protection                                                                                                                                                                                      |
| CHINCHWAD- PARVATI                       | IntraState                | 14/03/2023   | 07:50        | 14/03/2023 | 18:31      | PO          | Erection of Monopoe at loc no.17 (Monopole type 220V DC-PD (30-60)-DE(0-15)+27Mtr. Extn)                                                                                                                 |
| FLAGSHIP-CHINCHWAD                       | IntraState                | 14/03/2023   | 07:50        | 14/03/2023 | 18:24      | PO          | Erection of Monopoe at loc no.17 (Monopole type 220V DC-PD (30-60)-DE(0-15)+27Mtr. Extn)                                                                                                                 |
| NANDGAON PETH-AMRAVATI                   | IntraState                | 14/03/2023   | 08:23        | 14/03/2023 | 13:04      | PO          | Replacement of Damaged Conductor                                                                                                                                                                         |
| MIRAJ - ICHALKARANJJI                    | IntraState                | 14/03/2023   | 08:46        | 14/03/2023 | 19:28      | EO          | For making bunching arrangement between Ckt I & II of 220 KV Tilnani - Miraj line at I.oc. No" 24 & 28 for Erection of Loc. No. 26A (D+3), 27A (MAN - 9) & 28A (SPND+3) for Jaysingpur - Kurundwad link. |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 14/Mar/2023**

**Statement-VII**

Position as on 6.30 Hrs of 15/Mar/2023

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                             |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------|
| EKLAHARE (GCR) - AIROLI KNOW PARK         | IntraState                | 14/03/2023   | 09:17        | 14/03/2023 | 19:10      | PO          | For Insulator cold washing work from loc no 191 to 215 (Samaruddhi highway nearby locations) |
| NEW KOYNA - PEDAMBE                       | IntraState                | 14/03/2023   | 09:21        | 14/03/2023 | 12:07      | PO          | Diagnostic testing & Relay testing work & Routine maint. Work                                |
| GHATGHAR - BAPGAON                        | IntraState                | 14/03/2023   | 09:29        | 14/03/2023 | 19:22      | PO          | For Insulator cold washing work from loc no 191 to 215 (Samaruddhi highway nearby locations) |
| VITA - GHATNANDRE                         | IntraState                | 14/03/2023   | 09:53        | 14/03/2023 | 17:28      | PO          | Cold washing of Insulator                                                                    |
| GCR CHANDRAPUR - GRACE LTD                | IntraState                | 14/03/2023   | 10:50        | 14/03/2023 | 13:00      | T           | PT Section Fail                                                                              |
| BOISAR II - TARAPUR                       | IntraState                | 14/03/2023   | 11:19        | 14/03/2023 | 17:28      | PO          | Replacement of Rusted Hardware, Old earthwire and other maintenance work.                    |
| 220 KV PARLI -U-8 - PARBHANI CKT          | IntraState                | 14/03/2023   | 12:08        | 14/03/2023 | 19:25      | PO          | Flash-over String replacement                                                                |
| KARAD -MUDSHINGI CKT 2-TAK                | IntraState                | 14/03/2023   | 14:10        | 14/03/2023 | 14:59      | T           | Tripped on distance protection                                                               |
| TROMBAY - KALWA                           | IntraState                | 14/03/2023   | 17:44        | 14/03/2023 | 23:56      | T           | Tripped on distance protection                                                               |
| <b>220 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                              |
| 220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE | IntraState                | 12/10/2020   | 11:35        |            |            | T           | Tripped due to Grid disturbance.                                                             |
| 220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE | IntraState                | 10/11/2022   | 10:35        |            |            | EO          | For attending to abnormal Nosie from ICT                                                     |
| 220/132KV 100 MVA ICT NO 2 @ MAGARPATTA   | IntraState                | 01/03/2023   | 11:09        |            |            | EO          | Replacement of Diverter shaft                                                                |
| 220/132KV 200MVA ICT 4 @ EKLAHARE (OCR)   | IntraState                | 14/03/2023   | 10:15        | 14/03/2023 | 11:17      | PO          | Diagnostic testing work ( CB CRM )                                                           |
| <b>110 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                              |
| DHARAVI VIKHROLI                          | IntraState                | 10/02/2023   | 23:17        |            |            | PO          | for 400KV Project work of KVPTL                                                              |
| DHARAVI POWAI                             | IntraState                | 10/02/2023   | 23:35        |            |            | PO          | For 400KV project work on KVPTL                                                              |
| WAGHIVALI - MANKHURD                      | IntraState                | 14/03/2023   | 23:56        | 15/03/2023 | 04:40      | PO          | Project work - Movement of Jack up barge in the vicinity of line at location 81N             |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage