

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 14/Mar/2024 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	157.390	2235.052	1) Gujrat	5.582	70.484
2) Hydro	10.765	131.788	2) Madhya Pradesh	8.015	169.966
3) Gas	7.095	92.695	3) Chattisgarh	4.880	59.260
Total MSPGCL	175.250	2459.535	4) Maharashtra	186.967	2422.806
B) 1) APLM	69.272	827.362	5) Goa (Amona)	-1.840	-26.351
2) JSWEL	28.090	368.598	Total	203.604	2696.165
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.850	409.752
4) RPL(AMT)	24.507	412.903	b) Mumbai Drawl	33.352	458.512
5) SWPGPL	12.444	162.220	c) MSEDCL Bilateral *	106.214	1383.901
6) Other IPP	43.354	645.978	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.850	409.752
C) 1) TPCL Thermal	11.847	150.777	Include PX	0.000	0.000
2) TPCL Hydro	5.129	56.450	Standby	0.000	0.000
3) TPCL Gas	4.079	49.995	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.109	122.935	1) MSEDCL	543.610	7389.809
D) STATE			2) Mumbai Discoms	64.516	838.664
1) Thermal	357.013	4925.825	3) Other Discoms	10.908	150.882
(A1+C1+C4+(B1-B6))			TOTAL STATE	619.034	8379.355
2) Hydro (A2+C2)	15.894	188.238			
3) Gas (A3+B7+C3)	11.174	142.690			
4) Wind	13.180	183.443			
6) SOLAR	18.169	242.999			
TOTAL STATE	415.430	5683.195			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6325	6142	7088	6446
MSPGCL Hydro	319	478	1489	193
MSPGCL Gas	295	286	293	303
MSPGCL Total Generation	6939	6906	8870	6942
Central Sector Receipt	9469	9233	7665	7844
WIND	350	235	495	697
CPP / IPP Thermal	7352	7120	7705	7608
CPP / IPP Gas	0	0	0	0
SOLAR	2265	2444	0	0
Exchange with Mumbai	-1787	-1742	-1158	-1024
MSEDCL DEMAND MET	24099	23726	23087	21716
Load Shedding	0	0	0	0
MSEDCL DEMAND	24099	23726	23087	21716
TPCL GENERATION	955	983	1267	620
AEML GENERATION	478	501	501	308
MUMBAI DEMAND	3220	3226	2926	1952
OTHER DISCOM DEMAND	488	471	490	351
STATE DEMAND MET	27808	27422	26503	24019
STATE DEMAND	27808	27422	26503	24019
Frequency (Hz)	49.98	49.98	49.98	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 18:03 Hrs	49.79 Hz at 19:20 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 14/Mar/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.42	59.08	185	109
Unit 8	7.80	187.33	583	148
Unit 9	0.06	105.98	64	0
Unit 10	10.72	162.01	464	420
Total	22.01	514.41		
Bhusawal				
Unit 3	4.10	48.50	185	130
Unit 4	11.08	139.88	500	360
Unit 5	0.00	82.11	0	0
Total	15.18	270.49		
Parli				
Unit 6	4.57	57.31	246	145
Unit 7	4.40	56.12	241	144
Unit 8	4.84	36.64	250	146
Total	13.81	150.06		
Chandrapur				
Unit 3	3.65	45.25	157	140
Unit 4	4.05	36.45	173	139
Unit 5	9.97	117.08	435	350
Unit 6	9.67	118.02	425	330
Unit 7	10.12	118.01	453	359
Unit 8	9.95	129.44	420	400
Unit 9	11.61	133.16	492	472
Total	59.04	697.43		
Paras				
Unit 3	5.68	76.95	242	231
Unit 4	5.91	79.73	251	230
Total	11.59	156.68		
Khaparkheda				
Unit 1	3.80	51.13	185	120
Unit 2	4.17	54.19	201	141
Unit 3	4.04	52.68	176	148
Unit 4	4.19	55.17	192	145
Unit 5	11.91	141.14	500	492
Total	28.11	354.31		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.94	50.95	179	134
Unit 5	3.71	40.72	163	142
Total	7.65	91.68		
Uran				
All Units	7.10	92.70	305	285
Total	7.10	92.70		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.12	1.22	51	0
Total	0.12	1.22		
Koyna				
Stage 1-2	2.36	26.32	295	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	2.28	24.31	673	0
Stage 3	0.82	11.29	240	0
Total	5.47	61.93		
Hydro				
KDPH	0.86	12.10	36	36
VTRNA	0.69	9.13	61	0
TILLARI	0.70	6.80	66	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.92	36.34	130	114
GHATGHAR	0.00	4.26	0	0
Total	5.18	68.63		
Wind				
Total	13.18	183.44	0	0
Total	13.18	183.44		
CPP				
APML(Mus)	69.27	827.36	0	0
JSWEL(Mus)	28.09	368.60	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.51	412.90	0	0
SWPGPL-Mus	12.44	162.22	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.16	83.51	267	243
Other(Mus)	32.58	502.72	0	0
JPL	4.62	59.75	237	163
Total	177.67	2417.06		
SOLAR				
Total	18.17	243.00	0	0
Total	18.17	243.00		
Tata				
Trombay 5	7.73	98.64	446	261
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.54	30.46	108	79
Trombay 7B	1.54	19.54	65	57
TATA Hydro	5.13	56.45	429	41
Trombay 8	4.12	52.14	225	133
Total	21.06	257.22		
AEML				
DTPS U-1&2	10.11	122.94	501	308
Total	10.11	122.94		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	157.39	2235.05	MSPGCL Total	175.25	2459.54
			MSPGCL Thml+Gas	164.48	2327.75	Koyna 1,2 & 4 Total	4.64	50.64
			MSPGCL Hydro	10.76	131.79	State Total	415.43	5683.20

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 14/Mar/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6465	198	300	6963	539	7531	0	0	8281	8037	-1173	21487	0	0	21487	2333	409	24230	49.94
2	6504	193	300	6997	700	7628	0	0	8277	7983	-1185	21731	0	0	21731	2167	392	24290	49.97
3	6425	198	302	6925	794	7455	0	0	8147	7950	-1091	21680	0	0	21680	2043	353	24076	49.98
4	6446	193	303	6942	697	7608	0	0	8078	7844	-1024	21716	0	0	21716	1952	351	24019	49.98
5	6511	197	303	7011	781	7706	0	0	8246	8178	-1030	22279	0	0	22279	1958	367	24604	49.97
6	6579	267	305	7151	821	7689	0	0	8585	8640	-1129	22771	0	0	22771	2073	401	25245	49.97
7	6572	1145	303	8020	834	7827	0	20	8253	8055	-1092	23222	0	11	23222	2257	442	25921	50.01
8	6427	848	305	7580	581	7811	0	388	8155	8269	-880	23281	0	3	23281	2453	468	26202	50.05
9	6160	306	302	6768	445	7318	0	1146	8887	9294	-1338	23150	0	0	23150	2759	483	26392	50.02
10	6264	421	294	6979	370	7084	0	1798	9469	9504	-1664	23579	0	0	23579	3038	492	27109	50.00
11	6325	319	295	6939	350	7352	0	2265	9764	9469	-1787	24099	0	4	24099	3220	488	27808	49.98
12	6231	567	287	7085	236	7312	0	2410	9397	9127	-1854	23837	0	8	23837	3272	480	27588	50.00
13	6142	478	286	6906	235	7120	0	2444	9403	9233	-1742	23726	0	10	23726	3226	471	27422	49.98
14	6057	269	285	6611	338	6877	0	2431	9417	9199	-1865	23118	0	10	23118	3092	473	26683	50.03
15	6069	262	286	6617	312	6899	0	2068	9817	9471	-1931	22944	0	7	22944	3126	492	26562	49.98
16	6676	299	286	7261	459	6970	0	1763	9613	9296	-1900	23347	0	0	23347	3150	502	26999	49.97
17	6906	282	288	7476	513	7120	0	1024	9270	9052	-1674	23023	0	3	23023	3110	488	26621	49.96
18	7109	331	288	7728	473	7531	0	389	9040	8542	-1561	22614	0	4	22614	3033	488	26135	50.02
19	7116	760	290	8166	491	7615	0	23	8131	7659	-1436	22001	0	0	22001	2940	518	25458	50.00
20	7088	1489	293	8870	495	7705	0	0	7754	7665	-1158	23087	0	0	23087	2926	490	26503	49.98
21	7002	643	295	7940	588	7736	0	0	7943	7737	-1262	22253	0	0	22253	2787	486	25526	50.00
22	6825	326	300	7451	656	7393	0	0	7931	7790	-1247	21560	0	0	21560	2639	483	24682	49.98
23	6795	293	300	7388	751	7282	0	0	8099	7760	-1140	21607	0	0	21607	2528	434	24569	49.96
24	6696	481	299	7476	721	7098	0	0	8084	7850	-1189	21498	0	0	21498	2434	458	24390	49.96
MUs	157.39	10.77	7.09	175.25	13.18	177.67	0.00	18.17	208.04	203.60	-33.35	543.61	0.00	0.06	543.61	64.52	10.91	619.03	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR Carried out due to 132kv BBLR-Rahuri line Overload.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 14/Mar/2024

Position as on 6.30 Hrs of 15/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	28/03/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	10/04/2024
MSPGCL	Nasik Unit 3	210	18/01/2024	16:56		Continued.	Tolling (Converted to Planned outage on dt 02.02.2024 for boiler & allied work.)	17/03/2024
Total Capacity MSPGCL		398						
Total Capacity PLANNED OUTAGE		398						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Koradi Unit 9	660	09/03/2024	13:49	14/03/2024	22:56	SUSPECTED BTL	14/03/2024
MSPGCL	Bhusawal Unit 5	500	09/03/2024	22:00	15/03/2024	06:55	Boiler Tube Leakage	14/03/2024
MSPGCL	Ghatghar Unit-1	125	11/03/2024	18:40		Continued.	GM Link Fault	15/03/2024
MSPGCL	Uran Unit 6	108	12/03/2024	20:15		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Ghatghar Unit-2	125	14/03/2024	18:15		Continued.	GM Link Fault	15/03/2024
MSPGCL	Koradi Unit 6	210	15/03/2024	00:00		Continued.	Boiler Tube Leakage	18/03/2024
Total Capacity MSPGCL		1848						
IPP								
IPP	RPL(AMT) U-5	270	11/03/2024	03:00		Continued.	Air heater problem	18/03/2024
IPP	RPL(AMT) U-2	270	14/03/2024	16:30	14/03/2024	18:40	Due to unit board B tripped.	
Total Capacity IPP		540						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2708						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 14/Mar/2024

Position as on 6.30 Hrs of 15/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 15/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (411) OF DHARIWAL CKT - 2 & NANDED CKT @ CHANDRAPUR - 2	IntraState	08/03/2024	09:56			PO	Replacement of non-PIR CB by with PIR CB
TIE BAY OF (408) OF ICT-1 AND FUTURE CKT @ KUDUS	IntraState	14/03/2024	10:31	14/03/2024	20:27	PO	Annual Maintenance of bays equipment & Diagnostics Testing Work
400 KV MAINBAY Outages/Trippings							
BUS COUPLER @ CHANDRAPUR	IntraState	11/03/2024	13:46			PO	1. For attending the high CRM problem of CB by excuting the pole overhauling work. 2.Measurement of tandelta & capacitance of CT. 3. Bay routine maintenance work
MAIN BAY (407) OF ICT-1 @ KUDUS	IntraState	14/03/2024	10:31	14/03/2024	19:39	PO	Annual Maintenance of bays equipment & Diagnostics Testing Work
400 KV LINE Outages/Trippings							
DHULE - KHANDWA CKT - 1	InterState	14/03/2024	08:25	15/03/2024	01:30	PO	Line Maintenance work
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
PADGHE - KALWA CKT - 1	IntraState	11/02/2024	00:35			PO	For tapping of 400kV Kalwa-Padgha-1 line (Loc no. 1113) with 400kV Kalwa-Kharghar line Loc no. 167 (Tapping work will be finished by 11.06.2024 @ 06:00 Hrs) using ERS thereby forming temporary 400kV Kalwa-Kharghar -Padgha Tap line and carrying out replacement of existing conductor the HTLS conductor of 400kV Kalwa-Padgha-1 line 1148 (Airoli) to 1114 (Shilphata)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42			HT	H/T for controlling loading of 400kV Talegaon-Chakan
PARLI - KUMBHARGAON(NANDED) CKT - 2	IntraState	14/03/2024	11:03	14/03/2024	18:42	PO	Bay Maintenance, DCRM of Line Bay CB ,Relay Testing Works
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	14/03/2024	12:14	14/03/2024	19:00		1] Attending conductor damage at Loc no. 356,394,508 2] Replacement of PID faulty insulator strings
TBC @ BABHALESHWAR	IntraState	14/03/2024	12:24	14/03/2024	17:30	PO	CB DCRM/Timing testing work
EKTUNI - BABLESHWAR CKT - 1	IntraState	14/03/2024	13:22	14/03/2024	20:14	PO	Line Maintenance and Bay Maintenance Works
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	04/03/2024	11:26			PO	Internal inspection of 315 MVA ICT 02 by agency M/s Mahati Electrical.
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	13/03/2024	12:37			PO	Diagnostic Testing and routine maintenance work.
400/220/33 KV 500 MVA ICT - 3 @ JEJURI	IntraState	14/03/2024	12:45	14/03/2024	16:20	PO	ICT-3 220kV side CB testing work by shifting ICT-3 IV side on TBC.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 14/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 15/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	IntraState	14/03/2024	18:31	14/03/2024	19:39	PO	220kV side breaker DT work
400 KV BR Outages/Tripping							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	06/01/2024	11:55			PO	Existing 125 MVAR Reactor CB Have mechanical problem and need to replace
BUS REACTOR (50 MVar) @ KORADI	IntraState	15/03/2024	08:25			PO	Retrofitting of old YTG33 Backup Impedance relay by New GE make P443
220 KV TBC Outages/Tripping							
TBC @ LONAND	IntraState	14/03/2024	10:49			PO	Commissioning Work of 220kV CT's
220 KV MAINBAY Outages/Tripping							
220KV BUS COUPLER	IntraState	14/03/2024	11:08	14/03/2024	13:08	PO	Diagnostic testing work and bay maintenance work
220 KV LINE Outages/Tripping							
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
KARAD - DASGAON	IntraState	28/02/2024	18:03			PO	For Erection & Stringing of In-line narrow base multi circuit tower (Loc No.150,151 & 152) of New 220kV Karad-Koyana line
SADAWAGHAPUR KARAD CKT 2	IntraState	12/03/2024	09:27			PO	For Relay Retrofitting work
220 KV KAULEWADA-KORADI 2 CKT - I	IntraState	13/03/2024	22:13	14/03/2024	09:31	T	Distance protection operated.
TALOJA - PANCHANAND	IntraState	14/03/2024	09:18	14/03/2024	20:18	PO	Urgent Isolator Support Structure pole Replacement work of Line isolator, Bus Isolator & Auxiliary Isolator pole
LONIKAND 2 - BHOSARI	IntraState	14/03/2024	09:25	14/03/2024	10:58	T	Tripped on distance protection
ALEPHATA-PARGAON(KATHAPUR)	IntraState	14/03/2024	10:23	14/03/2024	17:35	PO	To carryout the work of fixing of repair sleeves at loc no.214-215 B-ph and 200-201 B-ph and Cleaning of disc insulator string by chemical washing
220 KV GIRWALI - MURUD CKT	IntraState	14/03/2024	10:35	14/03/2024	18:10	PO	Fixing of turbo wind driven birdguard
LAMBOTI - PANDHARPUR	IntraState	14/03/2024	10:35	14/03/2024	18:40	PO	PID testing of Insulator strings.
LAMBOTI - KARKAMB	IntraState	14/03/2024	10:40	14/03/2024	18:50	PO	PID Testing of Insulator Strings.
JNPT - JNPT SEZ	IntraState	14/03/2024	10:55	14/03/2024	17:30	PO	For relay testing & diagnostic testing work.
CENTURI ENKA- BHOSARI	IntraState	14/03/2024	11:09	14/03/2024	12:54	PO	CB CRM & CB Timing testing work and Half Yearly Maintenance Work
SAHARA-URSE	IntraState	14/03/2024	12:52	14/03/2024	17:00	PO	1) For fixing of conductor vibration damper. 2) Cold line washing of insulators.
BORIVALI - TARAPUR	IntraState	14/03/2024	16:05			PO	PM of 220kV Borivali Feeder's bay equipments (CT,Breaker,isolator,wave trap,CVT,LA etc.), gantry insulators inspection & current carrying clamps tightness/reconditioning.
POPHLI PEDHMBE LINE- 2	IntraState	15/03/2024	08:10			PO	For R,Y,B, Phase CT replacement work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 15/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - PADGHE	IntraState	15/03/2024	08:45			PO	. For the conversion of STN into DTN towards highway side due to crossing of National Highway (Mumbai Agra Highway) at loc.no.318.
KARAD - VITA CKT- 1	IntraState	15/03/2024	09:01			PO	Replacement Work of old disc insulator by long rod insulators at various locations.
220 KV ICT Outages/Trippings							
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	21/02/2024	10:23			PO	AUGUMENTATION OF ICT 3 FROM 100MVA ICT TO NEW 200MVA ICT
220/110 KV 155MVA ICT-1@ BHIRA (T)-220 KV	IntraState	05/03/2024	07:40			PO	ICI 1 overhauling ,Testing ,CRP replacement of CPLR 1-2 ,ICT 1
220/33 KV 50 MVA PTR 1@ HAMIDWADA	IntraState	14/03/2024	08:53	14/03/2024	15:18	PO	SFRA DFRA Testing By PAC circle. Relay Testing & Quarterly maintenance work.
220/132KV 100 MVA ICT 2@ PETH	IntraState	14/03/2024	09:01	14/03/2024	17:19	PO	1.OLTC gear box & DM box maintenance work 2.Testing & Checking healthiness with preventive maintenance of NIFPS
220/132 KV 200 MVA ICT 3	IntraState	14/03/2024	10:03	14/03/2024	11:45	T	OLTC BPh PRV Operated.
BUS COUPLER @ LONIKAND	IntraState	14/03/2024	11:28	14/03/2024	14:00	PO	DT and Bay Maintenance work
220/132 KV 150 MVA ICT @ BOISAR-II	IntraState	14/03/2024	22:17	14/03/2024	23:33	HT	Emergency outage for attending CTR Fire protection alarm
220/100 KV 200 MVA ICT 1 @ PADGHE	IntraState	15/03/2024	09:04			PO	For diagnostic testing of LV side CT's and for isolator structure repairing work.
220 KV BUSBAR Outages/Trippings							
BUS SECTION-2 @ MAHAPE	IntraState	15/03/2024	05:27			PO	Outage is required on 220kV Bus Section -1 & 2 with 220kV bus PT for:- 1)Maintenance work. 2) Maintenance & Diagnostic testing work of 220kV Bus PT. 3) Replacement of B ph CT of 220kV Mahape -TFIPL line
132 KV LINE Outages/Trippings							
KANHAN-PENCH	IntraState	15/03/2024	10:02			PO	For earthwire replacement & other Routine Maint. Work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
TROMBAY PAREL 3 / CARNAC 2	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
TROMBAY CARNAC 1 / 3	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
AMBERNATH - KALYAN CKT - 2	IntraState	14/03/2024	10:10	14/03/2024	13:29	PO	CLOSER INSPECTION

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage