

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 14/May/2015 THURSDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 118.489        | 1643.488        | 1) Gujrat                      | -3.861         | -52.047         |
| 2) Hydro            | 25.801         | 278.455         | 2) Madhya Pradesh              | 13.490         | 179.973         |
| 3) Gas              | 6.649          | 90.868          | 3) Chattisgarh                 | 6.420          | 86.990          |
| <b>Total MSPGCL</b> | <b>150.939</b> | <b>2012.811</b> | 4) Maharashtra Net             | 92.811         | 1422.738        |
| B) 1) APMIL         | 52.130         | 756.070         | 5) Goa                         | -6.891         | -101.613        |
| 2) JSWEL            | 20.710         | 329.178         | 6) TAPS 1&2 Injection          | 3.298          | 46.294          |
| 3) VIPL             | 9.283          | 161.029         | 7) RGPPL Injection             | 0.000          | 0.000           |
| 4) RPL(AMT)         | 4.620          | 78.130          | 8) Pench (MS)                  | 0.092          | 0.970           |
| 5) WPCL             | 8.152          | 116.207         | 9) Pench (Excess)              | -0.092         | -0.970          |
| 6) Other IPP        | 4.459          | 79.964          | <b>Total</b>                   | <b>105.175</b> | <b>1581.365</b> |
| C) 1) TPCL Thermal  | 17.194         | 232.875         | a) Mumbai Schedule             | 23.429         | 366.325         |
| 2) TPCL Hydro       | 4.126          | 51.134          | b) Mumbai Drawl                | 30.172         | 390.117         |
| 3) TPCL Gas         | 2.918          | 42.423          | c) MSEDCL Bilateral *          | 31.435         | 432.169         |
| 4) R-INFRA Thermal  | 12.295         | 167.758         | Include PX                     | -0.816         | 5.243           |
| <b>D) STATE</b>     |                |                 | d) Mumbai Bilateral *          | 23.429         | 366.275         |
| 1) Thermal          | 247.332        | 3564.699        | Include PX                     | 1.528          | 28.442          |
| (A1+C1+C4+(B1-B6))  |                |                 | Include Standby                | 0.000          | 0.050           |
| 2) Hydro            | 29.927         | 329.589         | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 3) Gas              | 9.567          | 133.291         | 1) MSEDCL                      | 332.697        | 4912.314        |
| 4) Wind             | 6.517          | 170.325         | 2) Mumbai Discoms              | 66.710         | 884.307         |
| 6) SOLAR            | 0.884          | 16.382          | <b>TOTAL STATE</b>             | <b>399.407</b> | <b>5796.621</b> |
| <b>TOTAL STATE</b>  | <b>294.227</b> | <b>4214.286</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 21 Hrs | D. Night Minimum at 5 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4959                      | 5002                  | 5230                      | 4872                      |
| MSPGCL Hydro             | 1869                      | 1889                  | 1306                      | 126                       |
| MSPGCL Gas               | 276                       | 280                   | 275                       | 277                       |
| MSPGCL Total Generation  | 7104                      | 7171                  | 6811                      | 5275                      |
| Central Sector Receipt   | 4444                      | 4765                  | 4501                      | 3967                      |
| WIND                     | 55                        | 31                    | 472                       | 592                       |
| CPP / IPP                | 4328                      | 4456                  | 4223                      | 3587                      |
| SOLAR                    | 116                       | 85                    | 0                         | 0                         |
| Exchange with Mumbai     | -1460                     | -1502                 | -1379                     | -914                      |
| <b>MSEDCL DEMAND MET</b> | <b>14587</b>              | <b>15006</b>          | <b>14628</b>              | <b>12507</b>              |
| Load Shedding            | 52                        | 48                    | 49                        | 47                        |
| MSEDCL DEMAND            | 14639                     | 15054                 | 14677                     | 12554                     |
| TPCL GENERATION          | 1314                      | 1300                  | 986                       | 708                       |
| R-INFRA GENERATION       | 510                       | 510                   | 519                       | 519                       |
| <b>MUMBAI DEMAND</b>     | <b>3284</b>               | <b>3312</b>           | <b>2884</b>               | <b>2141</b>               |
| STATE DEMAND MET         | 17871                     | 18318                 | 17512                     | 14648                     |
| <b>STATE DEMAND</b>      | <b>17923</b>              | <b>18366</b>          | <b>17561</b>              | <b>14695</b>              |
| Frequency (Hz)           | 49.98                     | 49.81                 | 49.94                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.17 Hz at 18.02 Hrs | 49.71 Hz at 22.07 Hrs | 49.95         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 14/May/2015

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 5             | 3.65         | 43.33         | 160      | 145      |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 3.77         | 51.94         | 165      | 150      |
| <b>Total</b>       | <b>7.42</b>  | <b>95.28</b>  |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 9.02         | 146.70        | 390      | 365      |
| Unit 5             | 7.27         | 140.62        | 400      | 0        |
| <b>Total</b>       | <b>16.28</b> | <b>287.32</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 3             | 0.00         | 9.15          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 3.59         | 40.41         | 156      | 146      |
| Unit 6             | 4.86         | 74.04         | 245      | 190      |
| Unit 7             | 4.99         | 73.49         | 250      | 187      |
| <b>Total</b>       | <b>13.43</b> | <b>197.10</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 3.04         | 33.83         | 133      | 117      |
| Unit 3             | 4.24         | 63.20         | 200      | 166      |
| Unit 4             | 0.00         | 47.75         | 0        | 0        |
| Unit 5             | 9.41         | 42.74         | 435      | 370      |
| Unit 6             | 9.10         | 100.72        | 415      | 360      |
| Unit 7             | 9.05         | 132.56        | 419      | 317      |
| <b>Total</b>       | <b>34.84</b> | <b>420.80</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.22         | 73.40         | 241      | 0        |
| Unit 4             | 5.10         | 74.47         | 250      | 197      |
| <b>Total</b>       | <b>9.31</b>  | <b>147.87</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.90         | 57.63         | 170      | 155      |
| Unit 2             | 3.58         | 50.50         | 165      | 125      |
| Unit 3             | 2.42         | 43.59         | 178      | 0        |
| Unit 4             | 4.08         | 58.62         | 177      | 160      |
| Unit 5             | 10.01        | 116.24        | 465      | 390      |
| <b>Total</b>       | <b>23.98</b> | <b>326.59</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 4.46         | 64.38         | 200      | 180      |
| Unit 4             | 4.40         | 57.68         | 194      | 180      |
| Unit 5             | 4.37         | 46.46         | 187      | 178      |
| <b>Total</b>       | <b>13.22</b> | <b>168.53</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.65         | 90.87         | 281      | 272      |
| <b>Total</b>       | <b>6.65</b>  | <b>90.87</b>  |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |

| Generating unit | Generation   |                |          |          |
|-----------------|--------------|----------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| Pench (MS)      | 0.09         | 0.97           | 45       | 0        |
| <b>Total</b>    | <b>0.09</b>  | <b>0.97</b>    |          |          |
| <b>Koyna</b>    |              |                |          |          |
| Stage 1-2       | 5.75         | 74.36          | 475      | 40       |
| Stage 4         | 12.00        | 106.27         | 1059     | 0        |
| Stage 3         | 3.60         | 39.47          | 300      | 0        |
| <b>Total</b>    | <b>21.35</b> | <b>220.10</b>  |          |          |
| <b>Hydro</b>    |              |                |          |          |
| KDPH            | 0.40         | 6.94           | 17       | 16       |
| VTRNA           | 0.83         | 12.65          | 61       | 0        |
| TILLARI         | 0.37         | 5.22           | 63       | 0        |
| BHTGR/VEER      | 0.06         | 0.88           | 3        | 2        |
| BHIRA T.R.      | 0.21         | 2.58           | 40       | 0        |
| RNGR+BHTSA      | 0.27         | 3.10           | 12       | 11       |
| BHANDARDRA      | 0.30         | 3.46           | 13       | 12       |
| ELDARY          | 0.23         | 2.09           | 10       | 9        |
| SMLHY_PTN       | 0.74         | 10.13          | 38       | 28       |
| GHATGHAR        | 1.05         | 11.31          | 250      | 0        |
| <b>Total</b>    | <b>4.45</b>  | <b>58.36</b>   |          |          |
| <b>Wind</b>     |              |                |          |          |
| Total           | 6.52         | 170.32         | 0        | 0        |
| <b>Total</b>    | <b>6.52</b>  | <b>170.32</b>  |          |          |
| <b>CPP</b>      |              |                |          |          |
| APML(Mus)       | 52.13        | 756.07         | 0        | 0        |
| JSWEL(Mus)      | 20.71        | 329.18         | 0        | 0        |
| VIPL(Mus)       | 9.28         | 161.03         | 0        | 0        |
| RPLAMT(Mus)     | 4.62         | 78.13          | 0        | 0        |
| WPCL(Mus)       | 8.15         | 116.21         | 0        | 0        |
| Other(Mus)      | 4.46         | 79.96          | 0        | 0        |
| <b>Total</b>    | <b>99.35</b> | <b>1520.58</b> |          |          |
| <b>SOLAR</b>    |              |                |          |          |
| Total           | 0.88         | 16.38          | 0        | 0        |
| <b>Total</b>    | <b>0.88</b>  | <b>16.38</b>   |          |          |
| <b>Tata</b>     |              |                |          |          |
| Trombay 5       | 11.21        | 150.05         | 496      | 397      |
| Trombay 6       | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A      | 2.03         | 25.42          | 107      | 59       |
| Trombay 7B      | 0.88         | 17.01          | 64       | 0        |
| Trombay 8       | 5.98         | 82.82          | 252      | 245      |
| TATA Hydro      | 4.13         | 51.13          | 471      | 0        |
| <b>Total</b>    | <b>24.24</b> | <b>326.43</b>  |          |          |
| <b>R-INFRA</b>  |              |                |          |          |
| 1-2             | 12.30        | 167.76         | 519      | 414      |
| <b>Total</b>    | <b>12.30</b> | <b>167.76</b>  |          |          |

| Summary         |             |               |
|-----------------|-------------|---------------|
| Particulars     | Daily (Mus) | Monthly (Mus) |
| MSPGCL Thermal  | 118.49      | 1643.49       |
| MSPGCL Thml+Gas | 125.14      | 1734.36       |

| Summary      |             |               |
|--------------|-------------|---------------|
| Particulars  | Daily (Mus) | Monthly (Mus) |
| MSPGCL Hydro | 25.80       | 278.46        |
| MSPGCL Total | 150.94      | 2012.81       |

| Summary             |             |               |
|---------------------|-------------|---------------|
| Particulars         | Daily (Mus) | Monthly (Mus) |
| Koyna 1,2 & 4 Total | 17.75       | 180.62        |
| State Total         | 294.23      | 4214.29       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 14/May/2015

### Annexure-2

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND | CPP /<br>IPP | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|------|--------------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |      |              |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4826        | 415   | 278  | 5519   | 588  | 4394         | 0     | 4329        | 4586        | -1366                | 13721                 | 71                   | 13792                     | 2686             | 16478           | 49.95         |
| 2                  | 4799        | 210   | 278  | 5287   | 562  | 4113         | 0     | 4263        | 4103        | -985                 | 13080                 | 47                   | 13127                     | 2460             | 15587           | 49.96         |
| 3                  | 4797        | 120   | 279  | 5196   | 633  | 3784         | 0     | 4316        | 4403        | -996                 | 13020                 | 47                   | 13067                     | 2320             | 15387           | 49.99         |
| 4                  | 4814        | 120   | 278  | 5212   | 614  | 3625         | 0     | 4138        | 4259        | -937                 | 12773                 | 47                   | 12820                     | 2205             | 15025           | 50.00         |
| 5                  | 4872        | 126   | 277  | 5275   | 592  | 3587         | 0     | 3990        | 3967        | -914                 | 12507                 | 47                   | 12554                     | 2141             | 14695           | 50.00         |
| 6                  | 4865        | 120   | 278  | 5263   | 491  | 3637         | 0     | 4355        | 4315        | -882                 | 12824                 | 52                   | 12876                     | 2134             | 15010           | 49.99         |
| 7                  | 4532        | 400   | 278  | 5210   | 437  | 3684         | 4     | 4466        | 4625        | -833                 | 13127                 | 54                   | 13181                     | 2094             | 15275           | 50.01         |
| 8                  | 4521        | 633   | 276  | 5430   | 251  | 3651         | 24    | 4495        | 4786        | -937                 | 13205                 | 54                   | 13259                     | 2197             | 15456           | 49.99         |
| 9                  | 4558        | 1145  | 278  | 5981   | 160  | 3726         | 53    | 4600        | 4941        | -1173                | 13688                 | 54                   | 13742                     | 2512             | 16254           | 49.94         |
| 10                 | 4655        | 1495  | 275  | 6425   | 149  | 4225         | 84    | 4602        | 4369        | -1443                | 13809                 | 54                   | 13863                     | 2962             | 16825           | 49.91         |
| 11                 | 4909        | 1699  | 276  | 6884   | 77   | 4312         | 103   | 4723        | 4620        | -1449                | 14547                 | 52                   | 14599                     | 3162             | 17761           | 49.94         |
| 12                 | 4959        | 1869  | 276  | 7104   | 55   | 4328         | 116   | 4739        | 4444        | -1460                | 14587                 | 52                   | 14639                     | 3284             | 17923           | 49.98         |
| 13                 | 5004        | 1596  | 277  | 6877   | 16   | 4466         | 118   | 4793        | 4503        | -1422                | 14558                 | 52                   | 14610                     | 3284             | 17894           | 49.92         |
| 14                 | 5009        | 1555  | 277  | 6841   | 27   | 4413         | 118   | 4683        | 4553        | -1484                | 14468                 | 52                   | 14520                     | 3219             | 17739           | 49.94         |
| 15                 | 5015        | 1561  | 278  | 6854   | 27   | 4491         | 113   | 4796        | 4880        | -1489                | 14876                 | 47                   | 14923                     | 3279             | 18202           | 49.86         |
| 16                 | 5002        | 1889  | 280  | 7171   | 31   | 4456         | 85    | 4649        | 4765        | -1502                | 15006                 | 48                   | 15054                     | 3312             | 18366           | 49.81         |
| 17                 | 4969        | 1864  | 281  | 7114   | 38   | 4366         | 42    | 4570        | 4686        | -1378                | 14868                 | 48                   | 14916                     | 3266             | 18182           | 49.96         |
| 18                 | 4828        | 1104  | 272  | 6204   | 45   | 4258         | 22    | 4265        | 4202        | -1427                | 13304                 | 48                   | 13352                     | 3141             | 16493           | 50.02         |
| 19                 | 4951        | 1471  | 274  | 6696   | 80   | 4300         | 2     | 3388        | 3633        | -1308                | 13403                 | 48                   | 13451                     | 2926             | 16377           | 49.93         |
| 20                 | 5172        | 1705  | 276  | 7153   | 140  | 4254         | 0     | 4105        | 3402        | -1348                | 13601                 | 49                   | 13650                     | 2905             | 16555           | 49.96         |
| 21                 | 5230        | 1306  | 275  | 6811   | 472  | 4223         | 0     | 4298        | 4501        | -1379                | 14628                 | 49                   | 14677                     | 2884             | 17561           | 49.94         |
| 22                 | 5349        | 944   | 275  | 6568   | 410  | 4238         | 0     | 4096        | 4048        | -1346                | 13918                 | 49                   | 13967                     | 2812             | 16779           | 49.99         |
| 23                 | 5419        | 948   | 277  | 6644   | 334  | 4325         | 0     | 4254        | 4521        | -1386                | 14438                 | 49                   | 14487                     | 2797             | 17284           | 49.85         |
| 24                 | 5434        | 1506  | 280  | 7220   | 288  | 4498         | 0     | 4193        | 4063        | -1328                | 14741                 | 49                   | 14790                     | 2723             | 17513           | 49.92         |
| MUs                | 118.49      | 25.80 | 6.65 | 150.94 | 6.52 | 99.35        | 0.88  | 105.11      | 105.17      | -30.17               | 332.70                | 1.22                 | 333.92                    | 66.70            | 400.62          | 49.95         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center,Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 14/May/2015

Position as on 6.30 Hrs of 15/May/2015

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                 |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 12/10/2014   | 22:39        |            | Continued. | Refuelling work                                                 |               |
| MSPGCL                | Koradi Unit 6           | 210      | 20/03/2015   | 01.02        |            | Continued. | Renovation and Modification work                                |               |
| MSPGCL                | Parli Unit 4            | 210      | 13/04/2015   | 11.27        |            | Continued. | Turbine vibration high.<br>Continued to AOH<br>w.e.f.01.05.2015 | 26/06/2015    |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                 |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |            | Continued. | Gas Shortage.                                                   |               |
| RGPL                  | Dabhol 3A               | 230      | 06/06/2013   | 08.28        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 2A               | 230      | 06/06/2013   | 09.10        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 2X               | 290      | 15/07/2013   | 15.09        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 2B               | 230      | 08/08/2013   | 15.03        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 3X               | 290      | 29/12/2013   | 05.47        |            | Continued. | Gas Shortage                                                    |               |
| RGPL                  | Dabhol 3B               | 230      | 29/12/2013   | 06.14        |            | Continued. | Gas Shortage                                                    |               |
| IPP                   | Dhariwal                | 300      | 28/05/2014   | 02.27        |            | Continued. | PA Fan Vibration Problem                                        |               |
| MSPGCL                | Chandrapur Unit 1       | 210      | 28/08/2014   | 07:15        |            | Continued. | Economic Shutdown.                                              |               |
| MSPGCL                | Bhusawal Unit 2         | 210      | 13/09/2014   | 12.43        |            | Continued. | Economic shutdown                                               |               |
| IPP                   | RPL(AMT) U-1            | 270      | 21/03/2015   | 23.28        |            | Continued. | Turbine vibration high.                                         |               |
| MSPGCL                | Chandrapur Unit-8       | 500      | 29/03/2015   | 18.26        |            | Continued. | Withdrawn                                                       |               |
| MSPGCL                | Koradi Unit-8           | 660      | 30/03/2015   | 20.22        |            | Continued. | BLR Tripped.                                                    |               |
| MSPGCL                | Uran Unit 6             | 108      | 01/04/2015   | 16.35        |            | Continued. | Gas shortage                                                    |               |
| IPP                   | RPL(AMT) U-4            | 270      | 03/04/2015   | 11.42        |            | Continued. | Boiler feed Pump problem.                                       |               |
| IPP                   | RPL(AMT) U-5            | 270      | 03/04/2015   | 14.22        |            | Continued. | turbine Shaft Vibration high.                                   |               |
| IPP                   | RPL(AMT) U-3            | 270      | 05/04/2015   | 22.01        |            | Continued. | Governor AVR Problem.                                           |               |
| TPC-G                 | Trombay 6               | 500      | 06/04/2015   | 16.27        |            | Continued. | Economic shut down.                                             |               |
| MSPGCL                | Uran Unit 7             | 108      | 17/04/2015   | 00.07        |            | Continued. | Gas turbine problem                                             |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 20/04/2015   | 00.00        |            | Continued. | no buyer as per msdcl requirment                                |               |
| MSPGCL                | Parli Unit 3            | 210      | 03/05/2015   | 20.51        |            | Continued. | Sparking on Slipring.                                           |               |
| IPP                   | Adani U-3               | 660      | 11/05/2015   | 00.52        |            | Continued. | Main Steam Drain MIY Bonnet Leakage.                            |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 12/05/2015   | 09.18        |            | Continued. | Boiler Tube Leakage                                             |               |
| MSPGCL                | Khaparkheda Unit 3      | 210      | 13/05/2015   | 19.15        | 14/05/2015 | 09.15      | Turbine Pressure High                                           |               |
| TPC-G                 | Trombay 7B              | 60       | 14/05/2015   | 01.58        | 14/05/2015 | 10.50      | AVR Problem                                                     |               |
| MSPGCL                | Bhusawal Unit 5         | 500      | 14/05/2015   | 05.58        | 14/05/2015 | 09.53      | Stator Earth Fault                                              |               |
| CENT.SECTOR           | TARAPUR 4               | 540      | 14/05/2015   | 14.58        |            | Continued. | OTI & WT1 Meter Calibration work                                |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 14/May/2015**

**Position as on 6.30 Hrs of 15/May/2015**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage        | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|-------------------------|---------------|
| MSPGCL             | Paras Unit 3            | 250      | 14/05/2015   | 16.43        | 14/05/2015 | 19.11      | Furnace Pressure High   |               |
| IPP                | JSW (J) U1              | 300      | 14/05/2015   | 19.16        |            | Continued. | Turbine Bearing Problem |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 14/May/2015**

**Statement-VII**

Position as on 6.30 Hrs of 15/May/2015

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                   |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------------------|
| <b>765 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                    |
| Wardha PG -Aurangabad PG III           | IntraState                | 21/04/2015   | 00.07        |            | Continued. | HT          | To Control Line Loading of Waluj-A'Bad PG                                                                          |
| Wardha PG - Aurangabad PG IV           | IntraState                | 21/04/2015   | 10.33        |            | Continued. | HT          | Line Rectification work                                                                                            |
| <b>400 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                    |
| Wardha (PG)-Warora II                  | InterState                | 04/05/2015   | 20.47        |            | Continued. | EO          | CB under lockout at Wardha PG end.                                                                                 |
| Talegaon PG - Aurangabad - II          | InterState                | 14/05/2015   | 10.07        | 14/05/2015 | 13.11      | HT          | Heavy sparking in CB at Talegaon                                                                                   |
| Kolhapur Mapusa II                     | InterState                | 14/05/2015   | 17.11        |            | Continued. | HT          | Over Voltage                                                                                                       |
| Dhule Sar'Sarovar I                    | InterState                | 14/05/2015   | 18.15        |            | Continued. | HT          | Over Voltage                                                                                                       |
| Akola II - RPL(Rattaniindia) Ckt I     | IntraState                | 07/04/2015   | 00.27        |            | Continued. | T           | "R" Phase Metering PT Burst.                                                                                       |
| Babhaleshwar-Taptitanda ckt-I          | IntraState                | 01/05/2015   | 12.16        |            | Continued. | HT          | Over Voltage                                                                                                       |
| Khadka- Deepnagar Ckt 2                | IntraState                | 14/05/2015   | 00.34        | 14/05/2015 | 11.09      | T           | DT received from Deepnagar end                                                                                     |
| Kalwa - Talegaon(PG)                   | IntraState                | 14/05/2015   | 01.13        | 14/05/2015 | 07.56      | PO          | To attend Hot Spot                                                                                                 |
| Girwali- Lonikand 2                    | IntraState                | 14/05/2015   | 09.18        | 14/05/2015 | 19.20      | PO          | Bay maint.work                                                                                                     |
| karad -kolhapur-II                     | IntraState                | 14/05/2015   | 16.39        |            | Continued. | HT          | Over Voltage                                                                                                       |
| Karad - Lonikand 1                     | IntraState                | 14/05/2015   | 17.15        | 14/05/2015 | 17.36      | T           | Distance Protection                                                                                                |
| Padghe - Kalwa- I                      | IntraState                | 15/05/2015   | 01.38        |            | Continued. | PO          | To attend Hot Spot                                                                                                 |
| <b>400 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                    |
| 400/220kv 315MVA ICT-II @Talegaon(PG)  | InterState                | 14/05/2015   | 16.50        | 14/05/2015 | 22.47      | HT          | To control 220KV Talegaon-Urse Line Loading                                                                        |
| 400/220kv 315MVA ICT-I @Talegaon(PG)   | InterState                | 15/05/2015   | 00.19        |            | Continued. | HT          | To control 220KV Talegaon-Urse Line Loading                                                                        |
| 400/220/33 Kv 315 MVA ICT -I @Kharghar | IntraState                | 14/05/2015   | 15.09        | 14/05/2015 | 16.01      | HT          | Sparking on B phase Isolator                                                                                       |
| 400/220 Kv 500 MVA ICT II @Jejuri      | IntraState                | 14/05/2015   | 18.44        | 15/05/2015 | 01.55      | PO          | Routine Maintenance Work                                                                                           |
| <b>220 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                    |
| Sahara-Urse                            | IntraState                | 03/03/2015   | 11.06        |            | Continued. | PO          | Tower erection work (90Days)                                                                                       |
| Chandrapur Gcr - Warora - I            | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107. |
| Chandrapur Gcr - Wani                  | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107. |
| Eklahara-(Ocr)-Navasari I              | IntraState                | 05/05/2015   | 23.09        |            | Continued. | HT          | To control Load on Bus section at Nasik GCR                                                                        |
| Theur-Jejuri                           | IntraState                | 13/05/2015   | 13.12        | 14/05/2015 | 09.02      | T           | Distance Protection                                                                                                |
| Nasik - Raymond                        | IntraState                | 13/05/2015   | 20.18        | 14/05/2015 | 02.06      | T           | Bus Bar Prot.operated at Raymond                                                                                   |
| Khaparkheda-Kaulewada-II               | IntraState                | 14/05/2015   | 09.42        | 14/05/2015 | 13.50      | PO          | Routine Maintenance Work                                                                                           |
| Lonand-Baramati                        | IntraState                | 14/05/2015   | 10.00        | 14/05/2015 | 18.20      | PO          | To attend Conductor Damage                                                                                         |
| Akola-Paras Ckt No-I                   | IntraState                | 14/05/2015   | 10.17        | 14/05/2015 | 16.05      | PO          | Tan Delta Measurment of CTs                                                                                        |
| Talandage - Sawantwadi I               | IntraState                | 14/05/2015   | 10.34        | 14/05/2015 | 17.37      | PO          | Insulator Cleaning work                                                                                            |
| Uran - Jnpt                            | IntraState                | 14/05/2015   | 10.41        | 14/05/2015 | 16.46      | PO          | Premansoon maint.work                                                                                              |
| Pedhambe - Oni                         | IntraState                | 14/05/2015   | 11.23        | 14/05/2015 | 17.30      | PO          | Insulator Cleaning work                                                                                            |
| Uran - Kharghar I                      | IntraState                | 14/05/2015   | 11.40        | 14/05/2015 | 19.55      | PO          | Breaker O/H work(Taken on TBC)                                                                                     |
| Telco- Chinchwad                       | IntraState                | 14/05/2015   | 13.42        | 14/05/2015 | 20.23      | PO          | Jumper work at C.P.Tower                                                                                           |
| Dhule-Chalisagaon                      | IntraState                | 14/05/2015   | 15.18        | 14/05/2015 | 15.54      | PO          | CT Ratio change at Chalisgaon end                                                                                  |
| Jejuri-Phursungi 1                     | IntraState                | 14/05/2015   | 15.39        | 14/05/2015 | 17.42      | PO          | To attend Hot Spot                                                                                                 |
| Dhule-Chalisagaon                      | IntraState                | 14/05/2015   | 17.51        | 14/05/2015 | 21.36      | T           | Heavy sparking on Isolator                                                                                         |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 14/May/2015**

**Statement-VII**

Position as on 6.30 Hrs of 15/May/2015

| Name of Line                            | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                        |
|-----------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|-----------------------------------------|
| <b>220 KV ICT Outages/Trippings</b>     |                              |                 |                 |            |               |                |                                         |
| 220/100 Kv 200 MVA ICT III<br>@Borivali | IntraState                   | 21/09/2014      | 09.16           |            | Continued.    | T              | Monkey Fault                            |
| 220/132 Kv 200 MVA ICT III<br>@Ambazari | IntraState                   | 14/05/2015      | 08.00           | 14/05/2015 | 13.00         | PO             | Tan Delta Measurment of CTs             |
| 220/132 Kv 200MVA ICT II @Dhule         | IntraState                   | 14/05/2015      | 15.58           | 14/05/2015 | 16.38         | PO             | Wiring work from CT Sec Box to<br>CT MB |
| <b>132 KV LINE Outages/Trippings</b>    |                              |                 |                 |            |               |                |                                         |
| Waghala(Nanded2) - Ardhapur             | IntraState                   | 14/05/2015      | 19.26           |            | Continued.    | T              | Y Phase LA Burst                        |