

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 14/May/2020 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	97.185	1089.317	1) Gujrat	5.178	95.824
2) Hydro	13.881	252.817	2) Madhya Pradesh	11.896	184.215
3) Gas	6.637	92.056	3) Chattisgarh	7.690	116.340
Total MSPGCL	117.703	1434.190	4) Maharashtra	131.687	1988.891
B) 1) APML	64.610	965.477	5) Goa (Amona)	-0.594	-5.984
2) JSWEL	16.027	220.196	Total	155.857	2379.286
3) VIPL	0.000	0.000	a) Mumbai Schedule	22.404	325.985
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	22.836	339.639
5) WPCL	2.643	37.443	c) MSEDCL Bilateral *	52.271	853.959
6) Other IPP	9.035	105.596	Include PX	27.407	523.775
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.404	325.985
C) 1) TPCL Thermal	7.363	92.214	Include PX	15.603	231.674
2) TPCL Hydro	5.361	70.362	Standby	0.000	0.000
3) TPCL Gas	4.397	61.469	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.067	132.684	1) MSEDCL	360.225	5142.142
D) STATE			2) Mumbai Discoms	51.024	696.361
1) Thermal	207.930	2642.927	TOTAL STATE	411.249	5838.503
(A1+C1+C4+(B1-B6))					
2) Hydro	19.242	323.179			
(A2+C2)					
3) Gas	11.034	153.525			
(A3+B7+C3)					
4) Wind	10.503	235.201			
6) SOLAR	6.683	104.392			
TOTAL STATE	255.392	3459.224			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	4057	4266	3890	4046
MSPGCL Hydro	650	1248	154	164
MSPGCL Gas	263	273	272	282
MSPGCL Total Generation	4970	5787	4316	4492
Central Sector Receipt	7310	7737	5319	5729
WIND	211	217	1168	947
CPP / IPP Thermal	3911	3906	3623	3824
CPP / IPP Gas	0	0	0	0
SOLAR	992	612	0	0
Exchange with Mumbai	-1029	-947	-961	-1185
MSEDCL DEMAND MET	16365	17312	13465	13807
Load Shedding	0	0	0	0
MSEDCL DEMAND	16365	17312	13465	13807
TPCL GENERATION	563	778	933	910
AEML GENERATION	501	503	374	373
MUMBAI DEMAND	2093	2228	2268	2468
STATE DEMAND MET	18458	19540	15733	16275
STATE DEMAND	18458	19540	15733	16275
Frequency (Hz)	49.98	49.98	50.00	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
49.84 Hz at 21:09 Hrs	50.27 Hz at 18:02 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 14/May/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	3.38	3.38	530	0
Unit 10	0.00	0.00	0	0
Total	3.38	3.38		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	7.59	0	0
Unit 8	5.20	47.67	237	194
Total	5.20	55.26		
Chandrapur				
Unit 3	4.32	9.76	190	163
Unit 4	3.93	8.76	170	160
Unit 5	9.67	28.37	460	365
Unit 6	10.25	140.85	463	349
Unit 7	0.78	99.20	210	11
Unit 8	10.68	155.56	500	360
Unit 9	10.21	143.18	460	360
Total	49.83	585.69		
Paras				
Unit 3	5.60	61.36	250	190
Unit 4	5.54	79.08	257	160
Total	11.14	140.44		
Khaparkheda				
Unit 1	4.00	11.34	175	150
Unit 2	4.24	43.33	185	160
Unit 3	4.38	42.81	190	158
Unit 4	4.08	58.60	180	160
Unit 5	10.94	148.48	500	360
Total	27.64	304.55		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	6.64	92.06	294	262
Total	6.64	92.06		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	1.96	43	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.15	1.96		
Koyna				
Stage 1-2	5.26	71.93	555	40
Stage 4	3.84	107.68	484	0
Stage 3	2.06	39.49	160	0
Total	11.15	219.10		
Hydro				
KDPH	0.78	10.59	33	32
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.21	3.87	80	0
RNGR+BHTSA	0.28	3.84	12	11
BHANDARDRA	0.47	6.59	38	11
ELDARY	0.38	0.60	22	0
SMLHY_PTN	0.61	8.23	34	23
GHATGHAR	0.00	0.00	0	0
Total	2.73	33.72		
Wind				
Total	10.50	235.20	0	0
Total	10.50	235.20		
CPP				
APML(Mus)	64.61	965.48	0	0
JSWEL(Mus)	16.03	220.20	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.64	37.44	0	0
Other(Mus)	9.04	105.60	0	0
Total	92.32	1328.71		
SOLAR				
Total	6.68	104.39	0	0
Total	6.68	104.39		
Tata				
Trombay 5	7.36	92.21	311	304
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.81	39.27	118	116
Trombay 7B	1.59	22.20	67	66
Trombay 8	0.00	0.00	0	0
TATA Hydro	5.36	70.36	459	31
Total	17.12	224.04		
AEML				
DTPS U-1&2	11.07	132.68	503	373
Total	11.07	132.68		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	97.18	1089.32	MSPGCL Total	117.70	1434.19
			MSPGCL Thml+Gas	103.82	1181.37	Koyna 1,2 & 4 Total	9.10	179.61
			MSPGCL Hydro	13.88	252.82	State Total	255.39	3459.22

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 14/May/2020

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4061	503	291	4855	386	3909	0	0	6472	6389	-1025	14514	0	14514	2405	16919	50.02
2	4102	734	272	5108	287	3914	0	0	6349	6372	-924	14757	0	14757	2280	17037	50.02
3	4236	609	282	5127	279	3910	0	0	6188	6171	-821	14666	0	14666	2156	16822	50.00
4	4016	898	283	5197	223	3938	0	0	6054	5945	-762	14541	0	14541	2064	16605	50.03
5	4039	898	284	5221	194	3958	0	0	6112	6085	-760	14698	0	14698	2018	16716	50.03
6	4021	896	274	5191	197	3928	0	0	6703	6733	-731	15318	0	15318	2013	17331	50.01
7	4022	940	294	5256	215	3952	0	51	7210	6893	-736	15631	0	15631	1901	17532	50.06
8	4014	762	274	5050	181	3903	0	243	6996	6758	-835	15300	0	15300	1877	17177	50.05
9	4030	422	280	4732	249	3908	0	477	6925	6888	-879	15375	0	15375	1934	17309	50.02
10	4035	635	279	4949	290	3925	0	699	6531	6705	-955	15613	0	15613	2010	17623	49.99
11	4073	654	275	5002	300	3946	0	888	6800	6645	-1015	15766	0	15766	2064	17830	50.04
12	4057	650	263	4970	211	3911	0	992	7365	7310	-1029	16365	0	16365	2093	18458	49.98
13	4092	679	262	5033	195	3929	0	969	7595	7144	-1059	16211	0	16211	2129	18340	49.98
14	4201	735	271	5207	85	3899	0	875	7617	7647	-1098	16615	0	16615	2151	18766	49.99
15	4266	1248	273	5787	217	3906	0	612	7781	7737	-947	17312	0	17312	2228	19540	49.98
16	4324	1068	263	5655	326	3876	0	478	7930	7574	-963	16946	0	16946	2241	19188	50.00
17	4065	245	276	4586	355	3808	0	258	7548	7223	-962	15268	0	15268	2150	17418	50.03
18	3744	233	267	4244	415	3710	0	115	6791	6740	-997	14227	0	14227	2022	16249	50.06
19	3684	152	278	4114	664	3505	0	26	5643	6034	-1046	13297	0	13297	1939	15236	50.05
20	4345	190	280	4815	1088	3782	0	0	5248	4895	-1002	13578	0	13578	2054	15632	50.03
21	3911	152	281	4344	1028	3620	0	0	5151	5154	-1062	13084	0	13084	2154	15238	50.02
22	3890	154	272	4316	1168	3623	0	0	5168	5319	-961	13465	0	13465	2268	15733	50.00
23	3911	260	281	4452	1003	3731	0	0	5694	5768	-1082	13872	0	13872	2405	16277	49.95
24	4046	164	282	4492	947	3824	0	0	6356	5729	-1185	13807	0	13807	2468	16275	50.01
MUs	97.19	13.88	6.64	117.70	10.50	92.31	0.00	6.68	158.23	155.86	-22.84	360.23	0.00	360.23	51.02	411.25	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 14/May/2020

Position as on 6.30 Hrs of 15/May/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Bhusawal Unit 4	500	22/03/2020	18.30		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	23/03/2020	01.13		Continued.	Zero schedule.	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
MSPGCL	Uran Unit 5	108	06/04/2020	13.23		Continued.	Gas shortage	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
MSPGCL	Koradi Unit-8	660	12/04/2020	00.00		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 9	660	12/04/2020	01.10	14/05/2020	10.30	Zero schedule.	
MSPGCL	Koradi Unit 10	660	12/04/2020	02.01		Continued.	Zero schedule.	
CPP	SWPGL U-3	135	25/04/2020	00.08		Continued.	No Schedule	
IPP	JSW (J) U3	300	30/04/2020	15.13		Continued.	No Schedule	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 14/May/2020

Position as on 6.30 Hrs of 15/May/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koyana Unit 1	70	11/05/2020	12.00		Continued.	Cooler Leakage	
MSPGCL	Parli Unit 7	250	12/05/2020	19.34		Continued.	Zero Schedule.	
MSPGCL	Chandrapur Unit 7	500	13/05/2020	19.22	14/05/2020	00.54	Faulty Overspeed Relay.	
MSPGCL	Chandrapur Unit 7	500	14/05/2020	02.48	14/05/2020	19.02	Over Speed Relay Fault.	
MSPGCL	Chandrapur Unit 7	500	14/05/2020	21.30		Continued.	malfunction of over speed device	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 14/May/2020

Statement-VII

Position as on 6.30 Hrs of 15/May/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	30/04/2020	17.40		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	07/04/2020	23.58		Continued.	EO	To attend Hot Spot(RFC 29.04.2020 Over voltage).
Chandrapur - Parli	IntraState	19/04/2020	02.20		Continued.	T	Distance Protection(Tower collapsed at Loc.No.59.60.61)
Chandrapur-II - Nanded ckt II	IntraState	19/04/2020	02.21		Continued.	T	Distance Protection(Tower collapsed at Loc.No.59.60.61)
Girwali - Lonikand 1	IntraState	11/05/2020	12.20		Continued.	PO	Changing 400KV CT Ratio(RFC 18.35Hrs To Control Loading Parli -Parli PG)
Koradi-Khaperkheda I	IntraState	13/05/2020	10.50	14/05/2020	15.34	PO	CVT Ratio Testing Work.
Dhule- Bableshwar - I	IntraState	13/05/2020	18.23		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	13/05/2020	18.27		Continued.	HT	Over Voltage
Nagothane - Dabhol-II	IntraState	14/05/2020	09.35	14/05/2020	22.18	EO	Emergency Tree Cutting Work.
Girwali-Solapur (Lamboti)	IntraState	14/05/2020	09.43	14/05/2020	17.46	EO	For faulty string replacement which were detected in PID.
New Koyana - Koyana Stage IV-II	IntraState	14/05/2020	10.00	14/05/2020	13.47	EO	To Attending Oil Leakage In B-PH CT.
Main Bus-I @ Jejuri	IntraState	14/05/2020	10.00	14/05/2020	20.01	PO	Annual maintenance work & testing work.
Akola-Nandgaonpeth (RPL)	IntraState	14/05/2020	10.00	14/05/2020	18.40	EO	In view of pre-monsoon activity, it is necessary to replace strings which are detected punctured in PID testing on urgent basis.
Pune(GIS)-A'bad(Waluj) Ckt 1	IntraState	14/05/2020	14.40	14/05/2020	17.09	T	Distance Protection
Khadka-Aurangabad (Waluj)	IntraState	14/05/2020	18.12		Continued.	HT	Over Voltage
Babhaleshwar - Padghe-I	IntraState	14/05/2020	18.29		Continued.	T	Distance Protection
karad -kolhapur-I	IntraState	14/05/2020	20.40		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57		Continued.	EO	Testing work (Bushing Tan Delta problem hence kept out.)
400/220/33 Kv 500 MVA ICT-II @Lonikand 2	IntraState	11/05/2020	06.18		Continued.	PO	Over Voltage
400/220kv, 500 MVA ICT-II @Deepnagar	IntraState	14/05/2020	09.15	14/05/2020	17.35	PO	HV, LV, Tertiary Bushing & winding Tan delta LVCT Tan delta testing work also Pre monsoon bay maintenance work.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05		Continued.	PO	Isolation of 220KV Cables on MSETCL Tower NO.240
Hinjewadi2 - Hinjewadi 3 ckt II	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Hinjewadi2 - Hinjewadi 3 ckt 1	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Deepnagar Bambhori	IntraState	14/05/2020	07.22	14/05/2020	16.35	PO	Line Maintenance work
Pusad - Hingoli	IntraState	14/05/2020	07.59	14/05/2020	13.11	PO	Line Maintenance work
Miraj-Ichalkaranji I	IntraState	14/05/2020	08.17	14/05/2020	11.01	EO	Emergency Jumpering Work.
Valve-Jamde	IntraState	14/05/2020	08.39	14/05/2020	11.45	PO	Line Maintenance work
Uran - Apta II	IntraState	14/05/2020	09.09	14/05/2020	17.51	PO	Y-PH CT tan delta testing & if faulty replacement work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 14/May/2020

Statement-VII

Position as on 6.30 Hrs of 15/May/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Warora - Warora Rly Tss 2	IntraState	14/05/2020	09.10	14/05/2020	12.50	PO	Diagnostic Testing Work.
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	14/05/2020	09.25	14/05/2020	17.49	PO	Restraining of conductor.
Nagothane - ACCIL	IntraState	14/05/2020	10.00	14/05/2020	14.45	PO	Removing of snapped metal sheet from top phase conductor at Loc No. 520 to 521 & routine maintenance work.
Urse-Chinchwad (ST tap)	IntraState	14/05/2020	12.55	14/05/2020	17.09	EO	Attending Hot Spot
Wani-Warora	IntraState	14/05/2020	13.34	14/05/2020	14.22	T	Distance Protection
Pandarpur-Khanapur	IntraState	14/05/2020	16.15	14/05/2020	16.25	T	Distance Protection
PANDHARPUR BHALVANI	IntraState	14/05/2020	16.15	14/05/2020	16.24	T	Distance Protection
Deepnagar Bambhori	IntraState	14/05/2020	16.39		Continued.	T	Distance Protection
Karad -Mudshingi Ckt- IV	IntraState	14/05/2020	18.15	14/05/2020	18.35	T	Distance Protection
Karad(400kv) - Wathar	IntraState	14/05/2020	18.18	14/05/2020	20.02	T	Distance Protection
Adlabs - Pedambe	IntraState	14/05/2020	18.20	14/05/2020	19.30	T	Distance Protection
220 KV ICT Outages/Trippings							
220/132Kv 200MVA ICT-I @ Chikhali	IntraState	09/05/2020	14.06		Continued.	PO	Oil Filtration work
220/132 KV 100MVA ICT-I @ Bhokar	IntraState	14/05/2020	10.00	14/05/2020	12.43	PO	Pre-monsoon maintenance work.
220/132 KV 100MVA ICT-I @ Walchandnagar	IntraState	14/05/2020	15.51	14/05/2020	17.16	PO	Pre-monsoon maintenance work.
220/132 KV 100MVA ICT-II @ Walchandnagar	IntraState	14/05/2020	17.18	14/05/2020	18.37	PO	Pre-monsoon maintenance work.
220/132 Kv 200 Mva Ict - 1 @Harangul	IntraState	14/05/2020	17.56	14/05/2020	22.19	PO	Pre-monsoon maintenance work.
220/33KV 100MVA ICT II @ chakan	IntraState	14/05/2020	20.06	14/05/2020	23.37	T	Tripped On OSR.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage