

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 14/May/2024 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.624	2394.261	1) Gujrat	-0.210	13.114
2) Hydro	17.137	224.609	2) Madhya Pradesh	9.571	106.508
3) Gas	6.902	97.906	3) Chattisgarh	4.760	60.950
Total MSPGCL	183.663	2716.776	4) Maharashtra	168.447	2591.029
B) 1) APML	61.775	890.194	5) Goa (Amona)	-1.885	-26.956
2) JSWEL	26.902	385.560	Total	180.683	2744.645
3) VIPL	0.000	0.000	a) Mumbai Schedule	44.991	590.970
4) RPL(AMT)	31.570	432.497	b) Mumbai Drawl	46.977	612.674
5) SWPGPL	12.320	170.791	c) MSEDCL Bilateral *	69.336	1165.008
6) Other IPP	14.621	244.424	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	44.991	590.970
C) 1) TPCL Thermal	13.302	168.157	Include PX	0.000	0.000
2) TPCL Hydro	5.363	65.990	Standby	0.000	0.000
3) TPCL Gas	4.096	53.104	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.342	131.487	1) MSEDCL	481.647	7276.783
D) STATE			2) Mumbai Discoms	75.080	1031.406
1) Thermal	325.456	4817.371	3) Other Discoms	11.604	159.185
(A1+C1+C4+(B1-B6))			TOTAL STATE	568.331	8467.374
2) Hydro	22.500	290.599			
3) Gas	10.998	151.010			
4) Wind	13.448	223.138			
6) SOLAR	15.246	240.617			
TOTAL STATE	387.648	5722.735			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	6551	6736	6704	6759
MSPGCL Hydro	314	1305	2047	209
MSPGCL Gas	273	275	285	291
MSPGCL Total Generation	7138	8316	9036	7259
Central Sector Receipt	8856	8834	6112	6286
WIND	140	527	366	1240
CPP / IPP Thermal	5351	5742	6927	6271
CPP / IPP Gas	0	0	0	0
SOLAR	2200	995	0	0
Exchange with Mumbai	-2353	-2376	-1687	-1473
MSEDCL DEMAND MET	20805	21507	20249	19197
Load Shedding	0	0	0	0
MSEDCL DEMAND	20805	21507	20249	19197
TPCL GENERATION	1056	1270	1227	635
AEML GENERATION	252	251	204	232
MUMBAI DEMAND	3661	3897	3118	2340
OTHER DISCOM DEMAND	527	531	505	386
STATE DEMAND MET	24993	25935	23872	21923
STATE DEMAND	24993	25935	23872	21923
Frequency (Hz)	50.01	50.02	50.00	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.22 Hz at 17:03 Hrs	49.8 Hz at 14:58 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 14/May/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.87	43.60	165	0
Unit 8	13.58	118.32	644	0
Unit 9	13.70	194.09	602	518
Unit 10	14.53	197.14	655	548
Total	42.68	553.17		
Bhusawal				
Unit 3	3.42	42.06	175	125
Unit 4	0.16	122.77	157	0
Unit 5	10.44	122.69	485	300
Total	14.02	287.52		
Parli				
Unit 6	4.06	62.60	230	145
Unit 7	4.14	60.73	248	144
Unit 8	2.58	60.91	235	0
Total	10.77	184.23		
Chandrapur				
Unit 3	3.55	49.75	164	124
Unit 4	3.62	51.24	163	124
Unit 5	8.98	120.11	425	265
Unit 6	0.00	105.47	0	0
Unit 7	9.36	127.26	450	295
Unit 8	10.30	144.89	453	324
Unit 9	10.99	155.21	493	364
Total	46.81	753.93		
Paras				
Unit 3	5.29	59.57	241	170
Unit 4	5.31	77.51	245	169
Total	10.60	137.08		
Khaparkheda				
Unit 1	3.78	49.50	175	140
Unit 2	4.38	57.89	197	147
Unit 3	4.10	54.12	175	148
Unit 4	4.04	52.32	187	149
Unit 5	10.98	123.72	485	400
Total	27.27	337.56		
Nasik				
Unit 3	0.00	40.59	0	0
Unit 4	3.92	50.58	182	127
Unit 5	3.54	49.61	165	117
Total	7.46	140.78		
Uran				
All Units	6.90	97.91	378	273
Total	6.90	97.91		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.23	4.30	47	0
Total	0.23	4.30		
Koyna				
Stage 1-2	5.88	52.45	560	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	5.19	87.83	1009	0
Stage 3	2.02	31.31	320	0
Total	13.09	171.60		
Hydro				
KDPH	0.65	9.32	27	27
VTRNA	0.75	11.99	61	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.09	28.19	118	75
GHATGHAR	0.56	3.50	125	0
Total	4.05	53.01		
Wind				
Total	13.45	223.14	0	0
Total	13.45	223.14		
CPP				
APML(Mus)	61.78	890.19	0	0
JSWEL(Mus)	26.90	385.56	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.57	432.50	0	0
SWPGPL-Mus	12.32	170.79	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.38	71.57	220	161
Other(Mus)	6.50	101.97	0	0
JPL	3.74	70.88	202	134
Total	147.19	2123.47		
SOLAR				
Total	15.25	240.62	0	0
Total	15.25	240.62		
Tata				
Trombay 5	8.85	117.97	469	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.56	32.74	108	106
Trombay 7B	1.53	20.36	65	63
TATA Hydro	5.36	65.99	418	69
Trombay 8	4.45	50.18	235	130
Total	22.76	287.25		
AEML				
DTPS U-1&2	5.34	131.49	252	157
Total	5.34	131.49		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.62	2394.26	MSPGCL Total	183.66	2716.78
			MSPGCL Thml+Gas	166.53	2492.17	Koyna 1,2 & 4 Total	11.07	140.28
			MSPGCL Hydro	17.14	224.61	State Total	387.65	5722.74

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 14/May/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7259	272	288	7819	993	6966	0	0	6416	6048	-1584	19803	0	0	19803	2917	439	23159	50.06
2	6881	211	289	7381	727	6540	0	0	7171	6718	-1790	19173	0	0	19173	2719	403	22295	50.00
3	6784	466	290	7540	656	6350	0	0	7003	6894	-1693	19371	0	0	19371	2548	376	22295	49.96
4	6980	214	291	7485	816	6737	0	0	6858	6125	-1544	19251	0	0	19251	2404	368	22023	50.02
5	6759	209	291	7259	1240	6271	0	0	6756	6286	-1473	19197	0	0	19197	2340	386	21923	50.02
6	6814	367	293	7474	894	6206	0	0	7018	7125	-1513	19766	0	0	19766	2333	420	22519	49.99
7	7049	212	292	7553	777	6438	0	125	7175	6835	-1408	19866	0	0	19866	2346	454	22666	50.03
8	6696	168	285	7149	718	5606	0	619	7486	7569	-1600	19581	0	0	19581	2514	480	22575	50.04
9	5769	153	282	6204	679	5139	0	1199	8098	8451	-1962	19197	0	14	19197	2855	513	22565	49.98
10	5979	471	276	6726	370	5241	0	1684	8258	8647	-2271	19877	0	32	19877	3231	520	23628	50.00
11	6442	266	273	6981	249	5340	0	2050	8809	8492	-2439	20155	0	33	20155	3506	518	24179	49.98
12	6551	314	273	7138	140	5351	0	2200	9288	8856	-2353	20805	0	63	20805	3661	527	24993	50.01
13	6493	444	273	7210	160	5249	0	2133	9372	8934	-2451	20718	0	4	20718	3712	517	24947	49.97
14	6543	369	273	7185	260	5299	0	1925	9373	9049	-2443	20765	0	4	20765	3690	510	24965	49.96
15	6641	549	274	7464	413	5718	0	1583	9446	8921	-2391	21196	0	30	21196	3818	512	25526	49.93
16	6736	1305	275	8316	527	5742	0	995	9194	8834	-2376	21507	0	11	21507	3897	531	25935	50.02
17	6789	1138	275	8202	663	6250	0	483	8525	8170	-2383	20848	0	1	20848	3767	537	25152	50.06
18	6725	357	278	7360	823	6472	0	214	8145	7450	-2261	19512	0	0	19512	3580	546	23638	50.01
19	6836	281	278	7395	782	6520	0	36	7828	7134	-2228	19097	0	0	19097	3385	542	23024	50.03
20	6713	1267	282	8262	435	6427	0	0	7527	7386	-1981	19999	0	0	19999	3295	530	23824	50.02
21	6749	1873	284	8906	400	6423	0	0	6986	6782	-1865	20130	0	0	20130	3170	516	23816	50.00
22	6704	2047	285	9036	366	6927	0	0	6357	6112	-1687	20249	0	0	20249	3118	505	23872	50.00
23	6403	2098	324	8825	154	6975	0	0	6915	6734	-1643	20556	0	0	20556	3133	489	24178	50.01
24	6329	2086	378	8793	206	7001	0	0	7444	7131	-1638	21028	0	0	21028	3141	465	24634	49.99
MUs	159.62	17.14	6.90	183.66	13.45	147.19	0.00	15.25	187.45	180.68	-46.98	481.65	0.00	0.19	481.65	75.08	11.60	568.33	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) ELR carried out due to overload of BBLSR 1&2 line.2)132KV BBLSR-Rahuri and Satana-Dindori line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 14/May/2024

Position as on 6.30 Hrs of 15/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Koradi Unit 6	210	12/05/2024	18:31	14/05/2024	17:13	GS WATER TANK LOW	13/05/2024
MSPGCL	Nasik Unit 3	210	13/05/2024	14:10		Continued.	ID Fan Problem	15/05/2024
MSPGCL	Chandrapur Unit 6	500	14/05/2024	00:00		Continued.	EXCESSIVELY HIGH DM WATER CONSUMPTION AND ABNORMAL PARAMETER DUE TO SUSPECTED BTL	16/05/2024
MSPGCL	Bhusawal Unit 4	500	14/05/2024	00:30		Continued.	BTL attending work	16/05/2024
MSPGCL	Koradi Unit 8	660	14/05/2024	22:17		Continued.	SUSPECTED BTL	17/05/2024
Total Capacity MSPGCL		2200						
AEML								
AEML	AEML Unit 1	250	13/05/2024	10:38		Continued.	Boiler Tube Leakage	16/05/2024
Total Capacity AEML		250						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2770						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	09/05/2024	20:15		Continued.	No Schedule from MSEDCL	
MSPGCL	Uran Unit 6	108	13/05/2024	22:03	14/05/2024	22:16	No Schedule from MSEDCL	
MSPGCL	Parli Unit 8	250	14/05/2024	16:45		Continued.	Zero Schedule Given By MSEDCL.	
MSPGCL	Uran Unit 6	108	15/05/2024	02:01		Continued.	No Schedule from MSEDCL	
Total Capacity MSPGCL		574						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		574						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 14/May/2024

Position as on 6.30 Hrs of 15/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/May/2024

Statement-VII

Position as on 6.30 Hrs of 15/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY - 705 OF EKTUNI-AKOLA II ckt-1 @ EKTUNI	IntraState	14/05/2024	10:19	14/05/2024	17:05	PO	Outage required for routine testing and Maintenance Works
400 KV TIEBAY Outages/Trippings							
TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	IntraState	14/05/2024	16:23	14/05/2024	19:02	PO	For the work of chemical cleaning (cold line cleaning and washing) of insulator of equipments at 400 KV Deepnagar-Khadka Ckt 1 TIE bay
400 KV MAINBAY Outages/Trippings							
MAIN BAY (405) OF KHADKA CKT - 1 @ DEEPNAGAR	IntraState	14/05/2024	08:07	14/05/2024	11:43	PO	For the work of chemical cleaning (cold line cleaning and washing) of insulator of equipments at 400 KV Deepnagar-Khadka Ckt 1 Main bay
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	14/05/2024	09:11	14/05/2024	18:38	PO	For Replacement of Missing Earth wire, Missing Hardware , Cold line washing & Other maintenance work.400 KV Dhule-SSNNL CKT 1 Auto Reclose switchwill be kept on Non Auto mode during Outage
AURANGABAD(MS) - AURANGABAD(PG) CKT -2	InterState	14/05/2024	12:40	14/05/2024	19:16	EO	CVT replacement work
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
BABHALESHWAR - PADGHE CKT - 2	IntraState	10/05/2024	09:56	14/05/2024	18:52	PO	1. B Bus PG Isolator Replacement work under LES Scheme. 2. CB Diagnostic Testing Work. 3.400KV BBLR-II in service through TBC.
MAIN BUS - 2 @ PADGHE	IntraState	10/05/2024	10:23	14/05/2024	14:57	PO	1.Replacement of Hanger Assembly of B Bus PG Isolator of BBLR-2 by Hot Line Method. 2.All Feeders on B Bus will be in service.
220 KV CHANDRAPUR GCR - CHANDRAPUR 2 CKT	IntraState	14/05/2024	09:10	14/05/2024	19:08	PO	Retrofitting of distance Relay
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
DABHOL - NAGOTHANE CKT - 1	IntraState	14/05/2024	13:37	14/05/2024	18:02	PO	Cold Washing Work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	13/05/2024	09:45			PO	CB, CT Diagnostic Testing work
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	14/05/2024	18:10	14/05/2024	20:24	T	Tripped on Rph. OLTC buchholz.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
AAREY - AEML SAKI CKT - 2	IntraState	08/05/2024	21:48			T	Tripped on Yph to ground fault

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/May/2024

Statement-VII

Position as on 6.30 Hrs of 15/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	13/05/2024	13:27			PO	To make the LILO point connection at Loc. 1 (Loc. 19 of 220kV Nashik - Navsari Line) of new 220kV CPRI Line & substation
220KV KALWA - GIS DCHI	IntraState	13/05/2024	15:47	14/05/2024	01:49	T	Tripped on distance protection
URAN - APTA 2	IntraState	13/05/2024	17:00			T	conductor snapping at loc 5,6
URAN - APTA CKT - 1	IntraState	13/05/2024	23:09	14/05/2024	02:04	EO	For hot spot attending work at wave trap Y Ph bottem clamp (hotspot temperature 70 degC)
KALWA - SIEMENS	IntraState	14/05/2024	02:05	14/05/2024	05:51	EO	To attend red hotspot on top ph jumper cone at Siemens LILO loc. No. 1
220KV PANDHARKAWDA - WANI CKT I	IntraState	14/05/2024	07:19	14/05/2024	12:34	PO	Measurement of Tan Delta
TILLARI - AMONA LINE	IntraState	14/05/2024	09:35			PO	For replacement of polymer by longrod
MALHARPETH - KARAD	IntraState	14/05/2024	12:51	14/05/2024	17:02	PO	Erection of B Ph Coupling Capacitor & Quarterly Mainntenance Work at 220kV Malharpeth end
MIRAJ - ICHALKARANJI	IntraState	14/05/2024	13:03	14/05/2024	20:31	PO	1)For replacement of Relay & testing work only
PARLI 3(OLD GCR)-PARLI NEWTPS CKT 1	IntraState	14/05/2024	14:05	14/05/2024	19:51	PO	220KV Y Phase CT replacement work
NEW KOYNA - LOTEPARSHURAM	IntraState	14/05/2024	15:26	14/05/2024	17:40	T	Tripped on distance protection.
220KV GEORAI(220KV)-TAPTITHANDA(400KV)CKT	IntraState	14/05/2024	15:35	14/05/2024	16:42	T	Distance Protection
TOPWORTH - Vile - bhagad	IntraState	14/05/2024	15:43	14/05/2024	19:17	PO	"Maintenance work and Diagnostic Testing Work of metering CT, PT, and protection CT, PT & CBs. "
TOPWORTH - KHANDESHWAR	IntraState	14/05/2024	15:45	14/05/2024	23:10	PO	"Routine Lines Maintenance Work Diagnostic Testing of metering CT and bus isolator maintenance work at Topworth S/s"
PANDHARPUR - MALINAGAR	IntraState	14/05/2024	16:18	14/05/2024	19:20	PO	Destringing & strining from Loc no. 37 to 46 to attain issue of low ground clarence.
EKLAHARE (GCR) - GHATGHAR	IntraState	14/05/2024	17:04	15/05/2024	06:14	T	Tripped on distance protection.
BORIVALI - CTRLS CKT	IntraState	14/05/2024	22:11	15/05/2024	04:53	PO	For the installation of saver assembly sets at TL no. 27/3, 28, 43, 45, 46, 47 & 48 (Total 24 sets out of 60 sets are to be installed)
KALWA - BORIVALI	IntraState	14/05/2024	22:16	15/05/2024	05:06	PO	For the installation of saver assembly sets at TL no. 4, 7, 20, 21, 22, 23, 25 & 26 (Total 27 sets out of 33 sets are to be installed)
220 KV ICT Outages/Trippings							
220/132 KV 200 MVA ICT - 2 @ HARANGUL	IntraState	14/05/2024	08:18	14/05/2024	17:44	PO	Maintenance work
220/132 KV 100 MVA ICT 1	IntraState	14/05/2024	09:25	14/05/2024	14:01	PO	R.M.work
220/132-110 KV 100MVA ICT 2 @ JATH	IntraState	14/05/2024	16:01	14/05/2024	17:33	PO	LV Side Y & B Ph CT Oil filling Work
220/132 100MVA ICT-1 @ AMRAPUR	IntraState	14/05/2024	16:14	14/05/2024	20:20	PO	1)Premansoon Maintenance of both ICT 2) Tan Delta of Both ICT 3)SFRA of ICT I by Mobile Testing Unit , Nashik.
220/132 100MVA ICT-2 @ AMRAPUR	IntraState	14/05/2024	16:15	14/05/2024	20:22	PO	Premansoon Maintenance of both ICT 2) Tan Delta of Both ICT 3)SFRA of ICT I by Mobile Testing Unit , Nashik.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/May/2024

Statement-VII

Position as on 6.30 Hrs of 15/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV BUSBAR Outages/Trippings							
MAIN BUS @ TOPWORTH	IntraState	14/05/2024	15:46	14/05/2024	19:17	PO	"Maintenance work and Diagnostic Testing Work of metering CT, PT, and protection CT, PT & CBs. "
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage