

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 14/Jun/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	152.591	2174.640	1) Gujrat	1.944	-32.305
2) Hydro	8.027	218.374	2) Madhya Pradesh	2.232	78.074
3) Gas	4.618	68.585	3) Chattisgarh	2.510	42.160
Total MSPGCL	165.236	2461.599	4) Maharashtra	203.751	2984.900
B) 1) APMIL	69.282	925.974	5) Goa (Amona)	-1.211	-19.716
2) JSWEL	22.666	336.641	Total	209.226	3053.113
3) VIPL	0.000	0.000	a) Mumbai Schedule	45.509	608.614
4) RPL(AMT)	25.500	420.824	b) Mumbai Drawl	49.561	670.624
5) SWPGPL	10.660	146.008	c) MSEDCL Bilateral *	132.295	1571.182
6) Other IPP	7.362	65.740	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	45.509	608.427
C) 1) TPCL Thermal	12.580	177.520	Include PX	0.000	0.000
2) TPCL Hydro	5.850	76.205	Standby	0.000	0.187
3) TPCL Gas	0.000	25.895	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.747	126.565	1) MSEDCL	522.732	7282.752
D) STATE			2) Mumbai Discoms	77.738	1076.809
1) Thermal	310.388	4373.912	3) Other Discoms	10.666	149.446
(A1+C1+C4+(B1-B6))			TOTAL STATE	611.136	8509.007
2) Hydro (A2+C2)	13.877	294.579			
3) Gas (A3+B7+C3)	4.618	94.480			
4) Wind	56.677	467.409			
6) SOLAR	16.350	225.514			
TOTAL STATE	401.910	5455.894			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5960	6230	6388	6825
MSPGCL Hydro	220	152	866	212
MSPGCL Gas	189	170	191	206
MSPGCL Total Generation	6370	6552	7444	7244
Central Sector Receipt	9311	9261	7630	8762
WIND	2531	2827	2284	1637
CPP / IPP Thermal	4996	5746	6325	5917
CPP / IPP Gas	0	0	0	0
SOLAR	2117	1423	0	0
Exchange with Mumbai	-2573	-2580	-1782	-1729
MSEDCL DEMAND MET	22265	22753	21421	21520
Load Shedding	0	0	0	0
MSEDCL DEMAND	22265	22753	21421	21520
TPCL GENERATION	707	807	1049	601
AEML GENERATION	462	432	448	295
MUMBAI DEMAND	3742	3819	3279	2625
OTHER DISCOM DEMAND	486	475	481	311
STATE DEMAND MET	26494	27048	25180	24456
STATE DEMAND	26494	27048	25180	24456
Frequency (Hz)	50.01	49.96	49.95	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.4 Hz at 08:00 Hrs	49.51 Hz at 22:34 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 14/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.54	65.10	200	160
Unit 8	14.46	116.60	612	595
Unit 9	13.89	102.73	602	549
Unit 10	12.69	181.08	545	494
Total	45.57	465.51		
Bhusawal				
Unit 3	0.00	28.97	0	0
Unit 4	10.12	139.06	460	380
Unit 5	11.22	150.30	495	425
Total	21.34	318.33		
Parli				
Unit 6	4.69	65.35	243	150
Unit 7	4.11	65.90	241	115
Unit 8	3.52	57.58	153	140
Total	12.31	188.83		
Chandrapur				
Unit 3	2.90	39.84	130	110
Unit 4	0.51	39.87	130	0
Unit 5	0.00	0.00	0	0
Unit 6	6.48	104.61	400	0
Unit 7	3.87	126.23	426	0
Unit 8	10.56	150.81	474	358
Unit 9	10.80	155.52	489	398
Total	35.11	616.89		
Paras				
Unit 3	5.48	70.06	240	203
Unit 4	0.00	54.79	0	0
Total	5.48	124.84		
Khaparkheda				
Unit 1	2.54	40.74	115	95
Unit 2	2.96	41.08	132	110
Unit 3	4.02	47.06	182	139
Unit 4	3.98	56.82	178	139
Unit 5	11.29	152.43	480	460
Total	24.79	338.12		
Nasik				
Unit 3	0.00	10.09	0	0
Unit 4	4.07	56.58	181	150
Unit 5	3.92	55.45	169	150
Total	7.99	122.12		
Uran				
All Units	4.62	68.58	207	170
Total	4.62	68.58		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.08	1.23	20	0
Total	0.08	1.23		
Koyna				
Stage 1-2	2.62	52.64	430	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	81.22	0	0
Stage 3	0.87	30.88	240	0
Total	3.50	164.73		
Hydro				
KDPH	0.20	4.64	9	9
VTRNA	1.19	15.70	61	0
TILLARI	0.00	1.04	0	0
BHIRA T.R.	0.28	4.83	77	0
SMLHY_PTN	2.49	25.64	106	100
GHATGHAR	0.28	0.56	125	0
Total	4.45	52.41		
Wind				
Total	56.68	467.41	0	0
Total	56.68	467.41		
CPP				
APML(Mus)	69.28	925.97	0	0
JSWEL(Mus)	22.67	336.64	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.50	420.82	0	0
SWPGPL-Mus	10.66	146.01	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.34	34.14	270	195
Other(Mus)	2.02	31.60	0	0
Total	135.47	1895.19		
SOLAR				
Total	16.35	225.51	0	0
Total	16.35	225.51		
Tata				
Trombay 5	8.30	116.27	452	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	14.05	0	0
Trombay 7B	0.00	11.84	0	0
TATA Hydro	5.85	76.20	440	64
Trombay 8	4.28	61.25	231	131
Total	18.43	279.62		
AEML				
DTPS U-1&2	9.75	126.56	498	295
Total	9.75	126.56		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	152.59	2174.64	MSPGCL Total	165.24	2461.60
			MSPGCL Thml+Gas	157.21	2243.22	Koyna 1,2 & 4 Total	2.62	133.85
			MSPGCL Hydro	8.03	218.37	State Total	401.91	5455.89

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 14/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6975	294	204	7472	2033	6317	0	0	8220	7818	-1616	21642	0	0	21642	3119	382	25144	49.99
2	6928	214	206	7348	1843	6235	0	0	8114	8180	-1530	21718	0	0	21718	2915	359	24992	50.04
3	6849	220	206	7274	1848	6149	0	0	8402	8629	-1734	21825	0	0	21825	2751	342	24918	50.01
4	6825	212	206	7244	1637	5917	0	0	8831	8762	-1729	21520	0	0	21520	2625	311	24456	50.00
5	6611	212	206	7030	1668	5855	0	0	9064	9097	-1648	21656	0	0	21656	2549	346	24550	50.00
6	6471	226	203	6900	1826	5922	0	16	9282	9549	-1668	22157	0	0	22157	2569	388	25114	50.00
7	6312	232	207	6752	1814	5811	0	191	9142	9640	-1708	22082	0	0	22082	2560	418	25060	50.01
8	6223	290	195	6708	2202	5766	0	633	8533	9162	-1927	22109	0	0	22109	2694	435	25238	50.18
9	5942	280	193	6416	2533	5506	0	1096	8788	8837	-2211	21704	0	0	21704	3011	473	25188	50.14
10	5876	256	192	6324	2762	4758	0	1612	8818	9265	-2336	21889	0	0	21889	3365	496	25750	49.97
11	5782	214	190	6186	2643	4517	0	1953	9329	9703	-2530	21964	0	0	21964	3635	509	26108	50.04
12	5960	220	189	6370	2531	4996	0	2117	9394	9311	-2573	22265	0	3	22265	3742	486	26494	50.01
13	6003	164	187	6354	2657	4478	0	2096	9468	9422	-2456	22064	0	5	22064	3744	488	26296	49.92
14	6207	150	178	6536	2748	4340	0	1979	9335	9461	-2485	22107	0	5	22107	3673	471	26252	49.96
15	6247	158	177	6582	2797	4904	0	1718	9367	9452	-2536	22463	0	3	22463	3732	453	26648	49.91
16	6230	152	170	6552	2827	5746	0	1423	9111	9261	-2580	22753	0	2	22753	3819	475	27048	49.96
17	6280	198	178	6656	2923	5783	0	994	9093	8487	-2463	21876	0	0	21876	3758	505	26138	49.99
18	6163	210	179	6552	3098	5437	0	430	8919	8488	-2541	20961	0	0	20961	3595	503	25060	50.02
19	6155	248	184	6588	2983	5596	0	92	8136	8001	-2346	20421	0	0	20421	3375	492	24288	50.06
20	6255	638	186	7078	2461	6199	0	0	7716	7695	-1996	20954	0	0	20954	3316	483	24754	49.91
21	6388	866	191	7444	2284	6325	0	0	7450	7630	-1782	21421	0	0	21421	3279	481	25180	49.95
22	6423	688	193	7304	2317	6291	0	0	7732	7601	-1700	21334	0	0	21334	3250	478	25062	49.90
23	6647	812	199	7658	2244	6303	0	0	7843	7782	-1687	21844	0	0	21844	3296	455	25596	49.71
24	6839	872	199	7910	1998	6319	0	0	7953	7993	-1779	22004	0	0	22004	3366	437	25806	49.97
MUs	152.59	8.03	4.62	165.24	56.68	135.47	0.00	16.35	208.04	209.23	-49.56	522.73	0.00	0.02	522.73	77.74	10.67	611.14	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR carried out due to overloading of 132kv BBLR-Rahuri.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 14/Jun/2023

Position as on 6.30 Hrs of 15/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Nasik Unit 3	210	08/06/2023	11:40		Continued.	Tolling Agreement with IEPL synchronised at 9:19 Hrs	
MSPGCL	Paras Unit 4	250	11/06/2023	13:46	15/06/2023	13:17	Boiler Tube Leakage	14/06/2023
MSPGCL	Chandrapur Unit 4	210	11/06/2023	18:51	14/06/2023	18:30	SUSPECTED BTL AT AB-4 ELEVATION	
MSPGCL	Bhusawal Unit 3	210	13/06/2023	03:15		Continued.	ID Fan Problem	15/06/2023
MSPGCL	Chandrapur Unit 6	500	14/06/2023	04:25	14/06/2023	09:24	Stator Earth Fault	
MSPGCL	Chandrapur Unit 6	500	14/06/2023	09:25	14/06/2023	10:48	Drum level low	
MSPGCL	Chandrapur Unit 7	500	14/06/2023	11:48	14/06/2023	22:21	Air heater problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 15/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	13/06/2023	00:30	14/06/2023	05:42	EO	Emergency Shutdown of HVDC Pole 1 for premonsoon maintenance work.
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	14/06/2023	00:30	14/06/2023	05:42	HT	Emergency Shutdown of HVDC Pole 1 for premonsoon maintenance work.
400 KV MAINBAY Outages/Trippings							
MAIN BAY (402) OF KHADKA CKT - 2 @ DEEPNAGAR	IntraState	25/05/2023	10:02		Continued.	PO	For servicing & overhauling of 400kv AREVA make KDK CKT-2 Main C.B. Mechanism
400 KV LR Outages/Trippings							
400 KV KARAD - SOLAPUR (PG) LR	IntraState	05/06/2023	10:58	14/06/2023	16:07	PO	Overhauling of 400 kv CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
LONIKAND I - TALEGAON (PGCIL)	InterState	12/06/2023	09:54			PO	400kv CB O/H work by shifting on TBC and 29-A PG Isolator mechanimc box replacement and trials
DHULE - KHANDWA CKT - 1	InterState	13/06/2023	09:08			PO	MTAMC Project work Main-I Dist Protn, REF & Master trip relay Gr-A &B replacement work
KHADKA- DEEPNAGAR CKT 2	IntraState	25/05/2023	10:02				Servicing &overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.
TBC 2 @ CHANDRAPUR	IntraState	12/06/2023	08:48			PO	Replacement of problematic old BHEL make 400kv quad break CB of TBC-2 bay with new siemens ltd make 400kv Quad CB.
JEJURI - KARAD	IntraState	12/06/2023	20:10	14/06/2023	19:32	PO	Overhauling of 400 kv CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad
NAGOTHANE - DABHOL CKT - 2	IntraState	13/06/2023	09:45	14/06/2023	12:57	T	bus 1 and bus -2 tripped at 400kv nagothane s/stn
NAGOTHANE - DABHOL CKT - 1	IntraState	13/06/2023	11:49	14/06/2023	13:50	HT	LINE H/T DUE TO HEAVY SPARKING ON Y PHASE CT AT NAGOTHANE END
220 KV CHANDRAPUR GCR - CHANDRAPUR 2 CKT	IntraState	14/06/2023	08:03	14/06/2023	17:05	PO	Attending R ph Damaged/Broken strand of conductor work.
220 KV CHANDRAPUR 2 - BALLARSHAH CKT	IntraState	14/06/2023	08:06	14/06/2023	17:07	PO	Safety purpose for attending R ph damaged strands of 220kv chandrapur 2 - chandrapur GCR.
PARLI - KUMBHARGAON(NANDED) CKT - 2	IntraState	14/06/2023	12:17	15/06/2023	03:24	PO	(1) Distance relay testing work. (2) Bay maintenance work. (3) Hardware tightning and fitting work.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	14/06/2023	12:55			HT	TO CONTROL LINE LOADING
KHADKA - BABLESHWAR	IntraState	14/06/2023	13:14	14/06/2023	17:21	PO	For routine bay maintenance works.
PADGHE - NAGOTHANE CKT - 1	IntraState	15/06/2023	11:17			PO	1. Stringing of 6 Nos of spans between location nos 310-313. 2. Disnmantling of 2 nos of Lattice towers

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 14/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 15/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PADGHE - PADGHE HVDC CKT- 1	IntraState	15/06/2023	17:00	15/06/2023	17:09	T	400kV HVDC-1 CB tripped at 400kV Padghe Stn only on 17.00Hrs on PDR
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	IntraState	15/06/2023	08:23			PO	1. Measurement of tandelta of CT, bushing & winding. 2. Premonsoon maintenance work. 3. Bay routine maintenance work.
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
BUS COUPLER @ SOUTH SOLAPUR	IntraState	14/06/2023	11:32	14/06/2023	13:05	PO	Outage is required for Quarterly Maintenance
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
BORIVALI - TARAPUR	IntraState	13/06/2023	17:27	14/06/2023	13:14	T	Tripped on Distance Protection.
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	IntraState	14/06/2023	03:52	14/06/2023	04:15	T	Tripped from Nagar end only
GOREGAON - VERSOVA CKT - 2	IntraState	14/06/2023	09:45	14/06/2023	20:52	EO	Attending the hotspots on line.
KHAPARKHEDA-KALMESHVAR	IntraState	14/06/2023	10:01	14/06/2023	15:20	PO	Replacement of F/O string at various location.
MAHALAXMI - AMONA	IntraState	14/06/2023	10:37	14/06/2023	16:54	PO	Maintenance work. For cold washing of 220 kv line bay equipments, Maintenance & alignments of all isolators, Maintenance of all Bay Equipments at 220kV Mahalaxmi ss.
BHUGAON - WARDHA (PG)	IntraState	14/06/2023	10:40	14/06/2023	17:35	PO	For Amp of Line Bay
PANDHARPUR - MALINAGAR	IntraState	14/06/2023	10:46	14/06/2023	19:37	PO	Outage is required for Date:- 12.06.2023; Cold line cleaning loc no. 1 to 30 Date:- 13.06.2023; Cold line cleaning loc no. 31 to 61 Date:- 14.06.2023; Cold line cleaning loc no. 62 to 118 For changing /replacement of faulty string at loc no LILO portion 60, 64, 67. Date:- 15.06.2023; Cold line cleaning LILO loc no. 1 to 30 Date:- 16.06.2023; Cold line cleaning LILO loc no. 31 to 60 Date:- 17.06.2023; Cold line cleaning LILO loc no. 61 to 62
OSMANABAD - SOLAPUR (BALE)	IntraState	14/06/2023	10:48	14/06/2023	19:31	PO	Outage is required for High tan delta CT replacement work
OSMANABAD - SOLAPUR (BALE)	IntraState	14/06/2023	10:48	14/06/2023	19:31	PO	High tan delta CT replacement work.
MAIN BUS @ VAIRAG	IntraState	14/06/2023	17:06	14/06/2023	19:41	PO	Outage is required for Quarterly Maintenance

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 14/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 15/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
LAMBOTI - VAIRAG	IntraState	14/06/2023	17:06	14/06/2023	19:41	PO	Outage is required for Quarterly Maintenance
TROMBAY CARNAC - 5	IntraState	14/06/2023	23:56	15/06/2023	02:11	PO	For Attending Hotspot of C Phase Dead end
AAREY - AEML SAKI CKT - 2	IntraState	15/06/2023	09:03			PO	Attending the cable damage of R phase and B phase.
NEW KOYNA - PEDAMBE	IntraState	15/06/2023	09:15	15/06/2023	12:00	PO	for attending unwound strands of Bph conductor jumper between brk to LS isolator
KHADKI- CENTURY ENKA	IntraState	15/06/2023	10:20	15/06/2023	13:34	PO	For attending CB ready signal in Distance relay is frequency getting low & high. Due to this problem in future chances of AR failure and Half yearly maintenance.
NANDED CITY-FLAGSHIP	IntraState	15/06/2023	11:44			PO	Half yearly maint. & Testing work
RANJANGAON-LONIKAND	IntraState	15/06/2023	11:50			PO	220kV Circuit breaker overhauling work.
ALKUD - VITA	IntraState	15/06/2023	15:26			PO	Jump Replacement work at Loc No.84 Y Ph
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132 KV 200 MVA ICT 2	IntraState	14/06/2023	08:05	14/06/2023	10:20	PO	Monsoon & routine maintenance work.
220/132 KV 200 MVA ICT 1	IntraState	14/06/2023	09:44	14/06/2023	15:45	PO	LV side main circuit breaker overhauling work by agency, Tan delta and premonsoon maint work.
220/132 KV 200 MVA ICT 1	IntraState	14/06/2023	09:50	14/06/2023	17:30	PO	Routine diagnostic testing of ICT work
220/132 KV 200 MVA PTR NO 5 @ PARVATI	IntraState	14/06/2023	10:51	14/06/2023	15:15	EO	For safety purpose to replace 132 kV PT 01
220/132KV 200MVA ICT 2 @ PANDHARPUR	IntraState	14/06/2023	11:51	14/06/2023	15:53	PO	Outage is required for Auxillary Protection trails Testing
220/100 KV 200 MVA ICT 1 @ PADGHE	IntraState	14/06/2023	16:23			HT	200MVA 220/100kV ICT-1, frequent starting problem of differential relay RET670.
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	14/06/2023	16:52	14/06/2023	19:55	PO	Outage is required for Auxillary Protection trails Testing
220 / 11 KV 200 MVA GT @ BHIRA (T)	IntraState	15/06/2023	06:09	15/06/2023	10:35	PO	Pre-monsoon Checks and attending Oil leakage in Radiator Bank
220/132 KV 100 MVA ICT 2 @ LONIKAND 2	IntraState	15/06/2023	08:33	15/06/2023	10:58	PO	Attending oil leakages of LV Y ph bushing
220/132 KV 100MVA ICT 2 @ BARAMATI	IntraState	15/06/2023	10:30	15/06/2023	14:14	PO	Preventive maintenance of NIFPS.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
KANHAN-MANSAR	IntraState	14/06/2023	10:50	14/06/2023	13:02	PO	Routine Maint. Work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALWA KALYAN	IntraState	13/06/2023	22:15	14/06/2023	06:42	PO	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)
BHIRA (T) - DAVDI	IntraState	14/06/2023	06:54	14/06/2023	12:12	PO	Lightning spikes installation
KALWA KALYAN	IntraState	14/06/2023	20:56	15/06/2023	06:28	PO	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage