

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 14/Jun/2024 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	142.588	2168.757	1) Gujrat	0.919	9.951
2) Hydro	6.856	125.003	2) Madhya Pradesh	1.090	17.388
3) Gas	6.964	95.618	3) Chattisgarh	1.150	30.570
Total MSPGCL	156.408	2389.378	4) Maharashtra	179.377	2720.392
B) 1) APLM	42.730	782.850	5) Goa (Amona)	-1.675	-28.781
2) JSWEL	21.124	355.606	Total	180.861	2749.520
3) VIPL	0.000	0.000	a) Mumbai Schedule	62.845	640.857
4) RPL(AMT)	30.514	417.630	b) Mumbai Drawl	47.002	656.148
5) SWPGPL	11.826	170.185	c) MSEDCL Bilateral *	78.548	1198.244
6) Other IPP	15.197	209.935	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	62.845	640.805
C) 1) TPCL Thermal	12.051	179.443	Include PX	0.000	0.000
2) TPCL Hydro	4.837	78.523	Standby	0.000	0.053
3) TPCL Gas	4.127	57.353	H) ENERGY CATERED (MUs)		
4) AEML Thermal	6.784	129.717	1) MSEDCL	447.853	6752.555
D) STATE			2) Mumbai Discoms	74.801	1101.181
1) Thermal	282.814	4414.123	3) Other Discoms	11.872	163.183
(A1+C1+C4+(B1-B6))			TOTAL STATE	534.526	8016.919
2) Hydro	11.693	203.526			
(A2+C2)					
3) Gas	11.091	152.971			
(A3+B7+C3)					
4) Wind	32.490	286.673			
6) SOLAR	15.577	210.109			
TOTAL STATE	353.665	5267.402			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5070	4978	6590	6179
MSPGCL Hydro	351	143	542	167
MSPGCL Gas	286	291	287	292
MSPGCL Total Generation	5707	5412	7419	6638
Central Sector Receipt	8395	8846	7894	6942
WIND	1353	1299	1335	1452
CPP / IPP Thermal	4524	4538	5490	4719
CPP / IPP Gas	0	0	0	0
SOLAR	2092	1761	0	0
Exchange with Mumbai	-2526	-2406	-2033	-1496
MSEDCL DEMAND MET	19004	18933	19589	17855
Load Shedding	0	0	0	0
MSEDCL DEMAND	19004	18933	19589	17855
TPCL GENERATION	843	894	1033	678
AEML GENERATION	166	206	238	317
MUMBAI DEMAND	3535	3506	3304	2491
OTHER DISCOM DEMAND	541	517	516	400
STATE DEMAND MET	23080	22956	23409	20746
STATE DEMAND	23080	22956	23409	20746
Frequency (Hz)	49.98	49.95	49.95	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 08.58 Hrs	49.75 Hz at 22.49 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 14/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.08	57.49	191	132
Unit 8	13.26	190.58	611	383
Unit 9	13.06	161.90	610	388
Unit 10	12.28	178.34	565	410
Total	42.69	588.31		
Bhusawal				
Unit 3	0.00	20.50	0	0
Unit 4	9.38	142.09	485	285
Unit 5	8.92	131.16	485	285
Total	18.30	293.76		
Parli				
Unit 6	0.00	34.93	0	0
Unit 7	0.00	26.47	0	0
Unit 8	0.00	38.18	0	0
Total	0.00	99.58		
Chandrapur				
Unit 3	3.33	49.74	160	123
Unit 4	3.38	50.55	165	125
Unit 5	8.04	90.34	440	275
Unit 6	7.90	73.34	435	270
Unit 7	8.53	124.78	473	285
Unit 8	4.76	132.34	455	0
Unit 9	9.94	118.64	496	281
Total	45.89	639.72		
Paras				
Unit 3	4.59	63.83	231	139
Unit 4	0.00	7.43	0	0
Total	4.59	71.26		
Khaparkheda				
Unit 1	3.16	49.34	160	105
Unit 2	3.48	57.41	178	117
Unit 3	3.46	43.90	168	128
Unit 4	3.61	58.69	177	128
Unit 5	10.84	153.32	480	290
Total	24.55	362.66		
Nasik				
Unit 3	3.31	47.74	164	113
Unit 4	0.00	19.19	0	0
Unit 5	3.25	46.53	167	119
Total	6.56	113.46		
Uran				
All Units	6.96	95.62	293	285
Total	6.96	95.62		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	1.42	0	0
Total	0.00	1.42		
Koyna				
Stage 1-2	2.51	39.96	290	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.37	29.55	230	0
Stage 3	0.88	17.12	160	0
Total	3.76	86.63		
Hydro				
KDPH	0.00	2.96	0	0
VTRNA	0.87	9.48	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.69	23.44	77	66
GHATGHAR	0.54	2.49	125	0
Total	3.10	38.37		
Wind				
Total	32.49	286.67	0	0
Total	32.49	286.67		
CPP				
APML(Mus)	42.73	782.85	0	0
JSWEL(Mus)	21.12	355.61	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.51	417.63	0	0
SWPGPL-Mus	11.83	170.18	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.67	80.38	267	193
Other(Mus)	3.53	59.92	0	0
JPL	5.99	69.62	273	234
Total	121.39	1936.21		
SOLAR				
Total	15.58	210.11	0	0
Total	15.58	210.11		
Tata				
Trombay 5	8.04	119.30	443	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	35.96	108	108
Trombay 7B	1.54	21.40	64	63
TATA Hydro	4.84	78.52	390	83
Trombay 8	4.01	60.14	228	129
Total	21.02	315.32		
AEML				
DTPS U-1&2	6.78	129.72	469	166
Total	6.78	129.72		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	142.59	2168.76	MSPGCL Total	156.41	2389.38
			MSPGCL Thml+Gas	149.55	2264.38	Koyna 1,2 & 4 Total	2.88	69.51
			MSPGCL Hydro	6.86	125.00	State Total	353.66	5267.40

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 14/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6890	326	290	7506	957	5954	0	0	7064	6395	-1714	18651	0	0	18651	3087	447	22185	49.99
2	6624	172	292	7088	1228	5173	0	0	7619	7098	-1650	18508	0	0	18508	2785	429	21722	49.96
3	6372	172	292	6836	1393	4809	0	0	7281	7081	-1564	18130	0	0	18130	2603	425	21158	50.01
4	6179	167	292	6638	1452	4719	0	0	7037	6942	-1496	17855	0	0	17855	2491	400	20746	50.01
5	6203	171	293	6667	1438	4804	0	0	6778	6927	-1335	18092	0	0	18092	2454	409	20955	49.98
6	6657	326	293	7276	1418	5061	0	0	6852	7282	-1333	19269	0	0	19269	2482	435	22186	50.02
7	6939	169	291	7399	1333	5666	0	177	7117	6698	-1410	19389	0	0	19389	2577	474	22440	50.05
8	6503	111	292	6906	1372	4890	0	599	8001	7130	-1618	18781	0	0	18781	2737	498	22016	50.04
9	5808	118	290	6216	1603	4564	0	1218	7934	7389	-1993	18471	0	0	18471	2985	526	21982	50.08
10	5040	119	291	5450	1705	4214	0	1794	8373	7658	-2189	18097	0	0	18097	3214	535	21846	50.12
11	4738	183	288	5209	1598	3965	0	1956	8640	8380	-2436	18145	0	0	18145	3425	527	22097	50.01
12	5070	351	286	5707	1353	4524	0	2092	8038	8395	-2526	19004	0	0	19004	3535	541	23080	49.98
13	5010	146	285	5441	1179	4553	0	1951	8435	8110	-2532	18173	0	0	18173	3600	529	22302	50.02
14	4649	152	290	5091	1155	4171	0	1869	8737	8576	-2366	17978	0	0	17978	3464	518	21960	49.98
15	4978	143	291	5412	1299	4538	0	1761	8976	8846	-2406	18933	0	0	18933	3506	517	22956	49.95
16	5147	117	291	5555	1649	4722	0	1269	8666	8263	-2386	18531	0	0	18531	3523	541	22595	49.95
17	5117	221	289	5627	2159	4634	0	611	8731	8166	-2356	18293	0	0	18293	3534	548	22375	49.99
18	5218	453	287	5958	1861	4832	0	246	8443	8379	-2424	18323	0	0	18323	3446	529	22298	49.96
19	6475	261	290	7026	1746	5267	0	34	7998	7486	-2237	18781	0	0	18781	3327	541	22649	49.98
20	6590	542	287	7419	1335	5490	0	0	8012	7894	-2033	19589	0	0	19589	3304	516	23409	49.95
21	6613	800	288	7701	921	6072	0	0	7118	7259	-1814	19612	0	0	19612	3252	527	23391	50.04
22	6576	454	290	7320	778	6237	0	0	7005	6824	-1695	18971	0	0	18971	3176	493	22640	50.01
23	6604	481	293	7378	801	6371	0	0	7062	7027	-1727	19357	0	0	19357	3143	493	22993	49.94
24	6588	701	293	7582	757	6161	0	0	6856	6656	-1762	18920	0	0	18920	3151	474	22545	49.96
MUs	142.59	6.86	6.96	156.41	32.49	121.39	0.00	15.58	186.77	180.86	-47.00	447.85	0.00	0.00	447.85	74.80	11.87	534.53	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 14/Jun/2024

Position as on 6.30 Hrs of 15/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Koyna Unit 2	70	15/06/2024	07:10		Continued.	Govrner renovation	10/07/2024
Total Capacity MSPGCL		70						
Total Capacity PLANNED OUTAGE		70						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Paras Unit 4	250	05/06/2024	03:59		Continued.	Fire in GT	16/06/2024
MSPGCL	Nasik Unit 4	210	06/06/2024	19:18		Continued.	ID Fan Problem(Under Tolling from 23.00Hrs DT.06-06-2024)	
MSPGCL	Chandrapur Unit 8	500	14/06/2024	12:25		Continued.	Abnormal Parameters which is created due to increase in leakage of FDV 9.	
Total Capacity MSPGCL		1205						
AEML								
AEML	AEML Unit 1	250	14/06/2024	10:16		Continued.	Boiler Tube Leakage	
Total Capacity AEML		250						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1775						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	05/06/2024	17:00		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	06/06/2024	17:40		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Parli Unit 7	250	08/06/2024	21:00		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 6	250	08/06/2024	21:13		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 8	250	09/06/2024	20:50		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	12/06/2024	16:15		Continued.	Zero schedule given by LM Cell Discom due to drop in	

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 14/Jun/2024

Position as on 6.30 Hrs of 15/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							demand	
Total Capacity MSPGCL		1176						
IPP								
IPP	Adani U-4	660	10/06/2024	16:16		Continued.	ZERO SCHEDULE BY MSEDCL	
Total Capacity IPP		660						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		1836						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 15/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (709) OF 765/21KV GT-5 @TIRORA	IntraState	14/06/2024	10:30	14/06/2024	13:24	PO	CT OIL SAMPLE COLLECTION FOR DGA
MAIN BAY (703) OF 765/21KV GT-4 @ TIRORA	IntraState	15/06/2024	09:35			PO	CT OIL SAMPLE COLLECTION FOR DGA
765 KV ICT Outages/Trippings							
765/400kV 1500MVA ICT-1 @ KORADI 3	IntraState	15/06/2024	09:47			PO	Six monthly changeover of R-Ph ICT to be taken in service in place of Spare Ph ICT as per CEA regulation at Koradi-III SS. Last changeover date 30.12.2023
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
CHANDRAPUR-PARLI CKT-3	IntraState	14/06/2024	08:19	14/06/2024	15:53	PO	1.Measurement of tandelta of Bushing of 50MVar Line shunt Reactor. 2.Premonsoon maintenance work of Reactor. 3. Maintenance and alignment of Isolators. 4. Bay routine maintenance work.
PADGHE - NAGOTHANE CKT - 1	IntraState	14/06/2024	12:35	14/06/2024	19:43	PO	For string replacement work
KHADKA - BABLESHWAR	IntraState	14/06/2024	14:08	14/06/2024	19:38	PO	Routine Line maintenance work;LBB relay testing
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	13/06/2024	10:11			PO	For work in vicinity for erection of scaffolding for installation of LA�s on 220KV Bays at KVTL Vikhroli (These Bays used for feeding 220/110kV, 250MVA, ICT-1 & ICT-2 of TPC Vikhroli).
400/220/20 KV 300 MVA ICT - 1 @ KORADI	IntraState	14/06/2024	09:41	14/06/2024	14:17	PO	For premonsson maintenance works
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	IntraState	14/06/2024	10:20	14/06/2024	16:53	PO	Routine Maintenance and Diagnostic Testing Work.
400/220/33 KV 315 MVA ICT - 2 @ KORADI	IntraState	14/06/2024	14:51	14/06/2024	17:33	PO	For premonsson maintenance works
400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	IntraState	15/06/2024	09:20			PO	HV CT tand Testing and bay maintenance work
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 14/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 15/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220KV GIS DCHI - COLOURCHEM	IntraState	31/05/2024	04:30			PO	For de-stringing & stringing of old circuit at new tower Loc. No. 6.
NTT - KALWA	IntraState	05/06/2024	00:20			PO	For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kV GIS S/tn M/s NTT Global DC NAV2 Pvt Ltd.
EKLAHARE (OCR) - PADGHE	IntraState	10/06/2024	08:42			HT	H/T for load management
TIFIL - KALWA	IntraState	13/06/2024	08:55			PO	For making 220kV Pawane-TIFIL line LILO for M/s NXTRA Data Ltd for the proposed 220kV GIS S/stn.
PARGAON(KATHAPUR)-LONIKAND	IntraState	13/06/2024	17:22	14/06/2024	00:19	PO	Loc No 306 Bph, 321 Rph, 322 Bph flashover string replacement work.
TALEGAON (AMBI)-TALEGAON (PG) CKT 1	IntraState	13/06/2024	23:43	14/06/2024	06:24	PO	Cold line washing of insulators.
220 KV GIRWALI (400 KV) -PARLI U-8 CKT	IntraState	14/06/2024	06:23	14/06/2024	19:30	HT	1. y phase ct replacement due to rising high tan delta values. 2. y phase la replacement due to high leakage current values as compared to previous results. 3. r phase cb to 29 d isolator jump replacement. 4. at present, the generation is stopped.
ADLABS - PEDAMBE	IntraState	14/06/2024	06:50	14/06/2024	14:35	PO	Outage tree cutting work at Loc.No.262-263,293-294,397-398 & Other line Maint. Works
WASHALA - GHATGHAR	IntraState	14/06/2024	08:16	14/06/2024	14:00	PO	1)Emergency Tree cutting maintenance work and 2) Emergency Tree monsoon maintenance work
BHAVEGHAR - ROMA	IntraState	14/06/2024	09:48	14/06/2024	14:06	PO	Insulator replacement Work identified in PID.
YEOTMAL- PUSAD	IntraState	14/06/2024	09:55	14/06/2024	17:43	HT	Measurement of c & tan delta of line ct�s & cc. cb crm, timing, ir values etc. routine maintenance work.
KURKUMBH - SHIRSHUPHAL CKT	IntraState	14/06/2024	10:17	14/06/2024	20:25	PO	Replacement of Distance protection relay, diagnostic testing of bay equipments
VERSOVA - GORAI	IntraState	14/06/2024	11:49			PO	Pre-monsoon Maintenance work
LAMBOTI - TULJAPUR CKT - 1	IntraState	14/06/2024	13:12	14/06/2024	16:58	T	Leakage attending work.
LAMBOTI - TULJAPUR CKT - 2	IntraState	14/06/2024	17:18	14/06/2024	18:13	T	Leakage attending work.
KANDALGAON - PIRANGUT	IntraState	15/06/2024	06:15			PO	For attending hot spot at various locations & double jumpering work.
KANDALGAON - ONGC PANVEL	IntraState	15/06/2024	08:45			PO	Outage tree cutting work at various location and other line maintenance work.
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/132KV 200MVA ICT 3 @ PANDHARPUR	IntraState	12/06/2024	10:50			PO	Outage is required for Pre Monsoon maintenance
220/100 KV 100 MVA ICT 1 @ JAMBHUL	IntraState	13/06/2024	11:46	14/06/2024	13:30	PO	Nitrogen Injection Pipeline reinstallation/ replacement work by M/s. CTR.
220/132 KV 200MVA ICT NO 2 @ THEUR	IntraState	14/06/2024	06:15	14/06/2024	14:28	PO	OLTC overhauling work
220/100 KV 200 MVA ICT 1 @ PALDOMBIVALI	IntraState	14/06/2024	09:28	14/06/2024	14:28	PO	Replacement of HV Back up relay.
220/132 KV 100 MVA ICT 1	IntraState	14/06/2024	10:00	14/06/2024	15:15	PO	1)Replacement of LV B-phase CT.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 15/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33KV 50MVA TF NO.1 @ SAYNE	IntraState	14/06/2024	12:45	14/06/2024	15:10	PO	For attending oil leakage of 33kV R-Ph & B-Ph CT. (Oil leakage observed recently from CT stud of R-Ph & B-Ph).
220/132 KV 200 MVA PTR 4 @ PHURSUNGI	IntraState	14/06/2024	18:04	14/06/2024	23:00	T	B ph LA of 132kV side is failed
220 KV BUSBAR Outages/Trippings							
TBC @220 KV NERUL	IntraState	14/06/2024	09:01	14/06/2024	12:17	PO	Pre-Monsoon Maintenance CB CRM Timing Auxiliary isolator maintenance work
132 KV LINE Outages/Trippings							
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.
110 KV LINE Outages/Trippings							
TATA BHIVPURI MSETCL NERAL	IntraState	14/06/2024	06:05	14/06/2024	13:14	PO	R/M of TBS GOD and Testing

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage