

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 14/Aug/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	130.660	1804.472	1) Gujrat	14.899	166.625
2) Hydro	13.520	194.146	2) Madhya Pradesh	9.080	105.812
3) Gas	0.688	3.096	3) Chattisgarh	1.120	26.140
Total MSPGCL	144.868	2001.714	4) Maharashtra	181.708	2207.382
B) 1) APML	61.701	775.316	5) Goa (Amona)	-1.681	-22.130
2) JSWEL	14.188	183.953	Total	205.126	2483.829
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.152	458.400
4) RPL(AMT)	31.143	367.806	b) Mumbai Drawl	37.021	508.750
5) SWPGPL	10.997	119.543	c) MSEDCL Bilateral *	102.243	1307.880
6) Other IPP	6.656	89.603	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.152	458.400
C) 1) TPCL Thermal	11.440	155.302	Include PX	0.000	0.000
2) TPCL Hydro	7.003	73.599	Standby	0.000	0.000
3) TPCL Gas	3.169	39.766	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.694	128.007	1) MSEDCL	474.101	6202.258
D) STATE			2) Mumbai Discoms	67.327	905.424
1) Thermal	275.479	3624.002	3) Other Discoms	9.920	139.461
(A1+C1+C4+(B1-B6))			TOTAL STATE	551.348	7247.143
2) Hydro (A2+C2)	20.523	267.745			
3) Gas (A3+B7+C3)	3.857	42.862			
4) Wind	35.615	669.529			
6) SOLAR	10.748	159.176			
TOTAL STATE	346.222	4763.314			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5237	5421	5567	5498
MSPGCL Hydro	318	988	1517	202
MSPGCL Gas	0	0	182	0
MSPGCL Total Generation	5555	6409	7266	5700
Central Sector Receipt	10599	9812	7499	6593
WIND	1250	1622	1718	1630
CPP / IPP Thermal	5184	5104	5200	5200
CPP / IPP Gas	0	0	0	0
SOLAR	1521	873	0	0
Exchange with Mumbai	-2289	-2164	-1226	-1077
MSEDCL DEMAND MET	21383	21232	20007	17703
Load Shedding	0	0	83	0
MSEDCL DEMAND	21383	21232	20090	17703
TPCL GENERATION	742	810	1298	700
AEML GENERATION	359	319	494	288
MUMBAI DEMAND	3390	3293	3018	2065
OTHER DISCOM DEMAND	437	424	450	343
STATE DEMAND MET	25210	24949	23475	20111
STATE DEMAND	25210	24949	23558	20111
Frequency (Hz)	49.98	49.94	49.98	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 18.04 Hrs	49.8 Hz at 09.38 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 14/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.38	43.82	160	120
Unit 8	13.38	184.58	610	521
Unit 9	12.59	171.44	550	485
Unit 10	0.00	0.00	0	0
Total	29.34	399.83		
Bhusawal				
Unit 3	3.19	42.03	135	125
Unit 4	0.83	88.71	230	0
Unit 5	11.14	132.48	480	450
Total	15.16	263.22		
Parli				
Unit 6	4.73	28.26	240	151
Unit 7	5.12	28.47	248	144
Unit 8	4.61	30.34	225	151
Total	14.45	87.07		
Chandrapur				
Unit 3	3.34	40.17	156	118
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	2.11	102.86	360	0
Unit 7	7.17	101.15	335	261
Unit 8	10.73	142.69	477	427
Unit 9	10.50	142.01	480	416
Total	33.85	528.88		
Paras				
Unit 3	5.36	65.21	239	214
Unit 4	4.70	61.60	206	182
Total	10.06	126.81		
Khaparkheda				
Unit 1	2.27	28.60	110	80
Unit 2	2.88	36.77	126	101
Unit 3	3.12	51.86	178	0
Unit 4	4.39	53.61	194	170
Unit 5	10.39	133.44	450	390
Total	23.06	304.26		
Nasik				
Unit 3	0.00	46.24	0	0
Unit 4	3.74	34.09	170	142
Unit 5	0.99	14.06	136	0
Total	4.73	94.40		
Uran				
All Units	0.69	3.10	182	0
Total	0.69	3.10		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.64	12.72	47	0
Total	0.64	12.72		
Koyna				
Stage 1-2	2.63	38.08	365	30

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	3.90	42.36	652	0
Stage 3	1.61	21.77	240	0
Total	8.15	102.21		
Hydro				
KDPH	0.00	7.15	0	0
VTRNA	0.00	0.61	0	0
TILLARI	0.00	1.62	0	0
BHIRA T.R.	0.44	6.15	80	0
SMLHY_PTN	3.99	59.39	170	160
GHATGHAR	0.31	4.30	125	0
Total	4.74	79.22		
Wind				
Total	35.62	669.53	0	0
Total	35.62	669.53		
CPP				
APML(Mus)	61.70	775.32	0	0
JSWEL(Mus)	14.19	183.95	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.14	367.81	0	0
SWPGPL-Mus	11.00	119.54	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.72	75.39	265	194
Other(Mus)	0.93	14.21	0	0
Total	124.68	1536.22		
SOLAR				
Total	10.75	159.18	0	0
Total	10.75	159.18		
Tata				
Trombay 5	7.59	102.54	464	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.92	23.51	108	39
Trombay 7B	1.25	16.26	64	35
TATA Hydro	7.00	73.60	436	131
Trombay 8	3.85	52.76	228	128
Total	21.61	268.67		
AEML				
DTPS U-1&2	8.69	128.01	494	288
Total	8.69	128.01		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	130.66	1804.47	MSPGCL Total	144.87	2001.71
			MSPGCL Thml+Gas	131.35	1807.57	Koyna 1,2 & 4 Total	6.54	80.44
			MSPGCL Hydro	13.52	194.15	State Total	346.22	4763.31

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 14/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5713	209	0	5922	1932	5312	0	0	6835	6560	-1213	18126	0	0	18126	2432	387	20945	50.00
2	5525	190	0	5715	1814	5267	0	0	6960	6830	-1192	18075	0	0	18075	2256	359	20690	49.97
3	5521	200	0	5721	1690	5252	0	0	7128	7107	-1111	18310	0	0	18310	2134	349	20793	49.98
4	5498	202	0	5700	1630	5200	0	0	7422	6593	-1077	17703	0	0	17703	2065	343	20111	49.98
5	5503	221	0	5724	1570	5261	0	0	8080	7733	-1032	18910	0	0	18910	2047	346	21303	49.52
6	5591	372	8	5971	1207	5196	0	0	8930	8526	-1086	19440	0	0	19440	2145	374	21959	49.98
7	5425	1129	97	6651	965	5246	0	68	9091	8931	-1089	20372	0	0	20372	2320	400	23092	50.04
8	5272	809	118	6199	855	5145	0	389	10163	10011	-1129	21063	0	0	21063	2519	407	23989	50.00
9	5186	574	0	5760	938	5120	0	724	10597	10358	-1720	20747	0	0	20747	2832	433	24012	49.94
10	5152	571	0	5723	1015	5117	0	1132	10557	10503	-2022	21013	0	0	21013	3143	455	24611	49.92
11	5118	448	0	5566	1114	5151	0	1436	10756	10784	-2279	21336	0	0	21336	3351	436	25123	50.03
12	5237	318	0	5555	1250	5184	0	1521	10835	10599	-2289	21383	0	0	21383	3390	437	25210	49.98
13	5290	257	0	5547	1229	5193	0	1439	10431	10196	-2304	20877	0	0	20877	3321	423	24621	49.99
14	5259	297	0	5556	1470	5164	0	1246	10052	9931	-2217	20734	0	0	20734	3189	416	24339	49.99
15	5315	461	0	5776	1487	5117	0	1083	10232	10062	-2180	20925	0	0	20925	3230	420	24575	49.88
16	5421	988	0	6409	1622	5104	0	873	10048	9812	-2164	21232	0	0	21232	3293	424	24949	49.94
17	5367	742	0	6109	1795	5141	0	586	9907	9542	-1997	20734	0	0	20734	3271	442	24447	50.02
18	5364	651	2	6017	1537	5124	0	228	9279	9001	-1853	19597	0	0	19597	3151	457	23205	50.08
19	5491	942	60	6493	1643	5220	0	23	8290	7893	-1444	19368	0	0	19368	3046	460	22874	50.05
20	5567	1517	182	7266	1718	5200	0	0	7687	7499	-1226	20007	83	0	20090	3018	450	23558	49.98
21	5687	932	176	6795	1836	5220	0	0	7482	7199	-1171	19434	0	0	19434	2942	445	22821	50.03
22	5729	496	45	6270	1853	5273	0	0	7032	6845	-1100	18698	0	0	18698	2826	443	21967	50.00
23	5728	692	0	6420	1721	5216	0	0	6565	6602	-1096	18453	0	0	18453	2727	410	21590	50.01
24	5701	306	0	6007	1724	5262	0	0	6558	6005	-1030	17562	0	0	17562	2679	406	20647	49.98
MUs	130.66	13.52	0.69	144.87	35.62	124.68	0.00	10.75	210.92	205.13	-37.02	474.10	0.08	0.00	474.18	67.33	9.92	551.43	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 14/Aug/2023

Position as on 6.30 Hrs of 15/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	27/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	OVERHAUL	25/08/2023
IPP	Adani U-4	660	12/08/2023	23:44		Continued.	Annual Overhaul	05/09/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/08/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	COH (Hot spot on Stator).	13/09/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05	15/08/2023	19:56	Compressor Surge Protection	15/08/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	20/08/2023
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	19/08/2023
MSPGCL	Nasik Unit 5	210	05/08/2023	00:00	14/08/2023	15:00	ID Fan Problem(On Tolling since 18:23Hrs DT. 05-08-2023)	
IPP	JSW (J) U4	300	10/08/2023	05:55	14/08/2023	22:33	CW system leakage	14/08/2023
MSPGCL	Bhusawal Unit 4	500	10/08/2023	22:44	14/08/2023	18:50	Boiler Tube Leakage	14/08/2023
MSPGCL	Uran Unit 7	108	12/08/2023	21:59	14/08/2023	06:02	Zero Schedule.	
MSPGCL	Uran Unit 6	108	12/08/2023	22:15	14/08/2023	05:30	Zero Schedule.	
MSPGCL	Koyna Unit 7	80	13/08/2023	09:00		Continued.	Spherical Valve maintenance	02/09/2023
MSPGCL	Nasik Unit 3	210	13/08/2023	16:00		Continued.	Tolling from 15:00 hrs on Dt 14.08.2023.	17/08/2023
MSPGCL	Koyna STG-IV Unit-2	250	13/08/2023	19:10	14/08/2023	01:45	Water Drain valve leakage.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 14/Aug/2023

Position as on 6.30 Hrs of 15/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 6	500	14/08/2023	06:30		Continued.	BTL	18/08/2023
MSPGCL	Uran Unit 6	108	14/08/2023	07:37	14/08/2023	17:46	Zero Schedule	
MSPGCL	Uran Unit 7	108	14/08/2023	07:56	14/08/2023	18:12	Zero Schedule	
MSPGCL	Koyana STG-IV Unit-2	250	14/08/2023	18:30	15/08/2023	00:00	Synchronising problem.	
MSPGCL	Uran Unit 6	108	14/08/2023	21:19		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	14/08/2023	21:30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	15/08/2023	01:30		Continued.	Due to Abnormal sound in APH	17/08/2023
MSPGCL	Uran Unit 8	108	15/08/2023	20:07		Continued.	No Schedule	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 14/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 15/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV TBC Outages/Trippings							
POLE-2 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	13/08/2023	21:05	14/08/2023	00:21	EO	Antiweeding of pole 2 Z1 & Z2 base filter As grass has grown very tall.
POLE-2 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	13/08/2023	21:05	14/08/2023	00:21	EO	Antiweeding of Pole II Z1 & Z2 Base Filter as grass has grown very tall
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of $\Delta Y \Delta$ phase Protection CT Of NTPP I (RPL 1)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	05/08/2023	10:07			HT	TO CONTROL LINE LOADING OF PUNE GIS
JAIGAD - KARAD CKT - 2	IntraState	14/08/2023	01:13	14/08/2023	08:14	HT	H/T to control Overvoltage
KORADI II - KORADI III CKT - 4	IntraState	14/08/2023	09:59	14/08/2023	12:51	PO	Annual Maintenance of Line equipment at Koradi III SS
JAIGAD - NEW KOYNA CKT - 2	IntraState	14/08/2023	11:02	14/08/2023	19:00	EO	Attending CB isolator alignment work as Spark is observed
KHADKA-AURANGABAD (WALUJ)	IntraState	14/08/2023	20:11		Continued.	HT	H/T on overvoltage
JAIGAD - KARAD CKT - 1	IntraState	14/08/2023	20:17	15/08/2023	08:41	HT	H/T on overvoltage
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	15/08/2023	05:45	15/08/2023	07:22	T	Tripped on distance protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	IntraState	12/08/2023	10:21	15/08/2023	20:24	PO	1.Commissioning of High velocity water spray system for 315MVA ICT-1. 2. Routine maintenance of ICT 2. Maintenance and alignment of Isolators 3. Bay routine maintenance work
400/220/33 KV 500 MVA ICT - 3 @ PARLI	IntraState	14/08/2023	09:38	14/08/2023	19:03	PO	(1) C & Tan D of Bushing & winding testing work. (2) Bay maintenance work.
220 KV MAINBAY Outages/Trippings							
METERING BAY (CONSUMER) - 1 @ SERUM	IntraState	14/08/2023	16:15	14/08/2023	17:25	EO	Replacement of 01 No. of CT Main R Phase
INTERCONNECTOR @ KALWA	IntraState	14/08/2023	20:50	15/08/2023	02:14	EO	1) B ph damaged twin Jumper replacement work of 52 C between CB to CT 2) B ph damage jumper replacement work in between 29 F isolator to stub bus
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
CHAKAN (400KV) - VOLKSWAGEN	IntraState	14/08/2023	10:39	14/08/2023	17:52	PO	SCADA Trial and Commissioning work
KARAD - NERLE	IntraState	14/08/2023	11:10	14/08/2023	17:55	PO	Quarterly Maintenance Work
220 KV JALKOT - KUMBHARGAON (400 KV) CKT - 1	IntraState	14/08/2023	11:48	14/08/2023	15:04	PO	Emergency Tree Cutting.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 14/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 15/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV PARLI -U-8 - PARBHANI CKT	IntraState	14/08/2023	11:50	14/08/2023	15:05	PO	Replacement Of Disc Insulator LOC No.283,284,285 All R-Phase.
TALANDGE - MUDSHINGI CKT - 2	IntraState	14/08/2023	13:57	14/08/2023	16:02	PO	Quarterly Maintenance and Diagnostic testing work
APTA - TAMBATI	IntraState	14/08/2023	16:53	14/08/2023	18:28	EO	For replacement of faulty jumper of RPh CT to CB side
TROMBAY MSETCL TIE - 2	IntraState	15/08/2023	00:08	15/08/2023	02:58	T	Tripped due to Y ph PT burst at TROMBAY SS
TROMBAY (M) - CHEMBUR CKT - 3	IntraState	15/08/2023	00:08	15/08/2023	02:40	T	Tripped due to Y ph PT burst at TROMBAY SS
BUS SECTION - 1 @ TROMBAY	IntraState	15/08/2023	00:08	15/08/2023	02:38	T	Tripped due to Y ph PT burst at TROMBAY SS
TROMBAY - KALWA	IntraState	15/08/2023	00:08	15/08/2023	02:38	T	Tripped due to Y ph PT burst at TROMBAY SS
AAREY - MSETCL BORIVALI CKT - 2	IntraState	15/08/2023	06:02			T	Tripped on Distance Protection
ROAD SIDE BUS @ KALWA	IntraState	15/08/2023	08:48	15/08/2023	17:56	PO	Replacement of Earth wire
BABLESHWAR AHAMADNAGAR-II	IntraState	15/08/2023	08:59	15/08/2023	13:38	PO	Replacement of faulty string found in pid report at loc no 11 DSN Y pH
MAHINDRA VEHICLE-BRIDGESTONE	IntraState	15/08/2023	09:18	15/08/2023	15:11	PO	Stringing work on the dummy line due to low clearance in between B-ph of 220 kV Mahindra vehicle-Bridgestone circuit & R-ph of dummy line on existing tower loc no. 4 and lilo arrangement at proposed LILO.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132 KV 200 MVA PTR NO 6 @ PARVATI	IntraState	13/08/2023	17:45	14/08/2023	10:03	T	Tripped while changing tap. OSR winding relay And master trip operated.
220/33KV 25MVA PTR 2 @ PAWAS	IntraState	14/08/2023	09:20	14/08/2023	18:54	PO	For replacement of 33kV LV & feeder CTs
220/132 KV 100 MVA ICT 1 @ PHALTAN MIDC	IntraState	14/08/2023	09:40	14/08/2023	17:18	PO	ICT Painting Work
220/100 KV 100 MVA ICT 1 @ KANDALGAON	IntraState	14/08/2023	10:06	14/08/2023	13:50	PO	R ph , Y ph & B ph lightening arrester of ICT 01 LV side replacement work to be carried out.
220/132 KV 200 MVA ICT 1 @ KALMESHVAR	IntraState	14/08/2023	10:25	14/08/2023	20:05	PO	Replacement Of CT Under LES Scheme.
220/33KV 25MVA PTR - 1 @ ONI	IntraState	14/08/2023	11:05	14/08/2023	12:25	EO	Attending oil leakage in 220/33 kV 25 MVA BBL TF LV B Ph CT.
220/132-110 KV 100MVA ICT No-02 @ OGLEWADI	IntraState	14/08/2023	14:56	14/08/2023	17:19	EO	Attending heavy oil leakage of HV B Ph CT
220/132 KV 100 MVA ICT 1 @ PHALTAN MIDC	IntraState	15/08/2023	09:00	15/08/2023	17:38	PO	ICT Painting Work
220/132 KV 100 MVA ICT 1 @ SAWANGI	IntraState	15/08/2023	09:30	15/08/2023	10:57	EO	To attend Hot Spot
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 15/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALYAN KALWA SALSETTE 1	IntraState	14/08/2023	16:55	15/08/2023	00:04	PO	Loop closing at loc. 78 towards Salsette side for taking line in service between Kalyan, Kalwa & Salsette end.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage