

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 14/Sep/2018 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	117.491	1431.856	1) Gujrat	2.967	24.660
2) Hydro	18.962	196.658	2) Madhya Pradesh	17.967	222.353
3) Gas	3.022	39.112	3) Chattisgarh	5.410	70.720
Total MSPGCL	139.475	1667.626	4) Maharashtra Net	128.017	1666.579
B) 1) APML	57.331	737.891	5) Goa (Amona)	-0.154	-5.588
2) JSWEL	25.105	242.682	Total	154.207	1978.724
3) VIPL	14.833	202.231	a) Mumbai Schedule	20.826	317.869
4) RPL(AMT)	31.352	407.225	b) Mumbai Drawl	21.315	319.213
5) WPCL	4.551	44.734	c) MSEDCL Bilateral *	57.169	563.636
6) PGPL	0.000	0.000	Include PX	35.537	267.712
7) Other IPP	6.744	92.948	d) Mumbai Bilateral *	20.826	317.869
C) 1) TPCL Thermal	16.735	212.309	Include PX	0.161	28.644
2) TPCL Hydro	5.285	64.852	Include Standby	0.000	0.000
3) TPCL Gas	4.368	60.694	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	12.011	152.523	1) MSEDCL	427.558	5477.610
D) STATE			2) Mumbai Discoms	59.712	809.586
1) Thermal	286.153	3524.399	TOTAL STATE	487.270	6287.196
(A1+C1+C4+(B1-B6))					
2) Hydro	24.247	261.510			
(A2+C2)					
3) Gas	7.390	99.806			
(A3+B6+C3)					
4) Wind	10.055	351.795			
6) SOLAR	5.220	70.967			
TOTAL STATE	333.065	4308.477			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4910	4936	5054	4743
MSPGCL Hydro	1032	1066	1287	491
MSPGCL Gas	102	102	159	126
MSPGCL Total Generation	6044	6104	6500	5360
Central Sector Receipt	8223	8069	4833	5325
WIND	92	167	985	412
CPP / IPP Thermal	5781	5766	5975	5616
CPP / IPP Gas	0	0	0	0
SOLAR	729	650	0	0
Exchange with Mumbai	-1310	-1267	-952	-501
MSEDCL DEMAND MET	19559	19490	17341	16212
Load Shedding	0	0	0	0
MSEDCL DEMAND	19559	19490	17341	16212
TPCL GENERATION	1234	1215	1351	875
R-INFRA GENERATION	499	501	500	501
MUMBAI DEMAND	3043	2983	2803	1877
STATE DEMAND MET	22602	22473	20144	18089
STATE DEMAND	22602	22473	20144	18089
Frequency (Hz)	49.98	49.96	49.88	49.93

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.02 Hz at 08.00 Hrs	49.88 Hz at 19.00 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 14/Sep/2018

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.15	0	0
Unit 7	0.00	0.00	0	0
Unit 8	8.57	97.53	494	300
Unit 9	0.00	38.80	0	0
Unit 10	9.30	66.78	471	300
Total	17.87	203.25		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	11.05	140.47	475	420
Total	11.05	140.47		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	14.31	0	0
Unit 7	4.70	74.63	205	180
Unit 8	4.44	72.41	199	165
Total	9.14	161.36		
Chandrapur				
Unit 3	4.13	54.19	180	143
Unit 4	4.12	54.96	180	134
Unit 5	4.01	59.85	406	77
Unit 6	6.07	114.65	266	196
Unit 7	9.96	39.26	430	389
Unit 8	9.76	72.73	431	388
Unit 9	8.68	119.36	413	309
Total	46.73	515.00		
Paras				
Unit 3	4.78	59.25	239	169
Unit 4	5.33	61.69	245	195
Total	10.12	120.94		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	27.37	0	0
Unit 3	3.66	51.44	163	145
Unit 4	3.40	16.85	150	138
Unit 5	7.57	120.73	350	300
Total	14.64	216.38		
Nasik				
Unit 3	4.09	58.52	192	146
Unit 4	3.86	9.80	181	115
Unit 5	0.00	6.13	0	0
Total	7.94	74.45		
Uran				
All Units	3.02	39.11	179	100
Total	3.02	39.11		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.07	1.02	41	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.07	1.02		
Koyna				
Stage 1-2	4.97	49.12	505	40
Stage 4	10.21	79.85	841	31
Stage 3	3.20	29.86	240	0
Total	18.38	158.82		
Hydro				
KDPH	0.00	7.24	0	0
VTRNA	0.00	5.00	0	0
TILLARI	0.00	5.98	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.28	4.85	80	0
RNGR+BHTSA	0.24	3.51	14	0
BHANDARDRA	0.00	2.57	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.07	6.17	12	0
GHATGHAR	0.00	2.53	0	0
Total	0.58	37.84		
Wind				
Total	10.06	351.80	0	0
Total	10.06	351.80		
CPP				
APML(Mus)	57.33	737.89	0	0
JSWEL(Mus)	25.10	242.68	0	0
VIPL(Mus)	14.83	202.23	0	0
RPLAMT(Mus)	31.35	407.22	0	0
WPCL(Mus)	4.55	44.73	0	0
Other(Mus)	6.74	92.95	0	0
Total	139.92	1727.71		
SOLAR				
Total	5.22	70.97	0	0
Total	5.22	70.97		
Tata				
Trombay 5	11.27	139.63	476	462
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.76	38.33	116	114
Trombay 7B	1.61	22.36	68	66
Trombay 8	5.46	72.68	239	215
TATA Hydro	5.28	64.85	459	6
Total	26.39	337.86		
R-INFRA				
DTPS U-1&2	12.01	152.52	502	498
Total	12.01	152.52		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	117.49	1431.86	MSPGCL Total	139.48	1667.63
			MSPGCL Thml+Gas	120.51	1470.97	Koyna 1,2 & 4 Total	15.18	128.96
			MSPGCL Hydro	18.96	196.66	State Total	333.06	4308.48

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 14/Sep/2018

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4771	756	106	5633	642	5663	0	0	5021	5314	-735	16517	0	16517	2151	18668	49.95
2	4743	571	119	5433	547	5606	0	0	5197	5415	-610	16391	0	16391	1981	18372	49.92
3	4743	491	126	5360	412	5616	0	0	5186	5325	-501	16212	0	16212	1877	18089	49.93
4	4744	496	132	5372	312	5685	0	0	5178	5502	-442	16429	0	16429	1820	18249	49.96
5	4720	510	155	5385	242	5797	0	0	5490	5762	-436	16750	0	16750	1809	18559	49.97
6	4693	804	163	5660	145	5798	0	2	6095	6712	-508	17809	0	17809	1877	19686	49.97
7	4791	1110	122	6023	132	5912	0	34	6935	7325	-567	18859	0	18859	1960	20819	49.95
8	4900	696	107	5703	83	5954	0	206	7337	7842	-747	19041	0	19041	2165	21206	50.02
9	4920	497	105	5522	58	5788	0	461	7688	8082	-1043	18868	0	18868	2469	21337	50.01
10	4972	422	104	5498	37	5758	0	625	7698	8013	-1168	18763	0	18763	2806	21569	49.96
11	4916	618	103	5637	93	5795	0	703	7927	7984	-1288	18924	0	18924	2988	21912	49.95
12	4910	1032	102	6044	92	5781	0	729	8178	8223	-1310	19559	0	19559	3043	22602	49.98
13	4936	1066	102	6104	167	5766	0	650	8035	8069	-1267	19490	0	19490	2983	22473	49.96
14	4934	1270	101	6305	234	5782	0	594	7433	7677	-1158	19434	0	19434	2824	22258	49.99
15	4937	1059	102	6098	245	5743	0	448	7629	7581	-1162	18953	27	18980	2836	21816	50.01
16	4949	801	100	5850	315	5928	0	374	7566	7614	-1170	18911	27	18938	2865	21803	49.98
17	4952	648	125	5725	443	5913	0	295	7178	7142	-1107	18411	27	18438	2855	21293	49.96
18	5020	679	122	5821	621	5816	0	98	6377	6087	-1090	17353	0	17353	2800	20153	49.93
19	5068	808	124	6000	1023	5975	0	1	4955	4886	-979	16906	0	16906	2788	19694	49.88
20	5054	1287	159	6500	985	5975	0	0	4744	4833	-952	17341	0	17341	2803	20144	49.88
21	4962	744	169	5875	1017	5963	0	0	4515	4695	-836	16714	0	16714	2686	19400	49.90
22	4968	678	168	5814	815	5985	0	0	4383	4490	-692	16412	0	16412	2539	18951	49.92
23	4968	820	179	5967	736	5958	0	0	4515	4835	-760	16736	0	16736	2416	19152	49.90
24	4920	1099	127	6146	659	5956	0	0	4470	4797	-787	16771	0	16771	2373	19144	49.95
MUs	117.49	18.96	3.02	139.47	10.05	139.92	0.00	5.22	149.73	154.21	-21.31	427.56	0.08	427.64	59.71	487.35	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 14/Sep/2018

Position as on 6.30 Hrs of 15/Sep/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 4	500	10/08/2018	01.02	15/09/2018	10.29	Capital Overhaul	
IPP	Adani U-3	660	03/09/2018	05.02		Continued.	Capital overhaul	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Bhusawal Unit 3	210	21/05/2018	18.46		Continued.	Coal Swapping IEPL	
MSPGCL	Ghatghar Unit-2	125	29/06/2018	01.12		Continued.	Stator Earth Fault	
MSPGCL	Ghatghar Unit-2	125	29/06/2018	01:12		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
MSPGCL	Koradi Unit 7	210	03/08/2018	15.54		Continued.	Poor Coal Receipt.	
MSPGCL	Khaparkheda Unit 1	210	11/08/2018	23.57		Continued.	Poor coal Receipt	
MSPGCL	Uran Unit A0	120	27/08/2018	02:06	15/09/2018	02.12	Generator protection	
MSPGCL	Uran Unit 5	108	27/08/2018	03.31	14/09/2018	01.21	Due to A0 Trip.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Koradi Unit 9	660	04/09/2018	12.48		Continued.	Poor Coal Receipt	
MSPGCL	Chandrapur Unit 5	500	07/09/2018	11.24	14/09/2018	11.15	poor coal.	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn due to B0 & U-7	
MSPGCL	Koradi Unit 6	210	09/09/2018	05.52		Continued.	Inspection of Boiler Tubes by R & M Team.	
MSPGCL	Khaparkheda Unit 2	210	10/09/2018	02.35		Continued.	Poor Coal Receipt.	
MSPGCL	Nasik Unit 5	210	11/09/2018	18.45		Continued.	Coal Swapping with DIL	
MSPGCL	Parli Unit 6	250	12/09/2018	06.57		Continued.	Poor Coal receipt	
IPP	JSW (J) U2	300	13/09/2018	13.50	14/09/2018	02.18	turbine balancing.	
MSPGCL	Uran Unit 5	108	14/09/2018	06.17	14/09/2018	16.06	Generator protection	
MSPGCL	Chandrapur Unit 6	500	14/09/2018	23.58		Continued.	Clinker Removed	
MSPGCL	Paras Unit 3	250	15/09/2018	00.55		Continued.	Stator Earth Fault	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 15/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	13/09/2018	22.00	14/09/2018	03.39	PO	oil top up in smoothing reactor & connector transformer. 14/Sep/2018 REC 03.39.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kv Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar II	InterState	13/09/2018	17.53	14/09/2018	06.21	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	14/09/2018	16.45	15/09/2018	10.32	HT	for charging.
Dhule Sar'Sarovar II	InterState	15/09/2018	18.04		Continued.	HT	Over Voltage
Dhule - Bableshwar - li	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Dhule- Bableshwar - I	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Karad - Jaigad - II	IntraState	13/09/2018	17.13	14/09/2018	09.16	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	13/09/2018	17.59	14/09/2018	06.07	HT	Over Voltage
Akola-Bhusawal(khadka) bay 410	IntraState	14/09/2018	00.07	14/09/2018	13.38	EO	hot spot R PHASE isolator clamp.
Bhusawal-Aurangabad	IntraState	14/09/2018	20.07	15/09/2018	05.59	HT	Over Voltage
karad -kolhapur-II	IntraState	15/09/2018	14.43	15/09/2018	18.34	T	Distance Protection
Bhusawal-Aurangabad	IntraState	15/09/2018	18.07		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220kv 315 MVA ICT-III@Padgha	IntraState	14/09/2018	09.50	14/09/2018	18.50	PO	Testing Work
400/220 KV 500MVA ICT-IV @ Babhaleshwar	IntraState	14/09/2018	14.20	14/09/2018	17.01	T	Bucholz relay same time LTS operated.
400/220/33 Kv 500 MVA ICT-III @Girwali	IntraState	14/09/2018	19.50	14/09/2018	23.30	EO	Attending Hot Spot
400/220KV 105MVASpare ICT@Akola	IntraState	15/09/2018	10.40	15/09/2018	15.20	PO	DCRM Of Breaker.
400/220kv 315 Mva ICT I @Karad	IntraState	15/09/2018	14.21	15/09/2018	16.27	T	Buccholz Protection Optd
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching Of Conductor at Loc No.86 Disconnecting Of jumper at Loc No.86 to 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To control line loading.
Kalwa 52B Interconnector CB	IntraState	19/08/2018	18.25		Continued.	HT	Taken In Service To Control Load Of Temghar Ckt At Kalwa 1 S/5 In Lieu Of 220kv Bus Outage At Padgha.
Nerul-Trombay	IntraState	31/08/2018	22.04		Continued.	PO	Conductor Replacement
JATH SHEDYAL	IntraState	05/09/2018	20.34	14/09/2018	23.29	HT	Over Voltage
Dhule-Chalisagaon	IntraState	14/09/2018	05.35	14/09/2018	08.12	HT	to control ict overloading.
Gadchandur - Virur-li	IntraState	14/09/2018	06.35	14/09/2018	08.45	T	sparking on bus isolator.
Uran - Apta III	IntraState	14/09/2018	10.24	14/09/2018	14.06	PO	bus post insulator replacement.
Miraj - Mhaishal	IntraState	14/09/2018	10.50	14/09/2018	13.40	HT	for load management.
Aurangabad (Waluj)-Bhenda	IntraState	14/09/2018	10.52	14/09/2018	15.15	PO	Routine Maintenance Work
Mahindra Vehicle-Bridgestone	IntraState	14/09/2018	11.00	14/09/2018	19.27	PO	Routine Maintenance Work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 15/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Padegaon-Sawangi	IntraState	14/09/2018	11.07	14/09/2018	13.06	EO	Attending Hot Spot
Miraj-Ichalkaranji I	IntraState	14/09/2018	11.30	14/09/2018	17.39	PO	Routine Maintenance Work
Nashik-Padgha	IntraState	14/09/2018	11.44	14/09/2018	14.35	PO	insulator replacement.
Badnera-Akola li	IntraState	14/09/2018	12.45	14/09/2018	17.30	PO	Line Maintenance work
chandrapur-Tadali	IntraState	14/09/2018	12.45	14/09/2018	15.43	PO	CB AND LINE ISO.
Uran - Kharghar I	IntraState	14/09/2018	14.16	14/09/2018	20.28	PO	Routine Maintenance Work
Bableshwar Ahamadnagar-li	IntraState	14/09/2018	14.20	14/09/2018	14.39	T	LTS operated due to tripping of ict 4.
Bableshwar -Ahamadnagar-I	IntraState	14/09/2018	14.20	14/09/2018	14.38	T	LTS operated due to tripping of ict 4.
Bableshwar-Alephata ckt I	IntraState	14/09/2018	14.20	14/09/2018	15.40	T	LTS operated due to tripping of ict 4.
Malegaon-Satana	IntraState	14/09/2018	14.55	14/09/2018	15.36	PO	line signature test.
Malegaon-Sayne	IntraState	14/09/2018	15.54	14/09/2018	17.14	PO	line signature test.
Dhule-Chalisagaon	IntraState	15/09/2018	06.11	15/09/2018	08.07	HT	Over Voltage
Mahindra Vehicle-Bridgestone	IntraState	15/09/2018	08.48	15/09/2018	18.30	PO	Stringing -Construction work
Hingoli- Girawali	IntraState	15/09/2018	09.40	15/09/2018	15.37	PO	CB Testing Measurement Of Tan Delta Of CT.
Trombay MSETCL Tie 2	IntraState	15/09/2018	11.28	15/09/2018	16.57	EO	To attend Hot Spot
Padegaon-Sawangi	IntraState	15/09/2018	11.38	15/09/2018	15.33	EO	Hot Spot On 29 D B Ph CT Line Side.
Washala - Ghatghar	IntraState	15/09/2018	13.25	15/09/2018	17.42	PO	Testing Work
Karad(400kv) - Ogalewadi Ckt 1	IntraState	15/09/2018	14.21	15/09/2018	16.40	T	Distance Protection
Wpcl-Warora 1	IntraState	15/09/2018	14.23	15/09/2018	16.17	EO	Attending Hot Spot
karad - Dasgaon	IntraState	15/09/2018	14.38	15/09/2018	15.10	T	Distance Protection
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	15/09/2018	18.38	15/09/2018	18.48	PO	LIS Reconnection Purpose
Kathapur-Ranjangaon	IntraState	15/09/2018	19.40	15/09/2018	21.17	PO	Decapping Loc.No.286 B Phase
220 KV ICT Outages/Trippings							
220/132 Kv 200 Mva Vijay Ict 2 @Chalisgaon	IntraState	14/09/2018	09.18	14/09/2018	12.34	PO	Routine Maintenance Work
220/22 Kv 50 Mva T&R Ptr 1 @Anandnagar	IntraState	14/09/2018	10.15	14/09/2018	12.25	PO	hot spot on LV jumper.
220/132 Kv 200 Mva Cgl Ict 1 @Boisar-li	IntraState	14/09/2018	11.16	14/09/2018	13.50	PO	Routine Maintenance Work
220/132 Kv 200 Mva Vijay Ict 1 @Chalisgaon	IntraState	14/09/2018	13.33	14/09/2018	19.17	PO	Routine Maintenance Work
220/100 Kv 200 MVA ICT II @Kolshet	IntraState	15/09/2018	10.23	15/09/2018	23.59	PO	Routine Maintenance Work
220/132 Kv 200 Mva Vijay Ict 1 @Chalisgaon	IntraState	15/09/2018	13.35	15/09/2018	19.52	PO	Line Isolator Alignment Work.
132 KV LINE Outages/Trippings							
Kaulewada-Gondia-li	IntraState	14/09/2018	04.22	14/09/2018	04.40	T	Distance Protection
Elichpur - Hingoli	IntraState	14/09/2018	07.29	14/09/2018	08.10	T	overloading.
Waghala (Nanded2) - Tamsa	IntraState	14/09/2018	12.07	14/09/2018	12.31	T	Distance Protection
Amravati - Tiwasa	IntraState	14/09/2018	13.57	14/09/2018	14.24	T	132KV OLD BUS SECTION BUS BAR PROTN OPTD.
Ambazari-Amravati	IntraState	14/09/2018	13.57	14/09/2018	20.10	T	132KV OLD BUS SECTION BUS BAR PROTN OPTD.
Ahamadnagar - Ashti	IntraState	14/09/2018	14.19	14/09/2018	14.39	T	Distance Protection
Raimoha - Pathardi	IntraState	14/09/2018	14.35	14/09/2018	19.35	T	Distance Protection
Gondia-Amgaon li	IntraState	14/09/2018	23.18	15/09/2018	00.10	T	Amgaon CKT Y PH CT Burst And Caught Fire.
Kaulewada-Gondia-I	IntraState	14/09/2018	23.18	15/09/2018	00.10	T	At Amgaon Y PH CT Burst And Caught Fire.
Kaulewada-Gondia-li	IntraState	14/09/2018	23.18	15/09/2018	00.11	T	At Amgaon Y PH CT Burst And Caught Fire.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 15/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Gondia-Amgaon 1	IntraState	14/09/2018	23.18	15/09/2018	00.10	T	Amgaon CKT Y PH CT Caught Fire.
Elichpur - Hingoli	IntraState	15/09/2018	06.35	15/09/2018	10.40	T	Nanded Waghala O/L Problem.
Brahmapuri - Aa Energy	IntraState	15/09/2018	12.25	15/09/2018	12.35	T	Breaker Tripped At AA Energy End On Under Voltage Trip Indication.
Brahmapuri - Aa Energy	IntraState	15/09/2018	15.40	15/09/2018	15.55	T	Breaker Tripped At AA Energy End Only On Under Voltage Trip Indication.