

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 14/Sep/2020 MONDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 125.402        | 1737.571        | 1) Gujrat                      | 10.184         | 156.135         |
| 2) Hydro            | 4.350          | 126.729         | 2) Madhya Pradesh              | 4.034          | 116.439         |
| 3) Gas              | 6.318          | 89.626          | 3) Chattisgarh                 | 4.130          | 65.630          |
| <b>Total MSPGCL</b> | <b>136.070</b> | <b>1953.926</b> | 4) Maharashtra                 | 132.583        | 1963.906        |
| B) 1) APML          | 37.467         | 517.651         | 5) Goa (Amona)                 | -1.191         | -1.191          |
| 2) JSWEL            | 16.811         | 245.801         | <b>Total</b>                   | <b>149.740</b> | <b>2300.919</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 27.704         | 370.924         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 30.584         | 400.281         |
| 5) WPCL             | 2.552          | 36.484          | c) MSEDCL Bilateral *          | 24.225         | 449.302         |
| 6) Other IPP        | 6.735          | 107.963         | Include PX                     | -0.462         | 103.814         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 27.704         | 370.924         |
| C) 1) TPCL Thermal  | 7.377          | 117.492         | Include PX                     | 21.800         | 265.145         |
| 2) TPCL Hydro       | 3.968          | 59.610          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 3.235          | 56.169          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 4.634          | 70.932          | 1) MSEDCL                      | 346.105        | 4986.067        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 49.798         | 704.484         |
| 1) Thermal          | 200.978        | 2833.894        | <b>TOTAL STATE</b>             | <b>395.903</b> | <b>5690.551</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 8.318          | 186.339         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 9.553          | 145.795         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 22.255         | 140.187         |                                |                |                 |
| 6) SOLAR            | 5.059          | 83.417          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>246.163</b> | <b>3389.632</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 10 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5466                      | 5141                  | 5840                      | 4891                      |
| MSPGCL Hydro             | 237                       | 401                   | 285                       | 105                       |
| MSPGCL Gas               | 260                       | 260                   | 270                       | 260                       |
| MSPGCL Total Generation  | 5963                      | 5802                  | 6395                      | 5256                      |
| Central Sector Receipt   | 7216                      | 7165                  | 6536                      | 4771                      |
| WIND                     | 942                       | 556                   | 776                       | 1158                      |
| CPP / IPP Thermal        | 2763                      | 2569                  | 3020                      | 2432                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 549                       | 698                   | 5                         | 0                         |
| Exchange with Mumbai     | -1570                     | -1642                 | -1202                     | -1030                     |
| <b>MSEDCL DEMAND MET</b> | <b>15863</b>              | <b>15148</b>          | <b>15530</b>              | <b>12587</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 15863                     | 15148                 | 15530                     | 12587                     |
| TPCL GENERATION          | 502                       | 666                   | 844                       | 433                       |
| AEML GENERATION          | 190                       | 189                   | 188                       | 188                       |
| <b>MUMBAI DEMAND</b>     | <b>2262</b>               | <b>2497</b>           | <b>2234</b>               | <b>1651</b>               |
| STATE DEMAND MET         | 18125                     | 17645                 | 17764                     | 14238                     |
| <b>STATE DEMAND</b>      | <b>18125</b>              | <b>17645</b>          | <b>17764</b>              | <b>14238</b>              |
| Frequency (Hz)           | 49.97                     | 50.03                 | 49.94                     | 50.03                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.11 Hz at 06.02 Hrs | 49.83 Hz at 15.20 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 14/Sep/2020

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 11.21        | 157.12        | 550      | 396      |
| Unit 9             | 11.46        | 154.39        | 560      | 407      |
| Unit 10            | 9.64         | 127.41        | 420      | 380      |
| <b>Total</b>       | <b>32.31</b> | <b>438.92</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 8.89         | 117.20        | 485      | 355      |
| Unit 5             | 8.84         | 138.12        | 460      | 360      |
| <b>Total</b>       | <b>17.72</b> | <b>255.32</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 19.70         | 0        | 0        |
| Unit 7             | 0.00         | 30.40         | 0        | 0        |
| Unit 8             | 4.30         | 64.10         | 250      | 0        |
| <b>Total</b>       | <b>4.30</b>  | <b>114.20</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.67         | 55.28         | 163      | 131      |
| Unit 4             | 3.66         | 28.02         | 156      | 150      |
| Unit 5             | 9.57         | 131.90        | 430      | 365      |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 10.17        | 144.62        | 470      | 360      |
| Unit 9             | 10.36        | 137.59        | 480      | 360      |
| <b>Total</b>       | <b>37.43</b> | <b>497.43</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 3.81         | 56.54         | 205      | 128      |
| Unit 4             | 4.38         | 51.70         | 200      | 162      |
| <b>Total</b>       | <b>8.19</b>  | <b>108.24</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.65         | 44.47         | 165      | 125      |
| Unit 2             | 3.96         | 39.90         | 180      | 160      |
| Unit 3             | 3.96         | 51.56         | 185      | 158      |
| Unit 4             | 4.01         | 51.94         | 185      | 161      |
| Unit 5             | 9.87         | 135.59        | 500      | 356      |
| <b>Total</b>       | <b>25.44</b> | <b>323.46</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.32         | 89.63         | 270      | 259      |
| <b>Total</b>       | <b>6.32</b>  | <b>89.63</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 1.21         | 17.01         | 53       | 33       |

| Generating unit | Generation   |               |          |          |
|-----------------|--------------|---------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>1.21</b>  | <b>17.01</b>  |          |          |
| <b>Koyna</b>    |              |               |          |          |
| Stage 1-2       | 1.57         | 41.14         | 245      | 40       |
| Stage 4         | 0.00         | 39.68         | 0        | 0        |
| Stage 3         | 0.55         | 19.44         | 80       | 0        |
| <b>Total</b>    | <b>2.12</b>  | <b>100.27</b> |          |          |
| <b>Hydro</b>    |              |               |          |          |
| KDPH            | 0.00         | 0.50          | 0        | 0        |
| VTRNA           | 0.02         | 0.56          | 20       | 0        |
| TILLARI         | 0.29         | 3.27          | 58       | 0        |
| BHTGR/VEER      | 0.00         | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.27         | 4.94          | 40       | 0        |
| RNGR+BHTSA      | 0.00         | 0.00          | 0        | 0        |
| BHANDARDRA      | 0.00         | 2.34          | 0        | 0        |
| ELDARY          | 0.53         | 7.15          | 23       | 22       |
| SMLHY_PTN       | 0.90         | 5.52          | 38       | 37       |
| GHATGHAR        | 0.22         | 2.19          | 125      | 0        |
| <b>Total</b>    | <b>2.23</b>  | <b>26.46</b>  |          |          |
| <b>Wind</b>     |              |               |          |          |
| Total           | 22.26        | 140.19        | 0        | 0        |
| <b>Total</b>    | <b>22.26</b> | <b>140.19</b> |          |          |
| <b>CPP</b>      |              |               |          |          |
| APML(Mus)       | 37.47        | 517.65        | 0        | 0        |
| JSWEL(Mus)      | 16.81        | 245.80        | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00          | 0        | 0        |
| RPLAMT(Mus)     | 0.00         | 0.00          | 0        | 0        |
| WPCL(Mus)       | 2.55         | 36.48         | 0        | 0        |
| Other(Mus)      | 6.74         | 107.96        | 0        | 0        |
| <b>Total</b>    | <b>63.56</b> | <b>907.90</b> |          |          |
| <b>SOLAR</b>    |              |               |          |          |
| Total           | 5.06         | 83.42         | 0        | 0        |
| <b>Total</b>    | <b>5.06</b>  | <b>83.42</b>  |          |          |
| <b>Tata</b>     |              |               |          |          |
| Trombay 5       | 7.38         | 117.49        | 312      | 292      |
| Trombay 6       | 0.00         | 0.00          | 0        | 0        |
| Trombay 7A      | 1.93         | 35.23         | 115      | 65       |
| Trombay 7B      | 1.31         | 20.94         | 66       | 49       |
| Trombay 8       | 0.00         | 0.00          | 0        | 0        |
| TATA Hydro      | 3.97         | 59.61         | 386      | 3        |
| <b>Total</b>    | <b>14.58</b> | <b>233.27</b> |          |          |
| <b>AEML</b>     |              |               |          |          |
| DTPS U-1&2      | 4.63         | 70.93         | 251      | 188      |
| <b>Total</b>    | <b>4.63</b>  | <b>70.93</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 125.40      | 1737.57       | MSPGCL Total        | 136.07      | 1953.93       |
|                |             |         | MSPGCL Thml+Gas | 131.72      | 1827.20       | Koyna 1,2 & 4 Total | 1.57        | 80.83         |
|                |             |         | MSPGCL Hydro    | 4.35        | 126.73        | State Total         | 246.16      | 3389.63       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 14/Sep/2020

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4975        | 105  | 260  | 5340   | 1510  | 2406      | 0    | 0     | 4880        | 4800        | -1278                | 12778                 | 0                    | 12778                     | 1926             | 14704           | 50.03         |
| 2                  | 4958        | 100  | 260  | 5318   | 1358  | 2428      | 0    | 0     | 4722        | 4564        | -1197                | 12471                 | 0                    | 12471                     | 1821             | 14292           | 50.01         |
| 3                  | 4944        | 105  | 259  | 5308   | 1266  | 2436      | 0    | 0     | 4471        | 4825        | -1096                | 12739                 | 0                    | 12739                     | 1716             | 14455           | 50.02         |
| 4                  | 4891        | 105  | 260  | 5256   | 1158  | 2432      | 0    | 0     | 4587        | 4771        | -1030                | 12587                 | 0                    | 12587                     | 1651             | 14238           | 50.03         |
| 5                  | 4885        | 115  | 261  | 5261   | 1108  | 2387      | 0    | 0     | 5120        | 4989        | -990                 | 12755                 | 0                    | 12755                     | 1611             | 14366           | 49.97         |
| 6                  | 5098        | 115  | 270  | 5483   | 1140  | 2442      | 0    | 0     | 5536        | 5743        | -1016                | 13792                 | 0                    | 13792                     | 1642             | 15434           | 49.98         |
| 7                  | 5408        | 145  | 260  | 5813   | 993   | 2696      | 0    | 23    | 6353        | 6063        | -1053                | 14535                 | 0                    | 14535                     | 1668             | 16203           | 50.00         |
| 8                  | 5499        | 158  | 260  | 5917   | 866   | 2697      | 0    | 136   | 6680        | 6612        | -1103                | 15125                 | 0                    | 15125                     | 1789             | 16914           | 49.94         |
| 9                  | 5475        | 217  | 270  | 5962   | 764   | 2698      | 0    | 299   | 6968        | 7010        | -1269                | 15464                 | 0                    | 15464                     | 2006             | 17470           | 49.94         |
| 10                 | 5466        | 237  | 260  | 5963   | 942   | 2763      | 0    | 549   | 7358        | 7216        | -1570                | 15863                 | 0                    | 15863                     | 2262             | 18125           | 49.97         |
| 11                 | 5214        | 162  | 270  | 5646   | 911   | 2634      | 0    | 665   | 7517        | 7188        | -1689                | 15355                 | 0                    | 15355                     | 2437             | 17792           | 50.00         |
| 12                 | 4972        | 182  | 260  | 5414   | 719   | 2526      | 0    | 676   | 7639        | 7383        | -1666                | 15052                 | 0                    | 15052                     | 2510             | 17562           | 50.01         |
| 13                 | 5141        | 401  | 260  | 5802   | 556   | 2569      | 0    | 698   | 7200        | 7165        | -1642                | 15148                 | 0                    | 15148                     | 2497             | 17645           | 50.03         |
| 14                 | 5057        | 189  | 259  | 5505   | 543   | 2574      | 0    | 637   | 7446        | 7131        | -1622                | 14768                 | 0                    | 14768                     | 2435             | 17203           | 50.04         |
| 15                 | 5127        | 184  | 260  | 5571   | 547   | 2587      | 0    | 551   | 7273        | 7418        | -1614                | 15060                 | 0                    | 15060                     | 2426             | 17486           | 50.00         |
| 16                 | 5342        | 234  | 270  | 5846   | 752   | 2641      | 0    | 421   | 7176        | 7038        | -1497                | 15201                 | 0                    | 15201                     | 2382             | 17583           | 49.96         |
| 17                 | 5423        | 185  | 270  | 5878   | 879   | 2670      | 0    | 291   | 6966        | 6735        | -1432                | 15021                 | 0                    | 15021                     | 2311             | 17332           | 49.94         |
| 18                 | 5437        | 204  | 260  | 5901   | 723   | 2732      | 0    | 108   | 6813        | 6879        | -1420                | 14923                 | 0                    | 14923                     | 2247             | 17170           | 49.99         |
| 19                 | 5840        | 285  | 270  | 6395   | 776   | 3020      | 0    | 5     | 6421        | 6536        | -1202                | 15530                 | 0                    | 15530                     | 2234             | 17764           | 49.94         |
| 20                 | 5835        | 290  | 260  | 6385   | 822   | 3221      | 0    | 0     | 6728        | 6262        | -1139                | 15551                 | 0                    | 15551                     | 2204             | 17755           | 49.99         |
| 21                 | 5194        | 190  | 259  | 5643   | 922   | 2972      | 0    | 0     | 6230        | 6304        | -1032                | 14809                 | 0                    | 14809                     | 2085             | 16894           | 50.00         |
| 22                 | 5099        | 219  | 270  | 5588   | 911   | 2778      | 0    | 0     | 5851        | 5928        | -1003                | 14202                 | 0                    | 14202                     | 2042             | 16244           | 50.01         |
| 23                 | 5087        | 99   | 270  | 5456   | 1065  | 2716      | 0    | 0     | 5881        | 5739        | -1026                | 13950                 | 0                    | 13950                     | 1968             | 15918           | 50.02         |
| 24                 | 5035        | 124  | 260  | 5419   | 1024  | 2540      | 0    | 0     | 5870        | 5441        | -998                 | 13426                 | 0                    | 13426                     | 1928             | 15354           | 50.04         |
| MUs                | 125.40      | 4.35 | 6.32 | 136.07 | 22.26 | 63.57     | 0.00 | 5.06  | 151.69      | 149.74      | -30.58               | 346.10                | 0.00                 | 346.10                    | 49.80            | 395.90          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 14/Sep/2020**

**Position as on 6.30 Hrs of 15/Sep/2020**

| Generating Company   | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                            | Expected Date |
|----------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------|---------------|
| <b>FORCED OUTAGE</b> |                         |          |              |              |           |            |                                                                                             |               |
| IPP                  | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                     |               |
| PGPL                 | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| PGPL                 | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| IPP                  | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |           | Continued. | No PPA                                                                                      |               |
| IPP                  | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage                                                                               |               |
| IPP                  | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal Shortage                                                                               |               |
| MSPGCL               | Koradi Unit 7           | 210      | 27/08/2019   | 09.52        |           | Continued. | Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs) |               |
| MSPGCL               | Bhusawal Unit 3         | 210      | 01/09/2019   | 17.56        |           | Continued. | Zero Schedule from 18:00hrs of 28/09/2019                                                   |               |
| MSPGCL               | Koradi Unit 6           | 210      | 06/09/2019   | 15.41        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| IPP                  | RPL(AMT) U-4            | 270      | 12/11/2019   | 00.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL               | Nasik Unit 5            | 210      | 12/12/2019   | 10.25        |           | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)                          |               |
| IPP                  | RPL(AMT) U-3            | 270      | 11/02/2020   | 18.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| IPP                  | RPL(AMT) U-5            | 270      | 11/02/2020   | 19.30        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL               | Nasik Unit 3            | 210      | 17/02/2020   | 00:00        |           | Continued. | C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)             |               |
| MSPGCL               | Uran Unit 8             | 108      | 01/03/2020   | 20.57        |           | Continued. | Gas shortage                                                                                |               |
| IPP                  | RPL(AMT) U-1            | 270      | 04/03/2020   | 19.30        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| IPP                  | RPL(AMT) U-2            | 270      | 09/03/2020   | 20.15        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Nasik Unit 4            | 210      | 25/03/2020   | 19.45        |           | Continued. | Reserve Shut Down.(Converted zero schedule from 25.03.2020)                                 |               |
| TPC_G                | Trombay 8               | 250      | 11/04/2020   | 16.55        |           | Continued. | Zero Schedule.                                                                              |               |
| MSPGCL               | Uran Unit B0            | 120      | 25/05/2020   | 12.51        |           | Continued. | Turbine Blade Failure                                                                       |               |
| MSPGCL               | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |           | Continued. | Turbine Blade Failure                                                                       |               |
| AEML                 | AEML Unit 1             | 250      | 27/06/2020   | 23.55        |           | Continued. | Zero schedule.                                                                              |               |
| MSPGCL               | Chandrapur Unit 7       | 500      | 06/08/2020   | 03.33        |           | Continued. | Sparkling in generator R phase winding.                                                     |               |
| CPP                  | SWPGL U-3               | 135      | 12/08/2020   | 00.45        |           | Continued. | Zero Schedule by MSEDCL                                                                     |               |
| CPP                  | SWPGL U-4               | 135      | 12/08/2020   | 00.45        |           | Continued. | Zero Schedule by MSEDCL                                                                     |               |
| MSPGCL               | Ghatghar Unit-1         | 125      | 27/08/2020   | 05.25        |           | Continued. | Runner band Drainage valve Leakage                                                          |               |
| MSPGCL               | Chandrapur Unit 6       | 500      | 27/08/2020   | 10.55        |           | Continued. | Boiler Tube Leakage                                                                         |               |
| IPP                  | Adani U-2               | 660      | 01/09/2020   | 19.41        |           | Continued. | Air pre-heater PA Bellow leakage.                                                           |               |
| IPP                  | JSW (J) U3              | 300      | 09/09/2020   | 10.56        |           | Continued. | CW Duct leakage                                                                             |               |
| MSPGCL               | Parli Unit 6            | 250      | 11/09/2020   | 23.55        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 14/Sep/2020**

**Position as on 6.30 Hrs of 15/Sep/2020**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                             | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|-----------|------------|----------------------------------------------|---------------|
| IPP                | Adani U-5               | 660      | 12/09/2020   | 20.54        |           | Continued. | Due HIP Casing Top & Bottom Difference High. |               |
| MSPGCL             | Parli Unit 7            | 250      | 14/09/2020   | 00.00        |           | Continued. | Zero Schedule.                               |               |
| MSPGCL             | Parli Unit 8            | 250      | 14/09/2020   | 20.45        |           | Continued. | Zero Schedule.                               |               |
| MSPGCL             | Uran Unit 5             | 108      | 15/09/2020   | 00.09        |           | Continued. | Filter Replacement.                          |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 14/Sep/2020**

**Statement-VII**

**Position as on 6.30 Hrs of 15/Sep/2020**

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                           |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                            |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                   |
| Dhule Khandwa I                                   | InterState                | 12/09/2020   | 01.05        |            | Continued. | HT          | Over Voltage                                                                               |
| Padgha Tarapur I                                  | InterState                | 14/09/2020   | 02.22        | 14/09/2020 | 08.51      | T           | Over Voltage                                                                               |
| Alkud-Solapur(PG)                                 | InterState                | 14/09/2020   | 11.59        | 14/09/2020 | 17.28      | PO          | Quarterly Maintenance Work & Diagnostic testing work.                                      |
| Padgha Tarapur I                                  | InterState                | 15/09/2020   | 02.56        | 15/09/2020 | 08.48      | T           | Over Voltage                                                                               |
| Dhule- Bableshtar - I                             | IntraState                | 11/09/2020   | 17.43        |            | Continued. | HT          | Over Voltage                                                                               |
| Karad - Jaigad - II                               | IntraState                | 11/09/2020   | 21.05        | 15/09/2020 | 08.10      | HT          | Over Voltage                                                                               |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 13/09/2020   | 17.14        | 14/09/2020 | 07.57      | HT          | Over Voltage                                                                               |
| Akola II - RPL(Rattanindia) Ckt I                 | IntraState                | 13/09/2020   | 17.56        |            | Continued. | HT          | Over Voltage                                                                               |
| Padghe - Kalwa- I                                 | IntraState                | 13/09/2020   | 21.46        | 14/09/2020 | 09.13      | HT          | Over Voltage                                                                               |
| Warora-Adani(Tiroda)1                             | IntraState                | 13/09/2020   | 23.26        | 14/09/2020 | 04.20      | HT          | Y-PH TC1 Faulty OF Main CB Of 400KV WARORA-ADANI CKT 1 Indication was Observed & Persists. |
| Lonikand I - Koyna stage-IV                       | IntraState                | 13/09/2020   | 23.31        | 14/09/2020 | 08.51      | HT          | Over Voltage                                                                               |
| Koradi 2-IEPL                                     | IntraState                | 14/09/2020   | 08.15        | 14/09/2020 | 20.59      | PO          | Routine Maintenance Work                                                                   |
| Babhaleshtar - Padghe-I                           | IntraState                | 14/09/2020   | 09.47        | 14/09/2020 | 18.09      | PO          | Chemical cleaning of insulator string.                                                     |
| Bhusawal-Aurangabad                               | IntraState                | 14/09/2020   | 18.14        | 15/09/2020 | 08.04      | HT          | Over Voltage                                                                               |
| Padghe - Kalwa- I                                 | IntraState                | 14/09/2020   | 22.07        | 15/09/2020 | 08.02      | HT          | Over Voltage                                                                               |
| Lonikand I - Koyna stage-IV                       | IntraState                | 14/09/2020   | 22.10        | 15/09/2020 | 07.53      | HT          | Over Voltage                                                                               |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                            |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe               | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection,Declared Faulty.                                                   |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 10/09/2020   | 09.58        |            | Continued. | PO          | Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.                                      |
| 400/220/33 Kv 315 MVA ICT-I @Aurangabad (Waluj)   | IntraState                | 14/09/2020   | 09.56        | 14/09/2020 | 21.09      | PO          | Dismantling of old flare protection system                                                 |
| 400/220/33 Kv 315 Mva Ict 2 @Koradi               | IntraState                | 14/09/2020   | 10.17        | 14/09/2020 | 20.53      | PO          | To carry out bushing tan delta, winding resistance and DFRA of ICT 2.                      |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                            |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule.                                                                               |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule.(close at Chikodi end only)                                                    |
| BOISAR BORIVALI                                   | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)                                               |
| Theur-Phursungi                                   | IntraState                | 14/08/2020   | 09.46        |            | Continued. | HT          | Outage Arrangement HTLS Work.                                                              |
| Theur- Magar Patta City                           | IntraState                | 14/08/2020   | 10.27        |            | Continued. | HT          | Outage Arrangement HTLS Work.                                                              |
| Lonikand1 (400 Kv)-Theur I                        | IntraState                | 14/08/2020   | 10.38        |            | Continued. | PO          | Replacement of Existing 0.4 DEER Conductor, hardware & Insulator to HTLS Conductor.        |
| Parli 3 (Old Gcr)-Girwali Ckt-3                   | IntraState                | 20/08/2020   | 13.05        |            | Continued. | PO          | Erection of Tower Due to Railway Crossing                                                  |
| Parli 3(Old Gcr)- Girwali Ckt 4                   | IntraState                | 20/08/2020   | 13.06        |            | Continued. | PO          | Erection of Tower Due to Railway Crossing                                                  |
| Main Bus -II @Kolhapur(Talandage)                 | IntraState                | 08/09/2020   | 16.20        | 14/09/2020 | 12.06      | PO          | String Replacement work                                                                    |
| Talandge(400kv)- Ichalkaranji ckt-2               | IntraState                | 14/09/2020   | 09.23        | 14/09/2020 | 12.23      | PO          | Quarterly bay maintenance work.                                                            |
| Kandalgaon - Bhira                                | IntraState                | 14/09/2020   | 09.56        | 14/09/2020 | 17.10      | PO          | PT replacement work.                                                                       |
| Chikhli-Jalna-I                                   | IntraState                | 14/09/2020   | 10.30        | 14/09/2020 | 17.45      | PO          | Testing & Routine Bay maintenance Work.                                                    |
| BHUGAON WARORA CKT-I                              | IntraState                | 14/09/2020   | 10.44        | 14/09/2020 | 13.07      | PO          | Replacement of flash Disc Insulator                                                        |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 14/Sep/2020**

**Statement-VII**

Position as on 6.30 Hrs of 15/Sep/2020

| Name of Line                                   | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                          |
|------------------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|-----------------------------------------------------------|
| Adlabs - Pedambe                               | IntraState                   | 14/09/2020      | 11.10           | 14/09/2020 | 17.53         | PO             | Replacement of flash over double string polymer insulator |
| <b>220 KV ICT Outages/Trippings</b>            |                              |                 |                 |            |               |                |                                                           |
| 220/132 Kv 200 Mva Cgl Ict 1 @Bale (Solapur 2) | IntraState                   | 14/09/2020      | 10.08           | 14/09/2020 | 18.28         | PO             | For CTR fire protection maintenance work.                 |