

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 14/Dec/2022 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	153.727	2054.845	1) Gujrat	-4.210	-75.985
2) Hydro	8.316	143.247	2) Madhya Pradesh	2.034	17.756
3) Gas	4.083	70.897	3) Chattisgarh	5.060	76.100
Total MSPGCL	166.126	2268.989	4) Maharashtra	178.442	2335.993
B) 1) APLM	60.495	965.019	5) Goa (Amona)	-1.311	-18.937
2) JSWEL	13.270	177.018	Total	180.015	2334.927
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.861	389.993
4) RPL(AMT)	25.391	379.591	b) Mumbai Drawl	37.423	454.240
5) SWPGPL	8.924	110.825	c) MSEDCL Bilateral *	89.951	1031.086
6) Other IPP	43.571	616.542	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.861	389.993
C) 1) TPCL Thermal	10.347	155.930	Include PX	0.000	0.000
2) TPCL Hydro	5.525	49.091	Standby	0.000	0.000
3) TPCL Gas	1.845	25.785	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.937	136.744	1) MSEDCL	476.892	6577.528
D) STATE			2) Mumbai Discoms	65.076	821.787
1) Thermal	325.662	4596.514	3) Other Discoms	9.772	131.446
(A1+C1+C4+(B1-B6))			TOTAL STATE	551.740	7530.761
2) Hydro (A2+C2)	13.841	192.338			
3) Gas (A3+B7+C3)	5.928	96.682			
4) Wind	16.347	167.032			
6) SOLAR	9.948	143.271			
TOTAL STATE	371.726	5195.837			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6338	6835	6952	5542
MSPGCL Hydro	773	315	997	77
MSPGCL Gas	135	136	138	235
MSPGCL Total Generation	7246	7286	8087	5854
Central Sector Receipt	9041	8501	7747	6110
WIND	808	641	227	1056
CPP / IPP Thermal	6383	6309	6465	6066
CPP / IPP Gas	0	0	0	0
SOLAR	1467	1518	2	0
Exchange with Mumbai	-1823	-1804	-1682	-1205
MSEDCL DEMAND MET	22678	22024	20389	17569
Load Shedding	0	0	0	0
MSEDCL DEMAND	22678	22024	20389	17569
TPCL GENERATION	935	938	914	484
AEML GENERATION	487	501	501	290
MUMBAI DEMAND	3245	3243	3097	1979
OTHER DISCOM DEMAND	444	427	457	312
STATE DEMAND MET	26367	25694	23943	19860
STATE DEMAND	26367	25694	23943	19860
Frequency (Hz)	49.88	49.86	50.01	50.08

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.32 Hz at 04.01 Hrs	49.68 Hz at 10.20 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 14/Dec/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.98	70.42	215	190
Unit 7	0.00	0.00	0	0
Unit 8	13.13	176.68	639	460
Unit 9	13.96	186.86	622	542
Unit 10	13.44	181.06	610	450
Total	45.50	615.02		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	10.32	133.61	495	280
Unit 5	10.56	138.32	495	275
Total	20.88	271.94		
Parli				
Unit 6	4.34	59.15	233	144
Unit 7	4.22	60.12	241	137
Unit 8	4.18	44.11	201	146
Total	12.74	163.38		
Chandrapur				
Unit 3	3.19	46.94	150	115
Unit 4	3.09	43.61	164	110
Unit 5	7.10	95.37	310	273
Unit 6	8.07	98.12	395	288
Unit 7	0.00	0.00	0	0
Unit 8	9.72	96.97	481	278
Unit 9	10.14	138.45	485	315
Total	41.30	519.46		
Paras				
Unit 3	5.09	55.74	221	206
Unit 4	0.00	63.00	0	0
Total	5.09	118.74		
Khaparkheda				
Unit 1	2.82	38.64	130	105
Unit 2	2.92	38.86	135	95
Unit 3	3.34	51.01	184	0
Unit 4	3.04	45.81	147	117
Unit 5	9.44	104.43	430	350
Total	21.56	278.75		
Nasik				
Unit 3	0.00	23.31	0	0
Unit 4	3.46	44.39	165	118
Unit 5	3.19	19.86	153	105
Total	6.65	87.55		
Uran				
All Units	4.08	70.90	237	135
Total	4.08	70.90		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.16	1.90	20	0
Total	0.16	1.90		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.08	43.42	450	40
Stage 4	1.81	37.87	406	0
Stage 3	1.28	17.76	240	0
Total	6.17	99.05		
Hydro				
KDPH	0.00	4.07	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.35	7.02	58	0
BHIRA T.R.	0.16	2.60	40	0
SMLHY_PTN	0.88	21.89	40	32
GHATGHAR	0.60	6.73	125	0
Total	1.99	42.30		
Wind				
Total	16.35	167.03	0	0
Total	16.35	167.03		
CPP				
APML(Mus)	60.50	965.02	0	0
JSWEL(Mus)	13.27	177.02	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.39	379.59	0	0
SWPGPL-Mus	8.92	110.82	0	0
Other(Mus)	43.57	616.54	0	0
Total	151.65	2249.00		
SOLAR				
Total	9.95	143.27	0	0
Total	9.95	143.27		
Tata				
Trombay 5	6.11	104.53	264	240
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.00	14.03	61	36
Trombay 7B	0.85	11.76	48	23
TATA Hydro	5.52	49.09	436	12
Trombay 8	4.24	51.40	242	131
Total	17.72	230.81		
AEMIL				
DTPS U-1&2	9.94	136.74	502	290
Total	9.94	136.74		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	153.73	2054.84	MSPGCL Total	166.13	2268.99
			MSPGCL Thml+Gas	157.81	2125.74	Koyna 1,2 & 4 Total	4.89	81.29
			MSPGCL Hydro	8.32	143.25	State Total	371.73	5195.84

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 14/Dec/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5641	82	233	5956	958	6050	0	0	6318	6286	-1438	17453	0	17453	2331	360	20143	49.96
2	5613	72	233	5918	1026	6036	0	0	6343	6323	-1341	17627	0	17627	2178	334	20140	49.97
3	5631	72	235	5938	1023	6015	0	0	6400	6096	-1245	17510	0	17510	2059	317	19886	50.00
4	5542	77	235	5854	1056	6066	0	0	6410	6110	-1205	17569	0	17569	1979	312	19860	50.08
5	5388	72	237	5697	1049	5881	0	0	6753	7046	-1161	18163	0	18163	1961	348	20473	50.05
6	6272	72	236	6580	980	6177	0	0	6655	7013	-1218	19167	0	19167	2067	365	21599	50.01
7	6570	73	233	6876	1070	6389	0	9	7528	7759	-1377	20334	0	20334	2240	392	22966	50.01
8	6686	842	234	7762	1029	6401	0	177	7418	7436	-1528	20862	0	20862	2434	415	23711	50.02
9	6690	706	150	7546	1077	6400	0	595	7786	8124	-1496	21822	0	21822	2742	423	24988	50.10
10	6562	729	137	7428	1068	6485	0	1118	8303	8414	-1806	22268	0	22268	3042	439	25749	49.99
11	6338	773	135	7246	808	6383	0	1467	9191	9041	-1823	22678	0	22678	3245	444	26367	49.88
12	5947	701	135	6783	702	6365	0	1596	9389	9419	-1849	22576	0	22576	3313	440	26329	49.99
13	6835	315	136	7286	641	6309	0	1518	8476	8501	-1804	22024	0	22024	3243	427	25694	49.86
14	7048	198	135	7381	516	6227	0	1362	8237	8510	-1764	21811	0	21811	3107	422	25339	50.02
15	6802	78	137	7017	341	6319	0	1044	9263	9265	-1756	21790	0	21790	3127	440	25357	50.05
16	6812	78	137	7027	295	6426	0	700	9445	9494	-1671	21822	0	21822	3128	449	25399	50.02
17	6822	150	137	7109	220	6384	0	308	8786	8706	-1632	20647	0	20647	3110	448	24205	50.03
18	6971	696	137	7804	231	6426	0	52	7634	7156	-1607	19618	0	19618	3064	444	23126	50.01
19	6952	997	138	8087	227	6465	0	2	7607	7747	-1682	20389	0	20389	3097	457	23943	50.01
20	7017	825	138	7980	278	6477	0	0	6967	6854	-1478	19669	0	19669	2964	441	23075	49.98
21	6776	217	138	7131	359	6518	0	0	6398	6733	-1615	18699	0	18699	2817	426	21943	49.93
22	6523	210	138	6871	409	6502	0	0	6194	5878	-1612	17623	0	17623	2684	424	20732	50.03
23	6333	143	139	6615	494	6460	0	0	6371	5995	-1622	17538	0	17538	2597	404	20539	50.08
24	5956	138	140	6234	490	6489	0	0	6505	6109	-1693	17232	0	17232	2548	397	20177	50.02
MUs	153.73	8.32	4.08	166.13	16.35	151.65	0.00	9.95	180.38	180.02	-37.42	476.89	0.00	476.89	65.08	9.77	551.74	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 14/Dec/2022

Position as on 6.30 Hrs of 15/Dec/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
IPP	JSW (J) U2	300	10/12/2022	15:51		Continued.	NO SCHEDULE	
IPP	Adani U-5	660	10/12/2022	23:56		Continued.	COH activities.	10/01/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	23/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	Zero Schedule.	
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.(unit out due to coal shortage from 15.11.2022)	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	31/12/2022
IPP	RPL(AMT) U-3	270	05/12/2022	12:00	15/12/2022	05:31	Coal Shortage	
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25		Continued.	Boiler Tube Leakage. Unit on tolling from 22:00Hrs Dtd 09.12.2022	
MSPGCL	Paras Unit 4	250	13/12/2022	06:53		Continued.	Generator electrical protection	16/12/2022
MSPGCL	Uran Unit 6	108	14/12/2022	08:14		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 3	210	14/12/2022	21:00		Continued.	Boiler Validity Renevoation	16/12/2022
TPC-G	Trombay 7B	60	14/12/2022	23:33		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	14/12/2022	23:58		Continued.	Gas shortage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 14/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 15/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
KHARGHAR - TALEGAON (PG)	IntraState	03/12/2022	23:54			PO	For Tapping of 400KV Kalwa-Padgha-2 Line on KHARGHAR - TALEGAON (PG) so as to form temporary 400KV Kalwa-Kharghar -Talegaon Line for replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/12/2022	08:48			PO	For attending SF6 gas leakage
KORADI - KHAPERKHEDA CKT - 2	IntraState	14/12/2022	10:13	14/12/2022	16:14	PO	Diagnostic Testing of CBs
KHADKA-AURANGABAD (WALUJ)	IntraState	14/12/2022	20:31	15/12/2022	07:27	HT	HAND TRIPPED DUE TO OVER VOLTAGE.
400 KV ICT Outages/Trippings							
400/11.5kV STATION TRANSFORMER - 4 @ TIRORA	IntraState	12/12/2022	09:53			PO	For bay equipment maintenance and testing work
400/220KV 315 MVA ICT - 1 @ NEW KOYNA	IntraState	14/12/2022	11:33	14/12/2022	19:52	PO	Diagnostic testing & Relay testing work & Routine maint. Work
220 KV TIEBAY Outages/Trippings							
MAIN BUS SECTIONALIZER -1 @ GHODBUNDER (GIS)	IntraState	14/12/2022	07:56	14/12/2022	17:07	PO	Annual maintenance of of main Bus-1 and Bus side isolators.
220 KV MAINBAY Outages/Trippings							
TBC @ FLAGSHIP	IntraState	14/12/2022	11:45	14/12/2022	18:40	PO	CB mechanism box fabrication and painting work
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	19/11/2022	14:33			HT	H/T TO CONTROL BBLR LINE LOADING
KALWA SALSETTE - 3	IntraState	01/12/2022	22:23			EO	Interchanging of BUS of 220KV Kalwa-Salshette-3 & 220KV Kalwa -Salshette-4 to free 220 kV TBC. 220 kV Kalwa Salsette 3 line on TBC from 12.11.2022 due to 29 A Bus damaged isolator.
KALWA SALSETTE - 4	IntraState	01/12/2022	22:42			EO	Interchanging of BUS of 220 kV Kalwa-Salsette-3 & 220 kV Kalwa-Salsette-4 to free 220 kV TBC. 220 kV Kalwa Salsette 3 line on TBC from 12.11.2022 due to 29 A Bus damaged isolator.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 14/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 15/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PADGHE - NALASOPARA - VASAI (T)	IntraState	10/12/2022	05:21			PO	Work of bunching, removing jumper & changing orientation of lines for backup supply to Vasai Ss & Nalasopara S/stn:1) 220kV Kamba-Vasai line jumper will be open at loc. No. 51 for 7 days continuous i.e. 159 Hrs.2) 220kV Padgha-Nalasopara & Vasai Tap line-Jumper will open at loc. 54 for 7 days continuous & 220kV Vasai-Nalasopara link line will be in service for 7 days.3) 220kV Padghe & Nalasopara-Vasai Tap line bunching work will be done to 220kV Kamba-Vasai line between loc. No. 51 & 52 after that line orientation will be change i.e. 220kV Padghe-Vasai line and after that load of 220kV Vasai will be feed from 400/220 Padghe s/stn.4) After bunching 220kV Padghe-Vasai line will be charged at 9:00 Hrs. on same day dtd. 10.12.2022. The line will be in service for 07 days continuous i.e. 159 Hrs.5) Erection of MDN+9 Tower (2 nos.)6) Stringing of conductor of one side ckt.
POPHALI - KDPH	IntraState	10/12/2022	10:20			PO	For erection & stringing of In-line Multi circuit tower (Loc No.1to7) of new 220KV Karad-Koyana line and restringing of existing 220KV D/C KDPH LILO line.
VANKUSWADE - KDPH	IntraState	10/12/2022	11:00			PO	For erection & Stringing of In line multi circuit tower (Loc no.01 to 07) of new 220kV Karad-Koyana line and re stringing of existing 220kV D/C KDPH LILO line.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 14/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 15/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KAMBA - VASAI	IntraState	11/12/2022	05:19			PO	Work of bunching, removing jumper & changing orientation of lines for backup supply to Vasai Ss & Nalasopara S/stn:1) 220kV Kamba-Vasai line jumper will be open at loc. No. 51 for 7 days continuous i.e. 159 Hrs. From Loc no. 52 to 220KV Vasai S/stn will be converted to 220KV Padgha-Vasai after bunching and same will be charged at 08:00 Hrs on 11.12.2022 (Temporary arrangement till 17.12.2022. 2) 220kV Padgha-Nalasopara & Vasai Tap line-Jumper is already opened at loc. 54 for 7 days continuous & 220kV Vasai-Nalasopara link line is established 7 days. 3) 220kV Padghe - Nalasopara-Vasai Tap line bunching work will be done to 220kV Kamba-Vasai line between loc. No. 51 & 52 after that line orientation will be change i.e. 220kV Padghe-Vasai line and after that load of 220kV Vasai will be feed from 400/220 Padghe s/stn. 4) After bunching 220kV Padghe-Vasai line will be charged at 8:00 Hrs. on same day dtd. 11.12.2022. The line will be in service for 07 days continuous i.e. 159 Hrs. 5) Erection of MDN+9 Tower (2 nos.) 6) Stringing of conductor of one side ckt.
KALWA - MULUND 1	IntraState	12/12/2022	09:18			PO	For Main CB pole Overhauling work after shifting the line on TBC.
EKLAHARE (OCR) - PADGHE	IntraState	13/12/2022	10:35			HT	For load management
MAIN BUS - 1 @ GHODBUNDER	IntraState	14/12/2022	07:57	14/12/2022	17:03	PO	Annual maintenance of Main Bus-1 and Bus side isolators.
GOREGAON - VERSOVA CKT - 2	IntraState	14/12/2022	09:14	14/12/2022	18:32	PO	Annual Maintenance of CB
SADAWAGHAPUR KARAD CKT 1	IntraState	14/12/2022	09:19	14/12/2022	14:29	PO	For CT Tan Delta & Quateraly Maintenance work.
KADEGAON-MIRAJ	IntraState	14/12/2022	09:42	14/12/2022	17:26	PO	Cold line washing work at Loc no.87 to 120
MALEGAON-SATANA	IntraState	14/12/2022	10:54	14/12/2022	16:26	HT	For load management
MALINAGAR - TEMBHURNI	IntraState	14/12/2022	10:55	14/12/2022	16:39	PO	Outage is required for Quarterly Maintenance
MAIN BUS - 2 @ MALINAGAR	IntraState	14/12/2022	11:11	14/12/2022	13:29	PO	Outage is required for Quarterly Maintenance
NAGOTHANE - WADKHAL (GIS) CKT-2	IntraState	14/12/2022	11:36	14/12/2022	14:53	HT	(EMERGENCY OUTAGE AVAILABLE) Replacement of flashover polymer insulator at Loc no. 54 (Top phase)
CHINCHWAD-2 - TELCO	IntraState	14/12/2022	11:43	14/12/2022	15:52	PO	Stringing of 1 no of conductor at newly erected Monopole tower loc no-19-20 on 220 kV Chinchwad- Telco Line
ALEPHATA-PARGAON(KATHAPUR)	IntraState	14/12/2022	13:01	14/12/2022	14:17	HT	For CTR work at Lonikand ss , and said for said work interconnector to be taken in service
SADAWAGHAPUR KARAD CKT 2	IntraState	14/12/2022	14:33	14/12/2022	18:49	PO	For CT Tan Delta & Quateraly Maintenance work
220 KV ICT Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 14/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 15/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/33KV 50MVA PTR 1 @ MIRAJ	IntraState	13/12/2022	08:21	14/12/2022	01:22	PO	Transformer Painting Work
220/33 KV 50 MVA PTR 3 @ KHARGHAR	IntraState	14/12/2022	07:40	14/12/2022	18:10	PO	For Diagnostic testing and Routine Maintenance work
220/22-22 KV 100 MVA PTR 3 @ PAL-DOMBIVALI	IntraState	14/12/2022	09:30	14/12/2022	17:02	PO	Replacement of oil pump gauge, Diagnostic testing & Bay RM Work
220/110 kV 200 MVA ICT 3 @ MUDSHINGI	IntraState	14/12/2022	10:03	14/12/2022	16:08	PO	For attending oil leakages by cold line welding method
220/132KV 150MVA ICT - 1 @ MALINAGAR	IntraState	14/12/2022	13:46	14/12/2022	16:14	PO	Outage is required for Testing work by TCC Pune (CT, Winding and Bushing Tan delta measurement)
220/132kV 200MVA ICT-1 @ KOPARGAON	IntraState	14/12/2022	16:18	14/12/2022	19:45	PO	1. Attending Hot Spot Y PH HV CT
220/132/11KV 200 MVA ICT 2 @ MALINAGAR	IntraState	14/12/2022	16:24	14/12/2022	18:24	PO	Outage is required for Testing work by TCC Pune (CT, Winding and Bushing Tan delta measurement)

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage