

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 15/Jan/2017 SUNDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 126.005        | 2029.480        | 1) Gujrat                      | -0.910         | -5.788          |
| 2) Hydro            | 23.480         | 231.238         | 2) Madhya Pradesh              | 9.656          | 139.971         |
| 3) Gas              | 10.814         | 152.666         | 3) Chattisgarh                 | 8.010          | 122.280         |
| <b>Total MSPGCL</b> | <b>160.299</b> | <b>2413.384</b> | 4) Maharashtra Net             | 114.449        | 1710.934        |
| B) 1) APML          | 43.238         | 729.885         | 5) Goa (Amona)                 | -0.532         | -9.980          |
| 2) JSWEL            | 9.015          | 138.611         | <b>Total</b>                   | <b>130.673</b> | <b>1957.417</b> |
| 3) VIPL             | 6.272          | 94.760          | a) Mumbai Schedule             | 13.646         | 228.341         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 18.365         | 316.968         |
| 5) WPCL             | 3.936          | 57.360          | c) MSEDCL Bilateral *          | 30.692         | 501.602         |
| 6) PGPL             | 0.000          | 24.068          | Include PX                     | 0.658          | 43.224          |
| 7) Other IPP        | 7.115          | 130.367         | d) Mumbai Bilateral *          | 13.646         | 228.341         |
| C) 1) TPCL Thermal  | 5.470          | 105.790         | Include PX                     | 3.639          | 59.327          |
| 2) TPCL Hydro       | 2.492          | 74.658          | Include Standby                | 0.000          | 0.000           |
| 3) TPCL Gas         | 4.379          | 57.067          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) R-INFRA Thermal  | 10.846         | 154.395         | 1) MSEDCL                      | 347.518        | 5314.212        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 41.554         | 708.880         |
| 1) Thermal          | 211.897        | 3440.648        | <b>TOTAL STATE</b>             | <b>389.072</b> | <b>6023.092</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 25.972         | 305.896         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 15.193         | 233.801         |                                |                |                 |
| (A3+B6+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 4.376          | 67.738          |                                |                |                 |
| 6) SOLAR            | 0.959          | 17.590          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>258.397</b> | <b>4065.673</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5495                      | 5474                  | 5338                      | 5256                      |
| MSPGCL Hydro             | 2059                      | 2006                  | 658                       | 165                       |
| MSPGCL Gas               | 432                       | 430                   | 448                       | 472                       |
| MSPGCL Total Generation  | 7986                      | 7910                  | 6444                      | 5893                      |
| Central Sector Receipt   | 6797                      | 6538                  | 6194                      | 3887                      |
| WIND                     | 278                       | 165                   | 60                        | 152                       |
| CPP / IPP Thermal        | 2969                      | 2968                  | 2921                      | 2885                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 139                       | 151                   | 0                         | 0                         |
| Exchange with Mumbai     | -772                      | -654                  | -865                      | -553                      |
| <b>MSEDCL DEMAND MET</b> | <b>17397</b>              | <b>17078</b>          | <b>14754</b>              | <b>12264</b>              |
| Load Shedding            | 2                         | 353                   | 0                         | 0                         |
| MSEDCL DEMAND            | 17399                     | 17431                 | 14754                     | 12264                     |
| TPCL GENERATION          | 681                       | 797                   | 586                       | 381                       |
| R-INFRA GENERATION       | 508                       | 509                   | 509                       | 387                       |
| <b>MUMBAI DEMAND</b>     | <b>1961</b>               | <b>1960</b>           | <b>1960</b>               | <b>1321</b>               |
| STATE DEMAND MET         | 19358                     | 19038                 | 16714                     | 13585                     |
| <b>STATE DEMAND</b>      | <b>19360</b>              | <b>19391</b>          | <b>16714</b>              | <b>13585</b>              |
| Frequency (Hz)           | 49.94                     | 49.95                 | 49.96                     | 49.98                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.26 Hz at 23.58 Hrs | 49.74 Hz at 20.35 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 15/Jan/2017

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 3.76         | 21.45         | 165      | 135      |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| Unit 9             | 13.95        | 175.22        | 660      | 479      |
| <b>Total</b>       | <b>17.71</b> | <b>196.68</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 10.70        | 123.94        | 510      | 355      |
| Unit 5             | 10.75        | 151.76        | 510      | 365      |
| <b>Total</b>       | <b>21.46</b> | <b>275.70</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 5.41         | 77.19         | 250      | 188      |
| Unit 7             | 4.92         | 78.00         | 248      | 151      |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>10.33</b> | <b>155.19</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 4.52         | 66.26         | 203      | 170      |
| Unit 4             | 4.50         | 65.38         | 201      | 168      |
| Unit 5             | 9.79         | 145.59        | 450      | 360      |
| Unit 6             | 9.69         | 118.56        | 450      | 356      |
| Unit 7             | 0.00         | 109.78        | 0        | 0        |
| Unit 8             | 6.49         | 146.54        | 295      | 200      |
| Unit 9             | 2.40         | 96.32         | 300      | 0        |
| <b>Total</b>       | <b>37.40</b> | <b>748.42</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 5.40         | 78.16         | 250      | 193      |
| <b>Total</b>       | <b>5.40</b>  | <b>78.16</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.90         | 61.60         | 190      | 135      |
| Unit 2             | 4.26         | 61.64         | 195      | 155      |
| Unit 3             | 4.44         | 59.90         | 203      | 163      |
| Unit 4             | 0.00         | 36.61         | 0        | 0        |
| Unit 5             | 10.38        | 153.02        | 500      | 375      |
| <b>Total</b>       | <b>22.98</b> | <b>372.76</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 4.39         | 61.34         | 204      | 162      |
| Unit 5             | 4.33         | 60.05         | 199      | 162      |
| <b>Total</b>       | <b>8.72</b>  | <b>121.39</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 10.81        | 152.67        | 474      | 420      |
| <b>Total</b>       | <b>10.81</b> | <b>152.67</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 14.50         | 0        | 0        |
| Unit 2             | 0.00         | 9.57          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>24.07</b>  |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |

| Generating unit | Generation   |                |          |          |
|-----------------|--------------|----------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| Pench (MS)      | 0.46         | 8.07           | 49       | 0        |
| <b>Total</b>    | <b>0.46</b>  | <b>8.07</b>    |          |          |
| <b>Koyna</b>    |              |                |          |          |
| Stage 1-2       | 5.64         | 54.64          | 470      | 40       |
| Stage 4         | 8.77         | 80.92          | 1000     | 0        |
| Stage 3         | 3.36         | 26.99          | 240      | 0        |
| <b>Total</b>    | <b>17.77</b> | <b>162.55</b>  |          |          |
| <b>Hydro</b>    |              |                |          |          |
| KDPH            | 0.89         | 3.62           | 37       | 36       |
| VTRNA           | 0.45         | 6.68           | 59       | 0        |
| TILLARI         | 0.50         | 4.84           | 64       | 0        |
| BHTGR/VEER      | 0.00         | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.13         | 4.48           | 80       | 0        |
| RNGR+BHTSA      | 0.30         | 4.77           | 13       | 12       |
| BHANDARDRA      | 0.45         | 4.55           | 19       | 18       |
| ELDARY          | 0.29         | 0.86           | 13       | 12       |
| SMLHY_PTN       | 0.57         | 9.06           | 24       | 23       |
| GHATGHAR        | 2.14         | 29.82          | 250      | 0        |
| <b>Total</b>    | <b>5.71</b>  | <b>68.69</b>   |          |          |
| <b>Wind</b>     |              |                |          |          |
| Total           | 4.38         | 67.74          | 0        | 0        |
| <b>Total</b>    | <b>4.38</b>  | <b>67.74</b>   |          |          |
| <b>CPP</b>      |              |                |          |          |
| APML(Mus)       | 43.24        | 729.88         | 0        | 0        |
| JSWEL(Mus)      | 9.02         | 138.61         | 0        | 0        |
| VIPL(Mus)       | 6.27         | 94.76          | 0        | 0        |
| RPLAMT(Mus)     | 0.00         | 0.00           | 0        | 0        |
| WPCL(Mus)       | 3.94         | 57.36          | 0        | 0        |
| Other(Mus)      | 7.12         | 130.37         | 0        | 0        |
| <b>Total</b>    | <b>69.58</b> | <b>1150.98</b> |          |          |
| <b>SOLAR</b>    |              |                |          |          |
| Total           | 0.96         | 17.59          | 0        | 0        |
| <b>Total</b>    | <b>0.96</b>  | <b>17.59</b>   |          |          |
| <b>Tata</b>     |              |                |          |          |
| Trombay 5       | 0.00         | 26.38          | 0        | 0        |
| Trombay 6       | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A      | 2.78         | 35.18          | 120      | 115      |
| Trombay 7B      | 1.60         | 21.89          | 68       | 66       |
| Trombay 8       | 5.47         | 79.41          | 250      | 199      |
| TATA Hydro      | 2.49         | 74.66          | 366      | 0        |
| <b>Total</b>    | <b>12.34</b> | <b>237.52</b>  |          |          |
| <b>R-INFRA</b>  |              |                |          |          |
| 1-2             | 10.85        | 154.40         | 511      | 385      |
| <b>Total</b>    | <b>10.85</b> | <b>154.40</b>  |          |          |

| * Infirm Power |             |         |
|----------------|-------------|---------|
| Particulars    | Daily (Mus) | Monthly |
| Koradi 10      | 2.01        | 81.18   |

| Summary         |             |               |
|-----------------|-------------|---------------|
| Particulars     | Daily (Mus) | Monthly (Mus) |
| MSPGCL Thermal  | 126.00      | 2029.48       |
| MSPGCL Thml+Gas | 136.82      | 2182.15       |
| MSPGCL Hydro    | 23.48       | 231.24        |

| Summary             |             |               |
|---------------------|-------------|---------------|
| Particulars         | Daily (Mus) | Monthly (Mus) |
| MSPGCL Total        | 160.30      | 2413.38       |
| Koyna 1,2 & 4 Total | 14.41       | 135.56        |
| State Total         | 258.40      | 4065.67       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 15/Jan/2017

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |       | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|-------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS   |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5289        | 190   | 459   | 5938   | 326  | 2840      | 0    | 0     | 3675        | 4004        | -779                 | 12329                 | 0                    | 12329                     | 1547             | 13876           | 50.06         |
| 2                  | 5290        | 146   | 472   | 5908   | 220  | 2894      | 0    | 0     | 3947        | 3940        | -666                 | 12296                 | 0                    | 12296                     | 1435             | 13731           | 49.99         |
| 3                  | 5309        | 155   | 463   | 5927   | 190  | 2900      | 0    | 0     | 4037        | 3839        | -581                 | 12275                 | 0                    | 12275                     | 1349             | 13624           | 50.00         |
| 4                  | 5256        | 165   | 472   | 5893   | 152  | 2885      | 0    | 0     | 4023        | 3887        | -553                 | 12264                 | 0                    | 12264                     | 1321             | 13585           | 49.98         |
| 5                  | 4823        | 435   | 470   | 5728   | 163  | 2890      | 0    | 0     | 4026        | 4347        | -556                 | 12572                 | 0                    | 12572                     | 1324             | 13896           | 49.94         |
| 6                  | 4840        | 415   | 458   | 5713   | 199  | 2851      | 0    | 0     | 4826        | 4924        | -620                 | 13067                 | 0                    | 13067                     | 1387             | 14454           | 50.01         |
| 7                  | 5190        | 405   | 461   | 6056   | 260  | 2867      | 0    | 0     | 5734        | 5707        | -665                 | 14225                 | 0                    | 14225                     | 1499             | 15724           | 50.03         |
| 8                  | 5630        | 1036  | 473   | 7139   | 423  | 2953      | 0    | 3     | 5777        | 5766        | -477                 | 15807                 | 0                    | 15807                     | 1564             | 17371           | 49.95         |
| 9                  | 5740        | 1876  | 461   | 8077   | 387  | 2944      | 0    | 37    | 6167        | 6348        | -606                 | 17187                 | 0                    | 17187                     | 1726             | 18913           | 49.97         |
| 10                 | 5641        | 1796  | 474   | 7911   | 471  | 2953      | 0    | 87    | 6109        | 6291        | -717                 | 16996                 | 0                    | 16996                     | 1830             | 18826           | 49.99         |
| 11                 | 5546        | 1533  | 454   | 7533   | 415  | 2942      | 0    | 120   | 6132        | 6453        | -827                 | 16636                 | 0                    | 16636                     | 1965             | 18601           | 49.97         |
| 12                 | 5495        | 2059  | 432   | 7986   | 278  | 2969      | 0    | 139   | 6076        | 6797        | -772                 | 17397                 | 2                    | 17399                     | 1961             | 19360           | 49.94         |
| 13                 | 5474        | 2006  | 430   | 7910   | 165  | 2968      | 0    | 151   | 5913        | 6538        | -654                 | 17078                 | 353                  | 17431                     | 1960             | 19391           | 49.95         |
| 14                 | 5485        | 2049  | 431   | 7965   | 73   | 2948      | 0    | 148   | 5774        | 5651        | -775                 | 16010                 | 615                  | 16625                     | 1893             | 18518           | 50.02         |
| 15                 | 5488        | 1989  | 420   | 7897   | 45   | 2898      | 0    | 131   | 5808        | 5573        | -743                 | 15801                 | 501                  | 16302                     | 1810             | 18112           | 50.00         |
| 16                 | 5498        | 1902  | 424   | 7824   | 28   | 2923      | 0    | 85    | 5815        | 5725        | -717                 | 15868                 | 368                  | 16236                     | 1779             | 18015           | 49.99         |
| 17                 | 5546        | 1340  | 427   | 7313   | 46   | 2948      | 0    | 48    | 5790        | 5835        | -660                 | 15530                 | 150                  | 15680                     | 1783             | 17463           | 49.95         |
| 18                 | 5422        | 773   | 427   | 6622   | 31   | 2924      | 0    | 10    | 5800        | 5862        | -726                 | 14723                 | 0                    | 14723                     | 1827             | 16550           | 49.97         |
| 19                 | 5338        | 658   | 448   | 6444   | 60   | 2921      | 0    | 0     | 5913        | 6194        | -865                 | 14754                 | 0                    | 14754                     | 1960             | 16714           | 49.96         |
| 20                 | 5332        | 804   | 438   | 6574   | 53   | 2900      | 0    | 0     | 5877        | 5765        | -999                 | 14293                 | 0                    | 14293                     | 2063             | 16356           | 50.01         |
| 21                 | 4812        | 369   | 446   | 5627   | 94   | 2890      | 0    | 0     | 5671        | 5606        | -1223                | 12994                 | 0                    | 12994                     | 2075             | 15069           | 49.94         |
| 22                 | 4520        | 646   | 453   | 5619   | 104  | 2829      | 0    | 0     | 5276        | 5463        | -1141                | 12874                 | 0                    | 12874                     | 1910             | 14784           | 49.98         |
| 23                 | 4518        | 526   | 465   | 5509   | 108  | 2791      | 0    | 0     | 4899        | 5031        | -1117                | 12322                 | 0                    | 12322                     | 1886             | 14208           | 50.01         |
| 24                 | 4523        | 207   | 456   | 5186   | 85   | 2748      | 0    | 0     | 4925        | 5127        | -926                 | 12220                 | 0                    | 12220                     | 1698             | 13918           | 50.10         |
| MUs                | 126.01      | 23.48 | 10.81 | 160.30 | 4.38 | 69.58     | 0.00 | 0.96  | 127.99      | 130.67      | -18.37               | 347.52                | 1.99                 | 349.51                    | 41.55            | 391.06          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 15/Jan/2017**

Position as on 6.30 Hrs of 16/Jan/2017

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                                                                                                 | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|-----------|------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |           |            |                                                                                                                                                                  |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |           | Continued. | Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul                                                |               |
| MSPGCL                | Paras Unit 3            | 250      | 25/10/2016   | 08.54        |           | Continued. | (Stator Fault)continued under AOH.26/10/2016 00.00hrs                                                                                                            |               |
| MSPGCL                | Koradi Unit-8           | 660      | 12/12/2016   | 23.59        |           | Continued. | Annual Overhaul                                                                                                                                                  |               |
| TPC-G                 | Trombay 5               | 500      | 03/01/2017   | 21.49        |           | Continued. | Annual Overhaul                                                                                                                                                  |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |           |            |                                                                                                                                                                  |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |           | Continued. | Gas Shortage.                                                                                                                                                    |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |           | Continued. | Gas Shortage                                                                                                                                                     |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |           | Continued. | Gas Shortage                                                                                                                                                     |               |
| IPP                   | Dhariwal                | 300      | 28/05/2014   | 02.27        |           | Continued. | No PPA.                                                                                                                                                          |               |
| MSPGCL                | Koradi Unit 6           | 210      | 09/07/2015   | 00.00        |           | Continued. | EE R&M LE Work                                                                                                                                                   |               |
| IPP                   | WPCL U-1                | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                                                                                          |               |
| IPP                   | WPCL U-2                | 135      | 29/02/2016   | 21.46        |           | Continued. | Change over against Unit III                                                                                                                                     |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                                                                                                |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                                                                                                |               |
| MSPGCL                | Bhusawal Unit 2         | 210      | 14/06/2016   | 19.35        |           | Continued. | Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)                                                                               |               |
| IPP                   | RPL(AMT) U-3            | 270      | 29/06/2016   | 03.01        |           | Continued. | Zero Shedule By MSEDCL.                                                                                                                                          |               |
| MSPGCL                | Uran Unit 8             | 108      | 14/08/2016   | 07.56        |           | Continued. | Maintenance work                                                                                                                                                 |               |
| RGPL                  | Dabhol 2A               | 230      | 24/08/2016   | 13.31        |           | Continued. | Change Over.                                                                                                                                                     |               |
| MSPGCL                | Koradi Unit 5           | 200      | 05/09/2016   | 00.21        |           | Continued. | ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 16/09/2016   | 00.02        |           | Continued. | Zero Schedule by MSEDCL                                                                                                                                          |               |
| IPP                   | Adani U-1               | 660      | 06/11/2016   | 11.10        |           | Continued. | Coal Shortage                                                                                                                                                    |               |
| IPP                   | RPL(AMT) U-5            | 270      | 15/11/2016   | 20.00        |           | Continued. | Zero schedule                                                                                                                                                    |               |
| IPP                   | JSW (J) U1              | 300      | 16/11/2016   | 14.38        |           | Continued. | Due To CW Duct Leakage.                                                                                                                                          |               |
| IPP                   | RPL(AMT) U-4            | 270      | 16/11/2016   | 21.03        |           | Continued. | Zero Schedule By MSEDCL.                                                                                                                                         |               |
| IPP                   | RPL(AMT) U-2            | 270      | 16/11/2016   | 22.36        |           | Continued. | Zero Schedule By MSEDCL.                                                                                                                                         |               |
| IPP                   | RPL(AMT) U-1            | 270      | 17/11/2016   | 17.23        |           | Continued. | Zero Schedule.                                                                                                                                                   |               |
| MSPGCL                | Parli Unit 8            | 250      | 18/11/2016   | 16.23        |           | Continued. | w/dn for balance work.                                                                                                                                           |               |
| IPP                   | JSW (J) U2              | 300      | 01/12/2016   | 00.00        |           | Continued. | No Schedule.                                                                                                                                                     |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 15/Jan/2017**

**Position as on 6.30 Hrs of 16/Jan/2017**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                          | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------|---------------|
| MSPGCL             | Nasik Unit 3            | 210      | 11/12/2016   | 16.50        |            | Continued. | withdraw on BTL ,converted to zero schedule w.e.f 16.12.2016 at 00:00 Hrs |               |
| IPP                | VIPL U-1                | 300      | 03/01/2017   | 00.45        |            | Continued. | turbine bearing temprature high.                                          |               |
| MSPGCL             | Khaparkheda Unit 4      | 210      | 09/01/2017   | 21.56        |            | Continued. | POSITIVE SIDE ROTER TRIPPED.                                              |               |
| MSPGCL             | Chandrapur Unit 7       | 500      | 12/01/2017   | 22.10        |            | Continued. | Boiler validity work                                                      |               |
| PGPL               | PGPL U1                 | 262      | 13/01/2017   | 19.15        |            | Continued. | No schedule.                                                              |               |
| PGPL               | PGPL U2                 | 126      | 13/01/2017   | 19.15        |            | Continued. | No schedule.                                                              |               |
| MSPGCL             | Koradi Unit 10          | 660      | 15/01/2017   | 04.10        |            | Continued. | Boiler Tube Leakage                                                       |               |
| MSPGCL             | Chandrapur Unit 9       | 500      | 15/01/2017   | 09.31        | 16/01/2017 | 05.52      | Drum level high                                                           |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 15/Jan/2017**

**Statement-VII**

Position as on 6.30 Hrs of 16/Jan/2017

| Name of Line                                | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                    |
|---------------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|---------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>        |                              |                 |                 |            |               |                |                                                                                                                     |
| Dhule Sar'Sarovar II                        | InterState                   | 14/01/2017      | 14.16           | 16/01/2017 | 06.48         | T              | Testing Work                                                                                                        |
| karad -kolhapur-II                          | IntraState                   | 14/01/2017      | 09.57           |            | Continued.    | PO             | Cold Washing Of Insulator String.(RFC 18.26)                                                                        |
| Bhusawal-Aurangabad                         | IntraState                   | 14/01/2017      | 17.52           | 15/01/2017 | 07.32         | HT             | Over Voltage                                                                                                        |
| Karad-Jaigad - I                            | IntraState                   | 14/01/2017      | 19.47           |            | Continued.    | HT             | Over Voltage                                                                                                        |
| Bhusawal-Aurangabad                         | IntraState                   | 15/01/2017      | 19.06           | 16/01/2017 | 06.56         | HT             | Over Voltage                                                                                                        |
| <b>400 KV ICT Outages/Trippings</b>         |                              |                 |                 |            |               |                |                                                                                                                     |
| 400/132 Kv 200 Mva Ict 2 @Khadka            | IntraState                   | 12/01/2017      | 16.35           | 15/01/2017 | 20.50         | PO             | Oil Filtration Work.                                                                                                |
| 400/220 Kv 600 MVA ICT-II @Kalwa            | IntraState                   | 15/01/2017      | 08.42           | 15/01/2017 | 09.02         | PO             | SFRA Testing Work.                                                                                                  |
| <b>220 KV LINE Outages/Trippings</b>        |                              |                 |                 |            |               |                |                                                                                                                     |
| Chandrapur GCR - Warora - I                 | IntraState                   | 05/04/2015      | 09.13           |            | Continued.    | PO             | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Chandrapur GCR - Wani                       | IntraState                   | 05/04/2015      | 09.15           |            | Continued.    | PO             | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Kharghar - Nerul                            | IntraState                   | 15/01/2017      | 07.52           | 15/01/2017 | 20.18         | PO             | Replacement Of Conductor.                                                                                           |
| Karkambh Tap Onlamboti-Vita                 | IntraState                   | 15/01/2017      | 13.53           | 15/01/2017 | 14.34         | T              | Distance Protection                                                                                                 |
| Eklahara(Gcr)(Nasik)- Bableshtar-I          | IntraState                   | 15/01/2017      | 20.20           | 15/01/2017 | 20.28         | T              | Distance Protection                                                                                                 |
| <b>220 KV ICT Outages/Trippings</b>         |                              |                 |                 |            |               |                |                                                                                                                     |
| 220/100 Kv 200 MVA ICT III @Borivali        | IntraState                   | 21/09/2014      | 09.16           |            | Continued.    | T              | Failed on internal Fault(Now repaired and ready for commissioning)                                                  |
| 220/100 Kv 50 Mva Gec Ict 1 @Kandalgaon     | IntraState                   | 15/12/2016      | 12.15           |            | Continued.    | PO             | Augmentation Work(Outage for 3 Months).                                                                             |
| 220/132 Kv 100 Mva Gec Ict 1 @Pusad         | IntraState                   | 13/01/2017      | 15.23           |            | Continued.    | PO             | Work of tap changer.                                                                                                |
| 220/33kV 100 MVA Transformer 4 @Versova R/S | IntraState                   | 14/01/2017      | 16.33           | 15/01/2017 | 04.23         | T              | Differential protection                                                                                             |
| <b>132 KV LINE Outages/Trippings</b>        |                              |                 |                 |            |               |                |                                                                                                                     |
| Daund-Alegaon                               | IntraState                   | 15/01/2017      | 08.00           |            | Continued.    | PO             | Construction Work.                                                                                                  |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage