

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 15/Jan/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	136.045	2189.093	1) Gujrat	-4.045	-92.335
2) Hydro	11.006	165.914	2) Madhya Pradesh	2.871	79.997
3) Gas	5.787	65.250	3) Chattisgarh	5.600	86.610
Total MSPGCL	152.838	2420.257	4) Maharashtra	132.691	1924.176
B) 1) APLM	67.907	1033.227	5) Goa (Amona)	-1.326	-21.004
2) JSWEL	14.900	208.018	Total	135.791	1977.444
3) VIPL	0.000	0.000	a) Mumbai Schedule	22.503	322.347
4) RPL(AMT)	25.157	393.110	b) Mumbai Drawl	23.538	347.546
5) SWPGPL	6.028	76.493	c) MSEDCL Bilateral *	64.258	826.188
6) Other IPP	32.323	574.362	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.503	322.225
C) 1) TPCL Thermal	9.486	148.922	Include PX	0.000	0.000
2) TPCL Hydro	3.049	60.585	Standby	0.000	0.123
3) TPCL Gas	0.000	9.340	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.171	135.940	1) MSEDCL	420.739	6416.026
D) STATE			2) Mumbai Discoms	44.244	702.332
1) Thermal	300.017	4759.165	3) Other Discoms	7.932	136.676
(A1+C1+C4+(B1-B6))			TOTAL STATE	472.915	7255.034
2) Hydro (A2+C2)	14.055	226.499			
3) Gas (A3+B7+C3)	5.787	74.590			
4) Wind	10.787	125.722			
6) SOLAR	6.478	91.615			
TOTAL STATE	337.124	5277.591			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	6478	6284	6153	4838
MSPGCL Hydro	720	443	728	296
MSPGCL Gas	237	244	231	244
MSPGCL Total Generation	7435	6971	7112	5378
Central Sector Receipt	7606	6923	5550	4549
WIND	480	285	231	353
CPP / IPP Thermal	6658	6620	6477	5166
CPP / IPP Gas	0	0	0	0
SOLAR	723	1031	3	0
Exchange with Mumbai	-1262	-1309	-985	-641
MSEDCL DEMAND MET	17732	16624	14345	11923
Load Shedding	0	0	0	0
MSEDCL DEMAND	17732	16624	14345	11923
TPCL GENERATION	662	596	736	385
AEML GENERATION	370	358	482	324
MUMBAI DEMAND	2294	2263	2203	1350
OTHER DISCOM DEMAND	355	354	368	262
STATE DEMAND MET	23934	22784	20591	16155
STATE DEMAND	23934	22784	20591	16155
Frequency (Hz)	50.03	50.00	50.04	49.93

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 17.01 Hrs	49.65 Hz at 09.09 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 15/Jan/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.31	41.34	175	115
Unit 7	0.00	0.00	0	0
Unit 8	12.23	200.39	581	370
Unit 9	11.83	164.42	544	350
Unit 10	11.32	172.39	548	329
Total	38.69	578.55		
Bhusawal				
Unit 3	3.16	38.42	170	115
Unit 4	0.00	100.73	0	0
Unit 5	8.12	125.11	420	280
Total	11.28	264.26		
Parli				
Unit 6	2.94	55.76	230	0
Unit 7	3.91	56.76	230	137
Unit 8	3.96	59.43	214	145
Total	10.82	171.94		
Chandrapur				
Unit 3	3.40	39.97	168	121
Unit 4	3.34	49.58	159	123
Unit 5	7.35	116.05	355	260
Unit 6	7.95	127.22	380	285
Unit 7	4.57	66.72	320	0
Unit 8	9.54	145.94	440	284
Unit 9	8.52	141.21	403	279
Total	44.66	686.69		
Paras				
Unit 3	4.31	64.58	238	141
Unit 4	0.08	56.88	72	0
Total	4.39	121.46		
Khaparkheda				
Unit 1	3.17	35.34	150	115
Unit 2	0.00	0.00	0	0
Unit 3	3.34	52.04	168	122
Unit 4	3.53	50.54	180	125
Unit 5	9.77	143.88	475	280
Total	19.80	281.80		
Nasik				
Unit 3	3.18	42.18	169	120
Unit 4	0.00	18.28	0	0
Unit 5	3.22	23.93	179	115
Total	6.41	84.38		
Uran				
All Units	5.79	65.25	256	230
Total	5.79	65.25		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.27	4.46	37	0
Total	0.27	4.46		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.61	34.31	365	35
Stage 4	0.00	17.71	0	0
Stage 3	0.66	11.93	160	0
Total	3.27	63.96		
Hydro				
KDPH	0.44	2.85	24	18
VTRNA	0.72	7.41	60	0
TILLARI	0.52	7.83	58	0
BHIRA T.R.	0.21	3.72	47	0
SMLHY_PTN	5.84	80.14	258	220
GHATGHAR	0.00	0.00	0	0
Total	7.74	101.96		
Wind				
Total	10.79	125.72	0	0
Total	10.79	125.72		
CPP				
APML(Mus)	67.91	1033.23	0	0
JSWEL(Mus)	14.90	208.02	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.16	393.11	0	0
SWPGPL-Mus	6.03	76.49	0	0
Other(Mus)	32.32	574.36	0	0
Total	146.32	2285.21		
SOLAR				
Total	6.48	91.62	0	0
Total	6.48	91.62		
Tata				
Trombay 5	6.35	97.82	277	252
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	5.17	0	0
Trombay 7B	0.00	4.17	0	0
Trombay 8	3.14	51.11	133	128
TATA Hydro	3.05	60.58	335	0
Total	12.54	218.85		
AEMIL				
DTPS U-1&2	8.17	135.94	482	300
Total	8.17	135.94		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	136.04	2189.09	MSPGCL Total	152.84	2420.26
			MSPGCL Thml+Gas	141.83	2254.34	Koyna 1,2 & 4 Total	2.61	52.02
			MSPGCL Hydro	11.01	165.91	State Total	337.12	5277.59

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 15/Jan/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4825	313	251	5389	302	5268	0	0	4841	4546	-738	14477	0	14477	1452	290	16219	50.00
2	4838	296	244	5378	353	5166	0	0	4838	4549	-641	14543	0	14543	1350	262	16155	49.93
3	4803	302	244	5349	503	5359	0	0	4766	4529	-577	14909	0	14909	1296	254	16459	49.99
4	4756	298	255	5309	639	5732	0	0	4745	4348	-550	15223	0	15223	1264	255	16742	50.00
5	4944	294	243	5481	812	5458	0	0	4838	4320	-578	15224	0	15224	1283	269	16776	50.06
6	5378	306	243	5927	911	5487	0	0	4950	4632	-677	15983	0	15983	1374	297	17654	50.05
7	5791	273	253	6317	885	6032	0	2	5125	5041	-757	17206	0	17206	1485	314	19005	50.02
8	5801	393	249	6443	818	6632	0	44	5584	5482	-872	18211	0	18211	1635	336	20182	49.93
9	5839	696	256	6791	593	6576	0	225	6498	6667	-1017	19487	0	19487	1884	348	21719	49.90
10	6223	777	241	7241	523	6755	0	440	7212	7185	-1200	20588	0	20588	2131	356	23075	49.92
11	6478	720	237	7435	480	6658	0	723	7717	7606	-1262	21285	0	21285	2294	355	23934	50.03
12	6300	456	234	6990	358	6603	0	980	7588	7614	-1278	20910	0	20910	2319	357	23586	50.04
13	6284	443	244	6971	285	6620	0	1031	7060	6923	-1309	20167	0	20167	2263	354	22784	50.00
14	5782	362	232	6376	177	6570	0	999	6906	6809	-1203	19391	0	19391	2125	337	21853	50.02
15	5706	486	231	6423	145	6503	0	911	7012	6995	-1211	19427	0	19427	2099	339	21865	50.01
16	5869	696	230	6795	139	6513	0	673	6800	6639	-1215	19201	0	19201	2091	343	21635	50.00
17	6204	584	232	7020	120	6480	0	365	6159	6276	-1223	18686	0	18686	2092	352	21130	50.02
18	6210	565	241	7016	148	6467	0	82	5404	5244	-1052	17541	0	17541	2109	364	20014	50.07
19	6153	728	231	7112	231	6477	0	3	5548	5550	-985	18020	0	18020	2203	368	20591	50.04
20	6071	509	231	6811	413	6546	0	0	5544	5606	-1123	17888	0	17888	2199	365	20452	50.03
21	5815	380	242	6437	430	6427	0	0	5228	5111	-1054	16993	0	16993	2038	358	19389	50.02
22	5408	375	239	6022	472	5574	0	0	5363	5167	-1113	15753	0	15753	1919	369	18041	50.00
23	5346	375	252	5973	508	5226	0	0	5179	4640	-1027	14959	0	14959	1745	361	17065	50.00
24	5221	379	232	5832	542	5186	0	0	4946	4312	-876	14669	0	14669	1594	327	16590	50.03
MUs	136.05	11.01	5.79	152.84	10.79	146.32	0.00	6.48	139.85	135.79	-23.54	420.74	0.00	420.74	44.24	7.93	472.92	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 15/Jan/2022

Position as on 6.30 Hrs of 16/Jan/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Bhusawal Unit 4	500	13/01/2022	00:00		Continued.	Annual Overhaul	
MSPGCL	Khaparkheda Unit 4	210	16/01/2022	23:52		Continued.	Extension of Boiler Steaming Validity.	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vibration high	
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55	15/01/2022	20:15	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	04/01/2022	19:40		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	04/01/2022	20:00		Continued.	Gas shortage	
MSPGCL	Nasik Unit 4	210	07/01/2022	22:00		Continued.	CONDENSER TUBE LEAKAGE	
IPP	SWPGL U-2	135	13/01/2022	08:00	16/01/2022	11:04	ID Fan Problem	
MSPGCL	Paras Unit 4	250	14/01/2022	15:05	15/01/2022	22:52	Furnace Pressure High	
IPP	JSW (J) U3	300	15/01/2022	07:46		Continued.	non availability of load schedule.	
MSPGCL	Chandrapur Unit 7	500	15/01/2022	11:20	15/01/2022	18:54	OVERSPEED DEVICE 2 OPERATED	15/01/2022
MSPGCL	Parli Unit 6	250	15/01/2022	13:08	15/01/2022	18:54	Furnace Pressure High	
MSPGCL	Chandrapur Unit 7	500	15/01/2022	19:11	16/01/2022	06:44	Generator Protection operated	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 15/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 16/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
BUS COUPLER @ CHANDRAPUR	IntraState	15/01/2022	09:39	15/01/2022	17:26	PO	1) Measurement of Tan delta & Capacitance of R, Y & B-ph CTs. 2) Back up relay testing. 3) Isolator maintenance work. 4) MTAMC project work.
400 KV LINE Outages/Trippings							
PADGHA - BOISAR (PG)	InterState	15/01/2022	04:01	15/01/2022	07:55	T	TRIPPED ON OVER VOLTAGE
PADGHE (GIS) PG - KUDUS CKT - 2	InterState	16/01/2022	09:31	16/01/2022	20:16	PO	AMP OF PADGHE KUDUS LINE 2 EQUIPMENTS/RELAY TESTING AT PADGHE/KUDUS END.
KUDUS - KALA CKT - 1	InterState	16/01/2022	10:18	16/01/2022	19:13	PO	For AMP works at Kala. Also, line AMP works. A/R OFF on ckt-2 and dia to be kept open.
KALWA - TALEGAON (PG)	InterState	16/01/2022	13:47	16/01/2022	19:30	PO	Cold Line cleaning, Chemical Cleaning of Insulators and Routine Maintenance Activity
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	21/12/2021	12:35			HT	HAND TRIPPED TO CONTROL LINE LOADING OF 400KV TALEGAON-KALWA AND 400KV TALEGAON - KHARGHAR CKT
400 KV WALUJ (400 KV) - BABHALESHWAR CKT	IntraState	04/01/2022	15:46			PO	Height raising work of 400kV Waluj-Babhleshwar line at Loc No. 239 to 240 crossing to Samruddhi Highway i.e. 1. Dismantling of loc No. 239,240,241 (all DA+01) 2. Erection of new towers at loc No.239, 240,241 (All DD+9) 3. Restranging between Loc No. 237 to 242
JAIGAD - KARAD CKT - 1	IntraState	14/01/2022	20:19	15/01/2022	09:49	HT	H/T For Overvoltage.
PADGHE - KALWA CKT - 1	IntraState	15/01/2022	04:01	15/01/2022	07:35	T	TRIPPED ON OVER VOLTAGE
220 KV TAPTITANDA (400 KV) - WALUJ CKT- 1	IntraState	15/01/2022	08:27	15/01/2022	18:44	T	Tripped on Dist Prot.
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	15/01/2022	08:32	15/01/2022	18:44	T	Tripped on dist. prot.
BABHALESHWAR - PADGHE CKT - 2	IntraState	15/01/2022	11:32	15/01/2022	18:19	EO	Agency has arranged to attend Flashover/Faulty Disc Insulators replacement at Towers. Loc. No. 759(Y-Phase) & 821 (R-Phase) under HVDC Junnar Lines Sub Division. 400 KV BBLR-PDG Ckt-I & CHD-PDG Bipole HVDC line is available with full capacity for load controlling.
JAIGAD - KARAD CKT - 2	IntraState	15/01/2022	20:17	16/01/2022	09:45	HT	Handtripped on Over Voltage
PADGHE - NAGOTHANE CKT - 1	IntraState	15/01/2022	23:45	16/01/2022	08:12	HT	HT FOR OVERVOLTAGE
JAIGAD - KARAD CKT - 1	IntraState	16/01/2022	21:30			HT	HT OV
PADGHE - NAGOTHANE CKT - 2	IntraState	16/01/2022	22:02		Continued.	HT	HT OV
LONIKAND I - KOYNA STAGE-IV	IntraState	16/01/2022	22:09		Continued.	HT	HT OV
400 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 16/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 600 MVA ICT - 4 @ PADGHE	IntraState	15/01/2022	00:00		Continued.	PO	1) Oil filtration of Bph unit due to low BDV value 46kV and Water content 20mg/kg. Toatal gases 1269 2) Oil filtration of Rph unit due to increasing trend of Gases. 3) Diagnostic Testing work 4) MTAMC work 5) Bay maint work. 6) Attending Hot spot 7) Oil leakage attending work 8) Replacement of Buchholz Relay 9) CB Overhauling work
400/220 KV 3X200 MVA ICT - 2 @ KALWA	IntraState	16/01/2022	06:12	16/01/2022	14:36	PO	1) Oil Top up in Conservator Tank R & Y Unit 2) All Diagnostic Testing and Bay maintenance Work.
220 KV LINE Outages/Trippings							
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18			PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
PADGHE - TEMGHAR - 2	IntraState	02/01/2022	23:25			HT	conductor replacement work
TATA BORIVLI MSETCL BORIVLI - 4	IntraState	07/01/2022	11:25			PO	For shifting to New GIS at Tata Borivali
BOISAR II - BOISAR (PG) CKT - 1	IntraState	10/01/2022	09:51			PO	REPLACEMENT OF old CONDUCTOR by HTLS CONDUCTOR
TEMGHAR - KALWA	IntraState	13/01/2022	23:10				As safety precaution for the replacement of CB pole of 220/22 kV, 50MVA PTR-2
GT - 3 @ EKLAHRE (GCR)	IntraState	14/01/2022	11:48	15/01/2022	12:32	EO	On Date 14.01.2022 at 11:48Hrs 220kV Gen.Unit No-3 on TBC for attending leakage problem of air compressor. same problem attend and compressor under observation upto 15.01.2022 morning.At 11:00Hrs 220kV Gen.Unit No-3 transfer to normal condition from TBC
GT - 3 @ EKLAHRE (GCR)	IntraState	14/01/2022	11:48	15/01/2022	12:32	EO	. Shifting of 220kV GT-3 on TBC (in view to attend air leakage from moisture release valve of the 220kV GT-3 Own Circuit Breaker) will be carried out on Dt.14.01.2022 @ 11:30Hrs.
BABHALESHWAR - UTECH SUGAR	IntraState	14/01/2022	18:21	15/01/2022	02:25	PO	29D & 29C isolator servicing and alignment
TROMBAY SALSETTE LINE-2	IntraState	14/01/2022	23:29	15/01/2022	06:23	PO	FOR METRO-4 WORK
LONAND-BOTHE	IntraState	15/01/2022	00:57	15/01/2022	01:24	T	TRIPPED ON DIST.PRTN
HALKARNI-MAHALAXMI LINE	IntraState	15/01/2022	09:26	15/01/2022	12:46	PO	Replacement faulty polymer insulator at location No.2 & 3
TROMBAY MSETCL TIE - 2	IntraState	15/01/2022	10:17	15/01/2022	18:09	PO	R/M and CT, CVT Testing work at both ends.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 15/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 16/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
URSE-CHINCHWAD	IntraState	15/01/2022	12:32	15/01/2022	18:24	PO	Work :-1) Restrunging of conductors loc 18-19-20-21,D/C .(Low ground clearance loc.18-19 of 6 M) 2) Restrunging of conductors loc 9-21 S/C. .(Low ground clearance loc.9-10 of 5.96 M, Loc 10-11(Pune Bangalore Highway (7.3 M))).
PEDAMBE-KALAMBANI(TSS)	IntraState	15/01/2022	13:57	15/01/2022	15:02	PO	220 KV. Pedhambe 2 Kalambani Line B Phase C.T. Oil Top up work.
TROMBAY SALSETTE LINE-2	IntraState	15/01/2022	23:25	16/01/2022	06:26	HT	Metro-4 Work
ADLABS - PEDAMBE	IntraState	15/01/2022	23:30	16/01/2022	00:25	T	Distance Protection
BABLESHWAR- ALEPHATA CKT - 1	IntraState	16/01/2022	08:57		Continued.	PO	for outage of 220 Kv Babhaleshwar Alephata Dc line For Line STRINGING erection work of the 220 kv SPND +3 tower between loc no 17 and 18 by LMSD Babhaleshwar
BABHALESHWAR - UTECH SUGAR	IntraState	16/01/2022	09:11		Continued.	PO	for outage of 220 Kv Babhaleshwar erection of the 220 kv SPND +3 tower between loc no 17 and 18 by LMSD Babhaleshwar)
CHAKAN-MAHINDRA VEHICLE	IntraState	16/01/2022	09:38	16/01/2022	19:11	PO	for jumper connection from Isolator to PT, Metering connections, CT-PT testing and charging of new CT-PT for 40MVA at Bay-2, Opportunity outage for Bay Maintenance and Dignostic Testing work.
MAHINDRA VEHICLE-BRIDGESTONE	IntraState	16/01/2022	09:38	16/01/2022	19:16	PO	for jumper connection from Isolator to PT, Metering connections, CT-PT testing and charging of new CT-PT for 40MVA at Bay-2, Opportunity outage for Bay Maintenance and Dignostic Testing work.
TROMBAY - SALSETTE CKT - 1	IntraState	16/01/2022	23:25	16/01/2022	06:26	HT	Metro-4 Work
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kv K'gaon S/s
220/132KV 100MVA ICT 1@ PETH	IntraState	13/01/2022	09:30	15/01/2022	15:15	PO	Oil filtration & oil leakage attending work by replacement of gaskets of bushing, PRV & inspection windows.
220/110 kv 200 MVA ICT 3 @ MUDSHINGI	IntraState	15/01/2022	09:15	15/01/2022	17:31	PO	Quarterly maint. Work & replacement of damaged /obsolete parts & testing of CTR system by agency
220/132 KV 200 MVA ICT 1 @ AHMEDNAGAR	IntraState	15/01/2022	09:55	15/01/2022	15:22	PO	For ICT diagnosing testing by mobile unit Nashik.
220/132 KV 100 MVA ICT 1 @ BELWANDI	IntraState	15/01/2022	10:14	15/01/2022	18:05	PO	For Integration of HV and LV Bays into New SCADA System.
220 / 110 / 33kv 250MVA ICT 8 @ DHARAVI	IntraState	16/01/2022	08:59			PO	For disconnecting 33KV for NGT replacement

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 15/Jan/2022

Statement-VII

Position as on 6.30 Hrs of 16/Jan/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22 KV 50 MVA PTR 3 @ NALASOPARA	IntraState	16/01/2022	09:10	16/01/2022	18:50	PO	1. Cap & Tandelta of Winding, bushing and CT, 10kV Excitation and PI of PTR. 2. Auxiliary protection Trials of PTR. 3. HV and LV side Isolator maintenance. 4. HV and LV side LA Meggering. 5. HT tapping of LV side jumper. 6. LV side CB timings and CRM. 7. Cooling fan maintenance work.
220/132KV 100 MVA ICT 2@ PETH	IntraState	16/01/2022	09:25			PO	Oil filtration & oil leakage attending work by replacement of gaskets of bushing, PRV & inspection window
220 / 110 / 22kV 250MVA ICT 1 @ SAKI	IntraState	16/01/2022	09:39			PO	Only breakers to be kept open (220/110/33 Kv)
132 KV LINE Outages/Trippings							
KANHAN-PENCH	IntraState	15/01/2022	09:19	15/01/2022	18:39	EO	Outage required for replacement Flashed over string at various locations

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage