

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 15/Feb/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	154.623	2293.511	1) Gujrat	-4.516	-83.229
2) Hydro	19.091	181.673	2) Madhya Pradesh	4.173	68.303
3) Gas	4.544	79.390	3) Chattisgarh	4.170	68.430
Total MSPGCL	178.258	2554.574	4) Maharashtra	161.157	2618.221
B) 1) APLM	75.972	1082.474	5) Goa (Amona)	-1.008	-20.554
2) JSWEL	25.031	279.583	Total	163.976	2651.171
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.543	443.386
4) RPL(AMT)	31.198	449.220	b) Mumbai Drawl	35.624	511.281
5) SWPGPL	7.279	125.531	c) MSEDCL Bilateral *	65.195	1084.934
6) Other IPP	41.686	640.352	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.538	443.048
C) 1) TPCL Thermal	12.947	90.773	Include PX	0.000	0.000
2) TPCL Hydro	3.333	63.209	Standby	0.006	0.338
3) TPCL Gas	1.421	30.587	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.034	144.248	1) MSEDCL	504.612	7501.789
D) STATE			2) Mumbai Discoms	63.359	840.098
1) Thermal	358.770	5105.692	3) Other Discoms	9.958	148.546
(A1+C1+C4+(B1-B6))			TOTAL STATE	577.929	8490.433
2) Hydro (A2+C2)	22.424	244.882			
3) Gas (A3+B7+C3)	5.965	109.977			
4) Wind	10.095	145.816			
6) SOLAR	16.699	232.895			
TOTAL STATE	413.953	5839.262			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6734	6598	6549	6258
MSPGCL Hydro	623	296	1728	201
MSPGCL Gas	225	219	130	245
MSPGCL Total Generation	7582	7113	8407	6704
Central Sector Receipt	8351	7997	6691	5986
WIND	475	377	290	516
CPP / IPP Thermal	7683	7484	7724	7371
CPP / IPP Gas	0	0	0	0
SOLAR	2186	2259	0	0
Exchange with Mumbai	-1870	-1879	-1566	-1015
MSEDCL DEMAND MET	23969	22904	21097	19237
Load Shedding	0	0	0	0
MSEDCL DEMAND	23969	22904	21097	19237
TPCL GENERATION	799	776	985	514
AEML GENERATION	481	485	484	318
MUMBAI DEMAND	3150	3140	3035	1847
OTHER DISCOM DEMAND	438	447	449	325
STATE DEMAND MET	27557	26491	24581	21409
STATE DEMAND	27557	26491	24581	21409
Frequency (Hz)	50.01	50.03	49.98	49.94

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 13:02 Hrs	49.52 Hz at 18:40 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 15/Feb/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.43	66.89	195	0
Unit 8	14.01	206.04	620	528
Unit 9	13.83	199.84	637	483
Unit 10	10.26	177.76	625	0
Total	38.53	650.53		
Bhusawal				
Unit 3	3.32	48.70	160	115
Unit 4	10.66	152.58	495	335
Unit 5	9.90	150.35	485	340
Total	23.88	351.63		
Parli				
Unit 6	5.07	67.58	245	155
Unit 7	2.22	34.54	187	0
Unit 8	3.19	53.13	165	101
Total	10.48	155.25		
Chandrapur				
Unit 3	3.79	52.34	168	130
Unit 4	2.83	43.21	120	113
Unit 5	0.00	76.31	0	0
Unit 6	9.17	126.62	415	295
Unit 7	0.00	0.00	0	0
Unit 8	11.77	167.16	500	480
Unit 9	10.98	83.66	498	425
Total	38.54	549.30		
Paras				
Unit 3	5.26	73.32	247	160
Unit 4	5.83	86.25	253	224
Total	11.09	159.58		
Khaparkheda				
Unit 1	2.02	29.32	100	70
Unit 2	2.87	40.83	130	110
Unit 3	3.99	54.94	182	130
Unit 4	4.05	44.26	190	129
Unit 5	11.45	159.83	495	435
Total	24.38	329.19		
Nasik				
Unit 3	3.90	54.22	181	120
Unit 4	0.00	2.54	0	0
Unit 5	3.81	41.28	176	112
Total	7.71	98.04		
Uran				
All Units	4.54	79.39	247	118
Total	4.54	79.39		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.30	7.57	48	0
Total	0.30	7.57		
Koyna				
Stage 1-2	5.51	47.00	585	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	6.19	39.20	761	0
Stage 3	2.43	18.71	320	0
Total	14.12	104.90		
Hydro				
KDPH	0.86	11.38	36	36
VTRNA	0.82	7.23	60	0
TILLARI	0.46	5.70	58	0
BHIRA T.R.	0.22	4.14	40	0
SMLHY_PTN	2.29	36.10	101	91
GHATGHAR	0.00	4.64	0	0
Total	4.67	69.20		
Wind				
Total	10.10	145.82	0	0
Total	10.10	145.82		
CPP				
APML(Mus)	75.97	1082.47	0	0
JSWEL(Mus)	25.03	279.58	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.20	449.22	0	0
SWPGPL-Mus	7.28	125.53	0	0
Dhariwal	0.00	18.40	0	0
IEPL	5.61	74.80	264	198
Other(Mus)	36.08	547.16	0	0
Total	181.17	2577.16		
SOLAR				
Total	16.70	232.90	0	0
Total	16.70	232.90		
Tata				
Trombay 5	8.35	30.95	470	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.78	16.65	61	0
Trombay 7B	0.64	13.94	48	0
TATA Hydro	3.33	63.21	285	9
Trombay 8	4.59	59.82	236	131
Total	17.70	184.57		
AEML				
DTPS U-1&2	10.03	144.25	501	307
Total	10.03	144.25		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	154.62	2293.51	MSPGCL Total	178.26	2554.57
			MSPGCL Thml+Gas	159.17	2372.90	Koyna 1,2 & 4 Total	11.70	86.20
			MSPGCL Hydro	19.09	181.67	State Total	413.95	5839.26

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 15/Feb/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6654	171	242	7067	349	7293	0	0	5857	5702	-1177	18860	0	18860	2195	374	21429	49.96
2	6217	397	244	6858	409	7260	0	0	6033	6100	-1125	19157	0	19157	2034	345	21536	49.97
3	6223	388	243	6854	453	7393	0	0	6044	5965	-1069	19273	0	19273	1921	323	21517	49.95
4	6258	201	245	6704	516	7371	0	0	6303	5986	-1015	19237	0	19237	1847	325	21409	49.94
5	6256	548	243	7047	493	7400	0	0	6155	6250	-1023	19824	0	19824	1854	343	22021	49.92
6	6267	1243	244	7754	520	7701	0	0	5834	5657	-934	20324	0	20324	1980	375	22678	49.94
7	6426	1714	245	8385	558	7737	0	5	5832	6016	-943	21377	0	21377	2202	381	23960	49.86
8	6443	1863	245	8551	465	7743	0	320	5897	6655	-1061	22261	0	22261	2393	412	25066	49.85
9	6689	1653	247	8589	317	7733	0	976	6648	6888	-1297	22788	0	22788	2646	418	25852	50.04
10	6736	998	240	7974	304	7725	0	1622	7357	7554	-1464	23294	0	23294	2937	421	26652	50.00
11	6671	1078	230	7979	409	7711	0	1955	7998	8116	-1779	23962	0	23962	3120	429	27511	49.99
12	6734	623	225	7582	475	7683	0	2186	8191	8351	-1870	23969	0	23969	3150	438	27557	50.01
13	6598	296	219	7113	377	7484	0	2259	8234	7997	-1879	22904	0	22904	3140	447	26491	50.03
14	6326	293	141	6760	316	7094	0	2239	8496	8718	-2017	22656	0	22656	2956	453	26066	50.08
15	6322	321	132	6775	291	7266	0	2028	8548	8842	-2101	22631	0	22631	2969	470	26070	50.03
16	6404	500	128	7032	315	7336	0	1658	8525	8276	-2111	22054	0	22054	2996	451	25502	49.97
17	6591	847	133	7571	336	7618	0	1066	7734	7389	-1913	21596	0	21596	3070	470	25137	49.97
18	6588	825	136	7549	294	7645	0	377	7091	6991	-1816	20574	0	20574	3112	466	24152	50.00
19	6552	1478	136	8166	283	7708	0	8	6227	6118	-1604	20215	0	20215	3085	463	23764	49.80
20	6549	1728	130	8407	290	7724	0	0	6208	6691	-1566	21097	0	21097	3035	449	24581	49.98
21	6470	899	127	7496	336	7683	0	0	5985	6053	-1496	19628	0	19628	2864	444	22936	50.00
22	6320	581	126	7027	543	7657	0	0	5865	5962	-1530	19223	0	19223	2749	435	22408	50.01
23	6220	270	125	6615	638	7651	0	0	6016	5885	-1448	18924	0	18924	2617	417	21958	49.99
24	6109	176	118	6403	808	7549	0	0	6056	5815	-1386	18796	0	18796	2487	393	21676	50.00
MUs	154.62	19.09	4.54	178.26	10.10	181.17	0.00	16.70	163.13	163.98	-35.62	504.63	0.00	504.63	63.36	9.94	577.93	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 15/Feb/2023

Position as on 6.30 Hrs of 16/Feb/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	22/02/2023
IPP	Dhariwal	300	05/02/2023	00:00		Continued.	Annual Overhaul	22/02/2023
IPP	SWPGPL U-2	135	08/02/2023	00:01		Continued.	Bag Filter replacement work	02/03/2023
MSPGCL	Chandrapur Unit 5	500	12/02/2023	00:05		Continued.	Boiler validity work	27/02/2023
TPC-G	Bhira PSU	150	15/02/2023	04:30		Continued.	Tunnel 1 inspection, RM Trials, Calibration and testing work.	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	20/02/2023
MSPGCL	Nasik Unit 4	210	01/02/2023	19:24		Continued.	NASHIK TPS U#4 TOLLING FROM DATED 02.02.2023 at 03.43 A.M	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Koradi Unit-10	660	15/02/2023	01:10	15/02/2023	05:41	ALL FLAME LOSS	
MSPGCL	Koradi Unit 6	210	15/02/2023	02:30		Continued.	SUSPECED BTL	17/02/2023
MSPGCL	Parli Unit 7	250	15/02/2023	13:25		Continued.	HP BYPASS VALVE PROBLEM.	17/02/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 15/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 16/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (408) OF RPL CKT-1 AND AKOLA-1 CKT-1 @ AKOLA 2	IntraState	15/02/2023	10:49	15/02/2023	20:38	PO	Annual maintenance of Bay equipments
400 KV MAINBAY Outages/Trippings							
BUS COUPLER @ KOLHAPUR-III (TALANDGE)-400 KV	IntraState	15/02/2023	11:13			PO	89A and 89B PG isolator overhauling work.
MAIN BAY (405) OF KHADKA CKT - 1 @ DEEPNAGAR	IntraState	15/02/2023	14:02	15/02/2023	16:21	EO	400kV Deepnagar-Khadka Ckt-I Main Bay B phase C.B. pole SF6 Gas Pressure Low (below 0.8 bar) alarm indication appears hence for refilling the SF6 Gas
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - AURANGABAD(PG) CKT -2	InterState	15/02/2023	02:04	15/02/2023	04:02	T	Tripped on Overvoltage protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	16/01/2023	11:34	15/02/2023	01:59	HT	For load management
KHADKA-AURANGABAD (WALUJ)	IntraState	14/02/2023	10:43	15/02/2023	19:22	PO	For CB mechanism and ONE pole O/H work by agency.
DHULE- - BABLESHWAR CKT - 1	IntraState	15/02/2023	09:45	15/02/2023	19:22	PO	cold line washing of insulator string and routine Line maintenance work ;Chemical cleaning of bay equipment , diagnostic testing and Quarterly maintenance
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	14/02/2023	09:52			PO	FOR LV side CB REPLACEMENT WORK
400/220kv 500MVA ICT-1 @ TAPTITANDA	IntraState	14/02/2023	20:20	15/02/2023	04:42	T	TRIPPED ON REF
400/220/33KV 500 MVA ICT - 1 @ KUDUS	IntraState	15/02/2023	10:06	15/02/2023	19:32	PO	Annual bay maintenance and diagnostic testing.
400/220/33 KV 315MVA ICT - 2 @ CHAKAN	IntraState	15/02/2023	12:52	15/02/2023	17:53	PO	own bay Bus isolator alignment and LV CB testing. ICT-2 LV will be in service through 220kV TBC bay.
400 KV BR Outages/Trippings							
400 KV GT- 5 TIE BAY (421)	IntraState	13/02/2023	13:15			PO	For servicing & overhauling of 400kV AREVA make C.B. Mechanism
220 KV TBC Outages/Trippings							
TBC @ GHODBUNDER	IntraState	15/02/2023	08:45	15/02/2023	17:45	PO	Opportunity Outage for Annual Maint of 220kV Dahanu-Ghodbunder line 1 & 2
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	05/02/2023	17:54			HT	HT for Load Management
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work.
BOISAR - VERSOVA	IntraState	13/02/2023	15:28			PO	1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
DAHANU - VERSOVA	IntraState	13/02/2023	15:34			PO	Project activity 1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
BORIVALI - TARAPUR	IntraState	15/02/2023	03:45	16/02/2023	01:04	T	Tripped on Distance Protection.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 15/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 16/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BORIVALI - BOISAR (PG)	IntraState	15/02/2023	03:45	16/02/2023	00:39	T	Tripped on Distance Protection.
WAGHIVALI - DHARAVI 7	IntraState	15/02/2023	08:33			PO	Project work for Shifting of conductor of Trombay Dharavi Salsette line
TALANDGE - MUDSHINGI CKT - 1	IntraState	15/02/2023	09:13	15/02/2023	12:12	PO	For attending hot spot at B-ph main bus T-palm of 220 kV Talandage ckt-1 by hot line method.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	15/02/2023	09:28	15/02/2023	18:36	PO	BREAKER POLE ERECTION WORK
URAN - SEZ JNPT	IntraState	15/02/2023	10:25	15/02/2023	18:40	PO	For disc insulator string replacement work & Diagnostic testing and bay maintenance work.
220 KV JALNA - THAPTITANDA CKT - II	IntraState	15/02/2023	10:26	15/02/2023	14:26	HT	Taptitanda lct-1
VITA - HIWARWADI	IntraState	15/02/2023	10:59	15/02/2023	17:27	PO	Replacement of Distance Protection Relay
KARAD - MUDSHINGI CKT 2-TAK	IntraState	15/02/2023	11:46	15/02/2023	11:54	PO	To close incomer isolator at 220kV Takarai LIS S/Stn
WASHALA - GHATGHAR	IntraState	15/02/2023	13:40	15/02/2023	18:00	PO	1] Relay testing work at 220kV Ghatghar S/s 2] To attend oil leakage from CT stud
DAHANU - GHODBUNDER CKT - 2	IntraState	15/02/2023	16:19	16/02/2023	03:25	PO	Project activity 1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project. Details of activity to be carried out: 1. De-stringing of existing conductors & OPGW cable. 2. Dismantling of existing towers. 3. Erection of Towers. 4. Re-stringing of conductors & OPGW cable
TROMBAY - SALSETTE CKT - 1	IntraState	15/02/2023	23:04	16/02/2023	06:40	PO	Project work for work in vicinity of TDS linf for shifting of conductor Trombay Dharavi Sasette line
WAGHIVALI - DHARAVI 8	IntraState	16/02/2023	00:34	16/02/2023	06:21	PO	Project work for shifting of conductor of Trombay Dharavi Salsette line.
ONGC PANVEL - TSS PANVEL	IntraState	16/02/2023	05:36			PO	1) Jumper opening at loc no 3A of 220kV Kharghar - ONGC line and jumper connection at loc no 3A to 1 (LILo point) of 220kV Kharghar-ONGC-line for separation of both line (i.e.220kV Kharghar-Panvel-TSS line & 220kV ONGC Panvel TSS line) and normalacy restoration.
KHARGHAR - TSS PANVEL	IntraState	16/02/2023	05:36			PO	1) Jumper opening at loc no 3A of 220kV Kharghar - ONGC line and jumper connection at loc no 3A to 1 (LILo point) of 220kV Kharghar-ONGC-line for separation of both line (i.e.220kV Kharghar-Panvel-TSS line & 220kV ONGC Panvel TSS line) and normalacy restoration.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 16/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132kV 100MVA ICT -1 @ LONI DEOKAR	IntraState	15/02/2023	11:10	15/02/2023	15:20	PO	DIAGNOSTIC TESTING WORK
220/132KV 100 MVA ICT NO 1 @ MAGARPATTA	IntraState	15/02/2023	14:04	15/02/2023	15:51	EO	Emergency outage to attend leakage of LV 132 kV CT at secondary box.
220/132kV 100MVA ICT -2 @ LONI DEOKAR	IntraState	15/02/2023	15:25	15/02/2023	17:48	PO	DIAGNOSTIC TESTING WORK
220/33 KV 50 MVA PTR 1 @ BABHLESHWAR	IntraState	15/02/2023	16:10	15/02/2023	20:05		Quarterly Maintenance &Diagnostic Testing of Bay equipments. Outage proposed on 220/33kV 50MVA TF-4. 220/33kV 50MVA TF-1,2,3 will be in service. 220/33kV 50MVA TF-4 element not add in OMS.
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 1 @ URAN	IntraState	15/02/2023	10:51	15/02/2023	17:40	PO	For MAIN BUS 1 insulator string replacement work.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	10/02/2023	23:17			PO	for 400KV Project work of KVPTL
DHARAVI POWAI	IntraState	10/02/2023	23:35			PO	For 400KV project work on KVPTL

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage