

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 15/Apr/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	170.733	2430.700	1) Gujrat	-5.749	-61.043
2) Hydro	12.118	308.902	2) Madhya Pradesh	7.225	128.105
3) Gas	3.740	36.511	3) Chattisgarh	4.040	72.290
Total MSPGCL	186.591	2776.113	4) Maharashtra	162.491	2699.994
B) 1) APML	76.218	1114.347	5) Goa (Amona)	-1.712	-22.558
2) JSWEL	24.818	367.154	Total	166.295	2816.788
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.984	501.349
4) RPL(AMT)	31.330	436.085	b) Mumbai Drawl	34.005	555.228
5) SWPGPL	12.354	169.374	c) MSEDCL Bilateral *	84.513	1433.503
6) Other IPP	19.174	329.402	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.984	501.349
C) 1) TPCL Thermal	14.363	174.541	Include PX	0.000	0.000
2) TPCL Hydro	6.609	83.001	Standby	0.000	0.000
3) TPCL Gas	3.700	42.301	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.337	145.133	1) MSEDCL	495.224	7709.341
D) STATE			2) Mumbai Discoms	70.014	1000.200
1) Thermal	360.327	5166.736	3) Other Discoms	10.269	152.665
(A1+C1+C4+(B1-B6))			TOTAL STATE	575.507	8862.206
2) Hydro (A2+C2)	18.727	391.903			
3) Gas (A3+B7+C3)	7.440	78.812			
4) Wind	10.616	186.107			
6) SOLAR	12.102	221.864			
TOTAL STATE	409.212	6045.422			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6883	7234	7368	6958
MSPGCL Hydro	374	991	831	228
MSPGCL Gas	130	211	209	139
MSPGCL Total Generation	7387	8436	8408	7325
Central Sector Receipt	8991	8342	6292	6003
WIND	68	185	412	611
CPP / IPP Thermal	6575	6854	6952	6892
CPP / IPP Gas	0	0	0	0
SOLAR	1626	1057	0	0
Exchange with Mumbai	-2046	-1633	-1288	-1143
MSEDCL DEMAND MET	22151	22767	20310	19357
Load Shedding	0	0	0	0
MSEDCL DEMAND	22151	22767	20310	19357
TPCL GENERATION	797	1250	1214	872
AEML GENERATION	492	488	481	450
MUMBAI DEMAND	3335	3371	2983	2465
OTHER DISCOM DEMAND	450	474	466	331
STATE DEMAND MET	25936	26612	23759	22153
STATE DEMAND	25936	26612	23759	22153
Frequency (Hz)	49.94	49.95	49.94	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 17.03 Hrs	49.49 Hz at 22.09 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 15/Apr/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.65	69.67	210	165
Unit 8	14.21	208.06	610	566
Unit 9	14.66	63.09	625	590
Unit 10	13.90	200.51	605	546
Total	47.43	541.34		
Bhusawal				
Unit 3	3.26	50.41	160	115
Unit 4	9.74	126.70	470	280
Unit 5	9.74	159.36	465	285
Total	22.74	336.47		
Parli				
Unit 6	4.61	74.70	247	146
Unit 7	4.54	70.31	245	144
Unit 8	3.48	57.99	189	0
Total	12.62	203.00		
Chandrapur				
Unit 3	3.56	56.37	170	125
Unit 4	3.49	33.96	166	121
Unit 5	8.47	134.87	410	285
Unit 6	8.44	131.63	410	295
Unit 7	0.00	126.27	0	0
Unit 8	11.20	167.29	497	356
Unit 9	11.27	117.15	494	369
Total	46.42	767.54		
Paras				
Unit 3	4.50	65.16	230	142
Unit 4	5.67	63.26	246	217
Total	10.17	128.43		
Khaparkheda				
Unit 1	0.80	42.56	130	0
Unit 2	2.99	34.91	141	110
Unit 3	3.98	57.45	184	132
Unit 4	4.15	63.64	192	136
Unit 5	11.39	138.52	500	425
Total	23.31	337.10		
Nasik				
Unit 3	3.95	59.96	178	120
Unit 4	4.09	28.56	182	132
Unit 5	0.00	28.30	0	0
Total	8.04	116.82		
Uran				
All Units	3.74	36.51	217	127
Total	3.74	36.51		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.01	1.72	6	0
Total	0.01	1.72		
Koyna				
Stage 1-2	2.40	77.25	385	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	3.60	123.88	762	0
Stage 3	1.58	43.29	240	0
Total	7.58	244.41		
Hydro				
KDPH	0.83	12.67	35	34
VTRNA	1.22	17.75	61	0
TILLARI	0.00	1.82	0	0
BHIRA T.R.	0.44	4.64	80	0
SMLHY_PTN	2.04	25.89	94	68
GHATGHAR	0.00	0.00	0	0
Total	4.53	62.77		
Wind				
Total	10.62	186.11	0	0
Total	10.62	186.11		
CPP				
APML(Mus)	76.22	1114.35	0	0
JSWEL(Mus)	24.82	367.15	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.33	436.08	0	0
SWPGPL-Mus	12.35	169.37	0	0
Dhariwal	6.16	89.95	272	203
IEPL	5.65	78.34	272	196
Other(Mus)	7.37	161.11	0	0
Total	163.89	2416.36		
SOLAR				
Total	12.10	221.86	0	0
Total	12.10	221.86		
Tata				
Trombay 5	9.32	114.40	434	279
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.27	24.67	108	42
Trombay 7B	1.43	17.63	65	38
TATA Hydro	6.61	83.00	438	114
Trombay 8	5.04	60.14	243	148
Total	24.67	299.84		
AEML				
DTPS U-1&2	11.34	145.13	501	431
Total	11.34	145.13		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	170.73	2430.70	MSPGCL Total	186.59	2776.11
			MSPGCL Thml+Gas	174.47	2467.21	Koyna 1,2 & 4 Total	6.00	201.13
			MSPGCL Hydro	12.12	308.90	State Total	409.21	6045.42

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 15/Apr/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	Transmission Constraint					
1	7654	269	138	8061	597	7010	0	0	5495	5618	-1403	19481	0	0	19481	2990	402	22873	49.98
2	7653	231	139	8023	623	7028	0	0	5617	5613	-1202	19717	0	0	19717	2790	368	22875	50.03
3	7538	227	139	7904	782	7015	0	0	5752	5166	-1046	19474	0	0	19474	2607	347	22428	50.04
4	6958	228	139	7325	611	6892	0	0	6017	6003	-1143	19357	0	0	19357	2465	331	22153	49.98
5	7390	229	139	7758	595	7009	0	0	5864	5845	-1144	19711	0	0	19711	2387	352	22450	49.96
6	7639	238	139	8016	367	7032	0	0	6019	5963	-1174	19833	0	0	19833	2438	371	22642	49.96
7	7539	322	140	8001	309	6938	0	46	6429	6699	-1186	20389	0	0	20389	2430	418	23237	49.99
8	6922	524	140	7586	132	6652	0	252	6918	7177	-1363	20008	0	8	20008	2481	428	22917	50.02
9	6741	447	138	7326	108	6634	0	747	7459	7188	-1499	20064	0	0	20064	2683	440	23187	50.01
10	6352	517	137	7006	79	6551	0	1108	8278	8269	-1748	20818	0	0	20818	2977	447	24242	49.98
11	6548	429	135	7112	70	6549	0	1371	9016	9260	-1962	21934	0	14	21934	3226	466	25626	49.98
12	6883	374	130	7387	68	6575	0	1626	9332	8991	-2046	22151	0	17	22151	3335	450	25936	49.94
13	6651	534	127	7312	66	6551	0	1694	8988	8911	-1884	22203	0	16	22203	3352	447	26002	49.92
14	6323	932	131	7386	89	6520	0	1711	8909	8477	-1543	22199	0	20	22199	3272	441	25912	49.91
15	6505	1004	208	7717	73	6509	0	1430	8878	8930	-1597	22634	0	20	22634	3345	428	26407	49.86
16	7234	991	211	8436	185	6854	0	1057	8498	8342	-1633	22767	0	16	22767	3371	474	26612	49.95
17	7447	990	216	8653	413	6771	0	712	7978	8010	-1526	22553	0	0	22553	3279	480	26312	49.97
18	7472	552	217	8241	613	6845	0	315	7321	6999	-1361	21176	0	0	21176	3121	476	24773	50.02
19	7385	394	210	7989	527	6928	0	33	6442	6042	-1259	19781	0	0	19781	2975	479	23235	49.95
20	7368	831	209	8408	412	6952	0	0	6068	6292	-1288	20310	0	0	20310	2983	466	23759	49.94
21	7296	609	140	8045	771	6967	0	0	5778	5494	-1271	19558	0	0	19558	2936	448	22942	49.96
22	7087	449	139	7675	920	6999	0	0	5809	5741	-1246	19635	0	0	19635	2871	454	22960	49.82
23	6998	572	139	7709	1168	7032	0	0	5822	5451	-1249	19675	0	0	19675	2840	436	22951	49.77
24	7150	225	140	7515	1038	7081	0	0	6007	5814	-1232	19797	0	0	19797	2860	419	23076	49.84
MUs	170.73	12.12	3.74	186.59	10.62	163.89	0.00	12.10	168.69	166.29	-34.00	495.22	0.00	0.11	495.22	70.01	10.27	575.51	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

Transmission Constraint Remark:

1) DLS implemented due to overloading of 220kv jejuri lonand line 2) 400KV Alkud ICT Over loading due to FLS done at Miraj & Alkud S/S.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 15/Apr/2023

Position as on 6.30 Hrs of 16/Apr/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	19/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	01/06/2023
MSPGCL	Nasik Unit 5	210	08/04/2023	20:20		Continued.	Boiler Tube Leakage(under tolling from 18.00Hrs DT. 13-04-2023)	
MSPGCL	Uran Unit 6	108	12/04/2023	21:03	15/04/2023	13:50	SYnchronised for the 400 KV Kharghar-Talegaon PG Line outage and Mumbai voltages improvement.	
MSPGCL	Chandrapur Unit 7	500	14/04/2023	07:58		Continued.	HPT Top bottom casing Temperature difference	18/04/2023
MSPGCL	Khaparkheda Unit 1	210	15/04/2023	06:30		Continued.	Air heater problem	16/04/2023
MSPGCL	Uran Unit 6	108	15/04/2023	19:47		Continued.	No Schedule.	
MSPGCL	Parli Unit 8	250	15/04/2023	22:05		Continued.	Boiler Tube Leakage	18/04/2023
MSPGCL	Koradi Unit 8	660	16/04/2023	11:24		Continued.	Boiler Tube Leakage	19/04/2023
IPP	SWPGPL U-1	135	16/04/2023	14:47	16/04/2023	17:03	Boiler aux supply MCB trip	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 15/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 16/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 1	IntraState	09/04/2023	22:22			T	Tripped on distance protection
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	15/04/2023	22:58	16/04/2023	05:40	EO	Emergency Shutdown of HVDC Pole-1 BASE FILTER Z11-Z1/Z2 for attending Hotspots at various locations in all the three phase, respective images are also attached
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF KARAD LINE AND 400/220KV 315MVA ICT - 1 @ SOLAPUR (PG)	InterState	15/04/2023	09:39			PO	411-Bay Y.Ph CT Replacement due to oil seepage from porcelain and cementing joint
400 KV MAINBAY Outages/Trippings							
MAIN BAY (431) OF 167 MVA SPARE ICT @ KORADI II	IntraState	15/04/2023	10:18	15/04/2023	22:43	EO	1)Attending oil leakage at CT(Yph) at Spare ICT Bay 431
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/04/2023	11:30			HT	H/T TO CONTROL LINE LOADING OF PUNE PG
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	11/04/2023	09:07			PO	Diagnostic testing and allied bay maintenance work
NEW KOYNA-KARAD CKT - 1	IntraState	14/04/2023	09:05	15/04/2023	08:30	PO	PID Faulty disc insulator replacement work & Cold line washing work
PADGHE - KALWA CKT - 2	IntraState	14/04/2023	23:23	15/04/2023	05:01	EO	To attend Hot spot at Loc no. 62 M-Phase (91.7 deg C) B-Phase (100 deg C), Loc no. 113-M-Phase (69.5 deg C) B -Phase (53.9 deg C), Loc no. 108 M-Phase (134 deg C), T-Phase (64.8 deg C) M - Phase (92.8 deg C), Loc 115 M-Phase (55.5 deg C) B-Phase (160.0 deg C), Loc 118 B-Phase (79.3 deg C) & Loc no 119 T-Phase (61.1 deg C) B Phase (60.5 deg C) B-Phase (64.6 deg C)
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	15/04/2023	04:42	15/04/2023	16:00	T	Tripped On Distance Protection.
KOLHAPUR (TALANDGE) - ALKUD	IntraState	15/04/2023	05:17	15/04/2023	14:55	T	Tripped on Distance Protection.
NEW KOYNA-KARAD CKT - 2	IntraState	15/04/2023	09:48	15/04/2023	18:48	PO	PID Faulty disc insulator replacement work & Cold line washing work
KHARGHAR - TALEGAON (PG)	IntraState	15/04/2023	12:50	15/04/2023	20:33	HT	For emergency outage at Talegaon PG end
JEJURI - KARAD	IntraState	16/04/2023	12:52	16/04/2023	14:43	T	Distance Protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	15/04/2023	09:26	15/04/2023	17:37	PO	For annual ICT maintenance work and bay maintenance work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 16/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	15/04/2023	09:36	15/04/2023	20:13	PO	1. To remove the Jumpers of HV, IV & tertiary connection from Y-ph Unit. 2. To make Connection for Spare unit with Y-ph (HV & IV connections) and rearrangement of tertiary Delta connection with spare unit. 3. Allied testing work to take spare in service.
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	IntraState	15/04/2023	21:38	16/04/2023	04:47	T	ICT TRIPPED ON NDR
220 KV MAINBAY Outages/Trippings							
220 KV MAIN BUS SECTION - 2	IntraState	15/04/2023	08:46	15/04/2023	11:30	PO	Replacement of Rusted/Damaged Gi nut bolt of isolator pad by hot line method.
BUS COUPLER @ BORIVALI	IntraState	15/04/2023	16:50	15/04/2023	18:31	EO	To confirm the current mismatch in bus coupler circuit breaker
220 KV LINE Outages/Trippings							
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	14/04/2023	18:52	15/04/2023	03:44	T	Tripped on distance protection
NALASOPARA - BOISAR PG	InterState	16/04/2023	07:37	16/04/2023	12:47	EO	1) Work is Proposed on newly formed Palghar- Nalasopara line for Attending hot spot work at R Phase Main Bus isolator Jaw main Bus Temp-259 deg.cent) at Nalasopara ss.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
KALWA - SALESETTE CKT - 5	IntraState	13/04/2023	10:10			PO	Normalization of 110 KV Kalwa Kalyan Salsette 2 section - 220 KV Kalwa Salsette 5 project work.
ALKUD - MENDHEGIRI CKT - 2	IntraState	14/04/2023	21:02	15/04/2023	03:55	T	Tripped on distance protection
ALEPHATA-PARGAON(KATHAPUR)	IntraState	15/04/2023	07:20	15/04/2023	17:03	HT	H/T for Load Management.
NEW KOYNA - POPHALI	IntraState	15/04/2023	09:08	15/04/2023	12:45	PO	To attend damaged cinductors at R & Y phase SF6 circuit breakerto respective CT's work
KALMESHWAR-PANDHURNA	IntraState	15/04/2023	09:21	15/04/2023	19:33	PO	s/d is for Re-sagging work at loc no 03R-278, 278-294
220KV HINGOLI -KURUNDA CKT	IntraState	15/04/2023	10:37	15/04/2023	17:05	PO	Cold line washing of disc insulator from LOC no 137 to 175
KARAD - VITA CKT- 2	IntraState	15/04/2023	10:42	15/04/2023	15:10	HT	H/T to control load on Alkud ICT
KARAD - VITA CKT- 1	IntraState	15/04/2023	10:42	15/04/2023	15:07	HT	H/T to control load on Alkud ICT
MIRAJ - MHAISHAL	IntraState	15/04/2023	10:51	15/04/2023	16:38	HT	H/T to control load on Alkud ICT
BUS SECTION @ KOLSHET	IntraState	15/04/2023	12:02	15/04/2023	15:47	PO	For jumpering work from new PTR -4 100KV Bus-isolator to 100KV Main Bus & other allied work
KANDALGAON - ONGC PANVEL	IntraState	15/04/2023	12:16	15/04/2023	18:02	PO	Replacement of faulty string observed in PID Testing at Loc.No.441 (Top Ph) and Outage tree cutting work at various location and other line maintenance work.
220KV BADNERA -NER CKT	IntraState	15/04/2023	12:23	15/04/2023	15:29	PO	Replacement of Disc at LOC no.105 R
INFOSYS - PEGASUS	IntraState	15/04/2023	12:39	16/04/2023	11:20	EO	CB overhauling work.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 15/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 16/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TALANDGE - MUDSHINGI CKT - 2	IntraState	15/04/2023	17:18	15/04/2023	22:46	PO	To attend hot spot observed in thermoscaning at loc no. 17 R ph, 9 R ph & Disc insulator string replacement at tower loc. no- 17 R & Y ph as per PID testing report.
MHAISAL - ALKUD	IntraState	15/04/2023	17:26	15/04/2023	19:24	PO	To attend hot spot of CT & aux. bus isolator alignment work
CHAKAN (400KV) - VOLKSWAGEN	IntraState	16/04/2023	07:45	16/04/2023	13:29	HT	HT due to sparking on R-ph CC
KALMESHVAR-PANDHURNA	IntraState	16/04/2023	09:34	16/04/2023	16:21	PO	s/d is for Re-sagging work at loc no 03R-278, 278-294
220KV HINGOLI -KURUNDA CKT	IntraState	16/04/2023	09:48	16/04/2023	15:45	PO	Cold line washing of disc insulator from LOC no 137 to 175
SAHARA-URSE	IntraState	16/04/2023	09:52	16/04/2023	15:22	HT	HT for Load Management
URSE - TALEGAON (AMBI) CKT 2	IntraState	16/04/2023	11:23	16/04/2023	15:12	PO	1) Chemical washing of Insulators. 2)Emergency tree cutting.
KANDALGAON - PIRANGUT	IntraState	16/04/2023	13:40	16/04/2023	14:30	T	Tripped on distance protection
BUS SECTION BREAKER-3 @ TROMBAY	IntraState	16/04/2023	14:51	16/04/2023	15:15	EO	FORRAISING SF6 GAS PRESSURE
NERLE - PEDAMBE	IntraState	16/04/2023	15:20	16/04/2023	18:22	EO	For fixing repair sleeve between loc 83 to 84 bottom ph due to damaged conductor.
TALOJA - PANCHANAND	IntraState	16/04/2023	17:00	16/04/2023	21:40	T	B-ph CC bursted @ Taloja end
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220 / 110 / 33kV 250MVA ICT 8 @ DHARAVI	IntraState	14/04/2023	07:02	15/04/2023	17:49	PO	PROJECT WORK-Connection of ICT side jumpers between 110 kV bushing and Cable sealing end.
220/132 KV 200 MVA ICT 2 @ SATANA	IntraState	15/04/2023	09:05	15/04/2023	12:30	PO	For urgent oil leakage work.
220/132 KV 200 MVA ICT 2 @ RAYMOND	IntraState	15/04/2023	09:20	15/04/2023	16:02	PO	Replacement of high delta 3nos. 132kV CTs and bay maintenance work
220/100 KV 100 MVA ICT 2 @ TAMBATI	IntraState	15/04/2023	10:27	15/04/2023	16:15	PO	Diagnostic testing work and attending hot spots on 100kv Main bus sec 2
220/33 KV 25 MVA PTR 1 @ AHMEDNAGAR	IntraState	15/04/2023	11:30	15/04/2023	15:40	PO	R phase 33KV L.V Incommer CT replacement work
220/100 KV 200 MVA ICT 2 @ KOLSHET	IntraState	15/04/2023	12:02	15/04/2023	15:47	PO	For jumpering work from new PTR -4 100KV Bus-isolator to 100KV Main Bus & other allied work
220/132 KV 150 MVA ICT 1 @ SATANA	IntraState	15/04/2023	13:17	15/04/2023	15:44	PO	For urgent oil leakage work.
220 / 110 / 33kV 250MVA ICT 2 @ SAKI	IntraState	16/04/2023	08:09	16/04/2023	15:40	PO	Premansoon checks & R/M, testing
110 KV LINE Outages/Trippings							
SALSETTE VIKHROLI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
WAGHIVALI - CHEMBUR	IntraState	04/04/2023	21:59	16/04/2023	03:00	PO	FOR 400 KV KVPTL WORK
WAGHIVALI - MANKHURD	IntraState	04/04/2023	23:57	16/04/2023	02:40	PO	FOR 400 KV KVPTL WORK
KALYAN KALWA SALSETTE 1	IntraState	15/04/2023	09:00	15/04/2023	13:27	PO	Attending Hot Spot.
110 KV BUSBAR Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 16/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS-1 @ KHOPOLI	IntraState	15/04/2023	01:47	15/04/2023	05:00	PO	Connecting Bus jumper of 110 KV KHP-Karnajade Bkr to Main bus section-1

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage