

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 15/Apr/2024 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	179.836	2602.561	1) Gujrat	-1.636	44.853
2) Hydro	23.088	161.462	2) Madhya Pradesh	11.996	175.743
3) Gas	7.030	97.629	3) Chattisgarh	4.370	58.800
Total MSPGCL	209.954	2861.652	4) Maharashtra	195.864	2756.266
B) 1) APLM	59.346	1029.555	5) Goa (Amona)	-3.149	-40.272
2) JSWEL	28.956	379.798	Total	207.445	2995.390
3) VIPL	0.000	0.000	a) Mumbai Schedule	40.187	535.664
4) RPL(AMT)	26.572	449.765	b) Mumbai Drawl	42.776	582.968
5) SWPGPL	10.071	165.182	c) MSEDCL Bilateral *	77.335	1344.033
6) Other IPP	15.594	373.501	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	40.187	535.664
C) 1) TPCL Thermal	13.109	181.213	Include PX	0.000	0.000
2) TPCL Hydro	5.138	60.818	Standby	0.000	0.000
3) TPCL Gas	4.130	59.469	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.126	154.864	1) MSEDCL	528.051	7946.329
D) STATE			2) Mumbai Discoms	76.279	1039.333
1) Thermal	344.610	5336.439	3) Other Discoms	11.073	162.041
(A1+C1+C4+(B1-B6))			TOTAL STATE	615.403	9147.703
2) Hydro	28.226	222.280			
(A2+C2)					
3) Gas	11.160	157.098			
(A3+B7+C3)					
4) Wind	7.335	198.967			
6) SOLAR	16.627	237.528			
TOTAL STATE	407.958	6152.312			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	7261	7645	7427	7844
MSPGCL Hydro	474	805	769	695
MSPGCL Gas	274	270	366	292
MSPGCL Total Generation	8009	8720	8562	8831
Central Sector Receipt	9339	10204	9822	7306
WIND	212	108	483	280
CPP / IPP Thermal	5750	5759	6064	5795
CPP / IPP Gas	0	0	0	0
SOLAR	2296	1389	0	0
Exchange with Mumbai	-2298	-2257	-1755	-1225
MSEDCL DEMAND MET	22798	23416	22695	20616
Load Shedding	0	0	0	0
MSEDCL DEMAND	22798	23416	22695	20616
TPCL GENERATION	961	1256	1214	623
AEML GENERATION	440	460	481	454
MUMBAI DEMAND	3699	3973	3450	2302
OTHER DISCOM DEMAND	510	507	481	371
STATE DEMAND MET	27007	27896	26626	23289
STATE DEMAND	27007	27896	26626	23289
Frequency (Hz)	50.05	49.99	50.00	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.28 Hz at 10.53 Hrs	49.64 Hz at 22.48 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 15/Apr/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.96	58.80	190	0
Unit 8	14.46	207.77	642	584
Unit 9	14.42	206.61	627	572
Unit 10	10.10	108.63	571	230
Total	41.92	581.80		
Bhusawal				
Unit 3	3.90	53.02	175	125
Unit 4	11.22	162.37	490	430
Unit 5	11.36	130.80	495	440
Total	26.49	346.18		
Parli				
Unit 6	5.21	63.42	250	149
Unit 7	5.09	65.80	231	148
Unit 8	5.34	64.39	246	146
Total	15.64	193.60		
Chandrapur				
Unit 3	3.23	46.46	140	130
Unit 4	2.20	53.28	140	0
Unit 5	0.00	102.37	0	0
Unit 6	8.60	130.75	455	295
Unit 7	10.32	119.08	465	328
Unit 8	10.06	149.16	425	402
Unit 9	11.76	171.36	498	480
Total	46.17	772.45		
Paras				
Unit 3	5.41	71.08	246	186
Unit 4	5.34	84.11	252	152
Total	10.75	155.19		
Khaparkheda				
Unit 1	3.44	56.36	170	110
Unit 2	4.57	62.99	199	170
Unit 3	4.19	58.95	178	170
Unit 4	4.23	58.65	188	158
Unit 5	10.95	168.19	490	400
Total	27.39	405.15		
Nasik				
Unit 3	3.87	39.58	174	127
Unit 4	3.91	56.31	170	134
Unit 5	3.69	52.29	167	125
Total	11.47	148.18		
Uran				
All Units	7.03	97.63	378	264
Total	7.03	97.63		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.23	2.64	50	0
Total	0.23	2.64		
Koyna				
Stage 1-2	5.67	40.24	555	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	9.36	39.16	962	61
Stage 3	3.38	17.67	240	0
Total	18.41	97.07		
Hydro				
KDPH	0.80	12.48	34	33
VTRNA	0.93	12.25	60	0
TILLARI	0.00	1.62	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.20	33.98	98	86
GHATGHAR	0.74	4.06	125	0
Total	4.68	64.39		
Wind				
Total	7.34	198.97	0	0
Total	7.34	198.97		
CPP				
APML(Mus)	59.35	1029.56	0	0
JSWEL(Mus)	28.96	379.80	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	26.57	449.76	0	0
SWPGPL-Mus	10.07	165.18	0	0
Dhariwal	0.00	0.00	0	0
IEPL	3.74	80.51	159	151
Other(Mus)	10.02	231.56	0	0
JPL	1.84	61.44	86	73
Total	140.54	2397.80		
SOLAR				
Total	16.63	237.53	0	0
Total	16.63	237.53		
Tata				
Trombay 5	8.59	119.08	469	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.58	36.98	108	106
Trombay 7B	1.55	22.49	65	64
TATA Hydro	5.14	60.82	425	51
Trombay 8	4.52	62.13	232	133
Total	22.38	301.50		
AEML				
DTPS U-1&2	11.13	154.86	499	392
Total	11.13	154.86		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	179.84	2602.56	MSPGCL Total	209.95	2861.65
			MSPGCL Thml+Gas	186.87	2700.19	Koyna 1,2 & 4 Total	15.03	79.40
			MSPGCL Hydro	23.09	161.46	State Total	407.96	6152.31

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 15/Apr/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	8039	1063	291	9393	429	5887	0	0	7499	7208	-1553	20940	0	0	20940	2785	424	24149	49.95
2	7980	729	292	9001	374	5827	0	0	7811	7549	-1410	20945	0	0	20945	2586	397	23927	50.00
3	7949	670	292	8911	255	5811	0	0	7559	7293	-1315	20591	0	0	20591	2418	364	23373	49.98
4	7844	695	292	8831	280	5795	0	0	7473	7306	-1225	20616	0	0	20616	2302	371	23289	49.98
5	7625	940	293	8858	281	5786	0	0	7669	7506	-1225	20838	0	0	20838	2241	368	23447	49.95
6	7540	990	294	8824	271	5784	0	0	8253	7973	-1209	21238	0	0	21238	2311	406	23954	49.95
7	7529	1423	294	9246	338	5849	0	56	8353	8003	-1153	21894	0	0	21894	2414	446	24753	49.98
8	7450	1295	291	9036	347	5816	0	512	8033	7784	-1357	21679	0	0	21679	2572	459	24710	50.02
9	7097	574	287	7958	448	5725	0	1133	8427	8195	-1791	21180	0	1	21180	2927	488	24595	49.93
10	7329	456	283	8068	389	5757	0	1688	8826	8708	-2119	21988	0	9	21988	3272	503	25763	49.91
11	7244	397	278	7919	299	5763	0	2104	9375	9414	-2244	22748	0	70	22748	3558	507	26813	50.02
12	7261	474	274	8009	212	5750	0	2296	9356	9339	-2298	22798	0	181	22798	3699	510	27007	50.05
13	6992	473	269	7734	162	5751	0	2272	9546	9424	-2270	22572	0	72	22572	3738	502	26811	49.94
14	7019	550	264	7833	117	5528	0	2122	9617	9537	-2253	22404	0	14	22404	3742	480	26626	50.01
15	7449	566	266	8281	128	5678	0	1879	9988	10053	-2361	23176	0	95	23176	3884	482	27542	50.09
16	7645	805	270	8720	108	5759	0	1389	10228	10204	-2257	23416	0	274	23416	3973	507	27896	49.99
17	7593	1381	272	9246	155	5787	0	858	10075	9730	-2141	23131	0	116	23131	3900	504	27535	49.96
18	7451	1468	276	9195	311	5787	0	302	9580	9424	-2019	22487	0	70	22487	3739	514	26739	49.99
19	7421	849	321	8591	401	5916	0	16	9991	9599	-1977	22035	0	0	22035	3488	511	26034	50.01
20	7427	769	366	8562	483	6064	0	0	10022	9822	-1755	22695	0	0	22695	3450	481	26626	50.00
21	7568	934	378	8880	479	6064	0	0	8880	8913	-1752	22109	0	0	22109	3350	476	25934	50.01
22	7467	1740	320	9527	372	6194	0	0	7820	8100	-1686	22021	0	0	22021	3284	487	25791	49.98
23	7442	1857	282	9581	353	6223	0	0	7997	8367	-1708	22366	46	0	22412	3308	450	26170	49.83
24	7475	1990	285	9750	343	6236	0	0	7855	7994	-1698	22185	783	0	22968	3338	439	26746	49.92
MUs	179.84	23.09	7.03	209.95	7.34	140.54	0.00	16.63	210.23	207.45	-42.78	528.05	0.83	0.90	528.88	76.28	11.07	616.23	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) 132 kV BBLR TO Rahuri line over Load Alarm 490 A/102.12 MW.

2) LTS operated due to overloading of 220kV Talegaon -Talegaon PG ckt 2 as 220kV Talegaon -Talegaon PG ckt 1 tripped.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 15/Apr/2024

Position as on 6.30 Hrs of 16/Apr/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	16/04/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	20/04/2024
Total Capacity MSPGCL		188						
Total Capacity PLANNED OUTAGE		188						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Chandrapur Unit 5	500	13/04/2024	00:31	16/04/2024	07:45	Excessively high DM consumption due to FD 47 and boiler side leakages.	17/04/2024
MSPGCL	Ghatghar Unit-1	125	13/04/2024	15:00		Continued.	GM Link Fault	16/04/2024
MSPGCL	Koradi Unit 6	210	15/04/2024	16:35		Continued.	Boiler Tube Leakage	17/04/2024
MSPGCL	Chandrapur Unit 4	210	15/04/2024	17:18		Continued.	Boiler Tube Leakage	18/04/2024
MSPGCL	Koyna STG-IV Unit-3	250	15/04/2024	21:20	15/04/2024	23:05	Numerical protection 32 trial tripped.	
Total Capacity MSPGCL		1415						
IPP								
IPP	RPL(AMT) U-1	270	12/04/2024	05:30	15/04/2024	18:18	Bottom ash evacuation problem	15/04/2024
IPP	Adani U-3	660	13/04/2024	04:57		Continued.	APH-A inlet bellow leakage	17/04/2024
Total Capacity IPP		930						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2665						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 6	108	07/04/2024	06:57	15/04/2024	18:19	Zero Schedule(Due to open cycle can be taken on bar as per MSEDCL requirement)	
Total Capacity MSPGCL		108						
IPP								

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 15/Apr/2024

Position as on 6.30 Hrs of 16/Apr/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	JPL Unit 2	150	14/04/2024	08:49		Continued.	Low net sales realization.	
Total Capacity IPP		150						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		258						
FORCED OUTAGE DUE TO NO PPA								
MSPGCL								
MSPGCL	Uran Unit 6	108	15/04/2024	21:30		Continued.	Zero Schedule(Due to open cycle can be taken on bar as per MSEDCL requirement)	
Total Capacity MSPGCL		108						
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		1096						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Apr/2024

Statement-VII

Position as on 6.30 Hrs of 16/Apr/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY (705) OF ICT - 2 & BUS REACTOR @ KORADI 3	IntraState	15/04/2024	10:38	15/04/2024	17:11	PO	Annual Maintenance of CB at Koradi-III SS.
765 KV ICT Outages/Trippings							
765/400kV 1500MVA ICT @ AKOLA 2	IntraState	14/04/2024	10:17	15/04/2024	03:41	PO	Insulation Coating of 33KV Tertiary yard
400 KV TIEBAY Outages/Trippings							
TIE BAY (402) OF 400/21KV GT-1 and 765/400KV ICT (LV Side) @ TIRORA	IntraState	15/04/2024	16:34	15/04/2024	18:06	PO	CT OIL SAMPLE COLLECTION FOR DGA
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	28/03/2024	23:52			HT	For load management of Talegaon Chakan line
PADGHE - KALWA CKT - 1	IntraState	12/04/2024	13:58			PO	1.B Bus PG Isolator replacement work under LES Scheme. 2. 400kV Kalwa-I in service through TBC. 3.CB Diagonostic Testing Work.
MAIN BUS - 2 @ PADGHE	IntraState	13/04/2024	12:40	15/04/2024	17:49	PO	1.Replacement of Hanger Assembly of B Bus PG Isolator of Kalwa-1 by hot line method. 2. All feeders on B Bus will be in service.
NEW KOYNA-KARAD CKT - 1	IntraState	15/04/2024	12:10	15/04/2024	20:43	PO	Diagnostic testing & Relay testing work , Routine maint. Work & B bus isolatar IPS tube extension work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	IntraState	15/04/2024	08:05	15/04/2024	16:57	PO	For replacement of 29D isolator drive mechanism & alignment works. Other routine maintenance works.
220 KV TBC Outages/Trippings							
TBC @ PAL-DOMBIVALI-220 KV	InterState	15/04/2024	10:10	15/04/2024	13:31	PO	CB Diagnostic & RM Work
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV BUS COUPLER	IntraState	15/04/2024	17:32	15/04/2024	19:04	PO	FOR 220 KV BUS 1 ISOLATOR MAINTENANCE WORK
220 KV LINE Outages/Trippings							
NARANGWADI - SOLAPUR PG CKT - 1	InterState	15/04/2024	09:55	15/04/2024	20:20	PO	Flashover String replacement at Loc no.187 R Ph, Pilot String clamp fixing at Loc no. H1-Y Ph, 239 - Y & B Ph
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	16/03/2024	01:34			HT	Hand Tripped For Load management

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Apr/2024

Statement-VII

Position as on 6.30 Hrs of 16/Apr/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DAHANU - VERSOVA	IntraState	09/04/2024	22:49			PO	Shifting of Lines on Newly constructed Towers for DFCCIL 1. Bunching of lines will be done on Tower no 82.
BOISAR - VERSOVA	IntraState	09/04/2024	22:53				Shifting of Lines on Newly constructed Towers for DFCCIL 1. Bunching of lines will be done on Tower no 82.
TATA BORIVLI MSETCL BORIVLI - 5	IntraState	15/04/2024	00:04	15/04/2024	02:57	PO	Cleaning & paint applying on porcelain insulator strings at Gantry Structure MSETCL Borivali end as observed heavy corona discharge on insulator string.
PHALTAN MIDC - SWARAJ CO GEN	IntraState	15/04/2024	09:26	15/04/2024	14:42	PO	1.Relay Testing Work 2.Diagnostic Testing Work 3.Quarterly Maintenance Work
220 KV PARAS - MALKAPUR CKT	IntraState	15/04/2024	10:19	15/04/2024	14:17	PO	FOR REPLACEMENT OF DAMAGED INSULATOR DISC AT LOC NO 137 (DTN) R-PHASE UNDER EHV LINE MAINTENANCE SUB DIVISION, KHAMGAON
BHUGAON - WARDHA (PG)	IntraState	15/04/2024	10:37	15/04/2024	21:31	PO	Routine line maintenance work
NIGADE- PETH LINE	IntraState	15/04/2024	11:24	15/04/2024	17:52	PO	CT Replacement Work of R,Y & B Ph
POPHALI - KDPH	IntraState	15/04/2024	11:30	15/04/2024	19:09	PO	For installation of OPGW from tower loc no. 1 to 11 of 220kV KDPH LILO line.
GHODBUNDER - MSETCL BOISAR	IntraState	15/04/2024	14:20	15/04/2024	18:00	T	Tripped on overcurrent
TALEGAON (AMBI)-TALEGAON (PG) CKT 1	IntraState	15/04/2024	15:00	15/04/2024	15:37	T	Tripped on distance protection
KEKATNIMBHORA - CHALISGAON CKT	IntraState	15/04/2024	15:04	15/04/2024	17:41	T	CHALIS= D/P YPH BPH 3.47KM IY 9.47KA, IB 8.212KA
PADGHE - TEMGHAR - 1	IntraState	15/04/2024	16:05			PO	Permission for shifting on TBC for Replacement of 245kV CB of 220kV Padghe- Temghar-1 line under project work
220 KV DEEPNAGAR - VIRODA	IntraState	15/04/2024	16:36	15/04/2024	19:20	PO	LINE MAINT
MIRAJ - ICHALKARANJI	IntraState	15/04/2024	17:22	15/04/2024	21:24	PO	1)For load management , 220KV Miraj Circuit Kept off for 220KV Talandage Circuit-1
TALANDGE - ICHALKARANJI 2	IntraState	15/04/2024	17:24	15/04/2024	21:22	PO	1) For Quarterly bay maintenance work. 2) Attending hotspots & Equipement testing work
KARAD - VITA CKT- 1	IntraState	16/04/2024	00:32	16/04/2024	01:33	T	Line tripped on distance protection
APTA - TALOJA	IntraState	16/04/2024	05:47			PO	Fitting of cross arm and Stringing of conductor between Loc no. 638 to 639 on new erected tower for height raising work at Taloja MIDC road crossing.
220 KV ICT Outages/Trippings							
220/33 kV 50 MVA CGL PTR 1 @ MUDSHINGI	IntraState	15/04/2024	08:20	15/04/2024	12:05	PO	"Transformer painting work."
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	15/04/2024	08:20	15/04/2024	13:04	PO	For 1)Isolator alignment & maintenance. 2)Bay equipment cold washing.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Apr/2024

Statement-VII

Position as on 6.30 Hrs of 16/Apr/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132-110KV 100MVA PTR 2 @ WATHAR	IntraState	15/04/2024	09:10	15/04/2024	18:49	PO	1) Quarterly maintenance work 2) Diagnostic testing work
220/22 KV 50 MVA PTR 1 @ PADGHE	IntraState	15/04/2024	09:23	15/04/2024	12:13	PO	Shifting of 220/22kV 50MVA BHEL TF on TBC for replacement of Y Phase Jaw Due to burnt during Sparking.
220/132 KV 200 MVA ICT 2	IntraState	15/04/2024	10:32	15/04/2024	16:35	PO	FOR DIGNOSTIC TESTING WORK BY MOBILE TESTING UNIT AKOLA AND CTR MAKE NIFPS PROTECTION TRIALS AND MAINTENANCE AND ICT PREMANSOON MAINTENANCE WORK.
200 MVA 220/132 KV ICT - 1 @ VIRODA	IntraState	15/04/2024	15:00	15/04/2024	19:31	PO	FOR 220 KV BUS 1 ISOLATOR MAINTENANCE WORK
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	15/04/2024	17:30	15/04/2024	19:20	T	DUE TO SUPPLY FAILED OF PENCH CKT DUE TO TRIPPING OF GOPAL GANJ CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
BHIVPURI - AMBERNATH CKT - 1	IntraState	15/04/2024	05:25	15/04/2024	11:57	PO	For CT to line side GOD bus connecting work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage