

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 15/Apr/2025 TUESDAY**

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	181.407	2495.319	1) Gujrat	0.499	24.261
2) Hydro	21.741	288.834	2) Madhya Pradesh	9.794	175.584
3) Gas	8.918	110.297	3) Chattisgarh	3.650	62.860
<b>Total MSPGCL</b>	<b>212.066</b>	<b>2894.450</b>	4) Maharashtra	220.760	3345.144
B) 1) APLM	66.481	974.910	5) Goa (Amona)	-2.068	-35.369
2) JSWEL	27.188	399.750	<b>Total</b>	<b>232.635</b>	<b>3572.480</b>
3) VIPL	0.000	0.000	a) Mumbai Schedule	46.095	652.916
4) RPL(AMT)	31.510	469.337	b) Mumbai Drawl	50.792	732.046
5) SWPGPL	11.836	184.169	c) MSEDCL Bilateral *	134.409	2022.634
6) Other IPP	18.471	279.656	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	46.095	652.916
C) 1) TPCL Thermal	10.952	160.177	Include PX	0.000	0.000
2) TPCL Hydro	5.323	68.663	Standby	0.000	0.000
3) TPCL Gas	3.697	56.895	<b>H) ENERGY CATERED (MUs)</b>		
4) AEML Thermal	9.276	140.844	1) MSEDCL	584.866	8450.603
D) STATE			2) Mumbai Discoms	80.040	1158.624
1) Thermal	357.121	5104.162	3) Other Discoms	13.098	200.155
(A1+C1+C4+(B1-B6))			<b>TOTAL STATE</b>	<b>678.004</b>	<b>9809.382</b>
2) Hydro	27.064	357.497			
(A2+C2)					
3) Gas	12.615	167.192			
(A3+B7+C3)					
4) Wind	22.952	245.979			
6) SOLAR	25.617	362.073			
<b>TOTAL STATE</b>	<b>445.369</b>	<b>6236.903</b>			

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6585	7585	8145	7875
MSPGCL Hydro	590	1544	1776	685
MSPGCL Gas	384	378	393	411
MSPGCL Total Generation	7559	9507	10314	8971
Central Sector Receipt	10752	10261	9543	8374
WIND	712	657	806	1006
CPP / IPP Thermal	5263	6084	7041	6816
CPP / IPP Gas	0	0	0	0
SOLAR	3414	2107	0	861
Exchange with Mumbai	-2960	-2897	-1755	-1783
<b>MSEDCL DEMAND MET</b>	<b>24155</b>	<b>25106</b>	<b>25354</b>	<b>23709</b>
Load Shedding	0	0	0	0
MSEDCL DEMAND	24155	25106	25354	23709
TPCL GENERATION	607	683	1261	675
AEML GENERATION	292	302	479	340
<b>MUMBAI DEMAND</b>	<b>3859</b>	<b>3882</b>	<b>3495</b>	<b>2798</b>
<b>OTHER DISCOM DEMAND</b>	<b>585</b>	<b>613</b>	<b>595</b>	<b>536</b>
STATE DEMAND MET	28599	29601	29444	27043
<b>STATE DEMAND</b>	<b>28599</b>	<b>29601</b>	<b>29444</b>	<b>27043</b>
Frequency (Hz)	50.01	50.01	49.92	50.01

**FREQUENCY PARTICULARS**

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.2 Hz at 17.02 Hrs	49.77 Hz at 19.25 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation, Maximum, Minimum for 15/Apr/2025

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Koradi</b>				
Unit 6	3.97	59.01	177	126
Unit 8	12.60	191.55	562	440
Unit 9	12.90	141.52	571	425
Unit 10	12.96	186.12	570	470
<b>Total</b>	<b>42.43</b>	<b>578.20</b>		
<b>Bhusawal</b>				
Unit 3	3.36	49.60	160	125
Unit 4	10.09	146.28	500	280
Unit 5	9.95	121.98	495	280
Unit 6	15.39	164.50	672	429
<b>Total</b>	<b>38.80</b>	<b>482.36</b>		
<b>Parli</b>				
Unit 6	4.62	65.92	248	141
Unit 7	4.56	53.54	241	140
Unit 8	4.34	63.59	216	147
<b>Total</b>	<b>13.52</b>	<b>183.04</b>		
<b>Chandrapur</b>				
Unit 3	0.00	26.11	0	0
Unit 4	3.33	49.71	147	123
Unit 5	8.66	127.75	405	275
Unit 6	9.88	139.14	470	280
Unit 7	9.57	138.00	459	295
Unit 8	9.58	136.64	471	285
Unit 9	0.00	0.00	0	0
<b>Total</b>	<b>41.01</b>	<b>617.35</b>		
<b>Paras</b>				
Unit 3	4.72	68.25	229	143
Unit 4	5.16	71.28	250	148
<b>Total</b>	<b>9.88</b>	<b>139.52</b>		
<b>Khaparkheda</b>				
Unit 1	3.76	56.08	175	115
Unit 2	3.77	58.33	190	115
Unit 3	4.10	61.45	189	130
Unit 4	3.89	45.95	176	127
Unit 5	9.96	139.30	435	380
<b>Total</b>	<b>25.48</b>	<b>361.12</b>		
<b>Nasik</b>				
Unit 3	3.30	30.44	151	118
Unit 4	3.56	53.61	170	123
Unit 5	3.42	49.66	163	118
<b>Total</b>	<b>10.27</b>	<b>133.71</b>		
<b>Uran</b>				
All Units	8.92	110.30	413	273
<b>Total</b>	<b>8.92</b>	<b>110.30</b>		
<b>PGPL</b>				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
<b>Total</b>	<b>0.00</b>	<b>0.00</b>		
<b>PENCH (MS)</b>				
Pench (MS)	0.25	1.15	35	0
<b>Total</b>	<b>0.25</b>	<b>1.15</b>		
<b>Koyna</b>				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.26	44.96	570	35
Stage 4	11.09	130.82	1004	0
Stage 3	2.72	38.51	320	0
<b>Total</b>	<b>17.08</b>	<b>214.28</b>		
<b>Hydro</b>				
KDPH	0.77	11.95	32	32
VTRNA	0.84	12.27	60	0
TILLARI	0.00	4.10	0	0
BHIRA T.R.	0.24	4.00	40	0
SMLHY_PTN	2.63	39.12	112	106
GHATGHAR	0.19	3.11	100	0
<b>Total</b>	<b>4.67</b>	<b>74.55</b>		
<b>Wind</b>				
Total	22.95	245.98	0	0
<b>Total</b>	<b>22.95</b>	<b>245.98</b>		
<b>CPP</b>				
APML(Mus)	66.48	974.91	0	0
JSWEL(Mus)	27.19	399.75	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.51	469.34	0	0
SWPGPL-Mus	11.84	184.17	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.19	90.68	269	182
Other(Mus)	6.13	98.76	0	0
JPL	6.16	90.22	289	222
<b>Total</b>	<b>155.49</b>	<b>2307.82</b>		
<b>SOLAR</b>				
Total	25.62	362.07	0	0
<b>Total</b>	<b>25.62</b>	<b>362.07</b>		
<b>Tata</b>				
Trombay 5	7.31	105.67	453	212
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.27	35.07	108	60
Trombay 7B	1.43	21.82	64	49
TATA Hydro	5.32	68.66	429	91
Trombay 8	3.64	54.51	224	125
<b>Total</b>	<b>19.97</b>	<b>285.74</b>		
<b>AEML</b>				
DTPS U-1&2	9.28	140.84	490	284
<b>Total</b>	<b>9.28</b>	<b>140.84</b>		

* Infirm Power		
Particulars	Daily (Mus)	Monthly

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	181.41	2495.32
MSPGCL Thml+Gas	190.32	2605.62
MSPGCL Hydro	21.74	288.83

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	212.07	2894.45
Koyna 1,2 & 4 Total	14.35	175.77
State Total	445.37	6236.90

**Hourly Load Data As on 15/Apr/2025**

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planne d	*Trans mission Constr aint					
1	8056	599	282	8937	1448	7095	0	0	9502	9779	-2013	24762	0	0	24762	3259	484	28505	50.01
2	8106	239	286	8631	1450	7073	0	0	9587	9548	-1801	24437	0	0	24437	3001	464	27902	49.97
3	7953	244	301	8498	1353	6998	0	0	9235	9342	-1632	24112	0	0	24112	2832	447	27391	49.96
4	7801	245	391	8437	1289	6889	0	0	8998	9419	-1472	24112	0	0	24112	2698	450	27260	50.00
5	8107	244	394	8745	1302	7074	0	0	8987	8899	-1331	24233	0	0	24233	2576	456	27265	50.02
6	8114	278	408	8800	997	7097	0	0	9608	9592	-1393	24639	0	0	24639	2589	454	27682	49.97
7	8109	441	413	8963	1069	7055	0	129	9542	9674	-1477	24930	0	0	24930	2640	483	28053	50.04
8	7875	685	411	8971	1006	6816	0	861	8457	8374	-1783	23709	0	0	23709	2798	536	27043	50.01
9	6989	632	396	8017	933	6002	0	1801	9145	8939	-2175	22952	0	0	22952	3146	565	26663	49.97
10	6730	441	387	7558	874	5794	0	2645	9686	9930	-2504	23730	0	0	23730	3489	567	27786	49.94
11	6636	625	383	7644	876	5545	0	3189	10621	10399	-2799	24266	0	3	24266	3739	588	28593	49.98
12	6585	590	384	7559	712	5263	0	3414	10984	10752	-2960	24155	0	5	24155	3859	585	28599	50.01
13	5858	509	377	6744	613	5239	0	3421	11053	11102	-2977	23560	0	3	23560	3868	582	28010	49.98
14	6078	553	373	7004	584	5288	0	3272	10985	11005	-2893	23650	0	6	23650	3791	610	28051	50.00
15	6786	936	376	8098	688	5505	0	2784	10948	10987	-2951	24510	0	10	24510	3880	601	28991	50.01
16	7585	1544	378	9507	657	6084	0	2107	10853	10261	-2897	25106	0	16	25106	3882	613	29601	50.01
17	7666	1744	385	9795	771	6073	0	1401	10671	10383	-2743	25080	0	70	25080	3863	600	29543	50.02
18	7760	1903	390	10053	811	6469	0	556	9961	9841	-2463	24671	0	38	24671	3701	596	28968	50.07
19	8094	1273	392	9759	759	6962	0	37	9050	9455	-2043	24309	0	1	24309	3523	620	28452	50.04
20	8145	1776	393	10314	806	7041	0	0	8898	9543	-1755	25354	0	0	25354	3495	595	29444	49.92
21	8120	1732	394	10246	906	7039	0	0	7911	8649	-1666	24601	0	0	24601	3381	573	28555	49.97
22	8106	1174	397	9677	1076	7023	0	0	7815	8669	-1647	24239	0	0	24239	3331	559	28129	50.02
23	8084	1397	354	9835	1016	7033	0	0	8112	9016	-1679	24679	0	0	24679	3332	542	28553	49.93
24	8064	1937	273	10274	956	7029	0	0	8430	9077	-1738	25069	0	0	25069	3367	529	28965	50.00
<b>MUs</b>	<b>181.41</b>	<b>21.74</b>	<b>8.92</b>	<b>212.07</b>	<b>22.95</b>	<b>155.49</b>	<b>0.00</b>	<b>25.62</b>	<b>229.04</b>	<b>232.63</b>	<b>-50.79</b>	<b>584.87</b>	<b>0.00</b>	<b>0.15</b>	<b>584.87</b>	<b>80.04</b>	<b>13.10</b>	<b>678.00</b>	<b>49.99</b>

**NOTE : ALL VALUES IN MW**

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

- 1) Due to 132kV BBLR to Rahuri line & 132kV Sonewadi to MIDC line overload.
- 2) Due to overloading of 400kV chakan-Talegaon line.

Maximum Demand scenario for the date 15/Apr/2025		
State Demand	MSEDC Non-Coincident Peak Demand	Mumbai Non-Coincident Peak Demand
29601 MW	25354 MW	3882 MW
16 Hrs	20 Hrs	16 Hrs
Includes LS - 0 MW	Includes LS - 0 MW	--

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 15/Apr/2025**

Position as on 6.30 Hrs of 16/Apr/2025

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date	
<b>FORCED OUTAGE</b>									
<b>MSPGCL</b>									
MSPGCL	Chandrapur Unit 9	500	11/01/2025	18:55		Continued.	Generator Protection operated	01/05/2025	
MSPGCL	Uran Unit 7	108	04/03/2025	14:15		Continued.	Turbine bearing vibration high	20/04/2025	
MSPGCL	Chandrapur Unit 3	210	07/04/2025	15:34		Continued.	Furnace Temperature High	17/04/2025	
MSPGCL	Uran Unit A0	120	15/04/2025	22:37	16/04/2025	00:46	Turbine Seal Steam Fault		
MSPGCL	Ghatghar Unit-2	125	16/04/2025	20:08		Continued.	Main PLC Fault		
<b>Total Capacity MSPGCL</b>		1063							
<b>CENT.SECTOR</b>									
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	30/06/2025	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2025	
<b>Total Capacity CENT.SECTOR</b>		320							
<b>Total Capacity FORCED OUTAGE</b>		1383							
<b>FORCED OUTAGE DUE TO NO PPA</b>									
<b>IPP</b>									
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)		
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)		
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)		
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)		
<b>Total Capacity IPP</b>		988							
<b>Total Capacity FORCED OUTAGE DUE TO NO PPA</b>		988							

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 15/Apr/2025**

**Statement-VII**

Position as on 6.30 Hrs of 16/Apr/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
<b>765 KV MAINBAY Outages/Trippings</b>							
MAIN BAY (711) OF BUS REATOR @ EKTUNI	IntraState	15/04/2025	17:38	15/04/2025	22:05	PO	Routine testing and Maintenance Works.
<b>400 KV MAINBAY Outages/Trippings</b>							
BUS COUPLER @ KOLHAPUR-III (TALANDGE)-400 KV	IntraState	15/04/2025	11:50	15/04/2025	18:48	PO	Quarterly Maintenance work
BUS COUPLER @ CHANDRAPUR	IntraState	15/04/2025	11:50	15/04/2025	16:27	PO	1. LBB Relay testing Work. 2. Diagnostic testing of Circuit Breaker. 3. Routine bay maintenance work.
<b>400 KV LR Outages/Trippings</b>							
50 MVAR LINE REACTOR OF 400KV KUMBHARGAON(NANDED) CKT 1 AT 400KV PARLI	IntraState	05/03/2025	20:45			HT	Due to Voltage constraint LR kept out at Parly ss.
<b>400 KV LINE Outages/Trippings</b>							
KORADI - BHILAI	InterState	15/04/2025	01:22	15/04/2025	02:49	T	D/PR-PH ,166 KM 2.2KA TRIPPED ONLY AT BHILAI END.
KORADI - BHILAI	InterState	15/04/2025	21:00	15/04/2025	21:49	T	Tripped at koradi end
KOLHAPUR - SOLAPUR (PG) CKT - 2	InterState	16/04/2025	13:07	16/04/2025	16:27	T	Tripped on distance protection.
CHAKAN - TALEGAON(PG)	InterState	16/04/2025	18:52			EO	For attending a hotspot at 89A B phase PG Isolator Hanger rod with Temp 160°C. (400kV Chakan-Talegaon (PGCIL) Line will be in service via 400kV TBC.)
220KV KORADI II (400KV)- BUTIBORI 3 CKT I	IntraState	01/10/2024	13:10			HT	H/T From Butibori 3 end
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	21/03/2025	00:53			HT	IN VIEW OF 400KV TALEGAON - CHAKAN LINE LOADING
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	09/04/2025	21:25			HT	load management
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	10/04/2025	13:39			EO	Need to carry out SF6 gas Refilling (Top-up) in the EMVT of 400kV NTPP-1 B-phase at Plant End (GIS).
KORADI-NANDGAONPETH (RPL)	IntraState	16/04/2025	09:29	16/04/2025	19:20	PO	WINDING & BUSHING OF REACTOR . CVT TAN-DELTA& ROUTINE MNTC WORK.
<b>400 KV ICT Outages/Trippings</b>							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
105 MVA SPARE ICT @ CHAKAN	IntraState	26/02/2025	10:59			PO	Long Duration outage required for Rapid restoration scheme work of ICT at 400kV Chakan s/sn
400/220/33KV SPARE ICT @ KORADI 2	IntraState	15/04/2025	12:04	15/04/2025	16:56	PO	Maintenance of isolators connected to main bus 2
400/220 KV SPARE 167 MVA ICT @ ALKUD	IntraState	15/04/2025	16:35	15/04/2025	20:27	PO	Pre-Monsoon Maintenance Work
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	16/04/2025	11:49	16/04/2025	17:54	PO	Diagnostic Testing of ICT,CT & CB
<b>220 KV TIEBAY Outages/Trippings</b>							
BUS COUPLER @ PHURSUNGI	IntraState	07/04/2025	06:57			HT	Hand Tripped.
<b>220 KV MAINBAY Outages/Trippings</b>							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 15/Apr/2025**

**Statement-VII**

Position as on 6.30 Hrs of 16/Apr/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS @ SAWANTWADI	IntraState	15/04/2025	09:16	15/04/2025	18:30	PO	Annual Maintenance of 220kV Bus strings, All Bus isolators, Bus Jumper replacement, 220 kV PT bays maintenance/ testing.
220 KV TBC	IntraState	15/04/2025	12:10			HT	Replacement of 220kv abo make pneumatic cb with new col make cb under le scheme.
<b>220 KV LINE Outages/Trippings</b>							
PRINT HOUSE - NAVI MUMBAI (PG)	InterState	05/12/2024	23:09			EO	1) For bunching at TL no 678/1 with 220kV Kalwa-Panchanand line to provide 2nd source to Panchanand & Taloja s/stn. 2)For opening jumpers at TL no 678/1.
WAGHIVALI (MSETCL) - ULWE GIS CKT - 2	IntraState	25/06/2024	08:05			T	Tripped on differential protection.
220KV KORADI II(400KV) - BUTIBORI 3 CKT II	IntraState	01/10/2024	13:11			HT	H/T From Koradi 2 end
KALWA - PANCHANAND	IntraState	17/10/2024	12:10			EO	For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Taloja.
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA ) End only For load management on 220kV Ulwe - Waghivali ckt -1
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1	IntraState	30/12/2024	10:44			HT	Hand tripped only at Waghivali (TATA ) End only For load management on 220kV Ulwe - Waghivali ckt -1
SAKI (AEML) - SAKI (TATA) CKT - 2	IntraState	21/01/2025	15:26			HT	Fire Caught near Marve Bridge
HINJAWADI I- CHINCHWAD	IntraState	14/04/2025	06:52	15/04/2025	00:12	HT	H/T for load management.
WARORA - WARDHA	IntraState	15/04/2025	07:10	15/04/2025	12:15	HT	1) diagnostic testing of complete bay equipment. 2) bay routine maintenance work 3) work of 5 replacement of r-ph broken disc insulator string at loc no. 313, 316 & y phat loc no 343 by l.m. s/dn. warora.
PARAS-BALAPUR I	IntraState	15/04/2025	08:18	15/04/2025	09:47	HT	Nut bolt tightening at loc no. 11 ryb.
TALANDGE - SAWANTWADI	IntraState	15/04/2025	09:00	15/04/2025	19:08	PO	Annual Maintenance of 220kV Bus strings, All Bus isolators, Bus Jumper replacement, 220 kV PT bays maintenance/ testing.
BIDRI - SAWANTWADI	IntraState	15/04/2025	09:16	15/04/2025	18:30	PO	Annual Maintenance of 220kV Bus strings, All Bus isolators, Bus Jumper replacement, 220 kV PT bays maintenance/ testing.
NANDGAON PETH-AMRAVATI	IntraState	15/04/2025	10:04	15/04/2025	13:42	HT	Replacement of faulty disc at tension location no. t2 r ph & yph stn found in 42 pid and inspection of b-ph conductor between lilo tower loc no. 63 & 64.
AMBAZARI-ABHIJEET	IntraState	15/04/2025	10:29	15/04/2025	14:40	HT	Yearly diagnostic testing work at amb ss.
YEOTMAL- PUSAD	IntraState	15/04/2025	12:14	15/04/2025	17:21	HT	OPGW cable tightening between span 180-181 under org work for the work of diversion of 220kv de oli pusad line for wardha yavatmal nanded railway line crossing.

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 15/Apr/2025**

**Statement-VII**

Position as on 6.30 Hrs of 16/Apr/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WARORA-BHUGAON CKT - 2	IntraState	15/04/2025	12:34	15/04/2025	17:05	HT	P&f of pilot string at loc no. 246 and 244 on ryb phases nut bolt tightening and routine maintenance by agency mis m.m. electricals.
TALANDAGE - CHIKODI	IntraState	15/04/2025	15:02	15/04/2025	19:15	T	Tripped on distance protection.
BUTIBORI 3 - WARDHA	IntraState	15/04/2025	17:35	15/04/2025	20:18	HT	Attending hot spot on LOC No. 252 RPH and BPH.
PALGHAR - NALASOPARA	IntraState	15/04/2025	23:51	16/04/2025	08:10	PO	For Replacement of existing 0.4 ACSR by HPC (High Performance Conductor).
PALGHAR - PANCHALI TSS	IntraState	16/04/2025	00:29	16/04/2025	08:09	PO	For Replacement of existing 0.4 ACSR by HPC(High Performance Conductor).
PAL DOMBIVALI - PALAVA	IntraState	16/04/2025	02:02	16/04/2025	02:37	T	Tripped due to 220 kV Busbar operation
PADGHE - PAL DOMBIVALI	IntraState	16/04/2025	02:02	16/04/2025	02:37	T	220 kV Busbar protection operated
BADNERA - NANDGAON PETH	IntraState	16/04/2025	09:31	16/04/2025	11:46	HT	Replacement of discs at tension location no. 52 y ph, 70a b ph, (lilo loc no. 27 b ph, 46 r & b ph) and earth wire straightening work at lilo loc. no. 62 to 66.
BHIGWAN-BARAMATI AGRO	IntraState	16/04/2025	10:54	16/04/2025	13:00	T	SPS operated
BUS SECTION @ KOLSHET	IntraState	16/04/2025	11:36			PO	BREKEAR OVER HAULING WORK
PANDHARPUR - MALINAGAR	IntraState	16/04/2025	13:10	16/04/2025	15:04	PO	Outage is required for Conversion of SSN to DSN for NTPC line crossings at various locations (26, 27, 68)
132KV BEED(220KV BEED)-GEORAI CKT 1	IntraState	16/04/2025	13:40	16/04/2025	15:40	T	W/I:-220KV BEED-DIST OPTD A/R LOCK OUT,Z1,DIST-13.14KM, CURRENT LL3080AMP IL33762AMP YPH,BPH. W/I:-GEORAI-YPH,BPH. .3128AMP.3164AMP. DIST 17.20.
132KV BEED (220KB BEED)-GEORAI CKT 2	IntraState	16/04/2025	13:40	16/04/2025	15:40	T	W/1:-220KV BEED:-DIST OPTD A/R LOCK OUT.Z1.DIST-13.14KM, CURRENT=ILY 3.08KA ILB 3.3KA, YPH,BPH GEORAI-YPH BPH ILY 3.12 KA,3.16 KA, DIST-17.20KM.
LAMBOTI - KARKAMB	IntraState	16/04/2025	14:21	16/04/2025	15:06	T	Tripped on distance protection.
TALANDGE - BIDRI	IntraState	16/04/2025	17:05	16/04/2025	19:45	EO	Hot-spot observed at R-phase, CT to stub bus jump
SATANA - GANGAPUR	IntraState	16/04/2025	17:41			HT	Replacement of damaged jumps.
SATANA - GANGAPUR	IntraState	16/04/2025	17:41			PO	For replacement of damaged jumps
<b>220 KV ICT Outages/Trippings</b>							
220/132 KV 80 MVA ICT 1 @ HINGANGHAT	IntraState	19/02/2025	12:45			HT	H/T Due to end of expected life of paper insulation of ICT
220/110 KV 200 MVA ICT - 1 @ ICHALKARANJI - II	IntraState	11/04/2025	09:30	15/04/2025	16:41	PO	1) Quarterly bay maintenance work 2) Bay Diagnostic testing work
220/33 KV 50 MVA PTR 1 @ KHARGHAR	IntraState	14/04/2025	09:58	15/04/2025	21:04	PO	For Replacement of 220kV Circuit Breaker
220/100 KV 200 MVA ICT 3 @ APTA	IntraState	15/04/2025	06:32	15/04/2025	11:14	PO	1. Diagnostic testing work 2. Bay maintenance work
220/132 KV 100 MVA ICT @ NANDGAONPETH	IntraState	15/04/2025	08:34	15/04/2025	16:40	HT	Installation of 89c isolator of hw bay of 100mva ict and premonsoon maintenance work, diagnostic testing.



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 15/Apr/2025**

**Statement-VII**

Position as on 6.30 Hrs of 16/Apr/2025

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33 KV 50 MVA PTR 1 @ KADEGAON	IntraState	15/04/2025	09:45	15/04/2025	15:12	PO	1.PT isolator's damaged insulator replacement work 2.33kV Bus section -1 Annual maintenance work 3. Relay testing work
220/33 KV 50MVA T/F - 2 @ MIRAJ	IntraState	15/04/2025	10:10	15/04/2025	15:05	PO	Nut Bolt replacement work at earthing pit & TF body earthing work
220/33KV 100MVA TF No.2 @ BOTHE	IntraState	15/04/2025	11:29	15/04/2025	15:03	PO	LV CT Oil leakage attending work
220/33 KV 50 MVA BBL PTR 2 @ MUDSHINGI	IntraState	15/04/2025	17:55	16/04/2025	01:14	T	Tripped due to LV Yph. CT burst.
220/100 KV 200 MVA ICT 1 @ PAL-DOMBIVALI	IntraState	16/04/2025	02:02	16/04/2025	02:37	T	Tripped due to 220 kV Busbar operation
220/100 KV 200 MVA ICT 2 @ PAL-DOMBIVALI	IntraState	16/04/2025	02:02	16/04/2025	02:37	T	Tripped on 220 kV Busbar operation
220/132 KV 100 MVA ICT 1 @ PUSAD	IntraState	16/04/2025	09:22	16/04/2025	18:26	HT	Diagnostic testing and premonsoon maintenance work.
220/100 KV 125 MVA ICT 2 @ JAMBHUL	IntraState	16/04/2025	10:36	16/04/2025	18:13		OLTC Overhauling work by M/s Trafocare. Diagnosing testing work & Bay R&M work.
220/132KV 200MVA ICT 2 @ JEUR	IntraState	16/04/2025	10:50	16/04/2025	13:15	PO	Outage is required for Quarterly Maintenance
220/33KV 100MVA PTR 1 @ GHATNANDRE	IntraState	16/04/2025	11:07	16/04/2025	18:15	PO	1. Diagnostic Testing Work 2. Quarterly Maintenance Work
<b>132 KV LINE Outages/Trippings</b>							
CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP	IntraState	16/10/2024	07:02			HT	For Load Management
132 KV PATHRI-MAJALGAON CKT	IntraState	06/01/2025	13:05			HT	After completion of outage on 132kv patri parbhani ckt
132 KV BADNAPUR - HYOSUNG (STERLIGHT) CKT	IntraState	14/02/2025	17:01		Continued.	T	B - R PH, Z2, 2.56 KA, 26 KM. H - R PH, 3 KA, 700 MTR.
132 KV UJANI - BASSK	IntraState	18/03/2025	13:10			T	Distance protection.
PARANDA - BHOOM	IntraState	15/04/2025	13:17	15/04/2025	15:13	HT	CB tripped at Boom end on distance protection.
NANDURBAR - RAILWAY TSS	IntraState	15/04/2025	15:20	15/04/2025	18:25	HT	Attending hot pot at LOC 3 R PH.
MALKAPUR - KHAMGAON	IntraState	16/04/2025	13:48	16/04/2025	14:22	T	MALKAPUR: W/I B PH 21,86 OPTD.CARRIER RECEIVED, A/R LOCK 2OUT, DIST-21.9KAMP BPH CURRENT,-3.9KAMP. KHAMGAON:- W/I- BPH DIST-32.8KM,IL:1.11KAMP.
<b>132 KV ICT Outages/Trippings</b>							
132/33 KV 50 MVA PTR 2 @ DONDAICHA	IntraState	15/11/2024	11:40			T	Tripped on Buchholz alarm

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage