

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 15/Jun/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	164.382	2339.022	1) Gujrat	1.029	-31.276
2) Hydro	8.616	226.990	2) Madhya Pradesh	3.307	81.381
3) Gas	4.666	73.251	3) Chattisgarh	3.260	45.420
Total MSPGCL	177.664	2639.263	4) Maharashtra	199.335	3184.235
B) 1) APML	67.180	993.154	5) Goa (Amona)	-1.408	-21.124
2) JSWEL	24.078	360.719	Total	205.523	3258.636
3) VIPL	0.000	0.000	a) Mumbai Schedule	43.589	652.203
4) RPL(AMT)	25.580	446.404	b) Mumbai Drawl	47.353	717.977
5) SWPGPL	10.700	156.708	c) MSEDCL Bilateral *	122.978	1694.160
6) Other IPP	7.263	73.003	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	43.589	652.016
C) 1) TPCL Thermal	13.552	191.072	Include PX	0.000	0.000
2) TPCL Hydro	6.401	82.606	Standby	0.000	0.187
3) TPCL Gas	0.000	25.895	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.410	136.975	1) MSEDCL	525.271	7808.023
D) STATE			2) Mumbai Discoms	77.716	1154.525
1) Thermal	323.145	4697.057	3) Other Discoms	10.849	160.295
(A1+C1+C4+(B1-B6))			TOTAL STATE	613.836	9122.843
2) Hydro	15.017	309.596			
(A2+C2)					
3) Gas	4.666	99.146			
(A3+B7+C3)					
4) Wind	48.499	515.908			
6) SOLAR	16.986	242.500			
TOTAL STATE	408.313	5864.207			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6672	6844	7267	6823
MSPGCL Hydro	166	152	696	214
MSPGCL Gas	187	179	194	206
MSPGCL Total Generation	7024	7174	8156	7242
Central Sector Receipt	9339	9206	7337	8648
WIND	2340	2463	1925	1748
CPP / IPP Thermal	4336	5211	6323	5936
CPP / IPP Gas	0	0	0	0
SOLAR	2180	1474	0	0
Exchange with Mumbai	-2605	-2394	-1618	-1695
MSEDCL DEMAND MET	22133	22631	21639	21546
Load Shedding	0	0	557	0
MSEDCL DEMAND	22133	22631	22196	21546
TPCL GENERATION	636	897	1136	627
AEML GENERATION	465	501	502	292
MUMBAI DEMAND	3706	3792	3256	2614
OTHER DISCOM DEMAND	481	504	484	334
STATE DEMAND MET	26320	26926	25379	24493
STATE DEMAND	26320	26926	25936	24493
Frequency (Hz)	49.96	49.97	49.96	49.94

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.31 Hz at 18.04 Hrs	49.6 Hz at 22.45 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 15/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.62	69.72	195	185
Unit 8	14.32	130.92	612	562
Unit 9	13.92	116.65	603	546
Unit 10	12.68	193.76	540	515
Total	45.53	511.04		
Bhusawal				
Unit 3	1.10	30.07	140	0
Unit 4	9.92	148.98	465	355
Unit 5	10.78	161.08	490	390
Total	21.80	340.13		
Parli				
Unit 6	3.78	69.14	243	112
Unit 7	4.78	70.67	242	144
Unit 8	3.58	61.16	156	141
Total	12.14	200.97		
Chandrapur				
Unit 3	3.17	43.01	150	110
Unit 4	3.21	43.08	155	120
Unit 5	0.00	0.00	0	0
Unit 6	9.08	113.69	405	310
Unit 7	8.64	134.86	406	289
Unit 8	10.76	161.57	480	314
Unit 9	10.98	166.51	486	334
Total	45.83	662.72		
Paras				
Unit 3	5.13	75.19	235	173
Unit 4	1.89	56.67	216	0
Total	7.02	131.86		
Khaparkheda				
Unit 1	2.76	43.50	130	85
Unit 2	2.59	43.67	128	73
Unit 3	3.77	50.83	181	120
Unit 4	3.63	60.45	174	108
Unit 5	11.33	163.76	475	470
Total	24.08	362.20		
Nasik				
Unit 3	0.00	10.09	0	0
Unit 4	4.05	60.64	177	124
Unit 5	3.92	59.36	170	135
Total	7.97	130.09		
Uran				
All Units	4.67	73.25	218	175
Total	4.67	73.25		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.10	1.33	20	0
Total	0.10	1.33		
Koyna				
Stage 1-2	3.64	56.27	465	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	81.22	0	0
Stage 3	0.63	31.51	240	0
Total	4.27	169.00		
Hydro				
KDPH	0.20	4.84	9	9
VTRNA	1.15	16.85	60	0
TILLARI	0.00	1.04	0	0
BHIRA T.R.	0.28	5.11	77	0
SMLHY_PTN	2.44	28.08	109	95
GHATGHAR	0.18	0.74	125	0
Total	4.25	56.66		
Wind				
Total	48.50	515.91	0	0
Total	48.50	515.91		
CPP				
APML(Mus)	67.18	993.15	0	0
JSWEL(Mus)	24.08	360.72	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.58	446.40	0	0
SWPGPL-Mus	10.70	156.71	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.22	39.36	271	153
Other(Mus)	2.04	33.65	0	0
Total	134.80	2029.99		
SOLAR				
Total	16.99	242.50	0	0
Total	16.99	242.50		
Tata				
Trombay 5	8.88	125.15	460	272
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	14.05	0	0
Trombay 7B	0.00	11.84	0	0
TATA Hydro	6.40	82.61	446	76
Trombay 8	4.67	65.92	236	135
Total	19.95	299.57		
AEML				
DTPS U-1&2	10.41	136.98	502	292
Total	10.41	136.98		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	164.38	2339.02	MSPGCL Total	177.66	2639.26
			MSPGCL Thml+Gas	169.05	2412.27	Koyna 1,2 & 4 Total	3.64	137.49
			MSPGCL Hydro	8.62	226.99	State Total	408.31	5864.21

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 15/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6947	576	202	7724	1877	6319	0	0	8164	8332	-1647	22199	0	0	22199	3241	406	25846	50.00
2	6978	262	203	7444	1926	6325	0	0	8395	8476	-1504	22288	0	0	22288	3008	378	25674	50.01
3	6804	212	203	7220	1811	5963	0	0	8748	8755	-1643	21747	0	0	21747	2767	359	24872	49.97
4	6823	214	206	7242	1748	5936	0	0	8604	8648	-1695	21546	0	0	21546	2614	334	24493	49.94
5	6777	308	209	7294	1653	6145	0	0	8274	8638	-1549	21817	0	0	21817	2573	364	24754	49.98
6	6738	240	212	7190	1442	6090	0	3	9376	9404	-1545	22179	0	0	22179	2597	405	25181	49.99
7	6677	428	218	7324	1520	5865	0	165	8891	9400	-1712	22132	0	0	22132	2598	429	25159	49.99
8	6728	562	208	7498	1758	5883	0	605	8189	8474	-1851	21902	0	0	21902	2733	465	25100	50.07
9	6234	336	206	6776	2355	5255	0	1195	9355	8930	-2196	21814	0	0	21814	3035	501	25350	50.08
10	5922	250	190	6362	2554	4407	0	1666	9541	9618	-2348	21749	0	0	21749	3372	510	25631	49.95
11	6663	206	181	7050	2522	4374	0	1996	9092	9162	-2570	22031	0	0	22031	3620	503	26154	50.03
12	6672	166	187	7024	2340	4336	0	2180	9195	9339	-2605	22133	0	0	22133	3706	481	26320	49.96
13	6558	146	177	6882	2275	4310	0	2198	9239	9209	-2436	21968	0	0	21968	3689	469	26126	49.96
14	6425	148	175	6748	2299	4351	0	2153	9413	9107	-2384	21819	0	2	21819	3613	456	25887	49.99
15	6735	156	183	7074	2299	4461	0	1853	9502	9609	-2392	22443	0	5	22443	3714	461	26617	49.84
16	6844	152	179	7174	2463	5211	0	1474	9046	9206	-2394	22631	0	4	22631	3792	504	26926	49.97
17	7040	202	179	7420	2456	5764	0	1003	8789	8574	-2321	22385	0	4	22385	3726	512	26623	50.02
18	7155	260	187	7602	2324	6046	0	432	7891	7976	-2192	21697	0	4	21697	3568	490	25755	50.02
19	7243	304	185	7732	2097	6135	0	63	7650	7583	-1998	21125	0	0	21125	3379	487	24992	50.09
20	7270	538	187	7996	1967	6316	0	0	7635	7939	-1813	21917	62	0	21979	3314	488	25780	49.90
21	7267	696	194	8156	1925	6323	0	0	7030	7337	-1618	21639	557	0	22196	3256	484	25936	49.96
22	7283	670	196	8150	1827	6326	0	0	6989	7185	-1591	21421	486	0	21907	3210	476	25592	49.90
23	7303	738	198	8238	1525	6326	0	0	7007	7597	-1633	21600	918	0	22518	3256	454	26228	49.72
24	7296	848	201	8344	1536	6336	0	0	7073	7025	-1716	21090	1886	0	22976	3335	436	26747	49.81
MUs	164.38	8.62	4.67	177.66	48.50	134.80	0.00	16.99	203.09	205.52	-47.35	525.27	3.91	0.02	529.18	77.72	10.85	617.75	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR due to 132kv BBLR To Rahuri line over loading

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 15/Jun/2023

Position as on 6.30 Hrs of 16/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Nasik Unit 3	210	08/06/2023	11:40		Continued.	Tolling Agreement with IEPL synchronised at 9:19 Hrs	
MSPGCL	Paras Unit 4	250	11/06/2023	13:46	15/06/2023	13:17	Boiler Tube Leakage	14/06/2023
MSPGCL	Bhusawal Unit 3	210	13/06/2023	03:15	15/06/2023	14:50	ID Fan Problem	15/06/2023
TPC-G	Trombay 7B	60	13/06/2023	23:10		Continued.	Gas shortage	16/06/2023
TPC-G	Trombay 7A	120	13/06/2023	23:24		Continued.	Gas shortage	16/06/2023
IPP	RPL(AMT) U-5	270	16/06/2023	06:45		Continued.	Ash Conveyer problem	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 15/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 16/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
MAIN BAY (402) OF KHADKA CKT - 2 @ DEEPNAGAR	IntraState	25/05/2023	10:02		Continued.	PO	For servicing & overhauling of 400kv AREVA make KDK CKT-2 Main C.B. Mechanism
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
LONIKAND I - TALEGAON (PGCIL)	InterState	12/06/2023	09:54			PO	400kv CB O/H work by shifting on TBC and 29-A PG Isolator mechanimc box replacement and trials
DHULE - KHANDWA CKT - 1	InterState	13/06/2023	09:08			PO	MTAMC Project work Main-I Dist Protn, REF & Master trip relay Gr-A & B replacement work
KHADKA- DEEPNAGAR CKT 2	IntraState	25/05/2023	10:02				Servicing &overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.
TBC 2 @ CHANDRAPUR	IntraState	12/06/2023	08:48			PO	Replacement of problematic old BHEL make 400kv quad break CB of TBC-2 bay with new siemens ltd make 400kv Quad CB.
PARLI - KUMBHARGAON(NANDED) CKT - 2	IntraState	14/06/2023	12:17	15/06/2023	03:24	PO	(1) Distance relay testing work. (2) Bay maintenance work. (3) Hardware tightning and fitting work.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	14/06/2023	12:55			HT	TO CONTROL LINE LOADING
PADGHE - NAGOTHANE CKT - 1	IntraState	15/06/2023	11:17			PO	1. Stringing of 6 Nos of spans between location nos 310-313. 2. Disnmantling of 2 nos of Lattice towers
PADGHE - PADGHE HVDC CKT- 1	IntraState	15/06/2023	17:00	15/06/2023	17:09	T	400kv HVDC-1 CB tripped at 400kv Padghe Strn only on 17.00Hrs on PDR
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	IntraState	15/06/2023	08:23	15/06/2023	22:50	PO	1. Measurement of tandelta of CT, bushing & winding. 2. Premonsoon maintenance work. 3. Bay routine maintenance work.
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
PUSAD - WARDHA (PG)	IntraState	13/06/2023	12:24	16/06/2023	00:40	EO	Urgent CB mechanism overhauling-- 1. Low SF6 Pressure alarm 2. Change Aux. Contact of CB

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 16/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY CARNAC - 5	IntraState	14/06/2023	23:56	15/06/2023	02:11	PO	For Attending Hotspot of C Phase Dead end
AAREY - AEML SAKI CKT - 2	IntraState	15/06/2023	09:03			PO	Attending the cable damage of R phase and B phase.
NEW KOYNA - PEDAMBE	IntraState	15/06/2023	09:15	15/06/2023	12:00	PO	for attending unwound strands of Bph conductor jumper between brk to LS isolator
KHADKI- CENTURY ENKA	IntraState	15/06/2023	10:20	15/06/2023	13:34	PO	For attending CB ready signal in Distance relay is frequency getting low & high. Due to this problem in future chances of AR failure and Half yearly maintenance.
NANDED CITY-FLAGSHIP	IntraState	15/06/2023	11:44	15/06/2023	18:14	PO	Half yearly maint. & Testing work
RANJANGAON-LONIKAND	IntraState	15/06/2023	11:50			PO	220kV Circuit breaker overhauling work.
NANDED 2 (WAGHALA) - PARBHANI	IntraState	15/06/2023	13:57	15/06/2023	17:25	HT	For replacement of faulty abb make rel 670 distn proten relay with repaired abb make relay.
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	IntraState	15/06/2023	14:30	15/06/2023	17:06	EO	Distance Relay Testing work and Attending flashover at loc no 37 R ph
KARAD - VITA CKT- 1	IntraState	15/06/2023	14:47	15/06/2023	19:01	EO	Hotspot attending work at Y ph 29D isolator palm towards CB Side.
ALKUD - VITA	IntraState	15/06/2023	15:26	15/06/2023	20:58	PO	Jump Replacement work at Loc No.84 Y Ph
BHUGAON - WARDHA (PG)	IntraState	15/06/2023	22:32	15/06/2023	23:43	HT	H/T For OD Control
WARDHA - WARDHA (PG)	IntraState	15/06/2023	22:36	16/06/2023	00:15	HT	H/T For OD control
AURANGABAD (WALUJ)-BHENDA	IntraState	16/06/2023	09:13	16/06/2023	10:05	PO	For attending hotspot of R ϕ pole CB Top Plate.
KARAD - KADEGAON	IntraState	16/06/2023	09:24			PO	Painting of MS rusted 220 kV Ganty Beam by applying Elastomeric Thermoplastic Graft co-Polymer Anticorrosive treatment to avoid corrosion to MS Gantry Beam
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/100 KV 200 MVA ICT 1 @ PADGHE	IntraState	14/06/2023	16:23	15/06/2023	19:25	HT	200MVA 220/100kV ICT-1, frequent starting problem of differential relay RET670.
220 / 11 KV 200 MVA GT @ BHIRA (T)	IntraState	15/06/2023	06:09	15/06/2023	10:35	PO	Pre-monsoon Checks and attending Oil leakage in Radiator Bank
220/33 KV 50 MVA TF I	IntraState	15/06/2023	07:12	15/06/2023	10:58	HT	For diagnostic testing & premonsoon maintenance work.
220/132 KV 100 MVA ICT 2 @ LONIKAND 2	IntraState	15/06/2023	08:33	15/06/2023	10:58	PO	Attending oil leakages of LV Y ph bushing
220/132 KV 200 MVA ICT 2	IntraState	15/06/2023	09:27	15/06/2023	16:26	HT	For routine diagnostic testing of ict and bay maintenance work.
220/33 KV 50 MVA PTR 3	IntraState	15/06/2023	10:27			HT	Diagnostic testing(tan delta & cap measurement) and premonsoon maintenance work.
220/132 KV 100MVA ICT 2 @ BARAMATI	IntraState	15/06/2023	10:30	15/06/2023	14:14	PO	Preventive maintenance of NIFPS.
220/22 KV 50 MVA PTR 1 @ CHAKAN	IntraState	15/06/2023	10:37	15/06/2023	18:23	EO	For attending oil leakages at HV Bushing turrets and Transformer body.
100 MVA 220/132 KV ICT - I @ JALKOT	IntraState	15/06/2023	1115			HT	LV back up prot optd.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 16/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22 KV 50 MVA PTR 2 @ ANANDNAGAR	IntraState	16/06/2023	08:28			PO	For premonsoon maintenance work
220/22-22 KV 50 MVA PTR 3 @ ANANDNAGAR	IntraState	16/06/2023	08:35	16/06/2023	09:27	PO	For premonsoon maintenance work
220/132 KV 200 MVA ICT 1 @ MALEGAON	IntraState	16/06/2023	08:50			PO	For premonsoon maintenance work
220/22KV 50MVA PTR - 1 @ PALAVA	IntraState	16/06/2023	09:20			PO	Pre-monsoon maintenance work and neutral earth pit resistance measurement work.
220 KV BUSBAR Outages/Trippings							
220KV PT-2 of BUS-1@ MULUND	IntraState	16/06/2023	08:44			PO	IR verification
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALWA KALYAN	IntraState	14/06/2023	20:56	15/06/2023	06:28	PO	Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)
KALWA KALYAN	IntraState	15/06/2023	21:08	16/06/2023	06:24	PO	Project work for Tower foundation work under vicinity of line at loc. 156A (Bullet Train Project)

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage