

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 15/Jun/2024 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	142.736	2311.493	1) Gujrat	-4.115	5.836
2) Hydro	9.699	134.702	2) Madhya Pradesh	-0.515	16.873
3) Gas	5.643	101.261	3) Chattisgarh	1.730	32.300
Total MSPGCL	158.078	2547.456	4) Maharashtra	181.117	2901.509
B) 1) APLM	46.464	829.314	5) Goa (Amona)	-1.647	-30.428
2) JSWEL	21.492	377.098	Total	176.570	2926.090
3) VIPL	0.000	0.000	a) Mumbai Schedule	40.666	662.703
4) RPL(AMT)	31.570	449.200	b) Mumbai Drawl	44.603	700.751
5) SWPGPL	12.319	182.504	c) MSEDCL Bilateral *	78.989	1277.233
6) Other IPP	13.795	223.730	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	40.666	662.651
C) 1) TPCL Thermal	13.591	193.034	Include PX	0.000	0.000
2) TPCL Hydro	5.677	84.200	Standby	0.000	0.053
3) TPCL Gas	3.490	60.843	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.482	135.199	1) MSEDCL	448.659	7201.214
D) STATE			2) Mumbai Discoms	72.843	1174.024
1) Thermal	287.449	4701.572	3) Other Discoms	11.624	174.807
(A1+C1+C4+(B1-B6))			TOTAL STATE	533.126	8550.045
2) Hydro (A2+C2)	15.376	218.902			
3) Gas (A3+B7+C3)	9.133	162.104			
4) Wind	27.045	313.718			
6) SOLAR	17.553	227.662			
TOTAL STATE	356.556	5623.958			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4811	6429	6380	6117
MSPGCL Hydro	250	256	1297	164
MSPGCL Gas	278	108	272	289
MSPGCL Total Generation	5339	6793	7949	6570
Central Sector Receipt	8355	7697	7169	6772
WIND	867	1062	1102	1352
CPP / IPP Thermal	4441	5211	6225	4864
CPP / IPP Gas	0	0	0	0
SOLAR	2240	922	0	0
Exchange with Mumbai	-2345	-2034	-1730	-1556
MSEDCL DEMAND MET	18374	19124	20214	17629
Load Shedding	0	0	0	0
MSEDCL DEMAND	18374	19124	20214	17629
TPCL GENERATION	851	1109	1204	757
AEML GENERATION	221	252	247	246
MUMBAI DEMAND	3417	3395	3181	2559
OTHER DISCOM DEMAND	523	527	501	373
STATE DEMAND MET	22314	23046	23896	20561
STATE DEMAND	22314	23046	23896	20561
Frequency (Hz)	49.97	50.03	50.01	49.95

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.13 Hz at 09.01 Hrs	49.71 Hz at 14.27 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 15/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.09	61.58	190	131
Unit 8	13.78	204.36	612	403
Unit 9	13.29	175.19	609	384
Unit 10	12.30	190.64	550	410
Total	43.47	631.78		
Bhusawal				
Unit 3	0.00	20.50	0	0
Unit 4	8.94	151.03	480	213
Unit 5	9.71	140.88	460	290
Total	18.65	312.41		
Parli				
Unit 6	0.00	34.93	0	0
Unit 7	0.00	26.47	0	0
Unit 8	0.00	38.18	0	0
Total	0.00	99.58		
Chandrapur				
Unit 3	2.83	52.57	160	0
Unit 4	3.51	54.06	165	126
Unit 5	8.70	99.04	440	275
Unit 6	7.93	81.27	410	275
Unit 7	9.26	134.04	479	289
Unit 8	0.00	132.34	0	0
Unit 9	9.79	128.43	492	284
Total	42.02	681.75		
Paras				
Unit 3	4.84	68.68	233	149
Unit 4	0.00	7.43	0	0
Total	4.84	76.11		
Khaparkheda				
Unit 1	3.34	52.69	165	115
Unit 2	3.98	61.39	193	112
Unit 3	3.74	47.64	173	129
Unit 4	4.18	62.87	190	122
Unit 5	11.14	164.46	480	335
Total	26.39	389.05		
Nasik				
Unit 3	3.70	51.44	174	122
Unit 4	0.00	19.19	0	0
Unit 5	3.67	50.20	166	124
Total	7.36	120.83		
Uran				
All Units	5.64	101.26	293	108
Total	5.64	101.26		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	1.42	0	0
Total	0.00	1.42		
Koyna				
Stage 1-2	3.47	43.43	390	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.53	31.08	590	0
Stage 3	1.36	18.47	160	0
Total	6.35	92.98		
Hydro				
KDPH	0.00	2.96	0	0
VTRNA	0.76	10.24	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.18	0.18	40	0
SMLHY_PTN	1.66	25.10	73	61
GHATGHAR	0.75	3.24	125	0
Total	3.35	41.72		
Wind				
Total	27.04	313.72	0	0
Total	27.04	313.72		
CPP				
APML(Mus)	46.46	829.31	0	0
JSWEL(Mus)	21.49	377.10	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.57	449.20	0	0
SWPGPL-Mus	12.32	182.50	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.84	86.22	267	162
Other(Mus)	1.93	61.85	0	0
JPL	6.03	75.66	271	234
Total	125.64	2061.85		
SOLAR				
Total	17.55	227.66	0	0
Total	17.55	227.66		
Tata				
Trombay 5	8.94	128.24	453	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.14	38.10	108	37
Trombay 7B	1.35	22.75	64	35
TATA Hydro	5.68	84.20	380	60
Trombay 8	4.65	64.79	228	132
Total	22.76	338.08		
AEML				
DTPS U-1&2	5.48	135.20	252	153
Total	5.48	135.20		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	142.74	2311.49	MSPGCL Total	158.08	2547.46
			MSPGCL Thml+Gas	148.38	2412.75	Koyna 1,2 & 4 Total	5.00	74.51
			MSPGCL Hydro	9.70	134.70	State Total	356.56	5623.96

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 15/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6551	391	293	7235	721	6003	0	0	6794	6531	-1637	18404	0	0	18404	3062	449	21915	50.00
2	6637	160	293	7090	897	6078	0	0	6695	6053	-1473	18225	0	0	18225	2868	420	21513	50.02
3	6377	165	291	6833	1117	5458	0	0	6946	6265	-1447	17840	0	0	17840	2693	386	20919	50.01
4	6117	164	289	6570	1352	4864	0	0	7161	6772	-1556	17629	0	0	17629	2559	373	20561	49.95
5	6045	238	291	6574	1477	4673	0	0	7022	7127	-1465	18007	0	0	18007	2496	379	20882	49.92
6	6475	452	293	7220	1477	4919	0	2	7036	6895	-1478	18614	0	0	18614	2524	421	21559	49.91
7	6515	277	292	7084	1258	5541	0	163	7093	6771	-1469	18889	0	0	18889	2517	459	21865	49.98
8	6201	118	290	6609	1379	4881	0	733	7546	7015	-1669	18443	0	0	18443	2550	505	21498	49.97
9	5545	113	287	5945	1477	4489	0	1439	7594	6986	-1939	17890	0	0	17890	2756	507	21153	50.01
10	4730	258	287	5275	1339	4360	0	1985	7882	7850	-2150	18151	0	0	18151	3040	508	21699	50.01
11	4713	350	286	5349	1149	4420	0	2136	7981	8070	-2410	18199	0	0	18199	3278	515	21992	50.00
12	4811	250	278	5339	867	4441	0	2240	8461	8355	-2345	18374	0	0	18374	3417	523	22314	49.97
13	5081	237	173	5491	720	4467	0	2174	8654	8310	-2409	18229	0	0	18229	3422	524	22175	49.94
14	5074	193	110	5377	786	4517	0	2067	8625	8126	-2214	18162	0	10	18162	3330	497	21989	49.96
15	5421	321	115	5857	955	4576	0	1892	8704	8289	-2250	18811	0	30	18811	3383	508	22702	49.87
16	6109	214	114	6437	1048	4770	0	1319	8441	8099	-2127	19018	0	18	19018	3445	528	22991	50.01
17	6429	256	108	6793	1062	5211	0	922	8108	7697	-2034	19124	0	0	19124	3395	527	23046	50.03
18	6251	306	111	6668	1159	5090	0	404	8316	8108	-1998	18879	0	0	18879	3250	552	22681	49.99
19	6381	266	121	6768	1276	5832	0	77	7992	7907	-1932	19376	0	0	19376	3181	552	23109	50.02
20	6331	1202	182	7715	1100	6159	0	0	7557	7302	-1865	19861	0	0	19861	3194	550	23605	49.99
21	6380	1297	272	7949	1102	6225	0	0	7361	7169	-1730	20214	0	0	20214	3181	501	23896	50.01
22	6324	819	288	7431	1215	6227	0	0	7273	7006	-1648	19726	0	0	19726	3104	505	23335	49.95
23	6169	740	290	7199	1068	6188	0	0	7273	7099	-1655	19436	0	0	19436	3080	463	22979	49.86
24	6069	912	289	7270	1044	6251	0	0	7213	6768	-1703	19156	0	0	19156	3118	474	22748	49.88
MUs	142.74	9.70	5.64	158.08	27.05	125.64	0.00	17.55	183.73	176.57	-44.60	448.66	0.00	0.06	448.66	72.84	11.62	533.13	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR carried out due to overload of Dindori-Satana line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 15/Jun/2024

Position as on 6.30 Hrs of 16/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Koyna Unit 2	70	15/06/2024	07:10		Continued.	Govrner renovation	10/07/2024
MSPGCL	Bhusawal Unit 4	500	16/06/2024	00:00		Continued.	Annual Overhaul	06/07/2024
Total Capacity MSPGCL		570						
Total Capacity PLANNED OUTAGE		570						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Paras Unit 4	250	05/06/2024	03:59		Continued.	Fire in GT	19/06/2024
MSPGCL	Nasik Unit 4	210	06/06/2024	19:18		Continued.	ID Fan Problem(Under Tolling from 23.00Hrs DT.06-06-2024)	
MSPGCL	Chandrapur Unit 8	500	14/06/2024	12:25	16/06/2024	02:03	Abnormal Parameters which is created due to increase in leakage of FDV 9.	16/06/2024
MSPGCL	Uran Unit 7	108	15/06/2024	12:34	15/06/2024	19:04	Black out at ONGC	
MSPGCL	Chandrapur Unit 3	210	15/06/2024	22.16		Continued.	Boiler Tube Leakage	19/06/2024
MSPGCL	Khaparkheda Unit 1	210	16/06/2024	16:56		Continued.	Bus Bar Differential Protection operated.	
MSPGCL	Khaparkheda Unit 4	210	16/06/2024	16:56		Continued.	Bus Bar Differential Protection operated.	
MSPGCL	Khaparkheda Unit 3	210	16/06/2024	16:56		Continued.	Bus Bar Differential Protection operated.	
MSPGCL	Khaparkheda Unit 2	210	16/06/2024	17:01		Continued.	AC Supply failure.	
Total Capacity MSPGCL		2363						
AEML								
AEML	AEML Unit 1	250	14/06/2024	10:16		Continued.	Boiler Tube Leakage	17/06/2024
Total Capacity AEML		250						
IPP								
IPP	JPL Unit 1	150	16/06/2024	08:09	16/06/2024	12:53	Electrical protection	
Total Capacity IPP		150						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 15/Jun/2024

Position as on 6.30 Hrs of 16/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		3083						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	05/06/2024	17:00		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	06/06/2024	17:40		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Parli Unit 7	250	08/06/2024	21:00		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 6	250	08/06/2024	21:13		Continued.	Zero Schedule by MSEDCL.	
MSPGCL	Parli Unit 8	250	09/06/2024	20:50		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	12/06/2024	16:15		Continued.	Zero schedule given by LM Cell Discom due to drop in demand	
Total Capacity MSPGCL		1176						
IPP								
IPP	Adani U-4	660	10/06/2024	16:16		Continued.	ZERO SCHEDULE BY MSEDCL	
Total Capacity IPP		660						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		1836						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 16/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (703) OF 765/21KV GT-4 @ TIRORA	IntraState	15/06/2024	09:35	15/06/2024	12:14	PO	CT OIL SAMPLE COLLECTION FOR DGA
765 KV ICT Outages/Trippings							
765/400KV 1500MVA ICT-1 @ KORADI 3	IntraState	15/06/2024	09:47	15/06/2024	20:19	PO	Six monthly changeover of R-Ph ICT to be taken in service in place of Spare Ph ICT as per CEA regulation at Koradi-III SS. Last changeover date 30.12.2023
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	14/06/2024	22:31	15/06/2024	04:57	EO	Wrapping of Polythene paper to Instrument relays of converter T/F
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
BUS COUPLER @ KALWA	IntraState	16/06/2024	06:42	16/06/2024	12:45	PO	Bay maintenance and R &M work.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	13/06/2024	10:11			PO	For work in vicinity for erection of scaffolding for installation of LA�s on 220KV Bays at KVTL Vikhroli (These Bays used for feeding 220/110kV, 250MVA, ICT-1 & ICT-2 of TPC Vikhroli).
400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	IntraState	15/06/2024	09:20	15/06/2024	16:42	PO	HV CT and Testing and bay maintenance work
400/220/33 KV 501MVA ICT - 5 @ BABHALESHWAR	IntraState	15/06/2024	16:02	15/06/2024	21:15	T	DC Leakage
220 KV TIEBAY Outages/Trippings							
HYBRID SWITCHGEAR (245kV) @ THEUR	IntraState	15/06/2024	11:04	15/06/2024	13:10	PO	To resolve problem of ingress of moisture appearing in B ph drive mechanism during rains by M/S CGL.
220 KV TBC Outages/Trippings							
BUS COUPLER @ MAHALAXMI GIS (T)	IntraState	15/06/2024	11:11	15/06/2024	13:46	PO	Breaker testing.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV BUS COUPLER	IntraState	16/06/2024	16:56	16/06/2024	18:40	T	Bus-1 BB Prot Optd
40MVA 220/6.6 KV STN T/F 3	IntraState	16/06/2024	16:56	16/06/2024	19:58	T	Bus-1 BB Prot Optd

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 16/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV MAIN BUS 1 @ 220KV KHAPARKHEDA S/S	IntraState	16/06/2024	16:56	16/06/2024	18:17	T	220 KV TBC Bay, Bus-1 isolator Yph jumpering by Hot line unit was in process .During restoration process , while moving hot line arrangement sudden rainfall started and Y phase earth fault occurred on 220 kV Bus1,through wet hot line ropes.
220 KV LINE Outages/Trippings							
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220KV GIS DCHI - COLOURCHEM	IntraState	31/05/2024	04:30			PO	For de-stringing & stringing of old circuit at new tower Loc. No. 6.
NTT - KALWA	IntraState	05/06/2024	00:20			PO	For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kV GIS S/tm M/s NTT Global DC NAV2 Pvt Ltd.
EKLAHARE (OCR) - PADGHE	IntraState	10/06/2024	08:42			HT	H/T for load management
TIFIL - KALWA	IntraState	13/06/2024	08:55			PO	For making 220kV Pawane-TIFIL line LILO for M/s NXTRA Data Ltd for the proposed 220kV GIS S/stn.
VERSOVA - GORAI	IntraState	14/06/2024	11:49			PO	Pre-monsoon Maintenance work
KANDALGAON - PIRANGUT	IntraState	15/06/2024	06:15	15/06/2024	10:57	PO	For attending hot spot at various locations & double jumpering work.
KANDALGAON - ONGC PANVEL	IntraState	15/06/2024	08:45	15/06/2024	11:20	PO	Outage tree cutting work at various location and other line maintenance work.
TATA BORIVLI MSETCL BORIVLI - 4	IntraState	15/06/2024	10:12	15/06/2024	14:28	PO	Protection testing & trials
NANDED 2 (WAGHALA) - PARBHANI	IntraState	15/06/2024	10:20	15/06/2024	14:15	PO	Replacement of Y Phase LA
KARAD - DASGAON	IntraState	15/06/2024	10:21	15/06/2024	15:00	PO	Checking Remote Operation through new SAS for 220kV Line & Bus Section CB
PETH- MUDSHINGI 1 LINE	IntraState	15/06/2024	12:40	15/06/2024	15:52	T	Distance Protection
TOPWORTH - KHANDESHWAR	IntraState	15/06/2024	14:24			PO	Making LILO of 220kV Khandeshwar - Topwarth line & 220kV Khandeshwar Panvel TSS line and commissioning of 220/33kV Timber Market GIS, Panvel
PANVEL TSS - KHANDESHWAR	IntraState	15/06/2024	14:30			PO	Making LILO of 220kV Khandeahwar Topwarth line & 220kV Khandeshwar - Panvel TSS line and commissioing of 220/33kV Timber Market GIS, Panvel
RANJANGAON - U TECH SUGAR CKT	IntraState	15/06/2024	15:58	15/06/2024	18:30	PO	For attending hot spot at various spot & genral bay maintenance work.
NANDED CITY - GIS KONDHWA	IntraState	15/06/2024	16:02			PO	1. Double jumpering work due to Hotspot L.N.-84 ¿R Phase L.N.-79 -B&R Phase L.N.-70-B Phase L.N.-65-Y Phase L.N.-5-B Phase 2. fixing of vibration Damper at various missing locations
MAIN BUS SECTION - 1 @ POPHALI	IntraState	16/06/2024	07:20	16/06/2024	18:12	PO	220 KV Main Bus Section I outage Damaged conductor replacement work related to 220 kv main bus worksd main bus isolators alignment work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 15/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 16/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PIRANGUT - HINJAWADI 2	IntraState	16/06/2024	09:50	16/06/2024	13:43	PO	Erection of monopole Loc No. 154 for height raising purpose and stringing of conductor at New Monopole Loc. No. 154-155
TROMBAY - VIKHROLI (GIS) CKT - 1 / CARNAC 7	IntraState	16/06/2024	10:46	16/06/2024	14:47	PO	1) Work in vicinity of 220KV TC-7/KVTL-2 line at ash pond for daff installation activity. Activity will be carried out by environment team at Trombay generating station
PADGHE - NALASOPARA - VASAI (T)	IntraState	16/06/2024	12:56	16/06/2024	17:11	PO	1) Insulator replacement Work identified in PID. 2) Diagnostic Testing and Pre-monsoon Maintenance Work at Vasai s/stn.
KALWA - MULUND 1	IntraState	16/06/2024	13:02	16/06/2024	18:06	PO	For the installation of saver assembly sets at TL no. 4 & 7 (Total 6 sets out of 6 sets are to be installed)
KHARGHAR - BORIVALI CKT - 2	IntraState	16/06/2024	13:02	16/06/2024	16:12	PO	For the installation of saver assembly sets at TL no. 4 & 7 (Total 6 sets out of 66 sets are to be installed) Total completed - 6 sets
KHAPERKHEDA - KALMESHVAR CKT	IntraState	16/06/2024	16:56	16/06/2024	18:41	T	Bus-1 BB Prot Optd
KHAPARKHEDA- SURYALAKSHMI	IntraState	16/06/2024	16:56	16/06/2024	18:49	T	Bus-1 BB Prot Optd
220 KV NEW KHAPERKHEDA (400 KV)-220KV OLD KHAPERKHEDA CKT 2	IntraState	16/06/2024	16:56	16/06/2024	18:17	T	Bus-1 Bus bar Protection operated
220KV PANDHARKAWDA - WANI CKT li	IntraState	16/06/2024	17:52	16/06/2024	18:42	T	Distance protection
KALWA - BORIVALI	IntraState	16/06/2024	18:40	16/06/2024	22:14	PO	For the installation of saver assembly sets at TL no. 4, 7, 20, 21, 22 & 23 (Total 17 sets out of 33 sets are to be installed) Total Completed - 16 sets
BORIVALI - CTRLS CKT	IntraState	16/06/2024	18:44	16/06/2024	22:12	PO	For the installation of saver assembly sets at TL no. 4, 7, 20, 21, 22 & 23 (Total 15 sets out of 33 sets are to be installed)
220 KV ICT Outages/Trippings							
220/33kv 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/132 KV 100 MVA ICT 2	IntraState	15/06/2024	10:08	15/06/2024	14:19	PO	Maintenance work
220/132 KV 200 MVA ICT 1@ RANJANGAON	IntraState	15/06/2024	10:30	15/06/2024	15:30	PO	Replacement of LA of HV side Y-ph & LV side B-ph due to high LCM value. General Bay maintenance work.
100 MVA 220/132 KV ICT 1	IntraState	15/06/2024	12:56	15/06/2024	14:32	PO	Tan Delta testing
220/22 KV 50 MVA PTR 2 @ LONIKAND	IntraState	15/06/2024	14:24	15/06/2024	17:23	PO	29D isolator alignment work
200 MVA 220/132 KV ICT - III @ CHALISGAON	IntraState	15/06/2024	15:00	15/06/2024	15:24	PO	To check physical Tap Position
220 / 110 / 33kv 250MVA AT 1 @ BACKBAY	IntraState	15/06/2024	16:58	15/06/2024	17:25	T	110KV Bus Fault
220 / 110 / 33kv 250MVA AT 2 @ BACKBAY	IntraState	15/06/2024	16:58	16/06/2024	19:11	T	110KV Bus Fault
220 / 110 / 22kv 250MVA ICT 1 @ BORIVALI (TATA)	IntraState	16/06/2024	09:32	16/06/2024	10:34	PO	OSR canopy installation
220 / 110 / 33kv 250MVA ICT 3 @ BORIVALI (TATA)	IntraState	16/06/2024	10:51	16/06/2024	11:41	PO	OSR canopy installation
40 MVA 220/6.6 KV STN TF - 1 @KHAPARKHEDA	IntraState	16/06/2024	16:56	16/06/2024	18:58	T	Bus-1 BB Prot Optd
132 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 16/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.
110 KV LINE Outages/Trippings							
BORIVLI (T) - BORIVLI (M) - BMC - KOLSHET	IntraState	16/06/2024	08:55	16/06/2024	19:59	PO	Old OHIO Make polymer insulator replacement
KARANJADE - BHOKARPADA	IntraState	16/06/2024	09:47	16/06/2024	12:34	PO	For Bird nest removal at loc.161,183,191

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage