

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 15/Aug/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	96.866	1591.876	1) Gujrat	9.336	114.263
2) Hydro	11.342	194.738	2) Madhya Pradesh	3.569	65.096
3) Gas	7.088	76.239	3) Chattisgarh	2.600	41.080
Total MSPGCL	115.296	1862.853	4) Maharashtra	84.700	2158.142
B) 1) APLM	40.779	706.435	5) Goa (Amona)	-2.022	-21.812
2) JSWEL	12.267	209.870	Total	98.183	2356.769
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.848	461.079
4) RPL(AMT)	21.671	290.507	b) Mumbai Drawl	26.704	500.906
5) SWPGPL	5.662	100.242	c) MSEDCL Bilateral *	63.077	1129.459
6) Other IPP	5.773	92.516	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.848	460.865
C) 1) TPCL Thermal	10.313	154.926	Include PX	0.000	0.000
2) TPCL Hydro	5.471	80.090	Standby	0.000	0.214
3) TPCL Gas	0.000	27.663	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.010	141.153	1) MSEDCL	323.048	5691.571
D) STATE			2) Mumbai Discoms	51.498	904.738
1) Thermal	202.341	3287.525	3) Other Discoms	8.182	129.764
(A1+C1+C4+(B1-B6))			TOTAL STATE	382.728	6726.073
2) Hydro	16.813	274.828			
(A2+C2)					
3) Gas	7.088	103.902			
(A3+B7+C3)					
4) Wind	54.363	590.772			
6) SOLAR	3.940	112.277			
TOTAL STATE	284.545	4369.304			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 9 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	4156	3798	4103	3910
MSPGCL Hydro	559	507	504	271
MSPGCL Gas	267	301	280	272
MSPGCL Total Generation	4982	4606	4887	4453
Central Sector Receipt	4922	3746	4330	3185
WIND	2300	2462	2463	2189
CPP / IPP Thermal	3946	3269	3964	3671
CPP / IPP Gas	0	0	0	0
SOLAR	257	91	1	0
Exchange with Mumbai	-1238	-1181	-1187	-962
MSEDCL DEMAND MET	14797	12632	14094	12205
Load Shedding	0	0	0	0
MSEDCL DEMAND	14797	12632	14094	12205
TPCL GENERATION	636	667	722	702
AEML GENERATION	348	324	423	475
MUMBAI DEMAND	2222	2172	2332	2139
OTHER DISCOM DEMAND	371	361	364	331
STATE DEMAND MET	17391	15165	16790	14675
STATE DEMAND	17391	15165	16790	14675
Frequency (Hz)	50.11	50.03	49.95	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.31 Hz at 13.13 Hrs	49.56 Hz at 05.51 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation, Maximum, Minimum for 15/Aug/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	1.99	38.24	115	45
Unit 7	0.00	0.00	0	0
Unit 8	8.44	53.16	440	265
Unit 9	0.00	46.51	0	0
Unit 10	9.35	155.42	440	355
Total	19.78	293.33		
Bhusawal				
Unit 3	1.55	7.10	105	9
Unit 4	8.24	120.91	430	285
Unit 5	0.00	55.81	0	0
Total	9.79	183.82		
Parli				
Unit 6	3.76	60.63	188	110
Unit 7	3.89	52.13	191	144
Unit 8	3.68	55.07	171	144
Total	11.33	167.83		
Chandrapur				
Unit 3	0.74	32.41	75	0
Unit 4	0.00	12.42	0	0
Unit 5	4.87	77.76	220	158
Unit 6	5.36	72.24	261	180
Unit 7	4.90	9.79	241	115
Unit 8	7.35	134.85	345	270
Unit 9	8.53	138.39	435	293
Total	31.75	477.86		
Paras				
Unit 3	1.05	52.79	145	0
Unit 4	2.93	55.24	148	102
Total	3.98	108.03		
Khaparkheda				
Unit 1	2.19	37.20	110	70
Unit 2	2.08	39.62	105	25
Unit 3	3.15	51.87	140	126
Unit 4	0.00	35.99	0	0
Unit 5	6.99	107.19	355	280
Total	14.40	271.88		
Nasik				
Unit 3	3.02	45.15	145	116
Unit 4	0.00	0.00	0	0
Unit 5	2.82	43.99	135	104
Total	5.84	89.13		
Uran				
All Units	7.09	76.24	314	261
Total	7.09	76.24		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.53	8.96	23	20
Total	0.53	8.96		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.40	37.31	375	35
Stage 4	0.39	27.12	243	0
Stage 3	0.93	22.66	160	0
Total	3.72	87.09		
Hydro				
KDPH	0.86	3.77	36	36
VTRNA	0.71	8.20	61	0
TILLARI	0.70	7.69	58	0
BHIRA T.R.	0.43	6.78	80	0
SMLHY_PTN	4.39	69.79	204	154
GHATGHAR	0.00	2.45	0	0
Total	7.10	98.69		
Wind				
Total	54.36	590.77	0	0
Total	54.36	590.77		
CPP				
APML(Mus)	40.78	706.44	0	0
JSWEL(Mus)	12.27	209.87	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	21.67	290.51	0	0
SWPGPL-Mus	5.66	100.24	0	0
Other(Mus)	5.77	92.52	0	0
Total	86.15	1399.57		
SOLAR				
Total	3.94	112.28	0	0
Total	3.94	112.28		
Tata				
Trombay 5	6.94	103.19	374	261
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	16.17	0	0
Trombay 7B	0.00	11.49	0	0
TATA Hydro	5.47	80.09	324	65
Trombay 8	3.37	51.74	175	131
Total	15.78	262.68		
AEML				
DTPS U-1&2	9.01	141.15	497	310
Total	9.01	141.15		

* Infirm Power		
Particulars	Daily (Mus)	Monthly

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	96.87	1591.88
MSPGCL Thml+Gas	103.95	1668.12
MSPGCL Hydro	11.34	194.74

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	115.30	1862.85
Koyna 1,2 & 4 Total	2.79	64.42
State Total	284.54	4369.30

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 15/Aug/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4377	370	293	5040	2247	3657	0	0	4308	4168	-1067	13727	0	13727	2101	318	16146	50.02
2	4184	302	307	4793	2073	3294	0	0	4214	4374	-920	13310	0	13310	1969	304	15583	49.95
3	4208	403	307	4918	2077	3500	0	0	4018	4084	-879	13416	0	13416	1871	284	15571	49.87
4	4359	460	306	5125	2099	3644	0	0	4040	4070	-848	13827	0	13827	1808	263	15898	49.96
5	4431	295	308	5034	2139	3927	0	0	4179	4449	-861	14411	0	14411	1810	277	16498	50.02
6	4410	485	305	5200	2215	4490	0	0	4694	4522	-921	15197	0	15197	1883	309	17389	49.71
7	4424	941	310	5675	2149	4586	0	26	5371	5241	-1005	16332	0	16332	1967	340	18639	49.91
8	4333	493	307	5133	2119	4554	0	112	5131	5206	-1113	15653	0	15653	2066	358	18077	50.05
9	4156	559	267	4982	2300	3946	0	257	5150	4922	-1238	14797	0	14797	2222	371	17391	50.11
10	3776	531	308	4615	2274	3081	0	387	4955	4774	-1190	13571	0	13571	2319	370	16260	50.08
11	3712	509	314	4535	2384	3297	0	503	3805	4455	-1251	13552	0	13552	2331	371	16254	50.11
12	3886	450	295	4631	2330	3188	0	542	3833	3839	-1335	12830	0	12830	2352	365	15547	50.14
13	3883	366	304	4553	2069	2976	0	538	3519	3951	-1344	12376	0	12376	2335	367	15078	50.22
14	3882	378	303	4563	2133	3288	0	479	2992	3644	-1292	12461	0	12461	2266	354	15081	50.24
15	3825	389	301	4515	2404	3023	0	422	3185	3320	-1309	12040	0	12040	2187	335	14562	50.09
16	3824	389	305	4518	2474	3067	0	345	3482	3088	-1236	11902	0	11902	2157	353	14413	49.98
17	3758	607	292	4657	2567	3148	0	227	3036	3133	-1116	12267	0	12267	2139	349	14755	49.88
18	3798	507	301	4606	2462	3269	0	91	3814	3746	-1181	12632	0	12632	2172	361	15165	50.03
19	3928	514	304	4746	2453	3673	0	10	4621	4249	-1197	13566	0	13566	2252	368	16186	50.02
20	4103	504	280	4887	2463	3964	0	1	4614	4330	-1187	14094	0	14094	2332	364	16790	49.95
21	3809	383	267	4459	2463	3483	0	0	4506	4372	-1107	13314	0	13314	2333	356	16003	50.01
22	3793	737	261	4791	2175	3553	0	0	3825	3891	-1088	12957	0	12957	2282	365	15604	49.99
23	4097	499	271	4867	2105	3874	0	0	3198	3170	-1057	12611	0	12611	2205	348	15164	49.97
24	3910	271	272	4453	2189	3671	0	0	3525	3185	-962	12205	0	12205	2139	331	14675	50.04
MUs	96.87	11.34	7.09	115.30	54.36	86.15	0.00	3.94	98.02	98.18	-26.70	323.05	0.00	323.05	51.50	8.18	382.73	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 15/Aug/2022

Position as on 6.30 Hrs of 16/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
IPP	Adani U-3	660	27/07/2022	00:05		Continued.	Annual Overhaul	19/08/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	20/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31		Continued.	Bottom ash Hopper damaged due to felling of clinker in the boiler (Converted into Annual Overhaul for 33 Days.)	10/09/2022
MSPGCL	Koyna STG-IV Unit-4	250	13/08/2022	10:06		Continued.	Commissioning and installation of new TSLG Governor	21/08/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vibration high	24/08/2022
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
IPP	SWPGPL U-2	135	20/07/2022	01:00		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 4	210	09/08/2022	20:25		Continued.	FURNACE DRAFT VERY HIGH	18/08/2022
TPC-G	Trombay 7B	60	10/08/2022	22:50	16/08/2022	21:55	zero Schedule.	17/08/2022
TPC-G	Trombay 7A	120	10/08/2022	23:15	16/08/2022	17:00	Zero Schedule.	17/08/2022
MSPGCL	Khaparkheda Unit 4	210	10/08/2022	23:58		Continued.	UNIT IS READY FROM 13.08.2022 (DALAY TO LIGHT UP DUE TO WET	18/08/2022

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 15/Aug/2022

Position as on 6.30 Hrs of 16/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							COAL).	
MSPGCL	Bhusawal Unit 3	210	12/08/2022	04:55	15/08/2022	00:35	Low forward power protection	
MSPGCL	Uran Unit A0	120	14/08/2022	09:24		Continued.	Gas shortage	
MSPGCL	Uran Unit B0	120	14/08/2022	09:24	16/08/2022	08:50	Gas shortage	
MSPGCL	Paras Unit 3	250	15/08/2022	08:50		Continued.	CHP coal feeding problem	16/08/2022
MSPGCL	Chandrapur Unit 3	210	15/08/2022	12:50		Continued.	Poor Coal Receipt	18/08/2022
MSPGCL	Uran Unit 5	108	15/08/2022	19:41		Continued.	Gas shortage	
IPP	SWPGPL U-4	135	16/08/2022	00:45		Continued.	Coal Shortage	
MSPGCL	Bhusawal Unit 3	210	16/08/2022	03:44		Continued.	Wet coal problem.	20/08/2022
MSPGCL	Khaparkheda Unit 1	210	16/08/2022	04:28		Continued.	DUE TO WET STEAM PROTECTION	
MSPGCL	Khaparkheda Unit 3	210	16/08/2022	08:09	16/08/2022	15:01	Furnace Pressure High	
MSPGCL	Uran Unit 6	108	16/08/2022	08:30		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 2	210	16/08/2022	15:09		Continued.	Flame Failure	19/08/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 15/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 16/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LR Outages/Trippings							
Pole-1 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC	IntraState	16/08/2022	15:11			HT	This breaker put in lock out at 15:06hrs dt.15.08.2022 and this filter is under breakdown and expert service are required for
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KALWA - TALEGAON (PG)	InterState	15/08/2022	09:08	15/08/2022	19:48	PO	Addition jumpering work by fire wedge connector.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	05/08/2022	00:06			HT	For load management
KHADKA-AURANGABAD (WALUJ)	IntraState	12/08/2022	20:36			HT	HT due to overvoltage
JAIGAD - KARAD CKT - 2	IntraState	15/08/2022	01:25		Continued.	HT	H/T to Control Over Voltages.
PADGHE - NAGOTHANE CKT - 2	IntraState	15/08/2022	01:32	16/08/2022	11:39	HT	H/T to Control Over Voltages.
JEJURI- KOYNA STAGE-IV	IntraState	15/08/2022	09:58	15/08/2022	19:10	PO	PID Faulty disc insulator replacement work & Chemical washing & Cold line washing work
LONIKAND I - KOYNA STAGE-IV	IntraState	16/08/2022	00:17	16/08/2022	07:15	HT	HAND TRIPPED TO CONTROL OVER VOLTAGE.
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	IntraState	16/08/2022	08:33	16/08/2022	23:07	PO	Retrofitting of Main-1 & Main-2 line differential relay work
WARORA - WARORA (PG)	IntraState	16/08/2022	15:29	16/08/2022	19:11	HT	Emergency outage availed for attending hot spot near Line side Isolator (412-89L- B phase) Jumper
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	IntraState	16/08/2022	04:55	16/08/2022	09:05	PO	Outage Requirement for TMS Installation under MTAMC project
220 KV TBC Outages/Trippings							
BUS SECTIONALIZER @ TAMBATI	IntraState	16/08/2022	12:23	16/08/2022	14:23	EO	Heavy sparking observed at R phase CB pole bottom palm and Red hot spots attending work
220 KV LINE Outages/Trippings							
HINJAWADI I- CHINCHWAD	IntraState	15/08/2022	00:01	15/08/2022	17:48	HT	LINE H/T FOR LOAD MANAGEMENT
CHAKAN - CHINCHWAD 2	IntraState	15/08/2022	00:13	15/08/2022	20:58	PO	For erection of monopole towers at location 16A (MCN+6) & 18 (MDN+12) for the diversion work of 220kV Chinchwad2-Telco & Chinchwad 2- Chakan line obstructing to the construction of ROB on road from Bhakti Shakti Chowk to Mukhai Kiwale BRS corridor at Shinde Vasti
CHINCHWAD-2 - TELCO	IntraState	15/08/2022	00:27	15/08/2022	21:03	PO	For erection of monopole towers at location 16A (MCN+6) & 18 (MDN+12) for the diversion work of 220kV Chinchwad2-Telco & Chinchwad 2- Chakan line obstructing to the construction of ROB on road from Bhakti Shakti Chowk to Mukhai Kiwale BRS corridor at Shinde Vasti
RANJANGAON-LONIKAND	IntraState	15/08/2022	14:08	15/08/2022	19:42	PO	Work of Dignostic Testing & half yearly maintenance
INFOSYS - HINJAWADI 1	IntraState	15/08/2022	17:30	15/08/2022	21:14	T	TRIPPED ONLY FROM INFOSYS END
SONKHAR - TROMBAY	IntraState	16/08/2022	00:24	16/08/2022	14:38	T	Tripped on distance protection.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 15/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 16/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PADGHE - JINDAL	IntraState	16/08/2022	02:05	16/08/2022	03:57	T	TRIPPED DUE TO BREAKER PROBLEM AT JINDAL END.
URAN - APTA 3	IntraState	16/08/2022	0939	16/08/2022	18:23	PO	For MAIN BUS insulator and stub Bus insulator string replacement work.
URAN - KHARGHAR 1	IntraState	16/08/2022	09:26	16/08/2022	18:50	PO	1) For MAIN BUS insulator and stub Bus insulator string replacement work.
GOREGAON - AAREY CKT - 2	IntraState	16/08/2022	09:45	16/08/2022	20:20	PO	Under MMRC Line Diversion scheme for Metro-3 project 220kV conductor removal from Tower no. VA-38 to Aarey Gantry
INFOSYS - HINJAWADI 1	IntraState	16/08/2022	10:37	16/08/2022	18:57	PO	A) Tower Erection - 72MT MCTT Tower Main Body Erection B) Erection of one side Cross Arm (Road Side) C) Tower Tightneing
TALANDAGE - FIVE STAR MIDC 2	IntraState	16/08/2022	11:35	16/08/2022	13:42	EO	The Distance Relay ABB REL 670 have display problem. Relay need to be tested
MHAISAL - ALKUD	IntraState	16/08/2022	14:25	16/08/2022	18:12	PO	PID testing work
BHUGAON - WARDHA (PG)	IntraState	16/08/2022	19:18	16/08/2022	20:15	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY
WALUJ - CHITEGAON II	IntraState	16/08/2022	19:26	16/08/2022	20:11	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY
OSMANABAD - PARLY (PG)	IntraState	16/08/2022	19:32	16/08/2022	20:08	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	16/08/2022	22:05	16/08/2022	22:45	T	TRIPPED ON DISTANCE PROTECTION
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220kV GT UNIT-6 @ URAN-220 KV	IntraState	16/08/2022	10:26			PO	1) For GT6 bay decapped hanging Tension string replacement work (it is hanging on BUS-2)
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ URAN	IntraState	16/08/2022	10:26	16/08/2022	19:45	PO	1) For MAIN BUS insulator and stub Bus insulator string replacement work & GT6 bay decapped hanging Tension string replacement work
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 16/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage