

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 15/Aug/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	137.409	1941.881	1) Gujrat	11.073	177.698
2) Hydro	10.713	204.859	2) Madhya Pradesh	5.633	111.445
3) Gas	0.003	3.099	3) Chattisgarh	0.620	26.760
Total MSPGCL	148.125	2149.839	4) Maharashtra	152.033	2359.415
B) 1) APLM	50.843	826.159	5) Goa (Amona)	-1.449	-23.579
2) JSWEL	17.658	201.611	Total	167.910	2651.739
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.719	482.119
4) RPL(AMT)	31.420	399.226	b) Mumbai Drawl	28.230	536.980
5) SWPGPL	10.996	130.539	c) MSEDCL Bilateral *	50.392	1358.272
6) Other IPP	1.038	90.641	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.719	482.119
C) 1) TPCL Thermal	12.387	167.689	Include PX	0.000	0.000
2) TPCL Hydro	4.917	78.516	Standby	0.000	0.000
3) TPCL Gas	3.061	42.827	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.619	137.626	1) MSEDCL	434.638	6636.896
D) STATE			2) Mumbai Discoms	58.214	963.638
1) Thermal	271.370	3895.372	3) Other Discoms	9.554	149.015
(A1+C1+C4+(B1-B6))			TOTAL STATE	502.406	7749.549
2) Hydro	15.630	283.375			
(A2+C2)					
3) Gas	3.064	45.926			
(A3+B7+C3)					
4) Wind	32.692	702.221			
6) SOLAR	11.740	170.916			
TOTAL STATE	334.496	5097.810			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	5473	5682	6010	5883
MSPGCL Hydro	403	362	572	245
MSPGCL Gas	0	0	1	0
MSPGCL Total Generation	5876	6044	6583	6128
Central Sector Receipt	8107	7509	5882	4852
WIND	1217	1268	1634	1383
CPP / IPP Thermal	3857	4017	5023	5105
CPP / IPP Gas	0	0	0	0
SOLAR	1627	1615	0	0
Exchange with Mumbai	-1665	-1560	-1039	-1025
MSEDCL DEMAND MET	18601	18471	17646	16037
Load Shedding	0	0	0	0
MSEDCL DEMAND	18601	18471	17646	16037
TPCL GENERATION	598	606	1082	1015
AEML GENERATION	306	420	478	497
MUMBAI DEMAND	2569	2586	2599	2537
OTHER DISCOM DEMAND	418	422	437	406
STATE DEMAND MET	21588	21479	20682	18980
STATE DEMAND	21588	21479	20682	18980
Frequency (Hz)	49.88	49.98	49.99	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.14 Hz at 17.02 Hrs	49.76 Hz at 22.15 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 15/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.10	46.92	170	105
Unit 8	12.94	197.52	558	525
Unit 9	12.30	183.74	548	465
Unit 10	0.00	0.00	0	0
Total	28.35	428.18		
Bhusawal				
Unit 3	3.10	45.14	135	120
Unit 4	10.00	98.71	480	260
Unit 5	10.80	143.28	485	340
Total	23.90	287.12		
Parli				
Unit 6	4.30	32.56	232	147
Unit 7	4.01	32.48	223	104
Unit 8	4.15	34.49	220	141
Total	12.46	99.53		
Chandrapur				
Unit 3	3.39	43.56	153	130
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	102.86	0	0
Unit 7	7.77	108.92	341	306
Unit 8	10.86	153.55	491	393
Unit 9	10.56	152.57	469	407
Total	32.58	561.46		
Paras				
Unit 3	4.92	70.13	221	187
Unit 4	4.62	66.22	202	187
Total	9.54	136.35		
Khaparkheda				
Unit 1	2.28	30.87	105	80
Unit 2	3.02	39.79	135	120
Unit 3	3.98	55.84	179	136
Unit 4	4.20	57.80	187	141
Unit 5	10.30	143.74	450	370
Total	23.78	328.04		
Nasik				
Unit 3	0.00	46.24	0	0
Unit 4	3.57	37.66	166	129
Unit 5	3.23	17.29	151	124
Total	6.80	101.20		
Uran				
All Units	0.00	3.10	2	0
Total	0.00	3.10		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.72	13.44	50	0
Total	0.72	13.44		
Koyna				
Stage 1-2	2.50	40.58	325	30

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	1.79	44.15	702	0
Stage 3	0.79	22.56	160	0
Total	5.09	107.30		
Hydro				
KDPH	0.00	7.15	0	0
VTRNA	0.00	0.61	0	0
TILLARI	0.00	1.62	0	0
BHIRA T.R.	0.48	6.63	80	0
SMLHY_PTN	4.03	63.42	170	165
GHATGHAR	0.39	4.69	125	0
Total	4.90	84.12		
Wind				
Total	32.69	702.22	0	0
Total	32.69	702.22		
CPP				
APML(Mus)	50.84	826.16	0	0
JSWEL(Mus)	17.66	201.61	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.42	399.23	0	0
SWPGPL-Mus	11.00	130.54	0	0
Dhariwal	0.00	0.00	0	0
IEPL	0.19	75.59	140	0
Other(Mus)	0.84	15.06	0	0
Total	111.96	1648.18		
SOLAR				
Total	11.74	170.92	0	0
Total	11.74	170.92		
Tata				
Trombay 5	8.04	110.58	451	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.84	25.34	108	39
Trombay 7B	1.22	17.48	64	35
TATA Hydro	4.92	78.52	335	119
Trombay 8	4.35	57.11	221	132
Total	20.36	289.03		
AEML				
DTPS U-1&2	9.62	137.63	497	296
Total	9.62	137.63		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	137.41	1941.88	MSPGCL Total	148.12	2149.84
			MSPGCL Thml+Gas	137.41	1944.98	Koyna 1,2 & 4 Total	4.30	84.74
			MSPGCL Hydro	10.71	204.86	State Total	334.50	5097.81

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 15/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5755	243	0	5998	1814	5249	0	0	6465	6032	-925	17785	0	0	17785	2491	383	20659	49.97
2	5658	213	0	5871	1634	5185	0	0	6493	6416	-938	17820	0	0	17820	2332	347	20500	49.93
3	5556	494	0	6050	1321	5055	0	0	6871	7062	-883	18269	0	0	18269	2204	336	20809	49.93
4	5749	558	0	6307	1328	5195	0	0	7374	6992	-841	18669	0	0	18669	2114	311	21095	49.98
5	5871	198	0	6069	1219	5287	0	0	7938	7727	-821	19138	0	0	19138	2102	342	21583	49.99
6	5790	1008	0	6798	1205	5306	0	0	8098	8576	-780	20743	0	0	20743	2180	362	23285	49.95
7	5852	1503	0	7355	1078	5308	0	49	8388	8033	-728	20702	0	0	20702	2232	392	23327	49.94
8	5813	860	0	6673	878	5144	0	281	8116	7822	-876	19523	0	0	19523	2332	399	22254	50.03
9	5712	623	0	6335	870	4952	0	638	7578	7448	-1168	18673	0	0	18673	2403	402	21478	50.02
10	5544	292	0	5836	1040	4474	0	1027	7979	7607	-1526	18054	0	0	18054	2482	404	20940	49.94
11	5537	213	0	5750	1226	3893	0	1512	8289	7939	-1616	18295	0	0	18295	2530	409	21234	49.93
12	5473	403	0	5876	1217	3857	0	1627	8185	8107	-1665	18601	0	0	18601	2569	418	21588	49.88
13	5682	362	0	6044	1268	4017	0	1615	7759	7509	-1560	18471	0	0	18471	2586	422	21479	49.98
14	5724	293	0	6017	1266	4032	0	1480	7695	7464	-1547	18309	0	0	18309	2514	403	21226	50.02
15	5728	259	0	5987	1340	3898	0	1342	7605	7616	-1507	18268	0	0	18268	2473	408	21149	50.01
16	5767	375	0	6142	1487	3949	0	1104	7624	7515	-1473	18325	0	0	18325	2437	399	21161	50.00
17	5764	240	0	6004	1482	3908	0	691	7555	7121	-1431	17356	0	0	17356	2406	419	20181	49.99
18	5452	249	0	5701	1736	3887	0	306	7195	6942	-1401	16742	0	0	16742	2411	429	19582	50.01
19	5632	507	0	6139	1799	4134	0	68	6468	6286	-1279	16711	0	0	16711	2457	436	19604	49.98
20	6010	572	1	6583	1634	5023	0	0	6057	5882	-1039	17646	0	0	17646	2599	437	20682	49.99
21	5874	366	2	6242	1590	5141	0	0	5973	5596	-986	17155	0	0	17155	2635	428	20218	50.00
22	5774	303	0	6077	1454	5041	0	0	5922	5616	-1141	16614	0	0	16614	2607	433	19654	49.99
23	5809	334	0	6143	1423	4915	0	0	5640	5752	-1074	16729	0	0	16729	2581	430	19740	49.94
24	5883	245	0	6128	1383	5105	0	0	5410	4852	-1025	16037	0	0	16037	2537	406	18980	50.02
MUs	137.41	10.71	0.00	148.13	32.69	111.96	0.00	11.74	172.68	167.91	-28.23	434.64	0.00	0.00	434.64	58.21	9.55	502.41	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 15/Aug/2023

Position as on 6.30 Hrs of 16/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	27/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	OVERHAUL	25/08/2023
IPP	Adani U-4	660	12/08/2023	23:44		Continued.	Annual Overhaul	05/09/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/08/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	COH (Hot spot on Stator).	13/09/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05	15/08/2023	19:56	Compressor Surge Protection	15/08/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	20/08/2023
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	19/08/2023
MSPGCL	Koyna Unit 7	80	13/08/2023	09:00		Continued.	Spherical Valve maintenance	02/09/2023
MSPGCL	Nasik Unit 3	210	13/08/2023	16:00		Continued.	Tolling from 15:00 hrs on Dt 14.08.2023.	17/08/2023
MSPGCL	Chandrapur Unit 6	500	14/08/2023	06:30		Continued.	BTL	18/08/2023
MSPGCL	Koyna STG-IV Unit-2	250	14/08/2023	18:30	15/08/2023	00:00	Synchronising problem.	
MSPGCL	Uran Unit 6	108	14/08/2023	21:19	16/08/2023	05:03	No Schedule	
MSPGCL	Uran Unit 7	108	14/08/2023	21:30	16/08/2023	05:12	No Schedule	
IPP	IEPL Unit 1	270	15/08/2023	01:30		Continued.	Due to Abnormal sound in APH	17/08/2023
MSPGCL	Uran Unit 8	108	15/08/2023	20:07		Continued.	No Schedule	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 15/Aug/2023

Position as on 6.30 Hrs of 16/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	16/08/2023	07:47	16/08/2023	15:45	Zero Schedule	
MSPGCL	Uran Unit 7	108	16/08/2023	08:00	16/08/2023	16:58	Zero Schedule	
MSPGCL	Paras Unit 3	250	16/08/2023	10:48		Continued.	Boiler Tube Leakage	19/08/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 15/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 16/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
MAIN BAY (401) OF ICT - 1 @ KORADI 3	IntraState	16/08/2023	13:57	16/08/2023	16:07	PO	DGA Test of Current Transformer
400KV 125MVAR BUS REACTOR MAIN BAY(420) @ 400KV DEEPNAGAR	IntraState	16/08/2023	14:55			PO	For low voltage testing on 400 kV 125 MVar Bus Reactor by M/s. CGL Testing Team
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of 2Y2 phase Protection CT Of NTPP I (RPL 1)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	05/08/2023	10:07			HT	TO CONTROL LINE LOADING OF PUNE GIS
KHADKA-AURANGABAD (WALUJ)	IntraState	14/08/2023	20:11	16/08/2023	09:53	HT	H/T on overvoltage
JAIGAD - KARAD CKT - 1	IntraState	14/08/2023	20:17	15/08/2023	08:41	HT	H/T on overvoltage
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	15/08/2023	05:45	15/08/2023	07:22	T	Tripped on distance protection
KHADKA-AURANGABAD (WALUJ)	IntraState	16/08/2023	20:11		Continued.	HT	H/T for voltage management
220 KV KALWA (400 KV) - SALSETTE CKT III	IntraState	16/08/2023	21:33	16/08/2023	22:08	T	220 KV Busbar operated while charging 220 kv Kalwa- TFIPL (PAWNE - MIDC)
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	IntraState	12/08/2023	10:21	15/08/2023	20:24	PO	1.Commissioning of High velocity water spray system for 315MVA ICT-1. 2. Routine maintenance of ICT 2. Maintenance and alignment of Isolators 3. Bay routine maintenance work
400/220 KV 3X200 MVA ICT - 2 @ KALWA	IntraState	16/08/2023	21:33	16/08/2023	21:55	T	220 KV Busbar operated while charging 220 kv Kalwa- TFIPL (PAWNE - MIDC)
400/220/20 KV 500MVA ICT - 1 @ KALWA	IntraState	16/08/2023	21:33	16/08/2023	21:53	T	220 KV Busbar operated while charging 220 kv Kalwa- TFIPL (PAWNE - MIDC)
220 KV MAINBAY Outages/Trippings							
INTERCONNECTOR @ KALWA	IntraState	14/08/2023	20:50	15/08/2023	02:14	EO	1) B ph damaged twin Jumper replacement work of 52 C between CB to CT 2) B ph damage jumper replacement work in between 29 F isolator to stub bus
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
BUS SECTION - 1 @ TROMBAY	IntraState	15/08/2023	00:08	15/08/2023	02:38	T	Tripped due to Y ph PT burst at TROMBAY SS
TROMBAY MSETCL TIE - 2	IntraState	15/08/2023	00:08	15/08/2023	02:58	T	Tripped due to Y ph PT burst at TROMBAY SS
TROMBAY (M) - CHEMBUR CKT - 3	IntraState	15/08/2023	00:08	15/08/2023	02:40	T	Tripped due to Y ph PT burst at TROMBAY SS
TROMBAY - KALWA	IntraState	15/08/2023	00:08	15/08/2023	02:38	T	Tripped due to Y ph PT burst at TROMBAY SS

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 15/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 16/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
AAREY - MSETCL BORIVALI CKT - 2	IntraState	15/08/2023	06:02			T	Tripped on Distance Protection
ROAD SIDE BUS @ KALWA	IntraState	15/08/2023	08:48	15/08/2023	17:56	PO	Replacement of Earth wire
BABLESHWAR AHAMADNAGAR-II	IntraState	15/08/2023	08:59	15/08/2023	13:38	PO	Replacement of faulty string found in pid report at loc no 11 DSN Y pH
MAHINDRA VEHICLE-BRIDGESTONE	IntraState	15/08/2023	09:18	15/08/2023	15:11	PO	Stringing work on the dummy line due to low clearance in between B -ph of 220 kV Mahindra vehicle-Bridgestone circuit & R-ph of dummy line on existing tower loc no. 4 and lilo arrangement at proposed LILO.
KALWA - TFIPL	IntraState	16/08/2023	00:27			PO	For removing the jumpers at Loc no.40 for making LILO through at 220KV Pawane GIS S/stn.
PARANDA-BARSHI	IntraState	16/08/2023	11:13	16/08/2023	20:20	PO	Outage is required for Attending Major SAG TL 133-134-135 , Y and B phase, Jump replacement at TL 131 and CP nut bolt tightening work
220 KV PARLI -U-8 - PARBHANI CKT	IntraState	16/08/2023	12:10	16/08/2023	15:05	PO	Replacement of Disc Insulator Loc no.291 R ph.
KHARGHAR - BORIVALI CKT - 2	IntraState	16/08/2023	13:02	16/08/2023	18:03	PO	Outage is required for safety purpose during the outage work on 220KV Kalwa-TFIPL line For removing the jumpers at Loc no.40 for making LILO through at 220KV Pawane GIS S/stn & erection of Monopole CTT work in between Loc no. 3-4 from LILO point to 220KV Tfilp S/stn for power supply to newly proposed 20KV GIS Nextra S/stn.
KHARGHAR - NET MAGIC GIS	IntraState	16/08/2023	13:18	16/08/2023	17:35	PO	Outage is required for safety purpose during the outage work on 220KV Kalwa-TFIPL line For removing the jumpers at Loc no.40 for making LILO through at 220KV Pawane GIS S/stn & erection of Monopole CTT work in between Loc no. 3-4 from LILO point to 220KV Tfilp S/stn for power supply to newly proposed 20KV GIS Nextra S/stn.
KALWA - MULUND 2	IntraState	16/08/2023	21:33	16/08/2023	22:01	T	220 KV Busbar operated while charging 220 kv Kalwa- TFIPL (PAWNE - MIDC)
KALWA - BORIVALI	IntraState	16/08/2023	21:33	16/08/2023	21:59	T	220 KV Busbar operated while charging 220 kv Kalwa- TFIPL (PAWNE - MIDC)
KALWA - COLOURCHEM	IntraState	16/08/2023	21:33	16/08/2023	22:21	T	220 KV Busbar operated while charging 220 kv Kalwa- TFIPL (PAWNE - MIDC)
KALWA SALSETTE - 3	IntraState	16/08/2023	21:33	16/08/2023	22:08	T	220 KV Busbar operated while charging 220 kv Kalwa- TFIPL (PAWNE - MIDC)
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132 KV 100 MVA ICT 1 @ PHALTAN MIDC	IntraState	15/08/2023	09:00	15/08/2023	17:38	PO	ICT Painting Work
220/132 KV 100 MVA ICT 1 @ SAWANGI	IntraState	15/08/2023	09:30	15/08/2023	10:57	EO	To attend Hot Spot
220/132 KV 100 MVA ICT 1 @ PHALTAN MIDC	IntraState	16/08/2023	09:10	16/08/2023	18:00	PO	ICT Painting Work
220/33KV 25MVA PTR - 1 @ ONI	IntraState	16/08/2023	09:54	16/08/2023	12:31	PO	Replacement of 220/33 kv 25 MVA BBL TF-1 LV B-Ph CT.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 16/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALYAN KALWA SALSETTE 1	IntraState	14/08/2023	16:55	15/08/2023	00:04	PO	Loop closing at loc. 78 towards Salsette side for taking line in service between Kalyan, Kalwa & Salsette end.
KALYAN KALWA SALSETTE 1	IntraState	16/08/2023	16:17	16/08/2023	18:14	PO	Project Work - Loop opening at loc. 78 towards Salsette side for keeping line in service between Kalyan & Kalwa and out from loc. 78 to Salsette end for raising of KKS lines project at Shangrilla Metro 4 crossing, Bhandup West.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage