

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 15/Oct/2024 TUESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 139.754        | 2155.589        | 1) Gujrat                      | 5.240          | 123.323         |
| 2) Hydro            | 7.468          | 124.379         | 2) Madhya Pradesh              | 8.526          | 54.193          |
| 3) Gas              | 5.943          | 94.068          | 3) Chattisgarh                 | 5.210          | 50.200          |
| <b>Total MSPGCL</b> | <b>153.165</b> | <b>2374.036</b> | 4) Maharashtra                 | 209.278        | 2947.452        |
| B) 1) APMIL         | 64.287         | 915.909         | 5) Goa (Amona)                 | -1.261         | -30.342         |
| 2) JSWEL            | 24.108         | 366.270         | <b>Total</b>                   | <b>226.993</b> | <b>3144.826</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 50.803         | 719.964         |
| 4) RPL(AMT)         | 17.740         | 270.430         | b) Mumbai Drawl                | 52.011         | 763.533         |
| 5) SWPGPL           | 8.749          | 137.061         | c) MSEDCL Bilateral *          | 96.397         | 1339.663        |
| 6) Other IPP        | 10.255         | 165.897         | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 50.803         | 715.964         |
| C) 1) TPCL Thermal  | 4.551          | 67.416          | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 3.208          | 61.327          | Standby                        | 0.000          | 4.000           |
| 3) TPCL Gas         | 4.153          | 62.740          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 9.219          | 128.471         | 1) MSEDCL                      | 462.817        | 6835.587        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 73.142         | 1083.475        |
| 1) Thermal          | 278.663        | 4207.043        | 3) Other Discoms               | 12.258         | 182.554         |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>548.217</b> | <b>8101.616</b> |
| 2) Hydro            | 10.676         | 185.706         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 10.096         | 156.808         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 3.282          | 129.193         |                                |                |                 |
| 6) SOLAR            | 18.507         | 278.052         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>321.224</b> | <b>4956.802</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 11 Hrs | B. Day Peak at 17 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 4974                      | 6038                  | 6405                      | 5745                      |
| MSPGCL Hydro               | 207                       | 219                   | 707                       | 184                       |
| MSPGCL Gas                 | 287                       | 280                   | 289                       | 144                       |
| MSPGCL Total Generation    | 5468                      | 6537                  | 7401                      | 6073                      |
| Central Sector Receipt     | 10597                     | 10311                 | 10629                     | 7713                      |
| WIND                       | 127                       | 76                    | 77                        | 141                       |
| CPP / IPP Thermal          | 4224                      | 5077                  | 5951                      | 5548                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 2334                      | 771                   | 0                         | 0                         |
| Exchange with Mumbai       | -2497                     | -2548                 | -2270                     | -1518                     |
| <b>MSEDCL DEMAND MET</b>   | <b>19696</b>              | <b>19660</b>          | <b>21207</b>              | <b>17565</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 19696                     | 19660                 | 21207                     | 17565                     |
| TPCL GENERATION            | 536                       | 539                   | 709                       | 390                       |
| AEML GENERATION            | 490                       | 492                   | 415                       | 334                       |
| <b>MUMBAI DEMAND</b>       | <b>3523</b>               | <b>3579</b>           | <b>3394</b>               | <b>2242</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>558</b>                | <b>563</b>            | <b>581</b>                | <b>392</b>                |
| STATE DEMAND MET           | 23776                     | 23803                 | 25182                     | 20199                     |
| <b>STATE DEMAND</b>        | <b>23776</b>              | <b>23803</b>          | <b>25182</b>              | <b>20199</b>              |
| Frequency (Hz)             | 50.00                     | 49.96                 | 50.02                     | 50.02                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.        | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|----------------------|-----------------------|---------------|---------------------|
| 50.2 Hz at 06.02 Hrs | 49.63 Hz at 18.28 Hrs | 49.97         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 15/Oct/2024

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.85         | 57.41         | 175      | 134      |
| Unit 8             | 11.74        | 184.72        | 552      | 373      |
| Unit 9             | 12.27        | 176.51        | 580      | 374      |
| Unit 10            | 12.36        | 173.96        | 590      | 375      |
| <b>Total</b>       | <b>40.22</b> | <b>592.59</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.12         | 36.95         | 155      | 115      |
| Unit 4             | 9.33         | 106.19        | 455      | 295      |
| Unit 5             | 8.90         | 130.08        | 445      | 290      |
| <b>Total</b>       | <b>21.34</b> | <b>273.22</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 4.02         | 56.88         | 233      | 142      |
| Unit 7             | 2.33         | 51.20         | 148      | 0        |
| Unit 8             | 3.78         | 58.50         | 186      | 145      |
| <b>Total</b>       | <b>10.13</b> | <b>166.58</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.48         | 49.53         | 190      | 130      |
| Unit 4             | 3.27         | 44.46         | 153      | 131      |
| Unit 5             | 7.57         | 113.78        | 385      | 280      |
| Unit 6             | 4.22         | 60.51         | 190      | 160      |
| Unit 7             | 6.37         | 107.26        | 298      | 240      |
| Unit 8             | 10.24        | 150.53        | 470      | 294      |
| Unit 9             | 0.75         | 1.01          | 219      | 0        |
| <b>Total</b>       | <b>35.90</b> | <b>527.07</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.90         | 68.18         | 234      | 143      |
| Unit 4             | 5.07         | 61.46         | 241      | 149      |
| <b>Total</b>       | <b>9.97</b>  | <b>129.64</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.52         | 52.83         | 180      | 110      |
| Unit 2             | 3.94         | 59.11         | 192      | 113      |
| Unit 3             | 3.83         | 50.34         | 170      | 132      |
| Unit 4             | 4.12         | 60.64         | 184      | 141      |
| Unit 5             | 0.00         | 146.37        | 0        | 0        |
| <b>Total</b>       | <b>15.40</b> | <b>369.29</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.44         | 49.82         | 160      | 124      |
| Unit 4             | 3.35         | 47.37         | 172      | 106      |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>6.79</b>  | <b>97.19</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 5.94         | 94.07         | 295      | 144      |
| <b>Total</b>       | <b>5.94</b>  | <b>94.07</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.97         | 11.14         | 44       | 40       |
| <b>Total</b>       | <b>0.97</b>  | <b>11.14</b>  |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 2.18         | 28.28         | 345      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 0.78          | 15.58          | 247      | 0        |
| Stage 3         | 0.75          | 10.16          | 206      | 0        |
| <b>Total</b>    | <b>3.71</b>   | <b>54.02</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.00          | 6.35           | 0        | 0        |
| VTRNA           | 0.00          | 0.00           | 0        | 0        |
| TILLARI         | 0.20          | 2.51           | 61       | 0        |
| BHIRA T.R.      | 0.24          | 4.32           | 40       | 0        |
| SMLHY_PTN       | 3.32          | 51.90          | 142      | 134      |
| GHATGHAR        | 0.00          | 5.28           | 0        | 0        |
| <b>Total</b>    | <b>3.76</b>   | <b>70.36</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 3.28          | 129.19         | 0        | 0        |
| <b>Total</b>    | <b>3.28</b>   | <b>129.19</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 64.29         | 915.91         | 0        | 0        |
| JSWEL(Mus)      | 24.11         | 366.27         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 17.74         | 270.43         | 0        | 0        |
| SWPGPL-Mus      | 8.75          | 137.06         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00           | 0        | 0        |
| IEPL            | 5.69          | 86.79          | 268      | 185      |
| Other(Mus)      | 0.33          | 7.51           | 0        | 0        |
| JPL             | 4.23          | 71.59          | 217      | 169      |
| <b>Total</b>    | <b>125.14</b> | <b>1855.57</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 18.51         | 278.05         | 0        | 0        |
| <b>Total</b>    | <b>18.51</b>  | <b>278.05</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 0.00          | 0.00           | 0        | 0        |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.63          | 39.64          | 112      | 88       |
| Trombay 7B      | 1.52          | 23.10          | 65       | 56       |
| TATA Hydro      | 3.21          | 61.33          | 358      | 46       |
| Trombay 8       | 4.55          | 67.42          | 223      | 163      |
| <b>Total</b>    | <b>11.91</b>  | <b>191.48</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 9.22          | 128.47         | 494      | 303      |
| <b>Total</b>    | <b>9.22</b>   | <b>128.47</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 139.75      | 2155.59       | MSPGCL Total        | 153.16      | 2374.04       |
|                |             |         | MSPGCL Thml+Gas | 145.70      | 2249.66       | Koyna 1,2 & 4 Total | 2.96        | 43.86         |
|                |             |         | MSPGCL Hydro    | 7.47        | 124.38        | State Total         | 321.22      | 4956.80       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 15/Oct/2024

| TIME SR. NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | Load Shedding |                          | MSEDC L DEM. WITH LS | MUMBAI DEMAND | OTHER DISCOM DEMAND | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|------|------|--------|------|-----------|------|-------|----------|----------|----------------|------------------|---------------|--------------------------|----------------------|---------------|---------------------|--------------|------------|
|              | THM         | HY   | GAS  |        |      | THM       | GAS  |       |          |          |                |                  | Planned       | *Transmission Constraint |                      |               |                     |              |            |
| 1            | 5765        | 178  | 291  | 6234   | 203  | 5917      | 0    | 0     | 8342     | 8052     | -1904          | 18039            | 0             | 0                        | 18039                | 2697          | 463                 | 21199        | 49.97      |
| 2            | 5575        | 178  | 285  | 6038   | 213  | 5627      | 0    | 0     | 8028     | 8069     | -1715          | 17809            | 0             | 0                        | 17809                | 2491          | 424                 | 20723        | 49.95      |
| 3            | 5522        | 263  | 155  | 5940   | 179  | 5382      | 0    | 0     | 7755     | 8116     | -1600          | 17612            | 0             | 0                        | 17612                | 2342          | 406                 | 20359        | 50.00      |
| 4            | 5745        | 184  | 144  | 6073   | 141  | 5548      | 0    | 0     | 7809     | 7713     | -1518          | 17565            | 0             | 0                        | 17565                | 2242          | 392                 | 20199        | 50.02      |
| 5            | 5954        | 180  | 144  | 6278   | 145  | 5490      | 0    | 0     | 7984     | 8156     | -1483          | 18187            | 0             | 0                        | 18187                | 2202          | 399                 | 20788        | 50.00      |
| 6            | 6130        | 185  | 144  | 6459   | 118  | 5231      | 0    | 0     | 8989     | 9231     | -1543          | 19050            | 0             | 0                        | 19050                | 2283          | 446                 | 21779        | 49.97      |
| 7            | 6274        | 299  | 144  | 6717   | 191  | 5606      | 0    | 73    | 9382     | 9822     | -1692          | 20223            | 0             | 0                        | 20223                | 2441          | 494                 | 23158        | 49.98      |
| 8            | 6146        | 372  | 150  | 6668   | 87   | 5708      | 0    | 637   | 9268     | 9517     | -1892          | 20217            | 0             | 0                        | 20217                | 2637          | 509                 | 23362        | 50.01      |
| 9            | 5910        | 359  | 211  | 6480   | 88   | 5338      | 0    | 1453  | 9339     | 9331     | -2215          | 19953            | 0             | 1                        | 19953                | 2964          | 522                 | 23439        | 50.04      |
| 10           | 5465        | 301  | 287  | 6053   | 109  | 4679      | 0    | 2083  | 10076    | 9835     | -2365          | 19858            | 0             | 18                       | 19858                | 3289          | 537                 | 23683        | 49.98      |
| 11           | 4974        | 207  | 287  | 5468   | 127  | 4224      | 0    | 2334  | 10446    | 10597    | -2497          | 19696            | 0             | 19                       | 19696                | 3523          | 558                 | 23776        | 50.00      |
| 12           | 5139        | 176  | 280  | 5595   | 168  | 4115      | 0    | 2583  | 10114    | 9976     | -2591          | 19291            | 0             | 10                       | 19291                | 3606          | 555                 | 23452        | 50.02      |
| 13           | 4788        | 180  | 280  | 5248   | 167  | 3891      | 0    | 2517  | 10038    | 10080    | -2588          | 18779            | 0             | 1                        | 18779                | 3594          | 536                 | 22909        | 50.00      |
| 14           | 4810        | 215  | 277  | 5302   | 143  | 3811      | 0    | 2437  | 9757     | 9939     | -2498          | 18609            | 0             | 0                        | 18609                | 3512          | 525                 | 22646        | 49.97      |
| 15           | 5230        | 469  | 276  | 5975   | 132  | 4009      | 0    | 1997  | 9740     | 9979     | -2568          | 18993            | 0             | 0                        | 18993                | 3585          | 531                 | 23109        | 49.91      |
| 16           | 5794        | 253  | 280  | 6327   | 122  | 4693      | 0    | 1476  | 9899     | 10103    | -2616          | 19554            | 0             | 0                        | 19554                | 3633          | 552                 | 23738        | 49.99      |
| 17           | 6038        | 219  | 280  | 6537   | 76   | 5077      | 0    | 771   | 10076    | 10311    | -2548          | 19660            | 0             | 0                        | 19660                | 3579          | 563                 | 23803        | 49.96      |
| 18           | 6175        | 371  | 280  | 6826   | 67   | 5330      | 0    | 144   | 10344    | 10418    | -2563          | 19662            | 0             | 4                        | 19662                | 3490          | 559                 | 23711        | 49.85      |
| 19           | 6319        | 776  | 281  | 7376   | 64   | 5976      | 0    | 2     | 10502    | 10534    | -2404          | 20998            | 0             | 1                        | 20998                | 3461          | 549                 | 25009        | 49.81      |
| 20           | 6405        | 707  | 289  | 7401   | 77   | 5951      | 0    | 0     | 10628    | 10629    | -2270          | 21207            | 0             | 0                        | 21207                | 3394          | 581                 | 25182        | 50.02      |
| 21           | 6461        | 657  | 294  | 7412   | 118  | 5936      | 0    | 0     | 9703     | 9752     | -2323          | 20335            | 0             | 0                        | 20335                | 3190          | 560                 | 24085        | 49.96      |
| 22           | 6481        | 375  | 294  | 7150   | 96   | 5966      | 0    | 0     | 9257     | 9206     | -2264          | 19593            | 0             | 0                        | 19593                | 3063          | 562                 | 23217        | 49.99      |
| 23           | 6343        | 179  | 295  | 6817   | 244  | 5919      | 0    | 0     | 8796     | 9046     | -2203          | 19303            | 0             | 0                        | 19303                | 2984          | 520                 | 22807        | 49.98      |
| 24           | 6311        | 185  | 295  | 6791   | 207  | 5713      | 0    | 0     | 8712     | 8581     | -2151          | 18625            | 0             | 0                        | 18625                | 2940          | 515                 | 22080        | 49.99      |
| MUs          | 139.75      | 7.47 | 5.94 | 153.17 | 3.28 | 125.14    | 0.00 | 18.51 | 224.98   | 226.99   | -52.01         | 462.82           | 0.00          | 0.05                     | 462.82               | 73.14         | 12.26               | 548.22       | 49.97      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

1)Overloading of 132kV Dindori-Satana line 2)LTS at 100kV Khopoli Bhokarpada Apta line at 100KV khopoli SS

| Maximum Demand scenario for the date 15/Oct/2024 |                                    |                                   |
|--------------------------------------------------|------------------------------------|-----------------------------------|
| State Demand                                     | MSEDC L Non-Coincident Peak Demand | Mumbai Non-Coincident Peak Demand |
| 25182 MW                                         | 21207 MW                           | 3633 MW                           |
| 20 Hrs                                           | 20 Hrs                             | 16 Hrs                            |
| Includes LS - 0 MW                               | Includes LS - 0 MW                 | --                                |

# State Load Despatch Center,Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 15/Oct/2024

Position as on 6.30 Hrs of 16/Oct/2024

| Generating Company            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                | Expected Date |
|-------------------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------------------------------------------------------------------------------------------|---------------|
| PLANNED OUTAGE                |                         |          |              |              |            |            |                                                                                                                 |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                 |               |
| MSPGCL                        | Nasik Unit 5            | 210      | 27/08/2024   | 23:55        |            | Continued. | On Tolling(Under COH from 00.00 Hrs DT.05.09.2024)                                                              | 16/10/2024    |
| MSPGCL                        | Koyna Unit 6            | 80       | 12/09/2024   | 15:10        |            | Continued. | Refurbishment of governing system & Upgradation of PLC system & Excitation system.                              | 16/10/2024    |
| Total Capacity MSPGCL         |                         | 290      |              |              |            |            |                                                                                                                 |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                 |               |
| IPP                           | SWPGPL U-3              | 135      | 09/10/2024   | 01:00        |            | Continued. | Annual Overhaul                                                                                                 | 26/10/2024    |
| Total Capacity IPP            |                         | 135      |              |              |            |            |                                                                                                                 |               |
| Total Capacity PLANNED OUTAGE |                         | 425      |              |              |            |            |                                                                                                                 |               |
| FORCED OUTAGE                 |                         |          |              |              |            |            |                                                                                                                 |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                 |               |
| MSPGCL                        | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                              | 31/10/2024    |
| MSPGCL                        | Ghatghar Unit-2         | 125      | 26/05/2024   | 13:17        |            | Continued. | Stator Earth Fault                                                                                              | 26/11/2024    |
| MSPGCL                        | Koyna Unit 5            | 80       | 18/08/2024   | 18:00        |            | Continued. | UGB Temperature High                                                                                            | 21/10/2024    |
| MSPGCL                        | Uran Unit 6             | 108      | 24/09/2024   | 10:30        |            | Continued. | Generator exciter end abnormal sound.                                                                           | 17/10/2024    |
| MSPGCL                        | Chandrapur Unit 9       | 500      | 13/10/2024   | 18:30        | 15/10/2024 | 04:18      | Due to high shaft vibration                                                                                     | 15/10/2024    |
| MSPGCL                        | Khaparkheda Unit 5      | 500      | 14/10/2024   | 13:45        |            | Continued. | Boiler Tube Leakage                                                                                             | 17/10/2024    |
| MSPGCL                        | Parli Unit 7            | 250      | 14/10/2024   | 16:05        | 15/10/2024 | 04:35      | Air heater problem                                                                                              | 15/10/2024    |
| MSPGCL                        | Ghatghar Unit-1         | 125      | 14/10/2024   | 23:30        | 16/10/2024 | 06:10      | Shaft seal pipeline leakage.                                                                                    | 16/10/2024    |
| MSPGCL                        | Uran Unit 8             | 108      | 15/10/2024   | 02.01        | 15/10/2024 | 07:39      | Testing,Instrumentation, Communication Fault.                                                                   |               |
| MSPGCL                        | Chandrapur Unit 9       | 500      | 15/10/2024   | 05:45        | 15/10/2024 | 20:54      | Due to high shaft vibration                                                                                     |               |
| Total Capacity MSPGCL         |                         | 2416     |              |              |            |            |                                                                                                                 |               |
| TPC-G                         |                         |          |              |              |            |            |                                                                                                                 |               |
| TPC-G                         | Trombay 5               | 500      | 22/09/2024   | 16:14        |            | Continued. | Emergency withdrwan due to fire in cable vault.                                                                 |               |
| Total Capacity TPC-G          |                         | 500      |              |              |            |            |                                                                                                                 |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                 |               |
| IPP                           | RPL(AMT) U-3            | 270      | 23/07/2024   | 00:47        |            | Continued. | Turbine Vibration High                                                                                          | 31/10/2024    |
| IPP                           | RPL(AMT) U-5            | 270      | 15/09/2024   | 15:21        |            | Continued. | Bottom Ash Evacuation Problem                                                                                   | 17/10/2024    |
| Total Capacity IPP            |                         | 540      |              |              |            |            |                                                                                                                 |               |
| CENT.SECTOR                   |                         |          |              |              |            |            |                                                                                                                 |               |
| CENT.SECTOR                   | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling. | 30/12/2024    |
| CENT.SECTOR                   | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged                                                                                         | 30/11/2024    |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 15/Oct/2024**

**Position as on 6.30 Hrs of 16/Oct/2024**

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                                                                | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------------------------------------------|---------------|
|                                               |                         |          |              |              |           |            | basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. |               |
| Total Capacity CENT.SECTOR                    |                         | 320      |              |              |           |            |                                                                                                                                 |               |
| Total Capacity FORCED OUTAGE                  |                         | 3776     |              |              |           |            |                                                                                                                                 |               |
| UNIT UNDER ZERO SCHEDULE / RSD                |                         |          |              |              |           |            |                                                                                                                                 |               |
| MSPGCL                                        |                         |          |              |              |           |            |                                                                                                                                 |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 14/10/2024   | 16:49        |           | Continued. | Zero Schedule By MSEDCL.                                                                                                        |               |
| Total Capacity MSPGCL                         |                         | 108      |              |              |           |            |                                                                                                                                 |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 108      |              |              |           |            |                                                                                                                                 |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |           |            |                                                                                                                                 |               |
| IPP                                           |                         |          |              |              |           |            |                                                                                                                                 |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA)                                                                                                            |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA)                                                                                                            |               |
| IPP                                           | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                         |               |
| IPP                                           | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                          |               |
| Total Capacity IPP                            |                         | 988      |              |              |           |            |                                                                                                                                 |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA    |                         | 988      |              |              |           |            |                                                                                                                                 |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 15/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 16/Oct/2024

| Name of Line                                       | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                   |
|----------------------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV MAINBAY Outages/Trippings</b>            |                              |                 |                 |            |               |                |                                                                                                                                                                                                                                                                                                                                                                                                    |
| MAIN BAY (402) OF KHADKA CKT - 2 @ DEEPNAGAR       | IntraState                   | 15/10/2024      | 11:20           | 15/10/2024 | 19:21         | PO             | For Diagnostic Testing of Bay Equipments                                                                                                                                                                                                                                                                                                                                                           |
| <b>400 KV LINE Outages/Trippings</b>               |                              |                 |                 |            |               |                |                                                                                                                                                                                                                                                                                                                                                                                                    |
| PADGHE - TARAPUR CKT - 1                           | InterState                   | 15/10/2024      | 13:12           | 15/10/2024 | 17:12         | EO             | To attend hosspot on C Bus B Ph PG Isolator, Temp 369 Deg.                                                                                                                                                                                                                                                                                                                                         |
| BUS REACTOR (50MVAR) @ PARLI                       | IntraState                   | 27/09/2023      | 15:30           |            |               | PO             | Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.                                                                                                                                                                                                                                                                                                                                |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1                | IntraState                   | 04/10/2024      | 08:31           |            |               | HT             | H/T for load management.                                                                                                                                                                                                                                                                                                                                                                           |
| NEW KOYNA - DABHOL CKT - 1                         | IntraState                   | 14/10/2024      | 17:30           | 15/10/2024 | 00:31         | T              | Tripped on distance protection.                                                                                                                                                                                                                                                                                                                                                                    |
| 220 KV CHANDRAPUR GCR (400 KV) - GRACE CKT         | IntraState                   | 15/10/2024      | 09:56           | 15/10/2024 | 16:18         | PO             | Relay testing and Isolator Maintenance work                                                                                                                                                                                                                                                                                                                                                        |
| KHADKA- DEEPNAGAR CKT 2                            | IntraState                   | 15/10/2024      | 10:52           | 15/10/2024 | 19:28         | PO             | for daignostic testing and routine bay maintaaince work at Khadka end                                                                                                                                                                                                                                                                                                                              |
| CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2         | IntraState                   | 15/10/2024      | 11:45           | 15/10/2024 | 20:21         | PO             | For replacement of polymer insulator string with long rod porcelain insulator string.                                                                                                                                                                                                                                                                                                              |
| PADGHE - KALWA CKT - 1                             | IntraState                   | 16/10/2024      | 06:36           |            |               | PO             | 1) Replacement of 29A bus PG isolator under LES scheme<br>2) A & B bus PG Isolator maint work<br>3) line will be in service through TBC . If required/ any emergency line will be charged on B bus .<br>4) Diagnostic Testing of CB                                                                                                                                                                |
| <b>400 KV ICT Outages/Trippings</b>                |                              |                 |                 |            |               |                |                                                                                                                                                                                                                                                                                                                                                                                                    |
| STATION TF No 3 @ CHANDRAPUR GCR                   | IntraState                   | 01/03/2023      | 15:07           |            |               | PO             | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                                                                                                                                                                                                     |
| 400/132 KV 200 MVA ICT - 2 @ KHADKA                | IntraState                   | 03/06/2024      | 23:26           |            |               | T              | Differential protection                                                                                                                                                                                                                                                                                                                                                                            |
| 400/220/33 KV 500MVA ICT - 2 @ KORADI 2            | IntraState                   | 15/10/2024      | 10:56           | 15/10/2024 | 20:07         | PO             | 1) Diagnostic testing( Tan delta Measurement) of bushing of ICT#2 & CVT at Bay 420                                                                                                                                                                                                                                                                                                                 |
| 400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE           | IntraState                   | 15/10/2024      | 11:11           | 15/10/2024 | 18:50         | PO             | Protection cold trials of Rapid Restoration System(RRS) scheme                                                                                                                                                                                                                                                                                                                                     |
| STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS | IntraState                   | 15/10/2024      | 13:37           | 15/10/2024 | 20:04         | T              | Mechanical protection operated.                                                                                                                                                                                                                                                                                                                                                                    |
| <b>400 KV BR Outages/Trippings</b>                 |                              |                 |                 |            |               |                |                                                                                                                                                                                                                                                                                                                                                                                                    |
| BUS REACTOR (80 MVAR) - 1 @ BABHALESHWAR           | IntraState                   | 07/10/2024      | 09:40           |            |               | PO             | The work of Dismantling of existing 80 MVAR replacement by 125 MVAR bus reactor along with allied requirement at 400KV Bableshwar has been entrusted to M/s RK Electrical vide Zone office order no. 1258 dtd 12.08.2022. Following work are proposed on reactor 1 1) Dismantling of reactor 1 2) Erection of new 125 MVAR reactor 3) Commissioning work 4) Replacement work as per the work order |
| <b>220 KV MAINBAY Outages/Trippings</b>            |                              |                 |                 |            |               |                |                                                                                                                                                                                                                                                                                                                                                                                                    |
| 220KV BUS SECTION BAY @ PEDAMBE                    | IntraState                   | 03/04/2024      | 15:55           |            |               | T              | Tripped due to Y ph CT burst                                                                                                                                                                                                                                                                                                                                                                       |
| <b>220 KV LINE Outages/Trippings</b>               |                              |                 |                 |            |               |                |                                                                                                                                                                                                                                                                                                                                                                                                    |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 15/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 16/Oct/2024

| Name of Line                               | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                                                                                 |
|--------------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| BALE - SOLAPUR (PG)                        | InterState                   | 19/06/2024      | 08:56           |            |               | PO             | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A)<br>2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                                                                                                                                                 |
| APTA - NAVI MUMBAI (PG) CKT - 1            | InterState                   | 15/10/2024      | 08:20           | 15/10/2024 | 15:43         | HT             | Load management                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| 220 KV HARANGUL - PARLY (PG) CKT           | InterState                   | 15/10/2024      | 12:27           | 15/10/2024 | 19:10         | EO             | Hotspot attending work at loc.no. 29 R ph                                                                                                                                                                                                                                                                                                                                                                                                                        |
| 220 KV HARANGUL - PARLY (PG) CKT           | InterState                   | 15/10/2024      | 12:27           | 15/10/2024 | 19:10         | EO             | To attend Hot Spot                                                                                                                                                                                                                                                                                                                                                                                                                                               |
| OSMANABAD - SOLAPUR (BALE)                 | IntraState                   | 19/06/2024      | 09:15           |            |               | PO             | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                                                                                                                                                    |
| WAGHIVALI (MSETCL) - ULWE GIS CKT - 2      | IntraState                   | 25/06/2024      | 08:05           |            |               | T              | Tripped on differential protection.                                                                                                                                                                                                                                                                                                                                                                                                                              |
| GHODBUNDER - GORAI                         | IntraState                   | 29/07/2024      | 12:14           |            |               | PO             | Bunching activity on line to form newly reconfigured line as 220kV Ghodbunder-Versova Line-2 for outage of 220kV Gorai EHV Station.                                                                                                                                                                                                                                                                                                                              |
| 220kV Koradi-2 - Uppalwadi ckt 2           | IntraState                   | 28/08/2024      | 00:14           |            |               | T              | Distance Protection                                                                                                                                                                                                                                                                                                                                                                                                                                              |
| EKLAHARE (OCR) - PADGHE                    | IntraState                   | 24/09/2024      | 07:48           |            |               | HT             | For load mgmt                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
| 220KV KORADI II (400KV)- BUTIBORI 3 CKT I  | IntraState                   | 01/10/2024      | 13:10           |            |               | HT             | H/T From Butibori 3 end                                                                                                                                                                                                                                                                                                                                                                                                                                          |
| 220KV KORADI II(400KV) - BUTIBORI 3 CKT II | IntraState                   | 01/10/2024      | 13:11           |            |               | HT             | H/T From Koradi 2 end                                                                                                                                                                                                                                                                                                                                                                                                                                            |
| EKLAHARE (OCR) - NAVASARI CKT - 1          | IntraState                   | 07/10/2024      | 15:10           |            |               | HT             | H/T For load management.                                                                                                                                                                                                                                                                                                                                                                                                                                         |
| EKLAHARE (OCR) - NAVASARI CKT - 2          | IntraState                   | 09/10/2024      | 12:00           |            |               | PO             | 1) PLCC, CVT, WT Foundation , Erection, Testing & Commissioning work at 220kV Navsari substation 2) PLCC, CVT, WT Erection, Testing & Commissioning work at 220kV Eklahare (OCR) substation                                                                                                                                                                                                                                                                      |
| APTA - TALOJA                              | IntraState                   | 10/10/2024      | 23:32           | 15/10/2024 | 08:06         | PO             | Erection of 2 No. of double circuit inline tower between Loc no. 625 to 626 with complete erection, stringing, dismantling of existing suspension tower etc. for LLO arrangement at 220kV PGCIL Navi Mumbai substation under MUML. During this outage period following maintenance work will be carried out by EHV Lines S/Dn Panvel - Jumper nut bolt tightening from Loc no. 584 to 638. Emergency tree cutting work etc.(Line reload as a Taloja-Navi mumbai) |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 15/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 16/Oct/2024

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                                             |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| APTA - PRINT HOUSE LINE                           | IntraState                | 10/10/2024   | 23:43        | 15/10/2024 | 16:25      | PO          | Erection of 2 No. of double circuit inline tower between Loc no. 625 to 626 with complete erection, stringing, dismantling of existing suspension tower etc. for LILO arrangement at 220kV PGCIL Navi Mumbai substation under MUMIL. During this outage period following maintenance work will be carried out by EHV Lines S/Dn Panvel - Jumper nut bolt tightening from Loc no. 584 to 638. Emergency tree cutting work etc |
| KARAD - DASGAON                                   | IntraState                | 14/10/2024   | 15:46        |            |            | PO          | i)Dismantling of Exst. S/C Tower Loc. No. 160 of 220 KV KaradDasgaon (Pedambe) line.<br>ii) Foundation of In-Line M/C Narrow Base Tower (MCN+3).<br>iii) Erection of Tower & stringing of 220 KV Karad - Dasgaon & 220 Karad Koyana line                                                                                                                                                                                     |
| 220 KV GIRWALI (400 KV) -PARLI U -8 CKT           | IntraState                | 15/10/2024   | 00:56        | 15/10/2024 | 10:46      | T           | Distance Protection                                                                                                                                                                                                                                                                                                                                                                                                          |
| HINJAWADI I- CHINCHWAD                            | IntraState                | 15/10/2024   | 06:54        | 15/10/2024 | 23:25      | HT          | For Load Management                                                                                                                                                                                                                                                                                                                                                                                                          |
| ALEPHATA-PARGAON(KATHAPUR)                        | IntraState                | 15/10/2024   | 07:31        |            |            | HT          | For Load Management                                                                                                                                                                                                                                                                                                                                                                                                          |
| MAHALAXMI - AMONA                                 | IntraState                | 15/10/2024   | 09:43        | 15/10/2024 | 16:53      | PO          | For replacement of old Polymer insulator from loc. No.330 to 372                                                                                                                                                                                                                                                                                                                                                             |
| EKLAHARE (GCR) - AIROLI KNOW PARK                 | IntraState                | 15/10/2024   | 09:48        | 15/10/2024 | 21:38      | HT          | Line hand tripped for load management.                                                                                                                                                                                                                                                                                                                                                                                       |
| GOREGAON - VERSOVA CKT - 2                        | IntraState                | 15/10/2024   | 10:13        | 15/10/2024 | 16:10      | EO          | To replace broken operating rod of 1189B isolator                                                                                                                                                                                                                                                                                                                                                                            |
| GHATGHAR - JINDAL                                 | IntraState                | 15/10/2024   | 10:31        | 16/10/2024 | 02:14      | HT          | For Load Management                                                                                                                                                                                                                                                                                                                                                                                                          |
| 220 KV PHULAMBRI - BHOKARDHAN                     | IntraState                | 15/10/2024   | 10:37        | 15/10/2024 | 19:35      | PO          | Line stringing work of 220KV nagewadi-Bhokardhan line                                                                                                                                                                                                                                                                                                                                                                        |
| BHANDARA-SUNFLAG 1                                | IntraState                | 15/10/2024   | 12:12        | 15/10/2024 | 15:45      | PO          | Installation of special energy meter by Discom                                                                                                                                                                                                                                                                                                                                                                               |
| 220KV KURUNDA -GIRWALI CKT                        | IntraState                | 15/10/2024   | 12:36        | 15/10/2024 | 13:49      | EO          | To attend Hot Spot                                                                                                                                                                                                                                                                                                                                                                                                           |
| TALOJA - PANCHANAND                               | IntraState                | 15/10/2024   | 14:30        | 15/10/2024 | 16:03      | EO          | To attend Red hot spot observed on middle phase jumper cone of 220kV Panchanand-Taloja line at Taloja LILO portion loc. No. 4                                                                                                                                                                                                                                                                                                |
| 132 KV KALMESHVAR (220 KV) - PATANSAWANGI TSS CKT | IntraState                | 15/10/2024   | 15:34        | 15/10/2024 | 00:33      | T           | Distance Protection                                                                                                                                                                                                                                                                                                                                                                                                          |
| PEDAMBE-KALAMBANI(TSS)                            | IntraState                | 15/10/2024   | 15:53        | 15/10/2024 | 20:13      | PO          | Urgent testing of Distance Relay of 220KV Pedhambe line at 220KV Kalambani TSS. Testing of Auto Reclosure trials to be done.                                                                                                                                                                                                                                                                                                 |
| PALGHAR - NALASOPARA                              | IntraState                | 15/10/2024   | 15:58        | 15/10/2024 | 19:22      | T           | Line tripped on distance protection.                                                                                                                                                                                                                                                                                                                                                                                         |
| TALOJA - PANCHANAND                               | IntraState                | 15/10/2024   | 16:03        |            |            | HT          | Line charged from panchanand end only , kept off from taloja end for load management.                                                                                                                                                                                                                                                                                                                                        |
| KADEGAON-MIRAJ                                    | IntraState                | 15/10/2024   | 16:21        | 15/10/2024 | 20:10      | PO          | 1. Replacement work of R Ph LA<br>2.Quarterly maintenance Work                                                                                                                                                                                                                                                                                                                                                               |
| KALWA - PRINT HOUSE LINE                          | IntraState                | 15/10/2024   | 16:31        |            |            | HT          | Hand tripped at Kalwa end for load management.                                                                                                                                                                                                                                                                                                                                                                               |
| EKLAHARE (GCR) - AIROLI KNOW PARK                 | IntraState                | 15/10/2024   | 22:33        |            |            | HT          | H/T for load management.                                                                                                                                                                                                                                                                                                                                                                                                     |
| ADLABS - PEDAMBE                                  | IntraState                | 15/10/2024   | 22:48        | 15/10/2024 | 23:46      | T           | Tripped on distance protection.                                                                                                                                                                                                                                                                                                                                                                                              |
| PEDAMBE-KALAMBANI(TSS)                            | IntraState                | 15/10/2024   | 22:57        |            |            | T           | Tripped on distance protection.                                                                                                                                                                                                                                                                                                                                                                                              |
| KANDALGAON - KOYNA (POPHALI)                      | IntraState                | 15/10/2024   | 23:08        |            |            | T           | Tripped on distance protection.                                                                                                                                                                                                                                                                                                                                                                                              |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 15/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 16/Oct/2024

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                       |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------|
| KOLSHET - KHARBAO                                 | IntraState                | 16/10/2024   | 00:20        | 16/10/2024 | 04:28      | PO          | For safety purpose for Work of metro rail project under near kolshet s/s                                               |
| 132 KV KALMESHVAR (220 KV) - PATANSAWANGI TSS CKT | IntraState                | 16/10/2024   | 15:34        | 16/10/2024 | 00:33      | T           | Distance Protection                                                                                                    |
| <b>220 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                        |
| 220/132 KV 100 MVA ICT 1@ BABHALESHWAR            | IntraState                | 12/07/2024   | 13:35        |            |            | PO          | Augmentation of 220/132kV 100MVA to 220/132kV 200MVA at Babheshwar.                                                    |
| 220/22KV 50MVA PTR 3 @ BHOSARI 2                  | IntraState                | 24/07/2024   | 23:02        |            |            | T           | Tripped due to caught fire.                                                                                            |
| 220/132 KV 100 MVA ICT I @ UPPALWADI              | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                            |
| 220/132 KV 100 MVA ICT II @ UPPALWADI             | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                            |
| 220/132 KV 100 MVA ICT - 1 @ ALEPHATA             | IntraState                | 23/09/2024   | 03:31        | 15/10/2024 | 20:50      | T           | Tripped on internal fault and main Buchholz.                                                                           |
| 220/33KV 50MVA PTR 2@ PETH                        | IntraState                | 15/10/2024   | 10:02        | 15/10/2024 | 16:12      | PO          | Quarterly Maintenance Work                                                                                             |
| 220/132 KV 100 MVA ICT 2                          | IntraState                | 15/10/2024   | 11:24        | 15/10/2024 | 16:35      | PO          | Replacement of HV R&B phase LA                                                                                         |
| 100 MVA 220/132 KV ICT - III @ HINGOLI            | IntraState                | 15/10/2024   | 13:12        | 15/10/2024 | 21:20      | PO          | To attend DC Earth Leakage                                                                                             |
| 220/33 KV 100 MVA PTR 1                           | IntraState                | 15/10/2024   | 15:42        | 15/10/2024 | 18:05      | PO          | Annual Testing work                                                                                                    |
| 220/132 KV 100 MVA ICT 1                          | IntraState                | 15/10/2024   | 18:12        | 15/10/2024 | 20:23      | PO          | Annual Testing work                                                                                                    |
| <b>220 KV BUSBAR Outages/Trippings</b>            |                           |              |              |            |            |             |                                                                                                                        |
| MAIN BUS - 1 @ PRINT HOUSE                        | IntraState                | 15/10/2024   | 12:23        | 15/10/2024 | 12:23      | PO          | Removal of MSEDCL Bus-I Check & Bus-II Check tariff meter with check summator meter for reprogramming for Open Access. |
| MAIN BUS - 2 @ PRINT HOUSE                        | IntraState                | 15/10/2024   | 12:32        | 15/10/2024 | 13:05      | PO          | Removal of MSEDCL Bus-I Check & Bus-II Check tariff meter with check summator meter for reprogramming for Open Access. |
| <b>132 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                        |
| MANSAR-PENCH                                      | InterState                | 26/09/2024   | 14:40        |            |            | HT          | H/T at 132KV Pench end                                                                                                 |
| RISOD-YELDARI                                     | IntraState                | 14/10/2024   | 13:55        | 15/10/2024 | 12:25      | T           | B Phase string decaping                                                                                                |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage