

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 15/Nov/2019 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	129.408	1549.049	1) Gujrat	3.119	41.683
2) Hydro	7.102	129.723	2) Madhya Pradesh	8.817	114.859
3) Gas	10.231	118.988	3) Chattisgarh	7.130	97.420
Total MSPGCL	146.741	1797.760	4) Maharashtra	111.520	1683.096
B) 1) APML	65.841	1046.125	5) Goa (Amona)	-0.682	-7.810
2) JSWEL	19.087	296.407	Total	129.904	1929.248
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.173	385.232
4) RPL(AMT)	0.000	49.977	b) Mumbai Drawl	29.686	428.028
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	26.141	370.483
6) Other IPP	6.753	119.150	Include PX	0.667	-0.644
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.173	385.232
C) 1) TPCL Thermal	13.278	202.328	Include PX	9.028	135.358
2) TPCL Hydro	4.423	61.461	Standby	0.000	0.000
3) TPCL Gas	4.360	62.814	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.709	148.151	1) MSEDCL	351.438	4998.369
D) STATE			2) Mumbai Discoms	61.456	902.777
1) Thermal	244.076	3411.187	TOTAL STATE	412.894	5901.146
(A1+C1+C4+(B1-B6))					
2) Hydro	11.525	191.184			
(A2+C2)					
3) Gas	14.591	181.802			
(A3+B7+C3)					
4) Wind	7.758	106.420			
6) SOLAR	5.040	81.310			
TOTAL STATE	282.990	3971.903			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	5275	5216	5941	4943
MSPGCL Hydro	444	129	395	78
MSPGCL Gas	422	419	428	438
MSPGCL Total Generation	6141	5764	6764	5459
Central Sector Receipt	6087	6288	5829	4338
WIND	302	220	236	494
CPP / IPP Thermal	4035	4206	4358	3304
CPP / IPP Gas	0	0	0	0
SOLAR	796	830	0	0
Exchange with Mumbai	-1661	-1746	-1279	-1010
MSEDCL DEMAND MET	15700	15562	15908	12585
Load Shedding	0	0	0	0
MSEDCL DEMAND	15700	15562	15908	12585
TPCL GENERATION	1076	937	1224	666
AEML GENERATION	375	374	472	373
MUMBAI DEMAND	3112	3057	2975	2049
STATE DEMAND MET	18812	18619	18883	14634
STATE DEMAND	18812	18619	18883	14634
Frequency (Hz)	50.04	49.98	50.05	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.23 Hz at 05.02 Hrs	49.78 Hz at 09.11 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 15/Nov/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	11.38	162.02	545	330
Unit 9	11.82	168.95	527	460
Unit 10	10.14	139.18	500	311
Total	33.35	470.15		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.72	140.03	390	345
Unit 5	8.78	141.40	410	350
Total	17.50	281.42		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.16	18.13	248	191
Unit 7	5.16	17.88	252	187
Unit 8	4.96	19.23	224	187
Total	15.28	55.24		
Chandrapur				
Unit 3	4.10	46.37	187	163
Unit 4	0.00	0.00	0	0
Unit 5	8.85	102.25	380	353
Unit 6	9.68	113.38	460	354
Unit 7	0.00	0.00	0	0
Unit 8	9.92	148.50	490	360
Unit 9	9.17	136.57	455	307
Total	41.72	547.06		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Total	0.00	0.00		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	3.86	4.42	190	135
Unit 4	3.72	10.69	170	150
Unit 5	9.86	123.47	500	360
Total	17.45	138.58		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.12	51.70	197	161
Unit 5	0.00	4.91	0	0
Total	4.12	56.60		
Uran				
All Units	10.23	118.99	449	387
Total	10.23	118.99		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.12	5.04	47	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.12	5.04		
Koyna				
Stage 1-2	2.26	42.32	415	35
Stage 4	2.66	44.76	973	0
Stage 3	0.69	19.21	160	0
Total	5.61	106.29		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.07	1.61	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.31	4.50	80	0
RNGR+BHTSA	0.39	3.85	17	16
BHANDARDRA	0.00	0.19	0	0
ELDARY	0.54	4.71	24	22
SMLHY_PTN	0.00	3.87	0	0
GHATGHAR	0.17	4.69	125	0
Total	1.49	23.44		
Wind				
Total	7.76	106.42	0	0
Total	7.76	106.42		
CPP				
APML(Mus)	65.84	1046.12	0	0
JSWEL(Mus)	19.09	296.41	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	49.98	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	6.75	119.15	0	0
Total	91.68	1511.66		
SOLAR				
Total	5.04	81.31	0	0
Total	5.04	81.31		
Tata				
Trombay 5	8.50	130.92	485	288
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	39.77	116	115
Trombay 7B	1.58	23.04	67	65
Trombay 8	4.77	71.40	202	196
TATA Hydro	4.42	61.46	402	0
Total	22.06	326.60		
AEML				
DTPS U-1&2	9.71	148.15	501	372
Total	9.71	148.15		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	129.41	1549.05	MSPGCL Total	146.74	1797.76
			MSPGCL Thml+Gas	139.64	1668.04	Koyna 1,2 & 4 Total	4.92	87.07
			MSPGCL Hydro	7.10	129.72	State Total	282.99	3971.90

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 15/Nov/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4983	73	435	5491	520	3302	0	0	4807	4642	-1160	12795	0	12795	2218	15013	49.96
2	4943	78	438	5459	494	3304	0	0	4429	4338	-1010	12585	0	12585	2049	14634	50.00
3	4952	123	439	5514	576	3314	0	0	4190	4238	-894	12748	0	12748	1933	14681	50.02
4	4962	115	447	5524	496	3309	0	0	4193	4294	-800	12823	0	12823	1842	14665	50.02
5	4952	83	437	5472	433	3312	0	0	4506	4721	-789	13149	0	13149	1832	14981	50.03
6	5620	138	448	6206	375	3596	0	0	5073	5174	-858	14493	0	14493	1923	16416	50.03
7	5711	1026	439	7176	347	3811	0	6	5350	5021	-757	15604	0	15604	2062	17666	49.99
8	5746	1243	449	7438	243	3790	0	130	5511	5571	-823	16349	0	16349	2220	18569	50.02
9	5877	1021	438	7336	245	3786	0	342	5545	5461	-955	16215	0	16215	2497	18712	50.01
10	5923	456	429	6808	301	3777	0	565	5735	5628	-1100	15979	0	15979	2809	18788	49.92
11	5447	494	425	6366	273	3761	0	671	5948	5849	-1396	15524	0	15524	3024	18548	50.02
12	5275	444	422	6141	302	4035	0	796	6127	6087	-1661	15700	0	15700	3112	18812	50.04
13	5216	129	419	5764	220	4206	0	830	6365	6288	-1746	15562	0	15562	3057	18619	49.98
14	5192	105	409	5706	224	4057	0	682	6390	6313	-1662	15320	0	15320	2931	18251	49.95
15	5192	173	401	5766	216	4046	0	528	6339	6344	-1684	15216	0	15216	2982	18198	49.98
16	5781	205	387	6373	172	4243	0	322	6060	5606	-1464	15252	0	15252	3011	18263	50.04
17	5865	85	387	6337	174	4263	0	149	5905	5706	-1482	15147	0	15147	2970	18117	49.98
18	5861	79	397	6337	173	4259	0	19	5782	5874	-1458	15204	0	15204	2929	18133	50.01
19	5941	395	428	6764	236	4358	0	0	5812	5829	-1279	15908	0	15908	2975	18883	50.05
20	5615	309	428	6352	350	4229	0	0	5823	5532	-1303	15160	0	15160	2858	18018	50.06
21	5121	96	429	5646	337	3878	0	0	5668	5867	-1382	14346	0	14346	2713	17059	50.03
22	5143	79	428	5650	393	3701	0	0	5218	5406	-1325	13825	0	13825	2579	16404	50.02
23	5101	74	432	5607	335	3688	0	0	4991	5134	-1345	13419	0	13419	2492	15911	50.00
24	4989	79	440	5508	323	3656	0	0	4861	4981	-1353	13115	0	13115	2438	15553	50.02
MUs	129.41	7.10	10.23	146.74	7.76	91.68	0.00	5.04	130.63	129.90	-29.69	351.44	0.00	351.44	61.46	412.89	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 15/Nov/2019

Position as on 6.30 Hrs of 16/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn On Shaft Seal Water Leakage.Converted to AOH From 1 Nov 2019.	
MSPGCL	Koyna Unit 7	80	31/10/2019	16.30		Continued.	Turbine Vibration(converted to Capital Overhaul for 60 Days from 09.00Hrs DT.01-11-2019)	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Khaparkheda Unit 1	210	12/10/2019	00.11		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	12/10/2019	00.17		Continued.	Zero Schedule	
MSPGCL	Paras Unit 3	250	23/10/2019	00.00		Continued.	Zero Schedule	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Chandrapur Unit 4	210	31/10/2019	08.16		Continued.	Excessive Consumption of Hydrogen Cylinder.	
MSPGCL	Nasik Unit 5	210	02/11/2019	10.35		Continued.	Boiler Tube Leakage(Converted to Zero Schedule from 19.05Hrs DT.03-11-2019)	
MSPGCL	Uran Unit 8	108	06/11/2019	19.23		Continued.	Turbine Vibration	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 15/Nov/2019

Position as on 6.30 Hrs of 16/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	RPL(AMT) U-5	270	09/11/2019	03.00		Continued.	Zero Schedule By MSEDCL.	
IPP	JSW (J) U3	300	10/11/2019	18.16		Continued.	Zero schedule.	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 16/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400kV 1500MVA ICT-I@Koradi-III	IntraState	15/11/2019	08.49	15/11/2019	18.27	PO	Routine Maintenance Work
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	12/11/2019	17.50	16/11/2019	09.10	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	16/11/2019	17.58		Continued.	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt I	IntraState	27/10/2019	14.07		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	14/11/2019	19.44	15/11/2019	08.20	HT	Over Voltage
Main Bus 1@Nagothane	IntraState	15/11/2019	06.38	15/11/2019	08.28	T	Bus Fault Due to Dabhol Ckt-1 R-phase CT Blast.
Main Bus-2 @Nagothane S/st.	IntraState	15/11/2019	06.38	15/11/2019	08.28	T	Bus Fault Due to Dabhol Ckt-1 R-Phase CT Blast.
Nagothane - Dabhol I	IntraState	15/11/2019	06.38	16/11/2019	15.53	T	R Phase CT Burst at Nagothane and Main Bus I&II operated alongwith Bus Coupler.
Nagothane - Dabhol-II	IntraState	15/11/2019	06.38	15/11/2019	08.44	T	Bus Bar Operated at Nagothane
Padghe - Nagothane - II	IntraState	15/11/2019	06.38	15/11/2019	08.28	T	Bus Bar Operated at Nagothane
Padghe - Nagothane - I	IntraState	15/11/2019	06.38	15/11/2019	09.10	T	Bus Bar operated at Nagothane
Akola II - Akola I Ckt-II	IntraState	15/11/2019	09.41	15/11/2019	18.34	PO	Routine Maintenance Work
Koradi-Khaperkheda li	IntraState	15/11/2019	10.03	15/11/2019	17.36	PO	Routine Maintenance Work
Dhule- Bableswhar - I	IntraState	15/11/2019	20.18	16/11/2019	08.02	HT	Over Voltage
Jaigad-Karad Ckt-II	IntraState	15/11/2019	23.48		Continued.	HT	Over Voltage
Kalwa - Kharghar	IntraState	16/11/2019	08.57	16/11/2019	22.57	PO	Relay Replacement Work.
Babhaleshwar - Padghe-II	IntraState	16/11/2019	11.17	16/11/2019	16.04	EO	Shifted On TBC At Padgha End.
Khadka-Aurangabad (Waluj)	IntraState	16/11/2019	17.30		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	15/11/2019	06.02	15/11/2019	08.05	PO	C.T Oil Leakage Work.
400/220/33 Kv 315 MVA ICT -I @Nagothane	IntraState	15/11/2019	06.38	15/11/2019	08.53	T	Bus Bar operated at Nagothane
400/220/33 Kv 315 MVA ICT- 2 @Nagothane	IntraState	15/11/2019	06.38	15/11/2019	08.48	T	Bus Bar operated at Nagothane
400/220/33 Kv 500 Mva Ict-3 @Nagothane	IntraState	15/11/2019	06.38	15/11/2019	08.38	T	Bus Bar operated at Nagothane
400/220 Kv 315 Mva Ict -2 @New Koyna	IntraState	15/11/2019	10.04	15/11/2019	19.08	PO	Routine Maintenance Work
400/220/33 Kv 315 MVA ICT II @Babhleshwar	IntraState	16/11/2019	09.36	16/11/2019	19.55	PO	Routine Maintenance Work
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Tillari Amona	InterState	15/11/2019	07.40	15/11/2019	09.35	T	D.C Earth Fault.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Lonikand-II- Kathapur	IntraState	14/11/2019	01.51	15/11/2019	07.23	PO	Construction work.
Lonikand2-Lonikand1 (Interconector)	IntraState	14/11/2019	09.40	15/11/2019	02.40	PO	Construction Work.
Lonikand1 (400 Kv)-Theur II	IntraState	14/11/2019	10.02	15/11/2019	02.32	PO	To Make Twin Conductor Arrangement Of 220Kv Lonikand 1-I Lonikand-2 Interconnector.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 16/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Lonikand-VSNL	IntraState	14/11/2019	11.03	15/11/2019	01.53	PO	To Make Twin Conductor Arrangement Of 220Kv Lonikand 1-Lonikand-2 Interconnector.
Goregaon Versova Line 2	IntraState	14/11/2019	11.07	15/11/2019	07.04	PO	OPGW Restranging.
Lonikand2 - Bhosari1	IntraState	15/11/2019	02.59	15/11/2019	07.23	PO	Construction Work.
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	15/11/2019	08.14	15/11/2019	09.27	T	Distance Protection
ANANDNAGAR - PALAVA	IntraState	15/11/2019	09.33	15/11/2019	17.55	PO	Routine Maintenance Work
Pedambe-Pophali	IntraState	15/11/2019	09.35	15/11/2019	09.45	EO	Attending Hot Spot
Washala - Ghatghar	IntraState	15/11/2019	09.42	15/11/2019	17.20	PO	Earth Wire Replacement Work.
Hamidwada-Mumewadi	IntraState	15/11/2019	10.05	15/11/2019	14.56	PO	Routine Maintenance Work
Kanhan-Umred 1	IntraState	15/11/2019	10.20	15/11/2019	19.58	PO	Conversion of SSN To DSN For Measurement Tan Delta of CT, CC.
Vita - Ghatnandre	IntraState	15/11/2019	10.22	15/11/2019	17.45	PO	Tan Delta Measurement Work.
BHUGAON WARORA CKT-II	IntraState	15/11/2019	10.40	15/11/2019	16.43	PO	Measurement of CRM and CB Timing NT Switch Replacement Work By Testing Unit Wardha.
Kharghar-Borivali ckt II	IntraState	15/11/2019	10.58	16/11/2019	10.09	PO	Stringing of OPGW
Malegaon-Satana	IntraState	15/11/2019	11.18	15/11/2019	15.14	EO	Attending Hot Spot
Vita-Wayphale	IntraState	15/11/2019	14.00	15/11/2019	15.18	EO	Emergency Tree Cutting.
Mumewadi-Belewadi	IntraState	15/11/2019	15.06	15/11/2019	17.37	PO	Routine Maintenance Work
Pusad - Hingoli	IntraState	15/11/2019	16.53	15/11/2019	18.57	PO	Quarterly Maintenance Work
Trombay - Mulund	IntraState	15/11/2019	20.08	16/11/2019	11.19	PO	Tower Piling Work.
Pusad-Ghatodi	IntraState	16/11/2019	08.07	16/11/2019	12.04	PO	Routine Maintenance Work
Ghatghar - Jindal	IntraState	16/11/2019	09.00	16/11/2019	15.06	PO	Earth wire Replacement.
Washala - Ghatghar	IntraState	16/11/2019	09.30	16/11/2019	17.45	PO	Earth wire Replacement.
Talandage - Sawantwadi I	IntraState	16/11/2019	09.47	16/11/2019	13.15	PO	Replacement Of Faulty Disc Insulator.
Bhugaon-WardhaPG (Deoli)	IntraState	16/11/2019	10.22	16/11/2019	17.57	PO	Tan Delta Measurement Replacement Work.
Chinchwad-Hinjewadi I	IntraState	16/11/2019	11.28	16/11/2019	19.41	HT	To Control Loading.
Mumewadi -Halkarni ckt-I	IntraState	16/11/2019	11.32	16/11/2019	13.04	PO	R.M. Work CB Timing, CRM Testing R.M Work.
Akola-Paras Ckt No-I	IntraState	16/11/2019	11.36	16/11/2019	17.47	PO	TNC Switch Replacement Work.
CHAKAN (400 KV)- Chinchwad2	IntraState	16/11/2019	11.54	16/11/2019	19.04	PO	Rplacement Of Insulator.
Mumewadi -Halkarni ckt-II	IntraState	16/11/2019	14.26	16/11/2019	16.46	PO	R.M. Work CB Timing, CRM Testing R.M Work.
Trombay - Mulund	IntraState	16/11/2019	19.59		Continued.	PO	Piling work At LOC 5 Completed.
220 KV ICT Outages/Trippings							
220/132 Kv 200 MVA ICT II @Babhleshwar	IntraState	16/11/2019	09.36	16/11/2019	19.55	PO	Routine Maintenance Work
100 MVA ICT I at Kandalgaon	IntraState	16/11/2019	10.47	16/11/2019	14.05	EO	Attending Hot Spot

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage