

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 15/Dec/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	151.268	2206.113	1) Gujrat	-7.658	-83.643
2) Hydro	13.160	156.407	2) Madhya Pradesh	2.663	20.419
3) Gas	3.313	74.210	3) Chattisgarh	5.160	81.260
Total MSPGCL	167.741	2436.730	4) Maharashtra	178.995	2514.988
B) 1) APLM	62.262	1027.281	5) Goa (Amona)	-1.184	-20.121
2) JSWEL	13.721	190.739	Total	177.976	2512.903
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.447	424.440
4) RPL(AMT)	29.449	409.040	b) Mumbai Drawl	38.946	493.186
5) SWPGPL	9.116	119.941	c) MSEDCL Bilateral *	77.032	1108.118
6) Other IPP	43.739	660.281	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.432	424.425
C) 1) TPCL Thermal	10.170	166.100	Include PX	0.000	0.000
2) TPCL Hydro	5.419	54.510	Standby	0.015	0.015
3) TPCL Gas	0.000	25.785	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.557	147.301	1) MSEDCL	472.584	7050.113
D) STATE			2) Mumbai Discoms	65.092	886.880
1) Thermal	330.282	4926.796	3) Other Discoms	9.529	140.974
(A1+C1+C4+(B1-B6))			TOTAL STATE	547.205	8077.967
2) Hydro (A2+C2)	18.579	210.917			
3) Gas (A3+B7+C3)	3.313	99.995			
4) Wind	6.973	174.005			
6) SOLAR	10.082	153.353			
TOTAL STATE	369.229	5565.066			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6547	6333	6550	5582
MSPGCL Hydro	836	131	1799	138
MSPGCL Gas	137	136	135	139
MSPGCL Total Generation	7520	6600	8484	5859
Central Sector Receipt	9201	8935	7111	6182
WIND	262	260	205	425
CPP / IPP Thermal	6652	6665	6757	6399
CPP / IPP Gas	0	0	0	0
SOLAR	1367	1615	1	0
Exchange with Mumbai	-1970	-1965	-1703	-1388
MSEDCL DEMAND MET	22606	21693	20413	17150
Load Shedding	0	0	0	0
MSEDCL DEMAND	22606	21693	20413	17150
TPCL GENERATION	768	777	868	429
AEML GENERATION	491	501	502	299
MUMBAI DEMAND	3229	3243	3073	2116
OTHER DISCOM DEMAND	426	417	442	327
STATE DEMAND MET	26261	25353	23928	19593
STATE DEMAND	26261	25353	23928	19593
Frequency (Hz)	50.11	50.04	49.85	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 10:27 Hrs	49.64 Hz at 05:15 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 15/Dec/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	5.02	75.44	215	200
Unit 7	0.00	0.00	0	0
Unit 8	12.40	189.08	575	430
Unit 9	12.67	199.53	557	481
Unit 10	13.09	194.16	600	481
Total	43.19	658.21		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	11.07	144.68	490	345
Unit 5	11.20	149.52	495	280
Total	22.26	294.20		
Parli				
Unit 6	4.43	63.58	233	150
Unit 7	4.56	64.68	241	147
Unit 8	3.98	48.09	201	145
Total	12.97	176.35		
Chandrapur				
Unit 3	2.97	49.91	155	100
Unit 4	3.28	46.88	160	118
Unit 5	7.09	102.46	305	285
Unit 6	7.88	106.01	365	282
Unit 7	0.00	0.00	0	0
Unit 8	10.53	107.50	500	286
Unit 9	10.47	148.92	500	315
Total	42.22	561.69		
Paras				
Unit 3	4.92	60.66	217	182
Unit 4	0.00	63.01	3	0
Total	4.92	123.66		
Khaparkheda				
Unit 1	2.92	41.56	135	110
Unit 2	2.88	41.74	135	100
Unit 3	0.00	51.01	0	0
Unit 4	3.12	48.93	156	118
Unit 5	10.38	114.81	465	390
Total	19.30	298.05		
Nasik				
Unit 3	0.00	23.31	0	0
Unit 4	3.21	47.60	158	115
Unit 5	3.19	23.05	158	115
Total	6.40	93.96		
Uran				
All Units	3.31	74.21	144	132
Total	3.31	74.21		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.18	2.08	43	0
Total	0.18	2.08		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.72	48.14	575	40
Stage 4	3.86	41.73	750	0
Stage 3	2.08	19.84	310	0
Total	10.65	109.70		
Hydro				
KDPH	0.00	4.07	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.17	7.19	58	0
BHIRA T.R.	0.22	2.82	80	0
SMLHY_PTN	1.06	22.94	51	37
GHATGHAR	0.87	7.60	125	0
Total	2.33	44.63		
Wind				
Total	6.97	174.00	0	0
Total	6.97	174.00		
CPP				
APML(Mus)	62.26	1027.28	0	0
JSWEL(Mus)	13.72	190.74	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	29.45	409.04	0	0
SWPGPL-Mus	9.12	119.94	0	0
Other(Mus)	43.74	660.28	0	0
Total	158.29	2407.28		
SOLAR				
Total	10.08	153.35	0	0
Total	10.08	153.35		
Tata				
Trombay 5	6.06	110.59	261	248
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	14.03	0	0
Trombay 7B	0.00	11.76	0	0
TATA Hydro	5.42	54.51	433	16
Trombay 8	4.11	55.51	234	131
Total	15.59	246.40		
AEMIL				
DTPS U-1&2	10.56	147.30	502	294
Total	10.56	147.30		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	151.27	2206.11	MSPGCL Total	167.74	2436.73
			MSPGCL Thml+Gas	154.58	2280.32	Koyna 1,2 & 4 Total	8.57	89.87
			MSPGCL Hydro	13.16	156.41	State Total	369.23	5565.07

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 15/Dec/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5571	138	139	5848	457	6406	0	0	6309	6406	-1578	17178	0	17178	2416	361	19955	50.05
2	5462	138	141	5741	435	6349	0	0	6428	6445	-1488	17146	0	17146	2244	336	19726	50.00
3	5582	138	139	5859	425	6399	0	0	6291	6182	-1388	17150	0	17150	2116	327	19593	49.97
4	5862	79	141	6082	420	6380	0	0	6293	6114	-1327	17346	0	17346	2021	323	19690	50.02
5	5932	79	139	6150	413	6407	0	0	6666	6603	-1309	17931	0	17931	2000	333	20264	49.99
6	5809	100	141	6050	401	6430	0	0	7213	7418	-1321	18631	0	18631	2093	347	21071	49.86
7	6501	627	144	7272	388	6543	0	4	7034	7518	-1326	20025	0	20025	2258	374	22657	49.97
8	6732	1656	141	8529	330	6608	0	193	6582	6977	-1301	20921	0	20921	2431	415	23767	49.96
9	6672	1361	140	8173	235	6669	0	569	7402	7327	-1434	21127	0	21127	2712	412	24251	50.09
10	6606	734	140	7480	274	6664	0	1059	8464	8669	-1755	21965	0	21965	3008	426	25399	50.02
11	6547	836	137	7520	262	6652	0	1367	9072	9201	-1970	22606	0	22606	3229	426	26261	50.11
12	6512	229	137	6878	277	6631	0	1630	9320	9002	-1897	22100	0	22100	3285	421	25806	50.03
13	6333	131	136	6600	260	6665	0	1615	8891	8935	-1965	21693	0	21693	3243	417	25353	50.04
14	6348	125	135	6608	242	6660	0	1466	8575	8792	-1866	21515	0	21515	3090	387	24992	50.10
15	6470	88	134	6692	149	6673	0	1186	9175	9203	-1935	21556	0	21556	3116	412	25084	50.02
16	6592	180	132	6904	123	6646	0	674	9186	9173	-1780	21327	0	21327	3129	413	24869	49.92
17	6551	721	132	7404	122	6657	0	280	8384	8316	-1768	20578	0	20578	3107	433	24118	49.96
18	6591	1485	134	8210	125	6685	0	38	7252	7401	-1735	20279	0	20279	3055	445	23779	49.85
19	6550	1799	135	8484	205	6757	0	1	6568	7111	-1703	20413	0	20413	3073	442	23928	49.85
20	6581	1495	138	8214	206	6679	0	0	6419	6517	-1527	19649	0	19649	2949	440	23038	49.97
21	6468	488	139	7095	240	6654	0	0	6377	6475	-1659	18375	0	18375	2796	430	21601	50.02
22	6389	336	139	6864	272	6657	0	0	6095	6205	-1698	17871	0	17871	2662	429	20962	50.02
23	6443	108	140	6691	331	6680	0	0	6136	6024	-1621	17710	0	17710	2560	395	20665	50.00
24	6164	89	140	6393	381	6736	0	0	6410	5962	-1595	17492	0	17492	2499	385	20376	49.97
MUs	151.27	13.16	3.31	167.74	6.97	158.29	0.00	10.08	176.54	177.98	-38.95	472.58	0.00	472.58	65.09	9.53	547.21	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 15/Dec/2022

Position as on 6.30 Hrs of 16/Dec/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10	16/12/2022	00:56	ZERO SCHEDULE	
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
IPP	JSW (J) U2	300	10/12/2022	15:51		Continued.	NO SCHEDULE	
IPP	Adani U-5	660	10/12/2022	23:56		Continued.	COH activities.	10/01/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	23/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	Zero Schedule.	
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.(unit out due to coal shortage from 15.11.2022)	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	31/12/2022
IPP	RPL(AMT) U-3	270	05/12/2022	12:00	15/12/2022	05:31	Coal Shortage	
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25		Continued.	Boiler Tube Leakage. Unit on tolling from 22:00Hrs Dtd 09.12.2022	
MSPGCL	Paras Unit 4	250	13/12/2022	06:53	15/12/2022	11:16	Generator electrical protection	16/12/2022
MSPGCL	Uran Unit 6	108	14/12/2022	08:14		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 3	210	14/12/2022	21:00		Continued.	Boiler Validity Renevoation	16/12/2022
TPC-G	Trombay 7B	60	14/12/2022	23:33		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	14/12/2022	23:58		Continued.	Gas shortage	
MSPGCL	Paras Unit 4	250	15/12/2022	11:23	16/12/2022	03:21	Generator protection	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 16/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (411) OF TIRODA CKT - 1 @ WARORA	IntraState	15/12/2022	10:13	15/12/2022	16:24	PO	Annual Maintenance of Bay Equipment
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
KHARGHAR - TALEGAON (PG)	IntraState	03/12/2022	23:54			PO	For Tapping of 400KV Kalwa-Padgha-2 Line on KHARGHAR - TALEGAON (PG) so as to form temporary 400KV Kalwa-Kharghar -Talegaon Line for replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/12/2022	08:48			PO	For attending SF6 gas leakage
KHADKA-AURANGABAD (WALUJ)	IntraState	14/12/2022	20:31	15/12/2022	07:27	HT	HAND TRIPPED DUE TO OVER VOLTAGE.
JEJURI - KARAD	IntraState	15/12/2022	09:51	16/12/2022	06:50	HT	H/T FOR LOAD MANAGEMENT
KARAD - TALANDGE CKT - 1	IntraState	16/12/2022	06:19			T	TRIPPED ON DISTANCE PROTECTION
400 KV ICT Outages/Trippings							
400/11.5KV STATION TRANSFORMER - 4 @ TIRORA	IntraState	12/12/2022	09:53			PO	For bay equipment maintenance and testing work
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	15/12/2022	08:02	15/12/2022	20:50	PO	OLD CT CABLE HV &LV REPLACEMENT WORK.
400/220/33 KV 315 MVA ICT - 1 @ WALUJ	IntraState	15/12/2022	09:02	15/12/2022	20:41	PO	Shifting of ICT 1 LV 220KV Bay through TBC FROM 220KV MAIN BUS 1 TO MAIN BUS 2 FOR New 220KV Hybrid Switchgear Erection Work AND VICE VERSA AFTER COMPLITION OF WORK 2) Diagnostic Testing of 220KV Bus PT
167 MVA SPARE ICT @ TALANDGE	IntraState	15/12/2022	09:44	15/12/2022	18:07	PO	Quarterly maintenance work and annual testing
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	IntraState	15/12/2022	11:32	15/12/2022	18:45	PO	Shifting of ICT 2 LV 220KV Bay through TBC FROM 220KV MAIN BUS 1 TO MAIN BUS 2 FOR New 220KV Hybrid Switchgear Erection Work AND VICE VERSA AFTER COMPLITION OF WORK 2) Diagnostic Testing of 220KV Bus PT
400/220/33 KV 500 MVA ICT - 3 @ JEJURI	IntraState	15/12/2022	12:04	15/12/2022	18:47	PO	Annual testing & maintenance.
400 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ CHANDRAPUR 2	IntraState	15/12/2022	11:25	15/12/2022	17:27	PO	Diagnostic testing and allied bay maintenance work.
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ KARAD - 1	IntraState	15/12/2022	15:37	15/12/2022	19:28	PO	For CT Tan Delta & Quarterly Maintenance work.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	19/11/2022	14:33			HT	H/T TO CONTROL BBLR LINE LOADING
KALWA SALSETTE - 3	IntraState	01/12/2022	22:23			EO	Interchanging of BUS of 220KV Kalwa-Salshette-3 & 220KV Kalwa -Salshette-4 to free 220 kv TBC. 220 kv Kalwa Salsette 3 line on TBC from 12.11.2022 due to 29 A Bus damaged isolator.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 16/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA SALSETTE - 4	IntraState	01/12/2022	22:42			EO	Interchanging of BUS of 220 kV Kalwa-Salsette-3 & 220 kV Kalwa-Salsette-4 to free 220 kV TBC. 220 kV Kalwa Salsette 3 line on TBC from 12.11.2022 due to 29 A Bus damaged isolator.
PADGHE - NALASOPARA - VASAI (T)	IntraState	10/12/2022	05:21			PO	Work of bunching, removing jumper & changing orientation of lines for backup supply to Vasai Ss & Nalasopara S/stn:1) 220kV Kamba-Vasai line jumper will be open at loc. No. 51 for 7 days continuous i.e. 159 Hrs.2) 220kV Padgha-Nalasopara & Vasai Tap line-Jumper will open at loc. 54 for 7 days continuous & 220kV Vasai-Nalasopara link line will be in service for 7 days.3) 220kV Padghe & Nalasopara-Vasai Tap line bunching work will be done to 220kV Kamba-Vasai line between loc. No. 51 & 52 after that line orientation will be change i.e. 220kV Padghe-Vasai line and after that load of 220kV Vasai will be feed from 400/220 Padghe s/stn.4) After bunching 220kV Padghe-Vasai line will be charged at 9:00 Hrs. on same day dtd. 10.12.2022. The line will be in service for 07 days continuous i.e. 159 Hrs.5) Erection of MDN+9 Tower (2 nos.)6) Stringing of conductor of one side ckt.
POPHALI - KDPH	IntraState	10/12/2022	10:20			PO	For erection & stringing of In-line Multi circuit tower (Loc No.1to7) of new 220KV Karad-Koyana line and restringing of existing 220KV D/C KDPH LILO line.
VANKUSWADE - KDPH	IntraState	10/12/2022	11:00			PO	For erection & Stringing of In line multi circuit tower (Loc no.01 to 07) of new 220kV Karad-Koyana line and re stringing of existing 220kV D/C KDPH LILO line.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 16/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KAMBA - VASAI	IntraState	11/12/2022	05:19	16/12/2022	04:10	PO	Work of bunching, removing jumper & changing orientation of lines for backup supply to Vasai Ss & Nalasopara S/stn:1) 220kV Kamba-Vasai line jumper will be open at loc. No. 51 for 7 days continuous i.e. 159 Hrs. From Loc no. 52 to 220KV Vasai S/stn will be converted to 220KV Padgha-Vasai after bunching and same will be charged at 08:00 Hrs on 11.12.2022 (Temporary arrangement till 17.12.2022. 2) 220kV Padgha-Nalasopara & Vasai Tap line-Jumper is already opened at loc. 54 for 7 days continuous & 220kV Vasai-Nalasopara link line is established 7 days. 3) 220kV Padghe - Nalasopara-Vasai Tap line bunching work will be done to 220kV Kamba-Vasai line between loc. No. 51 & 52 after that line orientation will be change i.e. 220kV Padghe-Vasai line and after that load of 220kV Vasai will be feed from 400/220 Padghe s/stn. 4) After bunching 220kV Padghe-Vasai line will be charged at 8:00 Hrs. on same day dtd. 11.12.2022. The line will be in service for 07 days continuous i.e. 159 Hrs. 5) Erection of MDN+9 Tower (2 nos.) 6) Stringing of conductor of one side ckt.
KALWA - MULUND 1	IntraState	12/12/2022	09:18	15/12/2022	17:33	PO	For Main CB pole Overhauling work after shifting the line on TBC.
EKLAHARE (OCR) - PADGHE	IntraState	13/12/2022	10:35			HT	For load management
OSMANABAD - BARSHI	IntraState	15/12/2022	09:33	15/12/2022	14:20	PO	Outage is required for Quarterly bay maintenance work
NANDED CITY-FLAGSHIP	IntraState	15/12/2022	09:41	15/12/2022	17:59	PO	Half Yearly Maintenance
MUMEWADI -HALKARNI 1 LINE	IntraState	15/12/2022	10:07	15/12/2022	18:24	PO	Quarterly Maintenance, Annual Protection Relay Testing and Diagnostic Testing Work
AURANGABAD (WALUJ)-DEOGAON RANGARI	IntraState	15/12/2022	12:23	15/12/2022	17:42	PO	Replacement of faulty insulator discs.
MAHAD-KALAMBANI(TSS)	IntraState	15/12/2022	12:50	15/12/2022	20:05	PO	Damaged conductor is to be attended at Loc.No.22,28 and other line maintenance work.
BHIGWAN-BARAMATI AGRO	IntraState	15/12/2022	13:03	15/12/2022	16:45	PO	RELAY TESTING & DIAGNOSTIC TESTING WORK.
ONGC PANVEL - TSS PANVEL	IntraState	15/12/2022	14:11	16/12/2022	04:48	PO	For stringing of 3 Nos of conductors & 1 no.OPGW earthwire from new Monopole to Monopole of 220KV ONGC-Panvel TSS line bet.loc no 2 & 3 for Height rising work of proposed DFCCIL Railway track.Also destringing of 3 no. old existing conductors
WARDHA - WARDHA (PG)	IntraState	15/12/2022	18:51	16/12/2022	02:08	HT	to control overdrawal
PADGHE - PAL DOMBIVALI	IntraState	16/12/2022	04:53			PO	1. Stringing-3 SPans 2. OPGW shifting - 4 SPans

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 15/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 16/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GHODBUNDER - MSETCL BOISAR	IntraState	16/12/2022	05:20			T	TRIPPED ON DISTANCE PROTECTION
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/110 kV 200 MVA ICT 1 @ MUDSHINGI	IntraState	15/12/2022	10:01	15/12/2022	16:38	PO	To attend ICT 1 oil leakage by cold line method
220/22KV 50MVA PTR 2 @ RANJANGAON	IntraState	15/12/2022	10:10	15/12/2022	15:50	PO	Diagnostic testing work
220/22 KV 50 MVA PTR 3 @ RANJANGAON	IntraState	15/12/2022	16:00	15/12/2022	19:10	PO	For Diagnostic testing work
110 KV BUSBAR Outages/Trippings							
BUS-1 @ KHOPOLI	IntraState	16/12/2022	00:54	16/12/2022	03:46	PO	For reconnection of 110 KV Unit-7 breaker jumper to Main bus side GOD

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage