

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 15/Dec/2024 SUNDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 140.927        | 2238.008        | 1) Gujrat                      | -4.419         | -35.503         |
| 2) Hydro            | 4.724          | 110.910         | 2) Madhya Pradesh              | 0.073          | 43.643          |
| 3) Gas              | 4.245          | 101.126         | 3) Chattisgarh                 | 6.440          | 96.660          |
| <b>Total MSPGCL</b> | <b>149.896</b> | <b>2450.044</b> | 4) Maharashtra                 | 182.005        | 3002.817        |
| B) 1) APLM          | 47.697         | 791.146         | 5) Goa (Amona)                 | -2.477         | -40.912         |
| 2) JSWEL            | 18.102         | 320.535         | <b>Total</b>                   | <b>181.622</b> | <b>3066.705</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 31.884         | 576.059         |
| 4) RPL(AMT)         | 25.399         | 363.817         | b) Mumbai Drawl                | 34.650         | 628.761         |
| 5) SWPGPL           | 9.176          | 138.420         | c) MSEDCL Bilateral *          | 93.003         | 1418.716        |
| 6) Other IPP        | 42.209         | 599.993         | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 31.884         | 575.080         |
| C) 1) TPCL Thermal  | 3.775          | 59.857          | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 1.323          | 45.304          | Standby                        | 0.000          | 0.979           |
| 3) TPCL Gas         | 3.853          | 61.984          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 7.300          | 119.374         | 1) MSEDCL                      | 468.362        | 7364.600        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 50.901         | 915.276         |
| 1) Thermal          | 294.585        | 4631.150        | 3) Other Discoms               | 11.772         | 182.328         |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>531.035</b> | <b>8462.204</b> |
| 2) Hydro            | 6.047          | 156.214         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 8.098          | 163.110         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 17.818         | 183.196         |                                |                |                 |
| 6) SOLAR            | 22.865         | 261.833         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>349.413</b> | <b>5395.503</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 24 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|----------------------------|
| MSPGCL Thermal             | 6109                      | 5720                  | 6782                      | 5158                       |
| MSPGCL Hydro               | 216                       | 158                   | 396                       | 99                         |
| MSPGCL Gas                 | 140                       | 139                   | 138                       | 304                        |
| MSPGCL Total Generation    | 6465                      | 6017                  | 7316                      | 5561                       |
| Central Sector Receipt     | 8848                      | 8528                  | 8546                      | 6620                       |
| WIND                       | 291                       | 227                   | 583                       | 984                        |
| CPP / IPP Thermal          | 6578                      | 5719                  | 6248                      | 4879                       |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                          |
| SOLAR                      | 2979                      | 3212                  | 16                        | 0                          |
| Exchange with Mumbai       | -1625                     | -1766                 | -1600                     | -1416                      |
| <b>MSEDCL DEMAND MET</b>   | <b>23054</b>              | <b>21434</b>          | <b>20559</b>              | <b>16136</b>               |
| Load Shedding              | 0                         | 0                     | 0                         | 0                          |
| MSEDCL DEMAND              | 23054                     | 21434                 | 20559                     | 16136                      |
| TPCL GENERATION            | 348                       | 297                   | 439                       | 379                        |
| AEML GENERATION            | 303                       | 284                   | 367                       | 281                        |
| <b>MUMBAI DEMAND</b>       | <b>2276</b>               | <b>2347</b>           | <b>2406</b>               | <b>2076</b>                |
| <b>OTHER DISCOM DEMAND</b> | <b>482</b>                | <b>503</b>            | <b>550</b>                | <b>492</b>                 |
| STATE DEMAND MET           | 25812                     | 24284                 | 23515                     | 18704                      |
| <b>STATE DEMAND</b>        | <b>25812</b>              | <b>24284</b>          | <b>23515</b>              | <b>18704</b>               |
| Frequency (Hz)             | 49.98                     | 49.91                 | 50.05                     | 50.02                      |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.41 Hz at 06.03 Hrs | 49.76 Hz at 16.27 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 15/Dec/2024

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.88         | 59.50         | 178      | 124      |
| Unit 8             | 12.76        | 188.33        | 576      | 397      |
| Unit 9             | 12.39        | 196.49        | 580      | 392      |
| Unit 10            | 12.58        | 193.20        | 575      | 410      |
| <b>Total</b>       | <b>41.62</b> | <b>637.52</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.30         | 49.60         | 175      | 125      |
| Unit 4             | 7.69         | 112.22        | 500      | 280      |
| Unit 5             | 0.86         | 109.10        | 270      | 0        |
| <b>Total</b>       | <b>11.86</b> | <b>270.91</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 3.68         | 59.56         | 245      | 138      |
| Unit 7             | 3.60         | 57.53         | 234      | 137      |
| Unit 8             | 3.86         | 59.16         | 237      | 145      |
| <b>Total</b>       | <b>11.15</b> | <b>176.24</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.32         | 54.79         | 183      | 125      |
| Unit 4             | 2.96         | 46.93         | 132      | 112      |
| Unit 5             | 7.32         | 71.36         | 410      | 275      |
| Unit 6             | 0.00         | 109.37        | 0        | 0        |
| Unit 7             | 7.72         | 53.78         | 419      | 283      |
| Unit 8             | 7.87         | 118.81        | 372      | 279      |
| Unit 9             | 8.62         | 122.54        | 438      | 283      |
| <b>Total</b>       | <b>37.81</b> | <b>577.58</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.40         | 57.28         | 247      | 156      |
| Unit 4             | 4.20         | 69.20         | 236      | 146      |
| <b>Total</b>       | <b>8.60</b>  | <b>126.48</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.54         | 55.75         | 165      | 115      |
| Unit 2             | 4.02         | 60.83         | 194      | 124      |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 3.90         | 38.42         | 187      | 135      |
| Unit 5             | 10.26        | 159.45        | 475      | 360      |
| <b>Total</b>       | <b>21.73</b> | <b>314.45</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 2.21         | 45.92         | 137      | 0        |
| Unit 4             | 3.10         | 46.81         | 156      | 117      |
| Unit 5             | 2.86         | 42.10         | 155      | 0        |
| <b>Total</b>       | <b>8.17</b>  | <b>134.83</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 4.24         | 101.13        | 304      | 137      |
| <b>Total</b>       | <b>4.24</b>  | <b>101.13</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.12         | 3.07          | 41       | 0        |
| <b>Total</b>       | <b>0.12</b>  | <b>3.07</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 1.74         | 35.15         | 305      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 0.12          | 18.88          | 109      | 0        |
| Stage 3         | 0.42          | 11.92          | 108      | 0        |
| <b>Total</b>    | <b>2.28</b>   | <b>65.96</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.30          | 4.87           | 18       | 0        |
| VTRNA           | 0.00          | 0.00           | 0        | 0        |
| TILLARI         | 0.49          | 6.84           | 62       | 0        |
| BHIRA T.R.      | 0.14          | 2.28           | 40       | 0        |
| SMLHY_PTN       | 1.36          | 26.90          | 59       | 54       |
| GHATGHAR        | 0.16          | 4.07           | 125      | 0        |
| <b>Total</b>    | <b>2.45</b>   | <b>44.96</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 17.82         | 183.20         | 0        | 0        |
| <b>Total</b>    | <b>17.82</b>  | <b>183.20</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 47.70         | 791.15         | 0        | 0        |
| JSWEL(Mus)      | 18.10         | 320.54         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 25.40         | 363.82         | 0        | 0        |
| SWPGPL-Mus      | 9.18          | 138.42         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00           | 0        | 0        |
| IEPL            | 4.28          | 90.92          | 266      | 0        |
| Other(Mus)      | 36.14         | 478.90         | 0        | 0        |
| JPL             | 1.79          | 30.17          | 76       | 74       |
| <b>Total</b>    | <b>142.58</b> | <b>2213.91</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 22.86         | 261.83         | 0        | 0        |
| <b>Total</b>    | <b>22.86</b>  | <b>261.83</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 0.00          | 0.00           | 0        | 0        |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.37          | 38.89          | 110      | 61       |
| Trombay 7B      | 1.48          | 23.09          | 66       | 51       |
| TATA Hydro      | 1.32          | 45.30          | 113      | 15       |
| Trombay 8       | 3.78          | 59.86          | 172      | 130      |
| <b>Total</b>    | <b>8.95</b>   | <b>167.14</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 7.30          | 119.37         | 382      | 281      |
| <b>Total</b>    | <b>7.30</b>   | <b>119.37</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 140.93      | 2238.01       | MSPGCL Total        | 149.90      | 2450.04       |
|                |             |         | MSPGCL Thml+Gas | 145.17      | 2339.13       | Koyna 1,2 & 4 Total | 1.86        | 54.03         |
|                |             |         | MSPGCL Hydro    | 4.72        | 110.91        | State Total         | 349.41      | 5395.50       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 15/Dec/2024

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | Load<br>Shedding |                             | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAND | OTHER<br>DISCOM<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|------------------------|------------------|-----------------------------|-------------------------------|------------------|---------------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                        | Planned          | *Transmission<br>Constraint |                               |                  |                           |                 |               |
| 1                  | 5046        | 116  | 295  | 5457   | 1494  | 5501      | 0    | 0     | 6685        | 6351        | -1318                | 16995                  | 0                | 0                           | 16995                         | 2049             | 490                       | 19534           | 49.95         |
| 2                  | 5021        | 118  | 287  | 5426   | 1400  | 5502      | 0    | 0     | 6649        | 6686        | -1245                | 17319                  | 0                | 0                           | 17319                         | 1908             | 450                       | 19677           | 49.96         |
| 3                  | 5299        | 117  | 149  | 5565   | 1359  | 5508      | 0    | 0     | 6488        | 6302        | -1158                | 17156                  | 0                | 0                           | 17156                         | 1808             | 420                       | 19384           | 49.98         |
| 4                  | 5471        | 123  | 145  | 5739   | 1257  | 5516      | 0    | 0     | 6389        | 6432        | -1088                | 17442                  | 0                | 0                           | 17442                         | 1746             | 414                       | 19602           | 50.00         |
| 5                  | 5932        | 120  | 144  | 6196   | 1175  | 5627      | 0    | 0     | 6378        | 6470        | -1064                | 17962                  | 0                | 0                           | 17962                         | 1731             | 442                       | 20135           | 49.98         |
| 6                  | 6038        | 130  | 145  | 6313   | 1122  | 6178      | 0    | 0     | 6684        | 6903        | -1139                | 18916                  | 0                | 0                           | 18916                         | 1811             | 461                       | 21188           | 50.03         |
| 7                  | 5970        | 176  | 144  | 6290   | 1048  | 6456      | 0    | 21    | 7541        | 7350        | -1202                | 19490                  | 0                | 0                           | 19490                         | 1845             | 473                       | 21808           | 50.09         |
| 8                  | 5963        | 328  | 147  | 6438   | 943   | 6569      | 0    | 413   | 7699        | 7630        | -1288                | 20219                  | 0                | 0                           | 20219                         | 1892             | 486                       | 22597           | 49.97         |
| 9                  | 6293        | 247  | 142  | 6682   | 679   | 6585      | 0    | 1457  | 7620        | 7658        | -1291                | 21270                  | 0                | 0                           | 21270                         | 2028             | 500                       | 23798           | 50.06         |
| 10                 | 6167        | 572  | 140  | 6879   | 402   | 6561      | 0    | 2370  | 7985        | 7859        | -1434                | 22138                  | 0                | 0                           | 22138                         | 2164             | 499                       | 24801           | 50.00         |
| 11                 | 6109        | 216  | 140  | 6465   | 291   | 6578      | 0    | 2979  | 9013        | 8848        | -1625                | 23054                  | 0                | 0                           | 23054                         | 2276             | 482                       | 25812           | 49.98         |
| 12                 | 5775        | 361  | 139  | 6275   | 217   | 6100      | 0    | 3307  | 8992        | 8775        | -1710                | 22476                  | 0                | 0                           | 22476                         | 2349             | 488                       | 25313           | 49.94         |
| 13                 | 5720        | 158  | 139  | 6017   | 227   | 5719      | 0    | 3212  | 9118        | 8528        | -1766                | 21434                  | 0                | 0                           | 21434                         | 2347             | 503                       | 24284           | 49.91         |
| 14                 | 5478        | 121  | 138  | 5737   | 217   | 5486      | 0    | 3163  | 8960        | 8438        | -1710                | 20843                  | 0                | 0                           | 20843                         | 2277             | 488                       | 23608           | 50.04         |
| 15                 | 5554        | 136  | 141  | 5831   | 212   | 5514      | 0    | 2726  | 9020        | 8694        | -1663                | 20830                  | 0                | 0                           | 20830                         | 2256             | 484                       | 23570           | 50.05         |
| 16                 | 5995        | 172  | 140  | 6307   | 239   | 6002      | 0    | 2063  | 9050        | 8444        | -1591                | 20959                  | 0                | 0                           | 20959                         | 2259             | 505                       | 23723           | 50.00         |
| 17                 | 6433        | 105  | 138  | 6676   | 283   | 6356      | 0    | 982   | 8661        | 8299        | -1547                | 20526                  | 0                | 0                           | 20526                         | 2236             | 523                       | 23285           | 49.93         |
| 18                 | 6819        | 249  | 137  | 7205   | 441   | 6372      | 0    | 156   | 8132        | 7973        | -1505                | 20096                  | 0                | 0                           | 20096                         | 2260             | 546                       | 22902           | 50.04         |
| 19                 | 6782        | 396  | 138  | 7316   | 583   | 6248      | 0    | 16    | 8792        | 8546        | -1600                | 20559                  | 0                | 0                           | 20559                         | 2406             | 550                       | 23515           | 50.05         |
| 20                 | 6602        | 298  | 158  | 7058   | 732   | 6275      | 0    | 0     | 8365        | 8059        | -1624                | 19966                  | 0                | 0                           | 19966                         | 2393             | 534                       | 22893           | 50.01         |
| 21                 | 5967        | 163  | 203  | 6333   | 828   | 6224      | 0    | 0     | 7627        | 7219        | -1623                | 18464                  | 0                | 0                           | 18464                         | 2347             | 517                       | 21328           | 49.98         |
| 22                 | 5866        | 109  | 288  | 6263   | 800   | 5639      | 0    | 0     | 7203        | 6780        | -1562                | 17402                  | 0                | 0                           | 17402                         | 2271             | 518                       | 20191           | 50.01         |
| 23                 | 5469        | 94   | 304  | 5867   | 885   | 5188      | 0    | 0     | 7256        | 6758        | -1481                | 16708                  | 0                | 0                           | 16708                         | 2166             | 509                       | 19383           | 49.99         |
| 24                 | 5158        | 99   | 304  | 5561   | 984   | 4879      | 0    | 0     | 7060        | 6620        | -1416                | 16136                  | 0                | 0                           | 16136                         | 2076             | 492                       | 18704           | 50.02         |
| MUs                | 140.93      | 4.72 | 4.24 | 149.90 | 17.82 | 142.58    | 0.00 | 22.87 | 187.37      | 181.62      | -34.65               | 468.36                 | 0.00             | 0.00                        | 468.36                        | 50.90            | 11.77                     | 531.03          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

| Maximum Demand scenario for the date 15/Dec/2024 |                                  |                                   |
|--------------------------------------------------|----------------------------------|-----------------------------------|
| State Demand                                     | MSEDC Non-Coincident Peak Demand | Mumbai Non-Coincident Peak Demand |
| 25812 MW                                         | 23054 MW                         | 2406 MW                           |
| 11 Hrs                                           | 11 Hrs                           | 19 Hrs                            |
| Includes LS - 0 MW                               | Includes LS - 0 MW               | --                                |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 15/Dec/2024**

Position as on 6.30 Hrs of 16/Dec/2024

| Generating Company            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-------------------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| PLANNED OUTAGE                |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        | Khaparkheda Unit 3      | 210      | 21/11/2024   | 00:32        |            | Continued. | Annual Overhaul                                                                                                                                         | 20/12/2024    |
| MSPGCL                        | Chandrapur Unit 6       | 500      | 14/12/2024   | 19:45        |            | Continued. | Capital overhaul                                                                                                                                        | 18/01/2025    |
| Total Capacity MSPGCL         |                         | 710      |              |              |            |            |                                                                                                                                                         |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                           | SWPGPL U-1              | 135      | 01/12/2024   | 00:00        |            | Continued. | Annual Overhaul                                                                                                                                         | 20/12/2024    |
| IPP                           | Adani U-5               | 660      | 01/12/2024   | 00:00        |            | Continued. | Annual Overhaul                                                                                                                                         | 25/12/2024    |
| IPP                           | JSW (J) U1              | 300      | 06/12/2024   | 23:53        |            | Continued. | Boiler Validity Renevoation                                                                                                                             | 24/12/2024    |
| Total Capacity IPP            |                         | 1095     |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity PLANNED OUTAGE |                         | 1805     |              |              |            |            |                                                                                                                                                         |               |
| FORCED OUTAGE                 |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 31/12/2024    |
| MSPGCL                        | Ghatghar Unit-2         | 125      | 26/05/2024   | 13:17        |            | Continued. | Stator Earth Fault                                                                                                                                      | 31/03/2025    |
| MSPGCL                        | Bhusawal Unit 5         | 500      | 14/12/2024   | 00:03        | 15/12/2024 | 18:51      | Boiler Tube Leakage                                                                                                                                     | 16/12/2024    |
| MSPGCL                        | Nasik Unit 3            | 210      | 15/12/2024   | 17:48        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 19/12/2024    |
| MSPGCL                        | Nasik Unit 5            | 210      | 15/12/2024   | 22:25        | 16/12/2024 | 02:29      | Furnace Pressure High                                                                                                                                   |               |
| Total Capacity MSPGCL         |                         | 1165     |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                         | Trombay 5               | 500      | 22/09/2024   | 16:14        |            | Continued. | Emergency withdrwan due to fire in cable vault.                                                                                                         |               |
| Total Capacity TPC-G          |                         | 500      |              |              |            |            |                                                                                                                                                         |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                           | RPL(AMT) U-3            | 270      | 23/07/2024   | 00:47        |            | Continued. | Turbine Vibration High                                                                                                                                  | 20/12/2024    |
| IPP                           | IEPL Unit 1             | 270      | 15/12/2024   | 17:21        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 19/12/2024    |
| Total Capacity IPP            |                         | 540      |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   |                         |          |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 30/12/2024    |
| CENT.SECTOR                   | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 30/12/2024    |
| Total Capacity CENT.SECTOR    |                         | 320      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity FORCED OUTAGE  |                         | 2525     |              |              |            |            |                                                                                                                                                         |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 15/Dec/2024**

Position as on 6.30 Hrs of 16/Dec/2024

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                            | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|-----------|------------|-------------------------------------------------------------|---------------|
| UNIT UNDER ZERO SCHEDULE / RSD                |                         |          |              |              |           |            |                                                             |               |
| MSPGCL                                        |                         |          |              |              |           |            |                                                             |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 11/12/2024   | 08:30        |           | Continued. | Due to zero schedule by MSEDCL                              |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 12/12/2024   | 19:00        |           | Continued. | Utilised as per requirement.now withdrwan on zero schedule. |               |
| Total Capacity MSPGCL                         |                         | 216      |              |              |           |            |                                                             |               |
| IPP                                           |                         |          |              |              |           |            |                                                             |               |
| IPP                                           | JPL Unit 2              | 150      | 21/11/2024   | 01:30        |           | Continued. | Unit Out due to Non-avaialbility of Schedule.               |               |
| Total Capacity IPP                            |                         | 150      |              |              |           |            |                                                             |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 366      |              |              |           |            |                                                             |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |           |            |                                                             |               |
| IPP                                           |                         |          |              |              |           |            |                                                             |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA)                                        |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA)                                        |               |
| IPP                                           | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                     |               |
| IPP                                           | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal shortage.(NO PPA From 20.05.2019)                      |               |
| Total Capacity IPP                            |                         | 988      |              |              |           |            |                                                             |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA    |                         | 988      |              |              |           |            |                                                             |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Tripping for 15/Dec/2024**

**Statement-VII**

**Position as on 6.30 Hrs of 16/Dec/2024**

| Name of Line                                     | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                             |
|--------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV LINE Outages/Tripping</b>              |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| TIRODA - KORADI 3 CKT - 2                        | IntraState                | 15/12/2024   | 08:49        | 15/12/2024 | 19:28      | PO          | Annual Maintenance of line                                                                                                                                                                                                                   |
| <b>765 KV ICT Outages/Tripping</b>               |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| 765KV/21KV GT - 5 @ TIRODA                       | IntraState                | 04/12/2024   | 10:11        |            |            | PO          | GT5 main & tie bay equipment maintenance                                                                                                                                                                                                     |
| <b>400 KV TIEBAY Outages/Tripping</b>            |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA | IntraState                | 11/12/2024   | 11:38        |            |            | PO          | CB R, Y, B ph pole Overhauling, CB R, Y, B ph pole Mechanism overhauling Work.                                                                                                                                                               |
| <b>400 KV LINE Outages/Tripping</b>              |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| DHULE - SSNNL CKT - 2                            | InterState                | 04/12/2024   | 12:04        |            |            | EO          | 400kV Dhule SSNNL-2 line CB as hydraulic operated CB mechanism oil pressure is 310bar & not building up so it is requested to give permission for shifting of 400KV Dhule SSNNL-2 line load shifting to 400KV TBC urgently & attending same. |
| BUS REACTOR (50MVAR) @ PARLI                     | IntraState                | 27/09/2023   | 15:30        |            |            | PO          | Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.                                                                                                                                                                          |
| 220KV KORADI II (400KV)- BUTIBORI 3 CKT I        | IntraState                | 01/10/2024   | 13:10        |            |            | HT          | H/T From Butibori 3 end                                                                                                                                                                                                                      |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2              | IntraState                | 26/11/2024   | 10:08        |            |            | HT          | For load management                                                                                                                                                                                                                          |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1              | IntraState                | 28/11/2024   | 21:52        |            |            | HT          | overvoltage                                                                                                                                                                                                                                  |
| KALWA - KHARGHAR                                 | IntraState                | 03/12/2024   | 14:48        |            |            | PO          | During this outage, Erection of 2 No&#65533; of QD+9 Towers and 1 no. of DD+6 tower and its conductor stringing work in Location No.168A -170                                                                                                |
| DHULE- - BABLESHWAR CKT - 1                      | IntraState                | 14/12/2024   | 17:48        |            |            | PO          | Retrofitting work of Distance M2 relay by new distance relay GE P443. Relay retrofitting agency will be available at site for outage work.                                                                                                   |
| KHADKA-AURANGABAD (WALUJ)                        | IntraState                | 14/12/2024   | 21:36        | 15/12/2024 | 08:21      | HT          | Over voltage.                                                                                                                                                                                                                                |
| PARLI - KARJAT CKT - 1                           | IntraState                | 14/12/2024   | 22:11        | 15/12/2024 | 04:40      | PO          | (1) CB testing & Reactor Backup relay testing. (2) Bay maintenance work. (3) Hardware tightening & fitting work                                                                                                                              |
| JAIGAD - KARAD CKT - 1                           | IntraState                | 14/12/2024   | 22:11        | 15/12/2024 | 09:51      | HT          | Over voltage.                                                                                                                                                                                                                                |
| JEJURI- KOYNA STAGE-IV                           | IntraState                | 15/12/2024   | 10:27        | 15/12/2024 | 19:09      | PO          | Insulator Replacement Work against Scheme                                                                                                                                                                                                    |
| JAIGAD - KARAD CKT - 2                           | IntraState                | 15/12/2024   | 20:03        |            |            | HT          | For voltage management                                                                                                                                                                                                                       |
| KHADKA-AURANGABAD (WALUJ)                        | IntraState                | 15/12/2024   | 20:54        | 16/12/2024 | 09:30      | HT          | For voltage management                                                                                                                                                                                                                       |
| PARLI - KARJAT CKT - 2                           | IntraState                | 15/12/2024   | 22:03        | 16/12/2024 | 04:04      | PO          | Cold washing                                                                                                                                                                                                                                 |
| PARLI - KARJAT CKT - 2                           | IntraState                | 15/12/2024   | 22:03        | 16/12/2024 | 04:04      | PO          | (1) CB testing & Reactor Backup relay testing. (2) Bay maintenance work. (3) Hardware tightening & fitting work                                                                                                                              |
| <b>400 KV ICT Outages/Tripping</b>               |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| STATION TF No 3 @ CHANDRAPUR GCR                 | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                                               |
| 400/132 KV 200 MVA ICT - 2 @ KHADKA              | IntraState                | 03/06/2024   | 23:26        |            |            | T           | Differential protection                                                                                                                                                                                                                      |
| 400/220KV SPARE ICT @ JEJURI                     | IntraState                | 12/12/2024   | 14:07        |            |            | PO          | CB¿ pole and mechanism overhauling work.                                                                                                                                                                                                     |
| <b>400 KV BR Outages/Tripping</b>                |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 15/Dec/2024**

**Statement-VII**

Position as on 6.30 Hrs of 16/Dec/2024

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                                                                 |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| BUS REACTOR (80 MVar) - 1 @ BABHALESHWAR | IntraState                | 07/10/2024   | 09:40        |            |            | PO          | The work of Dismantling of existing 80 MVAR replacement by 125 MVAR bus reactor along with allied requirement at 400KV Bableshwar has been entrusted to M/s RK Electrical vide Zone office order no. 1258 dtd 12.08.2022. Following work are proposed on reactor 1 1) Dismantling of reactor 1 2) Erection of new 125 MVAR reactor 3) Commissioning work 4) Replacement work as per the work order                                               |
| <b>220 KV MAINBAY Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| 220KV BUS SECTION BAY @ PEDAMBE          | IntraState                | 03/04/2024   | 15:55        |            |            | T           | Tripped due to Y ph CT burst                                                                                                                                                                                                                                                                                                                                                                                                                     |
| 220 KV GT - 3 BAY @ KHAPARKHEDA          | IntraState                | 06/12/2024   | 11:15        |            |            | HT          | Replacement of r y & b ph cts & synchronizing pt of 250mva gt-iii bay at 220kv gcr.                                                                                                                                                                                                                                                                                                                                                              |
| BUS COUPLER @ BABHALESHWAR               | IntraState                | 14/12/2024   | 12:30        |            |            | PO          | "For Replacement of Old 29 A and 29 B Center Break Isolator by Double break isolator"                                                                                                                                                                                                                                                                                                                                                            |
| INTERCONNECTOR @ KALWA                   | IntraState                | 14/12/2024   | 15:01        | 15/12/2024 | 14:22      | PO          | Disconnection & Removal of 220kV 52 A CTs having oil leakage (for replacement) , BUS-1 CB / BAY OF INTERCONNECTOR ( Normally kept Off )<br><br>(Above activities are to be done in respect of Installation & commissioning of 220kV Outdoor GIS bays in place existing 220kV Interconnector 52 A / B & shifting of 220kV Kalwa Salsette 5 line on outdoor GIS)                                                                                   |
| INTERCONNECTOR @ KALWA                   | IntraState                | 15/12/2024   | 06:21        | 15/12/2024 | 14:22      | PO          | OUTAGE IS ON BUS-2 CB / BAY OF INTERCONNECTOR AND COMMON CB /BAY OF INTERCONNECTOR<br><br>1) 220kV 52 B CTs shifting to 52 A section.<br><br>2) Disconnection & removal of interconnected stub bus between main bus 1 &2.<br><br>(Above activities are to be done in respect of Installation & commissioning of 220kV Outdoor GIS bays in place existing 220kV Interconnector 52 A / B & shifting of 220kV Kalwa Salsette 5 line on outdoor GIS) |
| <b>220 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                                                                  |
| BALE - SOLAPUR (PG)                      | InterState                | 19/06/2024   | 08:56        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A)<br>2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                                                                                                                                 |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 15/Dec/2024**

**Statement-VII**

Position as on 6.30 Hrs of 16/Dec/2024

| Name of Line                                  | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                   |
|-----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| JEUR - SOLAPUR PG                             | InterState                | 21/11/2024   | 08:24        |            |            | PO          | For Restoration of 400 KV PGCIL Karad Original Line after removing temporary bunching arrangement of 400 KV PGCIL-Karad Line with 220 KV Jeur-VSSK line and 220 KV Bale PGCIL ckt-2                                                                                                                                                |
| PRINT HOUSE - NAVI MUMBAI (PG)                | InterState                | 05/12/2024   | 23:09        |            |            | EO          | 1) For bunching at TL no 678/1 with 220kV Kalwa-Panchanand line to provide 2nd source to Panchanand & Taloja s/stn. 2)For opening jumpers at TL no 678/1.                                                                                                                                                                          |
| OSMANABAD - SOLAPUR (BALE)                    | IntraState                | 19/06/2024   | 09:15        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                      |
| WAGHIVALI (MSETCL) - ULWE GIS CKT - 2         | IntraState                | 25/06/2024   | 08:05        |            |            | T           | Tripped on differential protection.                                                                                                                                                                                                                                                                                                |
| 220kV Koradi-2 - Uppalwadi ckt 2              | IntraState                | 28/08/2024   | 00:14        |            |            | T           | Distance Protection                                                                                                                                                                                                                                                                                                                |
| EKLAHARE (OCR) - PADGHE                       | IntraState                | 24/09/2024   | 07:48        |            |            | HT          | For load mgmt                                                                                                                                                                                                                                                                                                                      |
| 220KV KORADI II(400KV) - BUTIBORI 3 CKT II    | IntraState                | 01/10/2024   | 13:11        |            |            | HT          | H/T From Koradi 2 end                                                                                                                                                                                                                                                                                                              |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1 | IntraState                | 16/10/2024   | 16:01        |            |            | HT          | Line Hand tripped for load management on 220kV Ulve - Waghivali ckt no 1.                                                                                                                                                                                                                                                          |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2 | IntraState                | 17/10/2024   | 06:26        |            |            | HT          | H/T for controlling load of 220kV Ulve-Waghivali ckt-1                                                                                                                                                                                                                                                                             |
| KALWA - PANCHANAND                            | IntraState                | 17/10/2024   | 12:10        |            |            | EO          | For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Taloja.                                                                                                                                                                                                              |
| KHAPARKHEDA- BUTIBORI                         | IntraState                | 11/12/2024   | 12:26        |            |            | T           | ATTENDING HOT SPOT AT 220 KV BUTIBORI 1 SS.                                                                                                                                                                                                                                                                                        |
| MAIN BUS SECTION - 1 @ TIFIL                  | IntraState                | 12/12/2024   | 11:12        |            |            | PO          | Siemens make bus bar relay replacement work by PAC division Kalwa.                                                                                                                                                                                                                                                                 |
| 220kV Koradi-2 - Uppalwadi ckt 1              | IntraState                | 13/12/2024   | 09:49        |            |            | HT          | In view of work on ckt-2.                                                                                                                                                                                                                                                                                                          |
| BABLESHWAR-BABLESHWAR(400KV)-II               | IntraState                | 14/12/2024   | 11:51        |            |            | EO          | Emergency Shifting of the 220KV Babhaleshwar-Babhaleshwar -2 from 220kV Main Bus-II to 220kV Main Bus -I is required to avoid overloading of 220kV BBLR-BBL-I and to balance the load on both 220kV Buses. The Original Bus configuration of 220kV BBLR-BBLR-II will be restored after the 220 kV bus Coupler is taken in service. |
| BORIVALI - TARAPUR                            | IntraState                | 14/12/2024   | 16:40        | 15/12/2024 | 19:10      | PO          | Shifting of 220 KV Tarapur-Borivali Line on ERS tower (06 Nos.) from loc.no. 46 to 48 for erection of 05 Nos of Monopole with one side X-arm & stringing between Loc. No. 46 to 46A & 47 to 47B Mumbai-Ahmadabad Bullet Train (NHSRCL) crossing under ORC scheme.                                                                  |
| NANDED CITY-FLAGSHIP                          | IntraState                | 14/12/2024   | 23:49        | 15/12/2024 | 01:38      | PO          | Bird Diverter fixing work.                                                                                                                                                                                                                                                                                                         |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 15/Dec/2024**

**Statement-VII**

Position as on 6.30 Hrs of 16/Dec/2024

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                 |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| MAIN BUS SECTION - 2 @ PEDAMBE           | IntraState                | 15/12/2024   | 06:44        | 15/12/2024 | 18:12      | PO          | for attending replacement of Oni, Nerle , Unit #11 ,Adlab ,50MVA Xmer No 1 bay CT to Overhead bus conductor replacement work and attending Oni bay Main Bus Isolators alignment problem. And all bays main bus isolators PM work |
| 132 KV BHANDARA- MAUDA CKT               | IntraState                | 15/12/2024   | 07:02        | 15/12/2024 | 18:24      | PO          | For de stringing restringing of loos span couductor between loc no 227-243.                                                                                                                                                      |
| CHINCHWAD 2 - FLAGSHIP                   | IntraState                | 15/12/2024   | 08:57        | 15/12/2024 | 14:24      | PO          | 1) Bird Diverter fixing work. 2) Bus isolators alignment work.                                                                                                                                                                   |
| PALGHAR - NALASOPARA                     | IntraState                | 15/12/2024   | 09:10        | 15/12/2024 | 18:12      | PO          | Replacement of damaged Insulator identified during partolling and Hot Spot attending Work.                                                                                                                                       |
| 220kV Koradi-2 - Uppalwadi ckt 1         | IntraState                | 15/12/2024   | 11:31        | 15/12/2024 | 18:41      | PO          | For safty reson for restoration of damage power cable of ckt.                                                                                                                                                                    |
| MURUD - TULJAPUR                         | IntraState                | 15/12/2024   | 13:32        | 15/12/2024 | 15:40      | PO          | Quarterly maintenance work.                                                                                                                                                                                                      |
| <b>220 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                  |
| 220/22KV 50MVA PTR 3 @ BHOSARI 2         | IntraState                | 24/07/2024   | 23:02        |            |            | T           | Tripped due to caught fire.                                                                                                                                                                                                      |
| 220/132 KV 100 MVA ICT I @ UPPALWADI     | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                                                                                                                                      |
| 220/132 KV 100 MVA ICT II @ UPPALWADI    | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                                                                                                                                      |
| 220/132 KV 100 MVA ICT 1@ BABHALESHWAR   | IntraState                | 14/10/2024   | 15:46        |            |            | PO          | Augmentation of 220/132kV 100MVA to 220/132kV 200MVA at Babheshwar.                                                                                                                                                              |
| 220/132 KV 150 MVA PTR NO 7 @ CHINCHWAD  | IntraState                | 11/11/2024   | 03:05        |            |            | T           | Bucholz Protection                                                                                                                                                                                                               |
| 220/33 KV 50MVA PTR 1                    | IntraState                | 11/12/2024   | 06:13        |            |            | HT          | Commissining of 100mva duel winding transformer.                                                                                                                                                                                 |
| 200 MVA 220/132 KV ICT 3 @ GIRWALI       | IntraState                | 11/12/2024   | 10:25        |            |            | HT          | OIL FILTRATION WORK.                                                                                                                                                                                                             |
| 220/33kV 125 MVA TF 5 @ VERSOVA (AEML)   | IntraState                | 13/12/2024   | 09:43        | 15/12/2024 | 20:59      | PO          | Annual Maintenance of 125 MVA Tr-5                                                                                                                                                                                               |
| 220/132 100MVA ICT-2 @ AMRAPUR           | IntraState                | 13/12/2024   | 10:46        | 15/12/2024 | 18:17      | PO          | ICT II ȳ Internal inspection work of ICT ȳII Carry out by M/s.Kanohar electrical (Manufacturer) due to abnormal DGA result.                                                                                                      |
| 250 MVA ICT-4 @ TROMBAY                  | IntraState                | 15/12/2024   | 09:33        | 15/12/2024 | 19:33      | PO          | Attending Hot spot on 110kV ICT 4 Main Bus side GOD                                                                                                                                                                              |
| <b>220 KV BUSBAR Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                                                                                                                  |
| BUS SECTION 1 @ FLAGSHIP                 | IntraState                | 15/12/2024   | 09:24        | 15/12/2024 | 14:24      | PO          | 1) Bird Diverter fixing work. 2) Bus isolators alignment work.                                                                                                                                                                   |
| BUS SECTION 2 @ FLAGSHIP                 | IntraState                | 15/12/2024   | 15:10        | 15/12/2024 | 17:53      | PO          | 1) Bird Diverter fixing work.2) Bus isolators alignment work.                                                                                                                                                                    |
| <b>132 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                                                  |
| MANSAR-PENCH                             | InterState                | 26/09/2024   | 14:40        |            |            | HT          | H/T at 132KV Pench end                                                                                                                                                                                                           |
| CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP | IntraState                | 16/10/2024   | 07:02        |            |            | HT          | For Load Management                                                                                                                                                                                                              |
| <b>132 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                  |
| 132/33 KV 50 MVA PTR 2 @ DONDAICHA       | IntraState                | 15/11/2024   | 11:40        |            |            | T           | Tripped on Buchholz alarm                                                                                                                                                                                                        |
| <b>110 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                                                  |
| BHIRA (T) - DAVDI                        | IntraState                | 15/12/2024   | 10:47        | 15/12/2024 | 11:41      | PO          | LOWERING OF JOINT                                                                                                                                                                                                                |
| BHIRA (T) - DAVDI                        | IntraState                | 15/12/2024   | 10:47        |            |            | PO          | HOISTING JOINT BOX                                                                                                                                                                                                               |

