

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 16/Jan/2020 THURSDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 124.450        | 1889.499        | 1) Gujrat                      | 5.223          | 70.958          |
| 2) Hydro            | 12.062         | 211.194         | 2) Madhya Pradesh              | 9.974          | 217.954         |
| 3) Gas              | 2.747          | 77.740          | 3) Chattisgarh                 | 6.340          | 115.430         |
| <b>Total MSPGCL</b> | <b>139.259</b> | <b>2178.433</b> | 4) Maharashtra                 | 124.245        | 1819.594        |
| B) 1) APML          | 73.918         | 1120.710        | 5) Goa (Amona)                 | -0.550         | -9.174          |
| 2) JSWEL            | 24.771         | 385.216         | <b>Total</b>                   | <b>145.232</b> | <b>2214.762</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 22.794         | 337.968         |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 22.032         | 356.741         |
| 5) WPCL             | 0.000          | 0.000           | c) MSEDCL Bilateral *          | 30.063         | 419.294         |
| 6) Other IPP        | 14.273         | 245.165         | Include PX                     | 7.545          | 65.928          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 22.794         | 337.968         |
| C) 1) TPCL Thermal  | 14.941         | 231.570         | Include PX                     | 9.140          | 129.518         |
| 2) TPCL Hydro       | 4.391          | 53.255          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 0.000          | 28.288          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 5.281          | 111.695         | 1) MSEDCL                      | 391.294        | 6028.652        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 46.648         | 781.551         |
| 1) Thermal          | 257.634        | 3983.855        | <b>TOTAL STATE</b>             | <b>437.942</b> | <b>6810.203</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 16.453         | 264.449         |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 2.747          | 106.028         |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 9.516          | 153.954         |                                |                |                 |
| 6) SOLAR            | 6.357          | 87.153          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>292.707</b> | <b>4595.439</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5469                      | 5429                  | 5253                      | 4542                      |
| MSPGCL Hydro             | 997                       | 570                   | 605                       | 70                        |
| MSPGCL Gas               | 118                       | 118                   | 117                       | 100                       |
| MSPGCL Total Generation  | 6584                      | 6117                  | 5975                      | 4712                      |
| Central Sector Receipt   | 7805                      | 7547                  | 5660                      | 4829                      |
| WIND                     | 297                       | 451                   | 352                       | 509                       |
| CPP / IPP Thermal        | 4959                      | 4967                  | 4910                      | 4153                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 919                       | 915                   | 0                         | 0                         |
| Exchange with Mumbai     | -1252                     | -1144                 | -966                      | -656                      |
| <b>MSEDCL DEMAND MET</b> | <b>19312</b>              | <b>18853</b>          | <b>15931</b>              | <b>13547</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 19312                     | 18853                 | 15931                     | 13547                     |
| TPCL GENERATION          | 974                       | 987                   | 1014                      | 499                       |
| AEML GENERATION          | 250                       | 251                   | 239                       | 187                       |
| <b>MUMBAI DEMAND</b>     | <b>2476</b>               | <b>2382</b>           | <b>2219</b>               | <b>1342</b>               |
| STATE DEMAND MET         | 21788                     | 21235                 | 18150                     | 14889                     |
| <b>STATE DEMAND</b>      | <b>21788</b>              | <b>21235</b>          | <b>18150</b>              | <b>14889</b>              |
| Frequency (Hz)           | 50.03                     | 49.98                 | 50.01                     | 50.03                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.26 Hz at 22:01 Hrs | 49.77 Hz at 16:43 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 16/Jan/2020

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 8.97         | 179.86        | 440      | 310      |
| Unit 9             | 9.20         | 178.51        | 490      | 280      |
| Unit 10            | 11.36        | 135.90        | 517      | 445      |
| <b>Total</b>       | <b>29.53</b> | <b>494.26</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 39.82         | 0        | 0        |
| Unit 7             | 0.00         | 45.72         | 0        | 0        |
| Unit 8             | 3.80         | 63.10         | 234      | 0        |
| <b>Total</b>       | <b>3.80</b>  | <b>148.65</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 4.26         | 67.91         | 190      | 158      |
| Unit 4             | 3.93         | 61.47         | 170      | 134      |
| Unit 5             | 8.20         | 132.24        | 350      | 335      |
| Unit 6             | 10.61        | 169.37        | 485      | 360      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 10.78        | 171.51        | 475      | 360      |
| Unit 9             | 10.52        | 166.17        | 470      | 360      |
| <b>Total</b>       | <b>48.29</b> | <b>768.67</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.16         | 73.68         | 245      | 187      |
| Unit 4             | 5.38         | 85.30         | 255      | 193      |
| <b>Total</b>       | <b>10.54</b> | <b>158.98</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 4.20         | 19.89         | 190      | 155      |
| Unit 2             | 4.24         | 20.32         | 185      | 160      |
| Unit 3             | 4.46         | 21.59         | 200      | 158      |
| Unit 4             | 4.34         | 24.87         | 195      | 160      |
| Unit 5             | 10.91        | 165.86        | 500      | 360      |
| <b>Total</b>       | <b>28.16</b> | <b>252.54</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 4.14         | 66.40         | 190      | 159      |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>4.14</b>  | <b>66.40</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 2.75         | 77.74         | 122      | 99       |
| <b>Total</b>       | <b>2.75</b>  | <b>77.74</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.09         | 1.52          | 27       | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.09</b>   | <b>1.52</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 4.22          | 54.92          | 520      | 40       |
| Stage 4         | 4.00          | 88.76          | 760      | 0        |
| Stage 3         | 1.40          | 30.37          | 240      | 0        |
| <b>Total</b>    | <b>9.61</b>   | <b>174.06</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.00          | 4.12           | 0        | 0        |
| VTRNA           | 0.00          | 0.00           | 0        | 0        |
| TILLARI         | 0.54          | 7.68           | 60       | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.17          | 2.20           | 80       | 0        |
| RNGR+BHTSA      | 0.33          | 5.35           | 14       | 13       |
| BHANDARDRA      | 0.00          | 0.00           | 0        | 0        |
| ELDARY          | 0.00          | 0.05           | 0        | 0        |
| SMLHY_PTN       | 0.29          | 5.47           | 13       | 12       |
| GHATGHAR        | 1.12          | 12.26          | 125      | 0        |
| <b>Total</b>    | <b>2.45</b>   | <b>37.14</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 9.52          | 153.95         | 0        | 0        |
| <b>Total</b>    | <b>9.52</b>   | <b>153.95</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 73.92         | 1120.71        | 0        | 0        |
| JSWEL(Mus)      | 24.77         | 385.22         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 0.00          | 0.00           | 0        | 0        |
| WPCL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| Other(Mus)      | 14.27         | 245.16         | 0        | 0        |
| <b>Total</b>    | <b>112.96</b> | <b>1751.09</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 6.36          | 87.15          | 0        | 0        |
| <b>Total</b>    | <b>6.36</b>   | <b>87.15</b>   |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 9.72          | 149.14         | 478      | 315      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 0.00          | 15.73          | 0        | 0        |
| Trombay 7B      | 0.00          | 12.56          | 0        | 0        |
| Trombay 8       | 5.23          | 82.43          | 244      | 183      |
| TATA Hydro      | 4.39          | 53.26          | 294      | 0        |
| <b>Total</b>    | <b>19.33</b>  | <b>313.11</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 5.28          | 111.70         | 251      | 186      |
| <b>Total</b>    | <b>5.28</b>   | <b>111.70</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 124.45      | 1889.50       | MSPGCL Total        | 139.26      | 2178.43       |
|                |             |         | MSPGCL Thml+Gas | 127.20      | 1967.24       | Koyna 1,2 & 4 Total | 8.21        | 143.68        |
|                |             |         | MSPGCL Hydro    | 12.06       | 211.19        | State Total         | 292.71      | 4595.44       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 16/Jan/2020

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4523        | 70    | 109  | 4702   | 528  | 4169      | 0    | 0     | 5000        | 5043        | -837                 | 13605                 | 0                    | 13605                     | 1523             | 15128           | 50.04         |
| 2                  | 4552        | 65    | 110  | 4727   | 505  | 4148      | 0    | 0     | 5000        | 5011        | -728                 | 13663                 | 0                    | 13663                     | 1413             | 15076           | 50.04         |
| 3                  | 4542        | 70    | 100  | 4712   | 509  | 4153      | 0    | 0     | 4923        | 4829        | -656                 | 13547                 | 0                    | 13547                     | 1342             | 14889           | 50.03         |
| 4                  | 4578        | 75    | 110  | 4763   | 456  | 4084      | 0    | 0     | 4904        | 5056        | -624                 | 13735                 | 0                    | 13735                     | 1309             | 15044           | 49.99         |
| 5                  | 4952        | 295   | 110  | 5357   | 376  | 4221      | 0    | 0     | 4999        | 5268        | -644                 | 14578                 | 0                    | 14578                     | 1328             | 15906           | 49.94         |
| 6                  | 5315        | 156   | 99   | 5570   | 358  | 4623      | 0    | 0     | 5547        | 5775        | -753                 | 15573                 | 0                    | 15573                     | 1465             | 17038           | 49.98         |
| 7                  | 5500        | 168   | 110  | 5778   | 311  | 4851      | 0    | 0     | 6636        | 6567        | -712                 | 16795                 | 0                    | 16795                     | 1695             | 18490           | 49.97         |
| 8                  | 5512        | 1114  | 115  | 6741   | 295  | 4831      | 0    | 54    | 6768        | 6917        | -782                 | 18056                 | 0                    | 18056                     | 1893             | 19949           | 50.01         |
| 9                  | 5479        | 1416  | 122  | 7017   | 151  | 4830      | 0    | 289   | 6775        | 6659        | -921                 | 18025                 | 0                    | 18025                     | 2139             | 20164           | 50.00         |
| 10                 | 5477        | 1468  | 120  | 7065   | 183  | 4868      | 0    | 597   | 6837        | 6913        | -1102                | 18524                 | 0                    | 18524                     | 2365             | 20889           | 49.99         |
| 11                 | 5487        | 1253  | 120  | 6860   | 203  | 4971      | 0    | 786   | 7366        | 7357        | -1228                | 18949                 | 0                    | 18949                     | 2469             | 21418           | 50.03         |
| 12                 | 5469        | 997   | 118  | 6584   | 297  | 4959      | 0    | 919   | 7758        | 7805        | -1252                | 19312                 | 0                    | 19312                     | 2476             | 21788           | 50.03         |
| 13                 | 5429        | 570   | 118  | 6117   | 451  | 4967      | 0    | 915   | 7541        | 7547        | -1144                | 18853                 | 0                    | 18853                     | 2382             | 21235           | 49.98         |
| 14                 | 5313        | 385   | 117  | 5815   | 531  | 4964      | 0    | 907   | 7354        | 7308        | -1060                | 18465                 | 0                    | 18465                     | 2229             | 20694           | 49.96         |
| 15                 | 5278        | 526   | 118  | 5922   | 519  | 4957      | 0    | 803   | 7368        | 7450        | -1075                | 18576                 | 0                    | 18576                     | 2220             | 20796           | 49.90         |
| 16                 | 5321        | 426   | 118  | 5865   | 504  | 4946      | 0    | 626   | 7232        | 7145        | -970                 | 18116                 | 0                    | 18116                     | 2219             | 20335           | 49.95         |
| 17                 | 5341        | 761   | 118  | 6220   | 421  | 4905      | 0    | 389   | 6311        | 6422        | -961                 | 17396                 | 0                    | 17396                     | 2222             | 19618           | 49.90         |
| 18                 | 5332        | 786   | 118  | 6236   | 309  | 4920      | 0    | 72    | 5717        | 5664        | -965                 | 16236                 | 0                    | 16236                     | 2225             | 18461           | 49.99         |
| 19                 | 5309        | 546   | 118  | 5973   | 307  | 4909      | 0    | 0     | 5528        | 5575        | -986                 | 15778                 | 0                    | 15778                     | 2248             | 18026           | 49.97         |
| 20                 | 5253        | 605   | 117  | 5975   | 352  | 4910      | 0    | 0     | 5474        | 5660        | -966                 | 15931                 | 0                    | 15931                     | 2219             | 18150           | 50.01         |
| 21                 | 5219        | 71    | 118  | 5408   | 444  | 4892      | 0    | 0     | 5261        | 5343        | -1001                | 15086                 | 0                    | 15086                     | 2077             | 17163           | 50.02         |
| 22                 | 5222        | 96    | 118  | 5436   | 500  | 4886      | 0    | 0     | 4825        | 4710        | -995                 | 14537                 | 0                    | 14537                     | 1918             | 16455           | 50.03         |
| 23                 | 5056        | 71    | 118  | 5245   | 489  | 4645      | 0    | 0     | 4794        | 4586        | -916                 | 14049                 | 0                    | 14049                     | 1734             | 15783           | 50.02         |
| 24                 | 4991        | 72    | 108  | 5171   | 517  | 4353      | 0    | 0     | 4715        | 4622        | -754                 | 13909                 | 0                    | 13909                     | 1535             | 15444           | 50.00         |
| MUs                | 124.45      | 12.06 | 2.75 | 139.26 | 9.52 | 112.96    | 0.00 | 6.36  | 144.63      | 145.23      | -22.03               | 391.29                | 0.00                 | 391.29                    | 46.65            | 437.94          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 16/Jan/2020**

Position as on 6.30 Hrs of 17/Jan/2020

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                                                          | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |           |            |                                                                                                                           |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |           | Continued. | Annual Overhaul                                                                                                           |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 27/07/2019   | 00.00        |           | Continued. | Annual Overhaul                                                                                                           |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 25/09/2019   | 04.20        |           | Continued. | Withdrawn On Shaft Seal Water Leakage. Converted to AOH From 1 Nov 2019.                                                  |               |
| MSPGCL                | Nasik Unit 4            | 210      | 20/11/2019   | 04.15        |           | Continued. | ID Fan Problem(Converted for Zero Schedule from 05.00hrs DT. 21-11-2019 and Continued for Annual Overhaul From 01.12.2019 |               |
| AEML                  | AEML Unit 2             | 250      | 06/01/2020   | 18.44        |           | Continued. | Annual Overhaul                                                                                                           |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |           |            |                                                                                                                           |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                                                   |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                                                         |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                                                         |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                                               |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                                               |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |           | Continued. | No PPA                                                                                                                    |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |           | Continued. | No Schedule.                                                                                                              |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |           | Continued. | No Schedule                                                                                                               |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage                                                                                                             |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal Shortage                                                                                                             |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/08/2019   | 09.52        |           | Continued. | Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)                               |               |
| IPP                   | RPL(AMT) U-1            | 270      | 01/09/2019   | 09.11        |           | Continued. | Generator Protection operated                                                                                             |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 01/09/2019   | 17.56        |           | Continued. | Zero Schedule from 18:00hrs of 28/09/2019                                                                                 |               |
| MSPGCL                | Koradi Unit 6           | 210      | 06/09/2019   | 15.41        |           | Continued. | Zero Schedule By MSEDCL                                                                                                   |               |
| IPP                   | RPL(AMT) U-3            | 270      | 25/10/2019   | 02.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                                                  |               |
| IPP                   | RPL(AMT) U-2            | 270      | 25/10/2019   | 22.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                                                  |               |
| IPP                   | RPL(AMT) U-5            | 270      | 09/11/2019   | 03.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                                                  |               |
| IPP                   | RPL(AMT) U-4            | 270      | 12/11/2019   | 00.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                                                  |               |
| MSPGCL                | Uran Unit 8             | 108      | 30/11/2019   | 19.14        |           | Continued. | Over Speed Bolt Trip.                                                                                                     |               |
| MSPGCL                | Nasik Unit 5            | 210      | 12/12/2019   | 10.25        |           | Continued. | PA Fan Problem (Under Case 4 Bidding From 04.25Hrs DT. 13-12-2019)                                                        |               |
| MSPGCL                | Bhusawal Unit 5         | 500      | 23/12/2019   | 22.05        |           | Continued. | Boiler Tube Leakage(Converted to Zero Schedule from 22.00Hrs DT. 26-12-2019)                                              |               |
| MSPGCL                | Uran Unit B0            | 120      | 28/12/2019   | 22:48        |           | Continued. | Gas shortage                                                                                                              |               |
| MSPGCL                | Uran Unit 7             | 108      | 28/12/2019   | 22:48        |           | Continued. | Gas shortage                                                                                                              |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 16/Jan/2020**

**Position as on 6.30 Hrs of 17/Jan/2020**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage         | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------|---------------|
| MSPGCL             | Bhusawal Unit 4         | 500      | 29/12/2019   | 00.57        |            | Continued. | Zero Schedule By MSEDCL  |               |
| MSPGCL             | Uran Unit 6             | 108      | 11/01/2020   | 16.02        |            | Continued. | Gas shortage             |               |
| MSPGCL             | Parli Unit 7            | 250      | 12/01/2020   | 00.00        |            | Continued. | Zero Schedule By MSEDCL. |               |
| MSPGCL             | Parli Unit 6            | 250      | 12/01/2020   | 00.00        |            | Continued. | Zero Schedule By MSEDCL. |               |
| MSPGCL             | Parli Unit 8            | 250      | 12/01/2020   | 00.00        | 16/01/2020 | 02.36      | Zero Schedule By MSEDCL. |               |
| TPC-G              | Trombay 7B              | 60       | 12/01/2020   | 20.14        |            | Continued. | Gas shortage             |               |
| TPC-G              | Trombay 7A              | 120      | 12/01/2020   | 20.30        |            | Continued. | Gas shortage             |               |
| MSPGCL             | Paras Unit 3            | 250      | 17/01/2020   | 06.02        |            | Continued. | Furnace Pressure High    |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 16/Jan/2020**

**Statement-VII**

Position as on 6.30 Hrs of 17/Jan/2020

| Name of Line                         | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                         |
|--------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                          |
| Karad Solapur (PG)                   | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403 |
| Dhule Sar'Sarovar II                 | InterState                | 15/01/2020   | 17.55        | 16/01/2020 | 05.57      | HT          | Over Voltage                                             |
| Dhule Sar'Sarovar I                  | InterState                | 16/01/2020   | 18.08        | 17/01/2020 | 05.42      | HT          | Over Voltage                                             |
| Khadka-Aurangabad (Waluj)            | IntraState                | 15/01/2020   | 17.51        | 16/01/2020 | 09.09      | HT          | Over Voltage                                             |
| Lonikand 1 - Chakan                  | IntraState                | 16/01/2020   | 02.32        | 16/01/2020 | 10.10      | T           | DT send from Chakan end due master trip relay problem    |
| Babhaleshwar - Padghe-I              | IntraState                | 16/01/2020   | 09.03        | 16/01/2020 | 20.27      | PO          | PID faulty String replacement work and Relay Testing     |
| Lonikand 1 -Jejuri                   | IntraState                | 16/01/2020   | 11.59        | 16/01/2020 | 23.48      | PO          | Replacement of Main 2 protection Relay                   |
| Khadka-Aurangabad (Waluj)            | IntraState                | 16/01/2020   | 19.53        |            | Continued. | HT          | Over Voltage                                             |
| <b>400 KV ICT Outages/Trippings</b>  |                           |              |              |            |            |             |                                                          |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe  | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection, Declared Faulty.                |
| 400/132 Kv 200 Mva Ict 1 @Khadka     | IntraState                | 16/01/2020   | 18.36        | 16/01/2020 | 19.37      | EO          | Y Phase LA Counter Cable replacement work                |
| <b>220 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                          |
| Mudshingi Chikodi                    | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule.(close at Mudshingi end only)                |
| Talandage - Chikodi                  | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule.(close at Chikodi end only)                  |
| BOISAR BORIVALI                      | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)             |
| MAHAPE - RELIANCE GIS                | IntraState                | 08/01/2020   | 10:44        |            | Continued. | HT          | At Mahape End For New Configuration.                     |
| Kalwa - Mulund 2                     | IntraState                | 15/01/2020   | 09.02        |            | Continued. | PO          | Stringing of HTLS conductor.                             |
| Pusad-WardhaPG(Deoli)                | IntraState                | 15/01/2020   | 11.54        | 16/01/2020 | 11.49      | EO          | Outage for height raising work.                          |
| Padghe - Nalasopara                  | IntraState                | 15/01/2020   | 18.49        | 16/01/2020 | 15.03      | T           | Distance Protection                                      |
| Badnera-Akola I                      | IntraState                | 16/01/2020   | 04.43        | 16/01/2020 | 06.39      | T           | C.B.problem                                              |
| Tambati - Adlabs                     | IntraState                | 16/01/2020   | 08.56        | 16/01/2020 | 17.54      | PO          | Relay Replacement work                                   |
| PAL DOMBIVALI - PALAVA               | IntraState                | 16/01/2020   | 09.20        | 16/01/2020 | 18.50      | PO          | Routine Maintenance Work                                 |
| Khaparkheda-Ambazari-I               | IntraState                | 16/01/2020   | 10.36        | 16/01/2020 | 15.12      | EO          | To attend Hot Spot                                       |
| Kalwa1- Airoli Knowledge Park        | IntraState                | 16/01/2020   | 10.39        | 16/01/2020 | 19.54      | PO          | Breaker Overhauling                                      |
| Uran - Jnpt                          | IntraState                | 16/01/2020   | 11.00        | 16/01/2020 | 14.46      | PO          | Line Maintenance work                                    |
| Wardha-Yeotmal                       | IntraState                | 16/01/2020   | 12.13        |            | Continued. | PO          | Shifting/Diversion work of 220KV Deoli-Pusad D/C Line    |
| Kalwa - Colourchem                   | IntraState                | 16/01/2020   | 14.40        | 16/01/2020 | 14.56      | EO          | To Remove Kite                                           |
| Kalwa - Colourchem                   | IntraState                | 16/01/2020   | 16.26        | 16/01/2020 | 18.13      | T           | Distance Protection                                      |
| <b>220 KV ICT Outages/Trippings</b>  |                           |              |              |            |            |             |                                                          |
| 220/100 KV 200MVA ICT II @ Pal       | IntraState                | 16/01/2020   | 09.25        | 16/01/2020 | 18.55      | PO          | Routine Maintenance Work                                 |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage