

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 16/Jan/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	144.697	2308.217	1) Gujrat	-4.469	-76.413
2) Hydro	12.208	217.163	2) Madhya Pradesh	1.001	52.327
3) Gas	5.867	76.763	3) Chattisgarh	4.550	90.580
Total MSPGCL	162.772	2602.143	4) Maharashtra	180.797	2839.078
B) 1) APLM	54.306	818.282	5) Goa (Amona)	-1.159	-25.380
2) JSWEL	19.084	309.339	Total	180.720	2880.192
3) VIPL	0.000	0.000	a) Mumbai Schedule	21.247	351.269
4) RPL(AMT)	31.034	371.842	b) Mumbai Drawl	24.704	412.333
5) SWPGPL	8.373	128.149	c) MSEDCL Bilateral *	64.150	1148.715
6) Other IPP	37.760	739.552	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	21.247	351.269
C) 1) TPCL Thermal	11.495	184.217	Include PX	0.000	0.000
2) TPCL Hydro	2.123	52.300	Standby	0.000	0.000
3) TPCL Gas	1.990	37.820	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.574	142.522	1) MSEDCL	475.875	7603.001
D) STATE			2) Mumbai Discoms	49.887	829.191
1) Thermal	316.323	5002.120	3) Other Discoms	9.820	154.014
(A1+C1+C4+(B1-B6))			TOTAL STATE	535.582	8586.206
2) Hydro (A2+C2)	14.331	269.463			
3) Gas (A3+B7+C3)	7.857	114.583			
4) Wind	3.133	120.260			
6) SOLAR	13.217	199.589			
TOTAL STATE	354.861	5706.015			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6092	5979	6594	4848
MSPGCL Hydro	1299	547	881	101
MSPGCL Gas	243	241	239	248
MSPGCL Total Generation	7634	6767	7714	5197
Central Sector Receipt	9551	9211	7236	5902
WIND	121	140	63	136
CPP / IPP Thermal	6743	6242	6538	5528
CPP / IPP Gas	0	0	0	0
SOLAR	1697	2012	0	0
Exchange with Mumbai	-1639	-1557	-1189	-279
MSEDCL DEMAND MET	23675	22376	19899	16108
Load Shedding	0	0	0	0
MSEDCL DEMAND	23675	22376	19899	16108
TPCL GENERATION	627	627	803	940
AEML GENERATION	300	291	446	499
MUMBAI DEMAND	2566	2475	2438	1718
OTHER DISCOM DEMAND	432	439	463	376
STATE DEMAND MET	26673	25290	22800	18202
STATE DEMAND	26673	25290	22800	18202
Frequency (Hz)	50.15	50.05	50.02	50.05

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.37 Hz at 17.03 Hrs	49.84 Hz at 19.18 Hrs	50.03	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 16/Jan/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.96	77.04	210	185
Unit 7	0.00	0.00	0	0
Unit 8	13.20	212.08	631	402
Unit 9	12.42	109.56	576	410
Unit 10	12.78	204.51	575	480
Total	43.35	603.19		
Bhusawal				
Unit 3	3.31	26.32	170	115
Unit 4	9.90	162.53	495	280
Unit 5	9.72	117.92	485	275
Total	22.94	306.77		
Parli				
Unit 6	1.84	66.42	239	0
Unit 7	0.00	13.70	0	0
Unit 8	0.00	52.59	0	0
Total	1.84	132.71		
Chandrapur				
Unit 3	3.50	54.25	165	120
Unit 4	3.07	38.13	145	115
Unit 5	2.56	97.56	300	0
Unit 6	8.58	136.34	415	281
Unit 7	0.00	0.00	0	0
Unit 8	10.65	172.50	494	280
Unit 9	10.72	174.07	496	340
Total	39.08	672.85		
Paras				
Unit 3	5.00	79.15	237	163
Unit 4	5.30	63.83	232	151
Total	10.30	142.98		
Khaparkheda				
Unit 1	2.74	43.04	130	100
Unit 2	2.99	43.46	140	114
Unit 3	3.68	54.82	182	129
Unit 4	3.19	46.06	148	119
Unit 5	9.72	159.20	450	280
Total	22.34	346.58		
Nasik				
Unit 3	1.37	1.37	168	0
Unit 4	3.48	53.78	167	118
Unit 5	0.00	47.98	0	0
Total	4.85	103.13		
Uran				
All Units	5.87	76.76	251	238
Total	5.87	76.76		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.35	6.17	45	0
Total	0.35	6.17		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.49	65.58	580	35
Stage 4	4.32	72.52	747	0
Stage 3	1.65	29.79	276	0
Total	9.46	167.90		
Hydro				
KDPH	0.00	3.13	0	0
VTRNA	0.00	0.04	0	0
TILLARI	0.00	4.41	0	0
BHIRA T.R.	0.08	3.20	40	0
SMLHY_PTN	1.47	22.21	64	55
GHATGHAR	0.85	10.10	125	0
Total	2.40	43.10		
Wind				
Total	3.13	120.26	0	0
Total	3.13	120.26		
CPP				
APML(Mus)	54.31	818.28	0	0
JSWEL(Mus)	19.08	309.34	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.03	371.84	0	0
SWPGPL-Mus	8.37	128.15	0	0
Other(Mus)	37.76	739.55	0	0
Total	150.56	2367.16		
SOLAR				
Total	13.22	199.59	0	0
Total	13.22	199.59		
Tata				
Trombay 5	7.57	121.75	473	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.06	21.64	45	43
Trombay 7B	0.93	16.18	39	37
TATA Hydro	2.12	52.30	265	2
Trombay 8	3.92	62.47	241	128
Total	15.61	274.34		
AEMIL				
DTPS U-1&2	9.57	142.52	499	291
Total	9.57	142.52		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	144.70	2308.22	MSPGCL Total	162.77	2602.14
			MSPGCL Thml+Gas	150.56	2384.98	Koyna 1,2 & 4 Total	7.82	138.11
			MSPGCL Hydro	12.21	217.16	State Total	354.86	5706.02

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 16/Jan/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4848	101	248	5197	136	5528	0	0	6156	5902	-279	16108	0	16108	1718	376	18202	50.05
2	5055	102	251	5408	108	5648	0	0	6144	6086	-272	16640	0	16640	1622	338	18600	50.05
3	5104	102	249	5455	118	5626	0	0	6290	5884	-250	16510	0	16510	1545	323	18378	50.01
4	5078	100	249	5427	157	5616	0	0	6360	6223	-241	16855	0	16855	1536	327	18718	50.01
5	5267	101	249	5617	126	5941	0	0	6389	6320	-272	17372	0	17372	1561	360	19293	49.98
6	5785	157	250	6192	114	6245	0	0	6802	7028	-623	18580	0	18580	1669	376	20625	50.01
7	6278	287	249	6814	178	6765	0	1	7183	7441	-828	19977	0	19977	1729	394	22100	50.02
8	6320	658	249	7227	211	6990	0	152	7702	7791	-898	21073	0	21073	1929	400	23402	50.03
9	6321	1199	249	7769	212	6846	0	615	7658	8337	-1125	22239	0	22239	2208	415	24862	50.09
10	6287	1791	246	8324	135	6785	0	1216	8238	8549	-1444	23146	0	23146	2433	419	25998	50.08
11	6092	1299	243	7634	121	6743	0	1697	9533	9551	-1639	23675	0	23675	2566	432	26673	50.15
12	6176	781	242	7199	134	6471	0	1904	9636	9506	-1648	23136	0	23136	2565	430	26131	50.04
13	5979	547	241	6767	140	6242	0	2012	9423	9211	-1557	22376	0	22376	2475	439	25290	50.05
14	6058	500	239	6797	158	6130	0	1890	8752	8917	-1480	21966	0	21966	2342	446	24754	50.01
15	6242	187	238	6667	166	6362	0	1675	8743	9051	-1442	22051	0	22051	2331	428	24810	49.99
16	6483	489	239	7211	123	6551	0	1242	8854	9035	-1465	22261	0	22261	2339	436	25036	50.00
17	6563	675	240	7478	88	6549	0	641	8276	8137	-1396	21048	0	21048	2345	449	23842	50.00
18	6604	420	239	7263	71	6508	0	172	7668	7616	-1350	19825	0	19825	2356	455	22636	50.05
19	6594	881	239	7714	63	6538	0	0	7136	7236	-1189	19899	0	19899	2438	463	22800	50.02
20	6642	1222	241	8105	50	6588	0	0	6565	6779	-1069	20005	0	20005	2308	448	22761	50.02
21	6407	255	243	6905	60	6385	0	0	6931	6769	-1206	18474	0	18474	2220	439	21133	50.01
22	6330	157	243	6730	77	5884	0	0	6569	6566	-1111	17712	0	17712	2071	434	20217	50.03
23	6263	98	245	6606	161	5795	0	0	6526	6451	-1005	17598	0	17598	1883	410	19891	50.02
24	5921	99	246	6266	226	5821	0	0	6558	6334	-915	17348	0	17348	1697	384	19429	50.04
MUs	144.70	12.21	5.87	162.77	3.13	150.56	0.00	13.22	180.09	180.72	-24.70	475.87	0.00	475.87	49.89	9.82	535.58	50.03

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/Jan/2023

Position as on 6.30 Hrs of 17/Jan/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
MSPGCL	Parli Unit 7	250	03/01/2023	22:16		Continued.	Annual Overhaul	31/01/2023
IPP	JSW (J) U4	300	04/01/2023	23:45	17/01/2023	00:22	NO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/02/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	20/01/2023
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25	16/01/2023	12:57	Boiler Tube Leakage. Unit on tolling from 22:00Hrs Dtd 09.12.2022	
IPP	Adani U-1	660	12/01/2023	11:02	17/01/2023	14:24	APH-B Hot PA below leakage.	15/01/2023
MSPGCL	Parli Unit 8	250	14/01/2023	08:51		Continued.	Lube oil system problem	18/01/2023
MSPGCL	Nasik Unit 5	210	15/01/2023	21:18		Continued.	ID Fan Problem	
MSPGCL	Chandrapur Unit 5	500	16/01/2023	00:14		Continued.	Loss of fuel	
MSPGCL	Parli Unit 6	250	16/01/2023	10:12		Continued.	DUE TO RISE IN FLUE GAS TEMPERTURE OF AIR HEATER B CONTUNOUSLY	
MSPGCL	Koyna Unit 6	80	16/01/2023	11:00		Continued.	Preventive Maintenance Work	19/01/2023
IPP	SWPGPL U-3	135	16/01/2023	13:05	16/01/2023	18:18	Generator protection	
MSPGCL	Chandrapur Unit 6	500	17/01/2023	10:17		Continued.	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 4	210	17/01/2023	12:24	17/01/2023	15:15	Generator protection	
MSPGCL	Khaparkheda Unit 3	210	17/01/2023	13:54		Continued.	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 16/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 17/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Tripping							
MAIN BAY (703) BUS REACTOR @ AKOLA 2	IntraState	16/01/2023	10:48	16/01/2023	20:05	PO	OEM Inspection of CB
MAIN BAY (703) BUS REACTOR @ AKOLA 2	IntraState	17/01/2023	09:38			PO	OEM Inspection of CB
765 KV LR Outages/Tripping							
709 LR (AKOLA CKT - 1) REACTOR @ KORADI 3	IntraState	17/01/2023	13:05			PO	For Reactor changeover Activity as per CEA guideline B- Ph reactor taken into service in place of Spare Reactor.
400 KV TIEBAY Outages/Tripping							
TIE BAY (406) OF AURANGABAD (PG) - 2 & ICT - 2	IntraState	17/01/2023	10:38	17/01/2023	14:09	PO	AMP of 406 Bay at Akola
400 KV TBC Outages/Tripping							
TBC @ KHARGHAR	IntraState	16/01/2023	08:25			PO	400kV CB mechanism Overhauling work
400 KV MAINBAY Outages/Tripping							
MAIN BAY - 418 OF AKOLA CKT - 2 @ AURANGABAD(PG)	InterState	16/01/2023	12:43	16/01/2023	17:53	PO	AMP of 407 Bay at Akola
BUS COUPLER @ NAGOTHANE	IntraState	16/01/2023	15:56	16/01/2023	20:24	EO	R-Ph A-bus BPI Clamp with flexible arrangement found broken.
400 KV LINE Outages/Tripping							
KOLHAPUR - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
JAIGAD - KARAD CKT - 1	IntraState	15/01/2023	21:22	16/01/2023	08:17	HT	H/T TO CONTROL O/V
KHARGHAR - TALEGAON (PG)	IntraState	15/01/2023	21:45	16/01/2023	02:54	PO	Removal of Tapping of 400KV Kalwa-Padgha-II line on 400KV Kharghar-Talegaon Line to normalise the network.
PADGHE - KALWA CKT - 2	IntraState	15/01/2023	21:45	16/01/2023	04:55	PO	Removal of Tapping of 400KV Kalwa-Padgha-2 line on 400KV Kharghar-Talegaon Line to normalize the Network.
NAGOTHANE - DABHOL CKT - 1	IntraState	16/01/2023	09:41	16/01/2023	15:03	PO	Dignostic testing work and Earthwire restringing work
TBC @ KORADI-1	IntraState	16/01/2023	11:14			PO	For 400KV TBC CB mechanism overhauling work by M/s Royal Corporation,Mumbai.During outage 400kV Bus reactor remain out of service as bus reactor charged through TBC
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	16/01/2023	11:34			HT	For load management
JAIGAD - KARAD CKT - 2	IntraState	17/01/2023	01:53	17/01/2023	09:49	HT	H/T to Control Over Voltage.
PADGHE - NAGOTHANE CKT - 1	IntraState	17/01/2023	09:58			PO	For earth wire restringing work
400 KV ICT Outages/Tripping							
400/220 KV 315MVA ICT - 2 @ KARAD	IntraState	16/01/2023	08:49			PO	Oil filtration work of ICT-II Y ph 105 MVA Unit having abnormal DGA reports & partial Discharge.SE,TCC Karad recommended to carry out filtration of oil for monitoring
400/220/33KV 315MVA ICT - 3 @ LONIKAND	IntraState	16/01/2023	12:55			PO	Overhauling and servicing of 29A & 29B PGI replacement of their mechanism box

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 17/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 500MVA ICT - 2 @ KORADI 2	IntraState	17/01/2023	10:22			PO	Diagnostic Testing of ICT and routine bay maintenance work
220 KV TBC Outages/Trippings							
BUS COUPLER @ PALAVA	IntraState	16/01/2023	12:03	16/01/2023	13:32	PO	Relay testing work of 220kV Bus Coupler bay
220 KV MAINBAY Outages/Trippings							
MAIN BUS SECTION-2 @ VSNL	IntraState	16/01/2023	12:02			PO	Metering CT Replacement activity at 220 KV STT GIS end
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
POPHALI - KDPH	IntraState	07/01/2023	10:32			PO	For Erection & stringing of In-line Multi circuit towers (Loc. No. 1 to 7) of new 220 KV Karad & Koyana line and restringing of existing 220 KV D/C KDPH LILO line.
VANKUSWADE - KDPH	IntraState	07/01/2023	10:46			PO	For Erection & Stringing of In line Multi Circuit tower (Loc No.1 to 7) of new 220kV Karad-Koyana Line and Re stringing of existing 220kV D/C KDPH LILO line.
TALANDAGE - FIVE STAR MIDC 1	IntraState	16/01/2023	10:00	16/01/2023	13:37	PO	For chemical washing of insulator strings and hotspot attending work
EKLAHARE (OCR) - PADGHE	IntraState	16/01/2023	11:11			HT	For load management
VSNL - STT GIS CKT - 2	IntraState	16/01/2023	12:02			PO	Metering CT Replacement activity at 220 KV STT GIS end
BOMBAY DYEING - SAHARA	IntraState	16/01/2023	12:34	16/01/2023	17:33	T	Tripped on ph-ph fault
TALANDAGE - FIVE STAR MIDC 2	IntraState	16/01/2023	14:02	16/01/2023	16:13	PO	For chemical washing of insulator strings and hotspot attending work
SADAWAGHAPUR KARAD CKT 1	IntraState	17/01/2023	08:53			PO	220 kV New PT bay for Bus-I & Bus-II is taken into service since 18.03.2021 & all bay PT extension is completed on new PT bay.Also outage on 220 KV SADAWAGHAPUR KARAD CKT 1 required for opening of Bus Section to avoid phase to phase fault while opening with the help of Hot Line Unit. 220 kV Sadawaghapur Ckt-I kept OFF.Also alignment of Bus-I isolator of Sadawaghapur Ckt-I will be carried out.
MHAISHAL- JATH	IntraState	17/01/2023	09:28	17/01/2023	17:22	PO	Cold line washing Work
MAIN BUS - 1 @ KARAD	IntraState	17/01/2023	09:52			PO	Dismantling of old 03 nos of 220 KV Bus-I PTs which are now out of service with help of Hot Line Unit,Ogalewadi by opening Bus-I jump in ICT-II bay as Bus PT are commissioned exact below the Bus by isolating bus section for 220 kV Sadawaghapur Ckt-I & II. PTs are to be dismantled by crane after isolating Bus PT.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	17/01/2023	10:16			PO	Erection and Stringing of 8nos of monopole, out of which of 6nos of In-line monopole loc.no.118, 118A,119A,122, 123, 123A.
MAIN BUS - 2 @ AAREY	IntraState	17/01/2023	10:36			PO	Annual maintenance of Main Bus-2 and Bus side isolators.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 17/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (GCR) - GHATGHAR	IntraState	17/01/2023	10:37			PO	Erection and Stringing of 8nos of monopole, out of which of 6nos of In-line monopole loc.no.118, 118A,119A,122, 123, 123A.
APTA - KALWA	IntraState	17/01/2023	12:19	17/01/2023	17:10	PO	Replacement of RY and B phase LA, due to IR Value low and bay maintenance
AUXILARY BUS @ KALWA	IntraState	17/01/2023	12:41	17/01/2023	15:03	EO	For removing bird nest for 220kv Aux.Bus B phase Gantry at 200MVA ICT No.1 Bay.
GORAI -MSETCL BORIVALI CKT -1	IntraState	17/01/2023	12:48			PO	For Annual Relay Testing at MSETCL Borivali End by Testing Division Kalwa.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	17/01/2023	12:57	17/01/2023	17:19	PO	Annual relay testing & dignostic testing work
POPHLI PEDHMBE LINE- 1	IntraState	17/01/2023	14:55	17/01/2023	15:55	EO	R Phase CT Oil Level low
DASTURI-KANDALGAON LINE	IntraState	17/01/2023	16:02			PO	C-Tan delta testing of R,Y,B phase CTs of 220KV Dasturi-Kandalgaon line. Also CB Timing test of line CB at Dasturi s/s.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	IntraState	23/12/2022	09:30		Continued.	PO	For TF Diagnostic Testing work , HV CT Tandelta , HV & LV Breaker CRM, Timing and R&M work
220/33-33KV 100MVA TF NO. - 1 @ ICHALKARANJI - II	IntraState	16/01/2023	09:03	16/01/2023	16:16	PO	1)Quarterly bay maintenance work 2) Hot spot attending work
220/100 KV 200 MVA ICT 4 @ APTA	IntraState	16/01/2023	09:26			PO	Bushing Gasket Replacement work & Schedule maintenance work.
220/33 KV 50 MVA PTR - 7 @ WATHAR	IntraState	16/01/2023	09:38	16/01/2023	17:21	PO	OLTC overhauling work& Quarterly maint work.
220/132 KV 100 MVA ICT 1 @ PHALTAN MIDC	IntraState	16/01/2023	10:27	16/01/2023	16:04	PO	Replacement work of HV Y Ph LA & Quarterly maintenance work.
35 MVA 220/ 6.6 KV STN TF - II @ PARLI U-8	IntraState	16/01/2023	11:08	16/01/2023	17:57	PO	Tandelta testing work
220/22KV 50MVA PTR - 1 @ PALAVA	IntraState	16/01/2023	13:09	16/01/2023	18:18	PO	Diagnostic testing works. Winding Resistance, Bushing & Winding Tan-Delta.
220/132 KV 200 MVA PTR 4 @ PHURSUNGI	IntraState	17/01/2023	09:00	17/01/2023	14:16	PO	ICT diagnostic Testing Work , HV CT tan delta testing & bay half yearly maint. work.
220/22 KV 50 MVA PTR 1 @ PAL-DOMBIVALI	IntraState	17/01/2023	10:30	17/01/2023	17:28	PO	Transformer Painting work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage