

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 16/Jan/2024 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	170.612	2558.509	1) Gujrat	-7.074	-76.791
2) Hydro	15.911	143.873	2) Madhya Pradesh	0.096	55.528
3) Gas	7.099	105.156	3) Chattisgarh	4.290	95.910
Total MSPGCL	193.622	2807.538	4) Maharashtra	183.235	2843.216
B) 1) APLM	49.885	913.868	5) Goa (Amona)	-1.176	-27.790
2) JSWEL	26.196	383.185	Total	179.371	2890.073
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.141	505.454
4) RPL(AMT)	31.500	390.138	b) Mumbai Drawl	33.594	566.271
5) SWPGPL	12.255	191.890	c) MSEDCL Bilateral *	71.399	1049.636
6) Other IPP	32.413	686.583	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.141	505.003
C) 1) TPCL Thermal	13.297	196.542	Include PX	0.000	0.000
2) TPCL Hydro	3.311	69.621	Standby	0.000	0.452
3) TPCL Gas	2.879	40.938	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.007	72.431	1) MSEDCL	504.279	7901.963
D) STATE			2) Mumbai Discoms	58.088	945.790
1) Thermal	341.165	5393.146	3) Other Discoms	10.158	163.674
(A1+C1+C4+(B1-B6))			TOTAL STATE	572.525	9011.427
2) Hydro (A2+C2)	19.222	213.494			
3) Gas (A3+B7+C3)	9.978	146.094			
4) Wind	6.082	159.321			
6) SOLAR	16.707	209.312			
TOTAL STATE	393.154	6121.367			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	7333	7076	7338	6362
MSPGCL Hydro	1125	220	1568	169
MSPGCL Gas	305	296	370	312
MSPGCL Total Generation	8763	7592	9276	6843
Central Sector Receipt	8890	8989	7709	6313
WIND	134	179	248	334
CPP / IPP Thermal	6440	5947	6067	6567
CPP / IPP Gas	0	0	0	0
SOLAR	2125	2397	1	0
Exchange with Mumbai	-1663	-1962	-1315	-1158
MSEDCL DEMAND MET	24240	22701	21512	18557
Load Shedding	0	0	0	0
MSEDCL DEMAND	24240	22701	21512	18557
TPCL GENERATION	1003	716	1224	495
AEML GENERATION	218	198	249	158
MUMBAI DEMAND	2884	2876	2788	1811
OTHER DISCOM DEMAND	449	441	474	342
STATE DEMAND MET	27573	26018	24774	20710
STATE DEMAND	27573	26018	24774	20710
Frequency (Hz)	50.04	49.98	49.98	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.22 Hz at 22:02 Hrs	49.76 Hz at 20:08 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 16/Jan/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.45	68.68	190	180
Unit 8	15.04	166.84	636	572
Unit 9	12.07	201.22	557	418
Unit 10	13.96	220.57	625	555
Total	45.52	657.31		
Bhusawal				
Unit 3	0.00	38.06	0	0
Unit 4	10.44	150.68	500	300
Unit 5	9.58	143.57	460	285
Total	20.02	332.31		
Parli				
Unit 6	4.62	69.25	250	145
Unit 7	4.71	66.89	248	144
Unit 8	0.00	53.22	0	0
Total	9.33	189.36		
Chandrapur				
Unit 3	3.52	52.40	157	122
Unit 4	3.30	43.13	149	120
Unit 5	9.12	134.19	430	295
Unit 6	7.66	118.51	355	272
Unit 7	8.32	67.09	441	286
Unit 8	9.84	137.18	430	345
Unit 9	11.34	154.30	490	309
Total	53.09	706.80		
Paras				
Unit 3	5.44	86.96	248	189
Unit 4	5.58	91.08	240	220
Total	11.02	178.04		
Khaparkheda				
Unit 1	2.31	54.06	180	0
Unit 2	0.00	27.92	0	0
Unit 3	4.14	60.90	177	153
Unit 4	4.57	66.59	195	166
Unit 5	10.81	162.10	480	410
Total	21.84	371.58		
Nasik				
Unit 3	3.08	19.38	137	122
Unit 4	3.64	51.33	172	122
Unit 5	3.08	52.39	136	115
Total	9.80	123.10		
Uran				
All Units	7.10	105.16	396	142
Total	7.10	105.16		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.74	3.57	52	0
Total	0.74	3.57		
Koyna				
Stage 1-2	3.54	35.28	485	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	5.19	31.34	756	0
Stage 3	1.72	14.67	240	0
Total	10.46	81.29		
Hydro				
KDPH	0.86	9.23	36	36
VTRNA	0.00	0.02	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.29	35.17	100	92
GHATGHAR	1.56	14.59	250	0
Total	4.72	59.01		
Wind				
Total	6.08	159.32	0	0
Total	6.08	159.32		
CPP				
APML(Mus)	49.88	913.87	0	0
JSWEL(Mus)	26.20	383.18	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.50	390.14	0	0
SWPGPL-Mus	12.26	191.89	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.56	74.65	268	196
Other(Mus)	26.85	587.78	0	0
JPL	0.00	24.15	0	0
Total	152.25	2565.66		
SOLAR				
Total	16.71	209.31	0	0
Total	16.71	209.31		
Tata				
Trombay 5	8.82	123.34	472	260
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.70	24.71	108	38
Trombay 7B	1.18	16.23	65	36
TATA Hydro	3.31	69.62	351	16
Trombay 8	4.47	73.20	231	133
Total	19.49	307.10		
AEML				
DTPS U-1&2	5.01	72.43	254	147
Total	5.01	72.43		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	170.61	2558.51	MSPGCL Total	193.62	2807.54
			MSPGCL Thml+Gas	177.71	2663.66	Koyna 1,2 & 4 Total	8.73	66.62
			MSPGCL Hydro	15.91	143.87	State Total	393.15	6121.37

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 16/Jan/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6130	169	312	6611	344	6749	0	0	6393	6392	-1330	18385	0	0	18385	2041	381	20807	49.92
2	6348	169	312	6829	345	6618	0	0	6267	6428	-1259	18586	0	0	18586	1906	375	20867	50.01
3	6362	169	312	6843	334	6567	0	0	6147	6313	-1158	18557	0	0	18557	1811	342	20710	50.02
4	6407	168	314	6889	365	6568	0	0	6083	6378	-1092	18785	0	0	18785	1741	323	20849	49.99
5	6824	168	314	7306	299	6600	0	0	6085	6533	-1097	19296	0	0	19296	1746	345	21387	50.01
6	7203	174	315	7692	258	6831	0	0	6669	6989	-1155	20244	0	0	20244	1879	371	22494	50.01
7	7397	202	316	7915	251	7081	0	5	7223	7534	-1106	21293	0	0	21293	2067	387	23747	49.98
8	7348	1386	315	9049	240	7185	0	194	6860	7329	-1028	22547	0	0	22547	2234	422	25203	49.94
9	7289	1707	315	9311	152	7041	0	920	7377	7717	-1296	23390	0	0	23390	2507	455	26352	49.98
10	7307	1473	307	9087	130	6760	0	1644	8107	8265	-1506	23930	0	9	23930	2736	450	27116	50.00
11	7333	1125	305	8763	134	6440	0	2125	8644	8890	-1663	24240	0	10	24240	2884	449	27573	50.04
12	7363	380	291	8034	146	6144	0	2393	8947	8937	-1780	23425	0	10	23425	2928	450	26802	49.97
13	7076	220	296	7592	179	5947	0	2397	8850	8989	-1962	22701	0	10	22701	2876	441	26018	49.98
14	6861	215	245	7321	207	5870	0	2332	8471	8766	-1876	22190	0	2	22190	2752	430	25372	49.94
15	7219	361	142	7722	211	5839	0	2084	8443	8693	-1811	22305	0	2	22305	2780	434	25518	50.00
16	7422	240	153	7815	223	5994	0	1537	8967	8872	-1671	22322	0	0	22322	2805	448	25575	49.99
17	7462	846	217	8525	224	6081	0	873	7909	7773	-1431	21582	0	0	21582	2787	464	24832	49.98
18	7463	1600	294	9357	232	6067	0	202	7140	6962	-1318	21038	0	0	21038	2760	464	24262	50.01
19	7338	1568	370	9276	248	6067	0	1	7672	7709	-1315	21512	0	0	21512	2788	474	24774	49.98
20	7401	1872	396	9669	211	6099	0	0	7218	7193	-1272	21433	0	0	21433	2736	468	24636	49.99
21	7482	1065	336	8883	254	6093	0	0	6590	6488	-1193	20070	0	0	20070	2565	456	23090	49.95
22	7455	215	306	7976	261	5948	0	0	7139	6626	-1304	19045	0	0	19045	2414	461	21921	50.00
23	7087	206	309	7602	397	5817	0	0	7073	6845	-1520	18706	0	0	18706	2239	434	21380	50.01
24	7035	213	307	7555	437	5841	0	0	6637	6750	-1451	18697	0	0	18697	2106	435	21238	49.95
MUs	170.61	15.91	7.10	193.62	6.08	152.25	0.00	16.71	176.91	179.37	-33.59	504.28	0.00	0.04	504.28	58.09	10.16	572.52	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR carried out due to overloading of 50MVA T/F at Kopargaon S/stn and 132KV BBLSR-Rahuri Line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 16/Jan/2024

Position as on 6.30 Hrs of 17/Jan/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	15/02/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	29/02/2024
MSPGCL	Koyna STG-IV Unit-3	250	24/11/2023	08:00		Continued.	Capital Overhauling	24/01/2024
MSPGCL	Khaparkheda Unit 2	210	10/01/2024	23:30		Continued.	Annual Overhaul	05/02/2024
MSPGCL	Koyna Unit 3	70	15/01/2024	08:45		Continued.	Generator Excitation system new panel commissioning activity	18/01/2024
Total Capacity MSPGCL		718						
AEML								
AEML	AEML Unit 2	250	20/12/2023	10:54		Continued.	Annual Overhaul	20/01/2024
Total Capacity AEML		250						
IPP								
IPP	Adani U-3	660	31/12/2023	23:59		Continued.	COH activities	05/02/2024
Total Capacity IPP		660						
CENT.SECTOR								
CENT.SECTOR	Tarapur 3	540	11/01/2024	21:45		Continued.	Annual Overhaul	29/02/2024
Total Capacity CENT.SECTOR		540						
Total Capacity PLANNED OUTAGE		2168						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Uran Unit 6	108	04/01/2024	20:03	16/01/2024	17:44	For open cycle No schedule from MSEDCL.	
MSPGCL	Bhusawal Unit 3	210	11/01/2024	23:56		Continued.	work Seal liner outage	20/01/2024
MSPGCL	Khaparkheda Unit 1	210	14/01/2024	06:04	16/01/2024	07:50	Drum level low	16/01/2024
MSPGCL	Parli Unit 8	250	15/01/2024	09:16		Continued.	Boiler Tube Leakage	17/01/2024
MSPGCL	Uran Unit 7	108	16/01/2024	13:41	16/01/2024	15:31	Generator Protection operated	
MSPGCL	Uran Unit 6	108	16/01/2024	20:29		Continued.	For open cycle No schedule from MSEDCL.	
Total Capacity MSPGCL		1114						
IPP								
IPP	JPL Unit 1	150	13/01/2024	01:00		Continued.	Due to low net sale realisation.	18/01/2024
IPP	Adani U-2	660	16/01/2024	10:32		Continued.	APH-A HOT PA bellow leakage	18/01/2024
Total Capacity IPP		810						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works	01/04/2024

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/Jan/2024

Position as on 6.30 Hrs of 17/Jan/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	identified which are being executed before refueling. For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2244						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Jan/2024

Statement-VII

Position as on 6.30 Hrs of 17/Jan/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400kv 1500 MVA ICT-1 @ TIRORA	IntraState	15/01/2024	10:12	16/01/2024	20:22	PO	Annual maintenance & testing transformer. Annual maintenance of main bay & tie bay equipment's.
400 KV TIEBAY Outages/Trippings							
TIE BAY (405) OF SWICHING SS CKT - 2 & NANDED - 1 @ CHANDRAPUR 2	IntraState	16/01/2024	11:43			PO	replacement of non pir breker with pir breaker
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
MAIN BAY (413) OF 500MVA ICT - 2 @ TAPTITANDA	IntraState	15/01/2024	12:30			PO	CB mechanism Overhauling work through M/s CGL service Engineer.
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-2	InterState	20/12/2023	12:11			HT	For ongoing project of "Upgradation of 400kv Line Bays (02 Nos) of Parli (PG) I&II at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS�
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	26/11/2023	19:17			HT	HT Load Management
PADGHE - KALWA CKT - 2	IntraState	30/12/2023	22:01			PO	During the outage on Dtd: 30.12.2023 temporary tapping arrangement on 400kv Kalwa-Padgha Ckt.2 line will be done by making a bunching arrangement from loc no 3 to loc 132 of 400Kv Padgha-Kharghar (dead line) line at Padgha substation premises. By this bunching arrangement, line will be diverted from loc no.132 to loc.No .09. Due to this tapping of 400Kv Kalwa-Padgha Ckt.2-line section b/w loc no 3 to Kalwa Substation (loc1135) will become dead. And this dead Ckt. will be free for completion of the balance HTLS conversion work i.e between Loc no. 61-62 to 1012 (approximately 2.7 km).
KHARGHAR - VIKHROLI GIS CKT - 1	IntraState	30/12/2023	22:43			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
KHARGHAR - VIKHROLI GIS CKT - 2	IntraState	30/12/2023	22:44			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
400KV TBC @ KHADKA	IntraState	16/01/2024	09:30	16/01/2024	13:17	PO	For C& tan delta Measurement and routine bay maintenance work
CHANDRAPUR GCR - CHANDRAPUR HVDC - 2	IntraState	16/01/2024	13:00			PO	1. Pole Overhauling of Bhel make CB of 400KV HVDC CKT-2 bay. 2. Diagnostic testing of Circuit breaker. 3. 400KV HVDC CKT-2 will be in service via TBC-2.
400 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 16/Jan/2024

Statement-VII

Position as on 6.30 Hrs of 17/Jan/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	30/12/2023	23:20			T	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	30/12/2023	23:21			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	30/12/2023	23:22			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
400KV/21KV GT - 3 @ TIRORA	IntraState	01/01/2024	10:45			PO	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.
GTR - 7 @ CHANDRAPUR	IntraState	01/01/2024	11:11				1) Measurement of CB timing, CRM & DCRM. 2) Measurement of tandelta & capacitance of CT & Sych CVT 2) Maintenance and alignment of Isolators. 3) Bay routine maintenance work.
400/220/33 KV 500MVA ICT - 2 @ KORADI 2	IntraState	16/01/2024	10:37	16/01/2024	20:52	PO	Diagnostic testing of Bushing & winding
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	IntraState	16/01/2024	12:03			PO	In view of the continuous H2 gas rising trend of Station Transformer 8A, forced outage needed for degassing/filtration of transformer oil from Dt. 16.01.2024 to Dt. 17.01.2024 tentatively.
400/132 KV 200 MVA ICT - 1 @ KHADKA	IntraState	16/01/2024	17:55	16/01/2024	23:00	PO	Differential relay replacement work
400 KV BR Outages/Tripping							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	06/01/2024	11:55			PO	Existing 125 MVAR Reactor CB Have mechanical problem and need to replace
220 KV MAINBAY Outages/Tripping							
MAIN BUS -2 @ ALKUD	IntraState	16/01/2024	15:25	16/01/2024	20:22	PO	For diagnostic testing, Relay testing & routine maintenance work of Bus coupler
MAIN BUS - 1 @ BABHALESHWAR	IntraState	16/01/2024	21:31	16/01/2024	22:39	T	Due to HV CB B-phase pole burst & top pad jump fall on 220 kV main Bus.
220 KV LINE Outages/Tripping							
BAPGAON - KALWA	IntraState	31/12/2023	18:05			T	Distance Protection
KARAD - OGALEWADI CKT 1	IntraState	15/01/2024	10:44			PO	HV CB Mechanism Overhauling Work
POPHALI - KDPH	IntraState	16/01/2024	09:25	16/01/2024	23:55	PO	For replacement of damaged conductor at loc no ¿20 R ph KDPH side & loc no ¿ 14R ph
MURUD - TULJAPUR	IntraState	16/01/2024	10:50	16/01/2024	13:05	PO	Routine maintenance work
URAN - APTA CKT - 1	IntraState	16/01/2024	11:14	16/01/2024	18:09	PO	"Routine line maintenance work. For Relay and diagnostic Testing at Uran and Apta End"
PADGHE - NALASOPARA	IntraState	16/01/2024	14:21	16/01/2024	14:35	T	Tripped on distance protection
220KV GIS DCHI - COLOURCHEM	IntraState	16/01/2024	16:40	16/01/2024	17:37	T	tripped on Distance protection.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Jan/2024

Statement-VII

Position as on 6.30 Hrs of 17/Jan/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MIRAJ - ICHALKARANJI	IntraState	16/01/2024	17:17	17/01/2024	00:46	PO	220KV Miraj Line kept off for proper load management at 220kV Tilawani S/S during outage period of outage on 220kV Talandage- Tilawani-2
TALANDGE - ICHALKARANJI 2	IntraState	16/01/2024	17:31	17/01/2024	00:44	PO	Cleaning of Jumpering of 20 No Tension towers & replacement of nut bolts if required.
URSE-CHINCHWAD	IntraState	16/01/2024	18:34	16/01/2024	21:10	T	LINE TRIPPED ON DISTANCE PROTECTION.
BABLESHWAR-BABLESHWAR(400KV)-I	IntraState	16/01/2024	21:31	16/01/2024	22:39	T	220kV BBLR-BBLR Ckt 1& 2 tripped on distance protection in Zone 4
BABLESHWAR-BABLESHWAR(400KV)-II	IntraState	16/01/2024	21:32	16/01/2024	23:09	T	220kV BBLR-BBLR Ckt 1& 2 tripped on distance protection in Zone 4
BHIGWAN - WALCHAND NAGAR	IntraState	17/01/2024	01:17	17/01/2024	02:44	T	Line tripped on distance protection
BUS SECTION BREAKER-3 @ TROMBAY	IntraState	17/01/2024	06:42			PO	Breaker replacement
KALYANI - BARAMATI AGRO	IntraState	17/01/2024	07:56	17/01/2024	09:23	T	Tripped due to Rph. metering PT Burst
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33KV 50MVA PTR 1 @ VITA	IntraState	16/01/2024	10:00	16/01/2024	12:00	PO	1.Diagnostic Testing Work 2.Replacement Work of WTI & OTI
220/22KV 50MVA PTR 1 @ CHAKAN PHASE II	IntraState	16/01/2024	10:17	16/01/2024	12:34	T	Buchholz trip
220/132 KV 100 MVA ICT 2 @ RANJANGAON	IntraState	16/01/2024	11:00	16/01/2024	16:55	PO	For Capacitance and tan delta test of HV & LV Bushing & Winding, HV & LV CT's. General Bay maintenance work.
220/100 KV 200 MVA ICT 3 @ KALWA	IntraState	16/01/2024	11:13	16/01/2024	20:22	PO	RM and Diagnostic work & CB overhauling work.
220/132 KV 100 MVA ICT 1 @ BELWANDI	IntraState	16/01/2024	11:15	16/01/2024	17:42	PO	A)Diagnostic Testing work B)For attending hot spot on R phase HV Bushing and R phase HV CT P2 side
220/132 KV 100 MVA ICT - 1 @KALWAN	IntraState	16/01/2024	11:25	16/01/2024	17:04	PO	Diagnostic Testing work
220/132 KV 200 MVA ICT 2	IntraState	16/01/2024	11:32	16/01/2024	15:44	PO	Inspection of Oil Leakage
220/33KV 25MVA PTR 1 @ HALKARNI	IntraState	16/01/2024	11:43			PO	For Replacement TF Oil of 25 MVA CGL TRF-I .
220/132 KV 100 MVA ICT - I	IntraState	16/01/2024	12:23	16/01/2024	19:42	PO	Testing work
220/33KV 50MVA PTR NO 1 @ BARAMATI	IntraState	16/01/2024	14:40	16/01/2024	17:54	PO	TF painting work.
220/33 KV 50 MVA TF - 1@BELWANDI	IntraState	16/01/2024	15:45	16/01/2024	17:49	PO	Diagnostic Testing Work
220/33 KV 50 MVA PTR 1 @ BABHLESHWAR	IntraState	16/01/2024	16:32	16/01/2024	19:56	PO	To Attend oil leakage
220/33 KV 50 MVA TF - 2@BELWANDI	IntraState	16/01/2024	18:05	16/01/2024	20:31	PO	Diagnostic Testing Work
220/33 KV 50 MVA PTR 1 @ BABHLESHWAR	IntraState	16/01/2024	21:31			T	Tripped due to HV CB pole burst
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage