

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 16/Feb/2016 TUESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 113.815        | 1716.338        | 1) Gujrat                      | -3.058         | -48.355         |
| 2) Hydro            | 5.995          | 92.529          | 2) Madhya Pradesh              | 9.502          | 130.784         |
| 3) Gas              | 10.732         | 153.320         | 3) Chattisgarh                 | 6.140          | 78.650          |
| <b>Total MSPGCL</b> | <b>130.542</b> | <b>1962.187</b> | 4) Maharashtra Net             | 85.691         | 1182.963        |
| B) 1) APML          | 59.119         | 955.022         | 5) Goa (Amona)                 | -0.452         | -7.642          |
| 2) JSWEL            | 26.447         | 393.687         | 6) TAPS 1&2 Injection          | 3.716          | 52.596          |
| 3) VIPL             | 5.736          | 152.256         | 7) RGPPL Injection             | 11.685         | 187.834         |
| 4) RPL(AMT)         | 15.709         | 351.061         | 8) Pench (MS)                  | 0.374          | 7.147           |
| 5) WPCL             | 4.459          | 72.332          | 9) Pench (Excess)              | -0.374         | -7.083          |
| 6) Other IPP        | 8.818          | 144.999         | <b>Total</b>                   | <b>112.850</b> | <b>1569.747</b> |
| C) 1) TPCL Thermal  | 8.846          | 127.628         | a) Mumbai Schedule             | 14.951         | 260.611         |
| 2) TPCL Hydro       | 4.546          | 60.441          | b) Mumbai Drawl                | 21.605         | 354.837         |
| 3) TPCL Gas         | 4.047          | 60.171          | c) MSEDCL Bilateral *          | 29.479         | 457.779         |
| 4) R-INFRA Thermal  | 10.891         | 167.206         | Include PX                     | -3.812         | -59.180         |
| <b>D) STATE</b>     |                |                 | d) Mumbai Bilateral *          | 14.951         | 260.611         |
| 1) Thermal          | 253.840        | 4080.529        | Include PX                     | 3.113          | 17.054          |
| (A1+C1+C4+(B1-B6))  |                |                 | Include Standby                | 0.000          | 0.000           |
| 2) Hydro            | 10.541         | 152.970         | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 3) Gas              | 14.779         | 213.491         | 1) MSEDCL                      | 347.214        | 5372.386        |
| 4) Wind             | 3.948          | 105.902         | 2) Mumbai Discoms              | 49.937         | 770.281         |
| 6) SOLAR            | 1.191          | 20.030          | <b>TOTAL STATE</b>             | <b>397.151</b> | <b>6142.667</b> |
| <b>TOTAL STATE</b>  | <b>284.299</b> | <b>4572.922</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 9 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|--------------------------|--------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5162                     | 4811                  | 4669                      | 4553                      |
| MSPGCL Hydro             | 677                      | 141                   | 246                       | 83                        |
| MSPGCL Gas               | 456                      | 431                   | 454                       | 466                       |
| MSPGCL Total Generation  | 6295                     | 5383                  | 5369                      | 5102                      |
| Central Sector Receipt   | 5534                     | 5140                  | 5360                      | 3987                      |
| WIND                     | 115                      | 227                   | 157                       | 79                        |
| CPP / IPP                | 5327                     | 5148                  | 5272                      | 4340                      |
| SOLAR                    | 52                       | 173                   | 0                         | 0                         |
| Exchange with Mumbai     | -744                     | -1022                 | -1264                     | -463                      |
| <b>MSEDCL DEMAND MET</b> | <b>16579</b>             | <b>15049</b>          | <b>14894</b>              | <b>13045</b>              |
| Load Shedding            | 6                        | 6                     | 5                         | 4                         |
| MSEDCL DEMAND            | 16585                    | 15055                 | 14899                     | 13049                     |
| TPCL GENERATION          | 862                      | 1027                  | 853                       | 497                       |
| R-INFRA GENERATION       | 516                      | 518                   | 403                       | 404                       |
| <b>MUMBAI DEMAND</b>     | <b>2122</b>              | <b>2567</b>           | <b>2520</b>               | <b>1364</b>               |
| STATE DEMAND MET         | 18701                    | 17616                 | 17414                     | 14409                     |
| <b>STATE DEMAND</b>      | <b>18707</b>             | <b>17622</b>          | <b>17419</b>              | <b>14413</b>              |
| Frequency (Hz)           | 49.95                    | 49.95                 | 49.98                     | 49.98                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.23 Hz at 18.01 Hrs | 49.75 Hz at 09.17 Hrs | 49.96         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 16/Feb/2016

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 5             | 2.83         | 57.28         | 130      | 110      |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 9.55         | 77.70         | 405      | 380      |
| <b>Total</b>       | <b>12.38</b> | <b>134.97</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 2             | 2.51         | 63.49         | 175      | 0        |
| Unit 3             | 4.05         | 53.68         | 180      | 165      |
| Unit 4             | 0.00         | 121.46        | 0        | 0        |
| Unit 5             | 9.53         | 114.82        | 500      | 365      |
| <b>Total</b>       | <b>16.09</b> | <b>353.45</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 4.22         | 66.92         | 200      | 140      |
| Unit 4             | 4.19         | 66.16         | 199      | 160      |
| Unit 5             | 9.26         | 147.10        | 460      | 360      |
| Unit 6             | 9.51         | 152.54        | 420      | 380      |
| Unit 7             | 9.22         | 93.33         | 463      | 353      |
| <b>Total</b>       | <b>36.40</b> | <b>526.05</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.26         | 74.98         | 250      | 188      |
| Unit 4             | 5.27         | 81.14         | 258      | 190      |
| <b>Total</b>       | <b>10.53</b> | <b>156.12</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.92         | 56.96         | 175      | 155      |
| Unit 2             | 3.89         | 54.45         | 170      | 155      |
| Unit 3             | 4.10         | 43.81         | 202      | 160      |
| Unit 4             | 3.98         | 61.37         | 200      | 150      |
| Unit 5             | 10.17        | 156.70        | 500      | 360      |
| <b>Total</b>       | <b>26.06</b> | <b>373.29</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 4.16         | 43.84         | 200      | 155      |
| Unit 4             | 4.07         | 64.86         | 190      | 160      |
| Unit 5             | 4.13         | 63.76         | 198      | 160      |
| <b>Total</b>       | <b>12.36</b> | <b>172.45</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 10.73        | 153.32        | 468      | 374      |
| <b>Total</b>       | <b>10.73</b> | <b>153.32</b> |          |          |

| Generating unit   | Generation    |                |          |          |
|-------------------|---------------|----------------|----------|----------|
|                   | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>PENCH (MS)</b> |               |                |          |          |
| Pench (MS)        | 0.37          | 7.15           | 34       | 0        |
| <b>Total</b>      | <b>0.37</b>   | <b>7.15</b>    |          |          |
| <b>Koyna</b>      |               |                |          |          |
| Stage 1-2         | 2.59          | 31.58          | 390      | 40       |
| Stage 4           | 0.97          | 4.96           | 238      | 0        |
| Stage 3           | 0.95          | 8.93           | 160      | 0        |
| <b>Total</b>      | <b>4.51</b>   | <b>45.46</b>   |          |          |
| <b>Hydro</b>      |               |                |          |          |
| KDPH              | 0.27          | 5.54           | 18       | 0        |
| VTRNA             | 0.00          | 0.28           | 0        | 0        |
| TILLARI           | 0.00          | 1.52           | 0        | 0        |
| BHTGR/VEER        | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.        | 0.18          | 3.74           | 40       | 0        |
| RNGR+BHTSA        | 0.26          | 3.89           | 11       | 11       |
| BHANDARDRA        | 0.00          | 4.89           | 0        | 0        |
| ELDARY            | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN         | 0.77          | 12.03          | 33       | 32       |
| GHATGHAR          | 0.00          | 15.18          | 0        | 0        |
| <b>Total</b>      | <b>1.48</b>   | <b>47.06</b>   |          |          |
| <b>Wind</b>       |               |                |          |          |
| Total             | 3.95          | 105.90         | 0        | 0        |
| <b>Total</b>      | <b>3.95</b>   | <b>105.90</b>  |          |          |
| <b>CPP</b>        |               |                |          |          |
| APML(Mus)         | 59.12         | 955.02         | 0        | 0        |
| JSWEL(Mus)        | 26.45         | 393.69         | 0        | 0        |
| VIPL(Mus)         | 5.74          | 152.26         | 0        | 0        |
| RPLAMT(Mus)       | 15.71         | 351.06         | 0        | 0        |
| WPCL(Mus)         | 4.46          | 72.33          | 0        | 0        |
| Other(Mus)        | 8.82          | 145.00         | 0        | 0        |
| <b>Total</b>      | <b>120.29</b> | <b>2069.36</b> |          |          |
| <b>SOLAR</b>      |               |                |          |          |
| Total             | 1.19          | 20.03          | 0        | 0        |
| <b>Total</b>      | <b>1.19</b>   | <b>20.03</b>   |          |          |
| <b>Tata</b>       |               |                |          |          |
| Trombay 5         | 8.85          | 91.85          | 494      | 316      |
| Trombay 6         | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A        | 2.51          | 36.86          | 115      | 84       |
| Trombay 7B        | 1.53          | 23.31          | 67       | 57       |
| Trombay 8         | 0.00          | 35.77          | 0        | 0        |
| TATA Hydro        | 4.55          | 60.44          | 426      | 6        |
| <b>Total</b>      | <b>17.44</b>  | <b>248.24</b>  |          |          |
| <b>R-INFRA</b>    |               |                |          |          |
| 1-2               | 10.89         | 167.21         | 518      | 403      |
| <b>Total</b>      | <b>10.89</b>  | <b>167.21</b>  |          |          |

|                     |              |      |          |      |
|---------------------|--------------|------|----------|------|
| <b>Infirm Power</b> | Chandrapur 8 | 0.00 | Koradi 9 | 0.00 |
|---------------------|--------------|------|----------|------|

| Summary         |             |               |
|-----------------|-------------|---------------|
| Particulars     | Daily (Mus) | Monthly (Mus) |
| MSPGCL Thermal  | 113.82      | 1716.34       |
| MSPGCL Thml+Gas | 124.55      | 1869.66       |

| Summary      |             |               |
|--------------|-------------|---------------|
| Particulars  | Daily (Mus) | Monthly (Mus) |
| MSPGCL Hydro | 6.00        | 92.53         |
| MSPGCL Total | 130.54      | 1962.19       |

| Summary             |             |               |
|---------------------|-------------|---------------|
| Particulars         | Daily (Mus) | Monthly (Mus) |
| Koyna 1,2 & 4 Total | 3.56        | 36.54         |
| State Total         | 284.30      | 4572.92       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 16/Feb/2016

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |       | TOTAL  | WIND | CPP /<br>IPP | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|-------|--------|------|--------------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS   |        |      |              |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4542        | 83   | 454   | 5079   | 130  | 4634         | 0     | 3993        | 4296        | -649                 | 13490                 | 5                    | 13495                     | 1542             | 15037           | 49.97         |
| 2                  | 4537        | 88   | 462   | 5087   | 79   | 4390         | 0     | 3716        | 4213        | -527                 | 13242                 | 4                    | 13246                     | 1426             | 14672           | 49.96         |
| 3                  | 4553        | 83   | 466   | 5102   | 79   | 4340         | 0     | 3589        | 3987        | -463                 | 13045                 | 4                    | 13049                     | 1364             | 14413           | 49.98         |
| 4                  | 4553        | 88   | 464   | 5105   | 118  | 4356         | 0     | 3455        | 4134        | -432                 | 13281                 | 4                    | 13285                     | 1332             | 14617           | 49.96         |
| 5                  | 4538        | 83   | 468   | 5089   | 137  | 4358         | 0     | 3745        | 4237        | -456                 | 13365                 | 4                    | 13369                     | 1357             | 14726           | 49.98         |
| 6                  | 4587        | 88   | 374   | 5049   | 120  | 4521         | 0     | 4601        | 4768        | -534                 | 13924                 | 6                    | 13930                     | 1455             | 15385           | 49.96         |
| 7                  | 4929        | 216  | 456   | 5601   | 152  | 4960         | 0     | 4691        | 5065        | -723                 | 15055                 | 6                    | 15061                     | 1710             | 16771           | 49.95         |
| 8                  | 5200        | 636  | 465   | 6301   | 134  | 5292         | 8     | 4769        | 5030        | -649                 | 16116                 | 6                    | 16122                     | 1882             | 18004           | 49.98         |
| 9                  | 5162        | 677  | 456   | 6295   | 115  | 5327         | 52    | 4931        | 5534        | -744                 | 16579                 | 6                    | 16585                     | 2122             | 18707           | 49.95         |
| 10                 | 5178        | 644  | 452   | 6274   | 162  | 5348         | 102   | 5032        | 4844        | -822                 | 15908                 | 6                    | 15914                     | 2361             | 18275           | 49.92         |
| 11                 | 5165        | 559  | 449   | 6173   | 227  | 5384         | 152   | 5149        | 5048        | -1023                | 15961                 | 6                    | 15967                     | 2571             | 18538           | 49.97         |
| 12                 | 5180        | 177  | 449   | 5806   | 272  | 5397         | 163   | 5236        | 5129        | -1078                | 15689                 | 6                    | 15695                     | 2602             | 18297           | 49.95         |
| 13                 | 4811        | 141  | 431   | 5383   | 227  | 5148         | 173   | 5277        | 5140        | -1022                | 15049                 | 6                    | 15055                     | 2567             | 17622           | 49.95         |
| 14                 | 4538        | 146  | 439   | 5123   | 224  | 4857         | 177   | 5195        | 5366        | -935                 | 14812                 | 7                    | 14819                     | 2429             | 17248           | 49.97         |
| 15                 | 4548        | 186  | 429   | 5163   | 144  | 4830         | 155   | 5190        | 5473        | -1062                | 14703                 | 5                    | 14708                     | 2464             | 17172           | 49.95         |
| 16                 | 4578        | 380  | 445   | 5403   | 137  | 4993         | 114   | 5145        | 5409        | -1054                | 15002                 | 5                    | 15007                     | 2477             | 17484           | 49.93         |
| 17                 | 4567        | 266  | 434   | 5267   | 138  | 5105         | 68    | 5022        | 5145        | -1104                | 14619                 | 5                    | 14624                     | 2482             | 17106           | 49.93         |
| 18                 | 4559        | 261  | 446   | 5266   | 164  | 5229         | 27    | 3994        | 4039        | -1199                | 13526                 | 5                    | 13531                     | 2462             | 15993           | 49.99         |
| 19                 | 4555        | 531  | 432   | 5518   | 151  | 5199         | 0     | 4183        | 4419        | -1249                | 14038                 | 5                    | 14043                     | 2479             | 16522           | 49.97         |
| 20                 | 4669        | 246  | 454   | 5369   | 157  | 5272         | 0     | 5254        | 5360        | -1264                | 14894                 | 5                    | 14899                     | 2520             | 17419           | 49.98         |
| 21                 | 4798        | 101  | 452   | 5351   | 242  | 5387         | 0     | 4831        | 4667        | -1271                | 14376                 | 5                    | 14381                     | 2376             | 16757           | 49.97         |
| 22                 | 4759        | 111  | 452   | 5322   | 251  | 5393         | 0     | 3769        | 3916        | -1240                | 13642                 | 5                    | 13647                     | 2127             | 15774           | 50.04         |
| 23                 | 4740        | 102  | 448   | 5290   | 224  | 5394         | 0     | 3629        | 3572        | -1155                | 13325                 | 5                    | 13330                     | 2015             | 15345           | 49.98         |
| 24                 | 4569        | 102  | 455   | 5126   | 164  | 5178         | 0     | 3904        | 4058        | -950                 | 13576                 | 5                    | 13581                     | 1813             | 15394           | 49.87         |
| MUs                | 113.82      | 6.00 | 10.73 | 130.54 | 3.95 | 120.29       | 1.19  | 108.30      | 112.85      | -21.61               | 347.21                | 0.13                 | 347.34                    | 49.94            | 397.27          | 49.96         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center,Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 16/Feb/2016

Position as on 6.30 Hrs of 17/Feb/2016

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                            | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                             |               |
| CENT.SECTOR           | Tarapur 2               | 160      | 10/09/2015   | 12.55        |            | Continued. | Refuelling work                             |               |
| MSPGCL                | Koyna Unit 10           | 80       | 29/12/2015   | 08:00        |            | Continued. | Annual Overhaul                             |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                             |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |            | Continued. | Gas Shortage.                               |               |
| RGPL                  | Dabhol 3A               | 230      | 06/06/2013   | 08.28        |            | Continued. | Gas Shortage                                |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |            | Continued. | Gas Shortage                                |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |            | Continued. | Gas Shortage                                |               |
| RGPL                  | Dabhol 2X               | 290      | 15/07/2013   | 15.09        |            | Continued. | Gas Shortage                                |               |
| IPP                   | Dhariwal                | 300      | 28/05/2014   | 02.27        |            | Continued. | No schedule                                 |               |
| MSPGCL                | Chandrapur Unit 1       | 210      | 28/08/2014   | 07:15        |            | Continued. | Economic Shutdown.                          |               |
| MSPGCL                | Koradi Unit 6           | 210      | 20/03/2015   | 01.02        |            | Continued. | Economic shutdown                           |               |
| MSPGCL                | Parli Unit 3            | 210      | 14/06/2015   | 12.58        |            | Continued. | Water Shortage                              |               |
| IPP                   | WPCL U-2                | 135      | 16/06/2015   | 00.00        |            | Continued. | No Schdule                                  |               |
| MSPGCL                | Parli Unit 6            | 250      | 25/06/2015   | 15.03        |            | Continued. | Water Shortage                              |               |
| MSPGCL                | Parli Unit 4            | 210      | 05/07/2015   | 18.45        |            | Continued. | Water Shortage                              |               |
| MSPGCL                | Parli Unit 5            | 210      | 06/07/2015   | 14.55        |            | Continued. | Water Shortage.                             |               |
| MSPGCL                | Parli Unit 7            | 250      | 08/07/2015   | 12.08        |            | Continued. | Water Shortage                              |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |            | Continued. | Economic shutdown                           |               |
| MSPGCL                | Chandrapur Unit-8       | 500      | 10/11/2015   | 12.10        |            | Continued. | Drum level low                              |               |
| MSPGCL                | Chandrapur Unit 2       | 210      | 12/01/2016   | 04.47        |            | Continued. | Boiler Tube Leakage                         |               |
| MSPGCL                | Uran Unit 5             | 108      | 19/01/2016   | 14.34        |            | Continued. | Overhauling                                 |               |
| MSPGCL                | Koradi Unit 7           | 210      | 30/01/2016   | 00.12        |            | Continued. | MSEDCL Zero Shedule.                        |               |
| TPC_G                 | Trombay 8               | 250      | 07/02/2016   | 17.40        |            | Continued. | Boiler Maintenance Work,Bearing Inspection. |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 09/02/2016   | 18.00        |            | Continued. | oil filtration work.                        |               |
| CPP                   | WPCL U-4                | 135      | 10/02/2016   | 21.46        | 16/02/2016 | 14.26      | ESP Maintenance Work.                       |               |
| IPP                   | VIPL U-2                | 300      | 13/02/2016   | 04:59        |            | Continued. | Boiler Tube Leakage                         |               |
| IPP                   | Adani U-2               | 660      | 13/02/2016   | 15.47        | 16/02/2016 | 13.24      | P A Outlet Duct Leakage Bellow.             |               |
| MSPGCL                | Bhusawal Unit 4         | 500      | 14/02/2016   | 12.10        |            | Continued. | Zero Schedule Given by MSEDCL.              |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 15/02/2016   | 00.00        |            | Continued. | Attending Water valve Leakage.              |               |
| IPP                   | RPL(AMT) U-2            | 270      | 16/02/2016   | 01.14        |            | Continued. | Due to Zero Schedule Given by MSEDCL.       |               |
| IPP                   | RPL(AMT) U-3            | 270      | 16/02/2016   | 01.17        |            | Continued. | Due to Zero Schedule Given by MSEDCL.       |               |
| MSPGCL                | Bhusawal Unit 2         | 210      | 16/02/2016   | 04.53        | 16/02/2016 | 13.33      | Switch Board Supply Tripped.                |               |
| CPP                   | WPCL U-1                | 135      | 16/02/2016   | 17.09        |            | Continued. | Change Over , No Schedule                   |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 17/02/2016   | 00.16        |            | Continued. | BTL.                                        |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 16/Feb/2016**

**Statement-VII**

Position as on 6.30 Hrs of 17/Feb/2016

| Name of Line                         | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                    |
|--------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Dhule Sar'Sarovar I                  | InterState                | 15/02/2016   | 1328         | 16/02/2016 | 06.23      | HT          | Over Voltage                                                                                                        |
| Kolhapur Solapur (PG) II             | InterState                | 15/02/2016   | 17.40        | 16/02/2016 | 06.31      | HT          | Over Voltage                                                                                                        |
| Dhule Sar'Sarovar I                  | InterState                | 16/02/2016   | 13.19        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Kolhapur(M)-Kolhapur(GIS) ckt1       | InterState                | 16/02/2016   | 16.36        | 16/02/2016 | 17.02      | T           | Tripped at PG End DT Received.                                                                                      |
| Kolhapur Solapur(PG) I               | InterState                | 16/02/2016   | 18.06        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Akola II - Taptitanda ckt-II         | IntraState                | 31/12/2015   | 18.16        |            | Continued. | HT          | Change over                                                                                                         |
| Bhusawal-Aurangabad                  | IntraState                | 11/02/2016   | 14.05        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Babhaleshwar-Taptitanda ckt-II       | IntraState                | 11/02/2016   | 18.40        |            | Continued. | HT          | CHANGE OVER                                                                                                         |
| karad -kolhapur-II                   | IntraState                | 14/02/2016   | 13.22        | 16/02/2016 | 10.20      | HT          | Over Voltage                                                                                                        |
| Karad-Jaigad - I                     | IntraState                | 15/02/2016   | 16.55        | 16/02/2016 | 10.22      | HT          | Over Voltage                                                                                                        |
| Lonikand I - Koyna stage-IV          | IntraState                | 15/02/2016   | 21.37        | 16/02/2016 | 08.24      | HT          | Over Voltage                                                                                                        |
| Chandrapur2-Parali 2 ckt1            | IntraState                | 16/02/2016   | 09.12        | 16/02/2016 | 17.25      | PO          | Line Maintenance work                                                                                               |
| New Koyna - Koyna Stage IV-II        | IntraState                | 16/02/2016   | 11.25        |            | Continued. | PO          | Shifted on TBC for Breaker Testing Work.                                                                            |
| karad -kolhapur-I                    | IntraState                | 16/02/2016   | 16.31        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Karad - Jaigad - II                  | IntraState                | 16/02/2016   | 16.35        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Lonikand I - Koyna stage-IV          | IntraState                | 16/02/2016   | 21.44        |            | Continued. | HT          | Over Voltage                                                                                                        |
| <b>220 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Hingoli- Girawali                    | InterState                | 14/02/2016   | 12.37        |            | Continued. | HT          | To Improve Voltage @ Hingoli.                                                                                       |
| Chandrapur GCR - Warora - I          | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Chandrapur GCR - Wani                | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Kalwa - Borivali                     | IntraState                | 10/01/2016   | 09:15        |            | Continued. | PO          | Tower Erection Work.                                                                                                |
| GIS Bhandup - Borivali               | IntraState                | 11/01/2016   | 07.42        |            | Continued. | PO          | Tower Erection Work.                                                                                                |
| Padghe - Vasai                       | IntraState                | 24/01/2016   | 08.32        |            | Continued. | PO          | For Formation of Temp. Padgha-Borivali (Charge upto 51/1).                                                          |
| Bableshtar- Alephata                 | IntraState                | 03/02/2016   | 06.28        |            | Continued. | HT          | controlling bblsr ICT Overloading                                                                                   |
| Bableshtar- Ranjangaon               | IntraState                | 03/02/2016   | 07.12        |            | Continued. | HT          | controlling bblsr ICT Overloading                                                                                   |
| Mahad - Pedambe                      | IntraState                | 16/02/2016   | 08.40        | 16/02/2016 | 14.40      | PO          | E/W Replacement work.                                                                                               |
| Karad(400kv) - Ogalewadi Ckt 2       | IntraState                | 16/02/2016   | 11.21        | 16/02/2016 | 16.56      | PO          | Retrofitting Work.                                                                                                  |
| TBC @ Magarpatta                     | IntraState                | 16/02/2016   | 12.00        |            | Continued. | PO          | For Breaker Overhauling work.                                                                                       |
| REL Borivali Aarey Line              | IntraState                | 17/02/2016   | 02.19        | 17/02/2016 | 02.51      | T           | Distance Protection                                                                                                 |
| Boisar-Viraj                         | IntraState                | 17/02/2016   | 02.28        | 17/02/2016 | 04.09      | T           | HT consumer PT Flashed.                                                                                             |
| Dahanu Boisar Line                   | IntraState                | 17/02/2016   | 02.28        | 17/02/2016 | 04.18      | T           | HT consumer PT Flashed.                                                                                             |
| <b>220 KV ICT Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                     |
| 220/100 Kv 200 MVA ICT III @Borivali | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Failed on internal Fault(Now repaired and ready for commissioning)                                                  |
| 220/132 Kv 200 Mva Ict - 2 @Harangul | IntraState                | 15/02/2016   | 13.04        |            | Continued. | PO          | Work of Oil Filtration of ICT.                                                                                      |
| 220/100kv 200MVA ICT @ Ogalewadi     | IntraState                | 16/02/2016   | 11.01        | 16/02/2016 | 14.10      | PO          | To Attend Oil Leakage.                                                                                              |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage