

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 16/Apr/2020 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	60.447	931.772	1) Gujrat	10.551	167.098
2) Hydro	22.095	279.904	2) Madhya Pradesh	14.274	254.072
3) Gas	6.793	112.036	3) Chattisgarh	6.550	126.160
Total MSPGCL	89.335	1323.712	4) Maharashtra	127.919	1977.665
B) 1) APLM	68.943	966.252	5) Goa (Amona)	0.000	0.000
2) JSWEL	17.449	234.156	Total	159.294	2524.995
3) VIPL	0.000	0.000	a) Mumbai Schedule	18.851	268.714
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	16.136	217.169
5) WPCL	5.465	88.143	c) MSEDCL Bilateral *	52.996	814.753
6) Other IPP	8.308	131.624	Include PX	32.370	521.176
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	18.851	268.714
C) 1) TPCL Thermal	10.036	204.621	Include PX	2.894	108.037
2) TPCL Hydro	6.398	57.865	Standby	0.000	0.000
3) TPCL Gas	4.358	49.586	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.870	175.229	1) MSEDCL	354.361	5341.961
D) STATE			2) Mumbai Discoms	47.798	704.469
1) Thermal	181.518	2731.797	TOTAL STATE	402.159	6046.430
(A1+C1+C4+(B1-B6))					
2) Hydro	28.493	337.769			
(A2+C2)					
3) Gas	11.151	161.622			
(A3+B7+C3)					
4) Wind	14.669	173.120			
6) SOLAR	7.034	117.128			
TOTAL STATE	242.865	3521.436			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	2580	2520	2335	2620
MSPGCL Hydro	501	805	773	1442
MSPGCL Gas	290	279	285	289
MSPGCL Total Generation	3371	3604	3393	4351
Central Sector Receipt	7659	7701	5407	5799
WIND	248	594	1618	366
CPP / IPP Thermal	4186	4244	3853	4259
CPP / IPP Gas	0	0	0	0
SOLAR	985	623	0	0
Exchange with Mumbai	-514	-721	-770	-603
MSEDCL DEMAND MET	15935	16045	13501	14172
Load Shedding	0	0	0	0
MSEDCL DEMAND	15935	16045	13501	14172
TPCL GENERATION	976	864	839	830
AEML GENERATION	502	419	374	501
MUMBAI DEMAND	1992	2004	1983	1934
STATE DEMAND MET	17927	18049	15484	16106
STATE DEMAND	17927	18049	15484	16106
Frequency (Hz)	49.98	50.00	49.99	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.2 Hz at 06.02 Hrs	49.78 Hz at 21.08 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 16/Apr/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	112.89	0	0
Unit 9	0.00	112.84	0	0
Unit 10	0.00	108.90	0	0
Total	0.00	334.63		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	0.00	13.91	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.69	118.44	485	400
Unit 9	11.04	144.32	485	425
Total	21.74	276.68		
Paras				
Unit 3	5.85	87.02	254	150
Unit 4	5.92	74.34	255	209
Total	11.77	161.37		
Khaparkheda				
Unit 1	4.02	15.18	175	150
Unit 2	4.04	19.85	190	150
Unit 3	4.40	21.18	190	158
Unit 4	4.18	16.77	190	160
Unit 5	10.30	86.11	460	365
Total	26.94	159.10		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	6.79	112.04	299	268
Total	6.79	112.04		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.24	1.82	52	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.24	1.82		
Koyna				
Stage 1-2	5.60	86.17	585	45
Stage 4	7.56	100.85	1000	0
Stage 3	2.81	40.75	240	0
Total	15.97	227.78		
Hydro				
KDPH	0.89	13.55	37	37
VTRNA	0.00	0.00	0	0
TILLARI	0.28	6.82	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.36	2.41	80	0
RNGR+BHTSA	0.31	4.67	13	12
BHANDARDRA	0.49	8.75	33	11
ELDARY	0.36	4.14	15	14
SMLHY_PTN	3.44	11.79	144	143
GHATGHAR	0.00	0.00	0	0
Total	6.12	52.13		
Wind				
Total	14.67	173.12	0	0
Total	14.67	173.12		
CPP				
APML(Mus)	68.94	966.25	0	0
JSWEL(Mus)	17.45	234.16	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	5.46	88.14	0	0
Other(Mus)	8.31	131.62	0	0
Total	100.16	1420.18		
SOLAR				
Total	7.03	117.13	0	0
Total	7.03	117.13		
Tata				
Trombay 5	10.04	149.80	484	310
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	29.38	116	114
Trombay 7B	1.58	20.20	67	65
Trombay 8	0.00	54.82	0	0
TATA Hydro	6.40	57.86	345	146
Total	20.79	312.07		
AEML				
DTPS U-1&2	10.87	175.23	502	374
Total	10.87	175.23		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	60.45	931.77	MSPGCL Total	89.34	1323.71
			MSPGCL Thml+Gas	67.24	1043.81	Koyna 1,2 & 4 Total	13.16	187.02
			MSPGCL Hydro	22.10	279.90	State Total	242.86	3521.44

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 16/Apr/2020

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	2474	1899	277	4650	457	4348	0	0	5843	5769	-846	14378	0	14378	2269	16647	49.96
2	2530	1722	298	4550	495	4321	0	0	5768	5796	-740	14422	0	14422	2129	16551	50.02
3	2608	1615	279	4502	423	4261	0	0	5759	5759	-666	14279	0	14279	2023	16302	49.98
4	2620	1442	289	4351	366	4259	0	0	5731	5799	-603	14172	0	14172	1934	16106	49.99
5	2645	1292	299	4236	397	4253	0	0	6207	6076	-572	14390	0	14390	1882	16272	50.02
6	2630	854	281	3765	309	4252	0	0	7435	7411	-571	15166	0	15166	1880	17046	50.00
7	2640	1592	292	4524	261	4239	0	26	7467	7528	-507	16071	0	16071	1828	17899	50.03
8	2615	1209	299	4123	271	4240	0	187	7214	7287	-455	15653	0	15653	1807	17460	50.01
9	2580	974	277	3831	160	4161	0	462	6901	6852	-484	14982	0	14982	1842	16824	50.00
10	2597	850	284	3731	202	4184	0	702	6923	7203	-458	15564	0	15564	1876	17440	50.03
11	2546	485	271	3302	232	4176	0	813	7180	7317	-500	15340	0	15340	1946	17286	50.05
12	2580	501	290	3371	248	4186	0	985	7781	7659	-514	15935	0	15935	1992	17927	49.98
13	2500	454	268	3222	294	4176	0	971	7837	7791	-530	15924	0	15924	2012	17936	49.95
14	2526	330	278	3134	384	4189	0	928	8032	7999	-640	15994	0	15994	2003	17997	49.94
15	2520	531	268	3319	414	4179	0	792	8062	7957	-818	15843	0	15843	2005	17848	49.94
16	2520	805	279	3604	594	4244	0	623	7882	7701	-721	16045	0	16045	2004	18049	50.00
17	2498	281	273	3052	978	4234	0	375	7281	7163	-478	15324	0	15324	1949	17273	50.03
18	2330	336	295	2961	781	4062	0	147	6418	6457	-559	13849	0	13849	1840	15689	50.06
19	2331	646	275	3252	1163	3862	0	23	5660	5602	-642	13260	0	13260	1844	15104	50.02
20	2335	773	285	3393	1618	3853	0	0	5524	5407	-770	13501	0	13501	1983	15484	49.99
21	2374	452	285	3111	1484	3896	0	0	5200	5263	-877	12877	0	12877	2082	14959	49.99
22	2389	663	287	3339	1131	3969	0	0	5237	5560	-929	13070	0	13070	2139	15209	49.96
23	2543	1047	276	3866	1167	4318	0	0	5570	5707	-1079	13979	0	13979	2223	16202	49.98
24	2516	1342	288	4146	840	4303	0	0	5878	6231	-1177	14343	0	14343	2306	16649	50.01
MUs	60.45	22.10	6.79	89.33	14.67	100.17	0.00	7.03	158.79	159.29	-16.14	354.36	0.00	354.36	47.80	402.16	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/Apr/2020

Position as on 6.30 Hrs of 17/Apr/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	22/03/2020	10.45		Continued.	Zero Schedule. (R S D FROM 10:45 TO 16:00 Hrs.)	
MSPGCL	Bhusawal Unit 4	500	22/03/2020	18.30		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	23/03/2020	01.13		Continued.	Zero schedule.	
MSPGCL	Parli Unit 8	250	23/03/2020	18.00		Continued.	Zero Schedule.	
MSPGCL	Chandrapur Unit 6	500	23/03/2020	21.59		Continued.	Clinker Removal Work (Given Zero Schedule On 29/3/2020 At 12hrs By MSEDCL).	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
IPP	JSW (J) U2	300	26/03/2020	00.13		Continued.	No schedule.	
MSPGCL	Chandrapur Unit 4	210	26/03/2020	16.06		Continued.	Zero Schedule By MSEDCL	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/Apr/2020

Position as on 6.30 Hrs of 17/Apr/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 5	500	26/03/2020	20.29		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 7	500	28/03/2020	23.56		Continued.	Zero Schedule.	
MSPGCL	Uran Unit 5	108	06/04/2020	13.23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 3	210	10/04/2020	20.30		Continued.	Zero Schedule By MSEDCL	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
MSPGCL	Koradi Unit-8	660	12/04/2020	00.00		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 9	660	12/04/2020	01.10		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 10	660	12/04/2020	02.01		Continued.	Zero schedule.	
MSPGCL	Paras Unit 3	250	17/04/2020	09.05	17/04/2020	15.03	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Apr/2020

Statement-VII

Position as on 6.30 Hrs of 17/Apr/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	30/03/2020	17.32		Continued.	HT	Over Voltage
Koradi Satpur	InterState	16/04/2020	11.28	16/04/2020	12.15	T	Bus Bar Protection-I Operated at Koradi
Koradi Bhilai	InterState	16/04/2020	11.28	16/04/2020	12.09	T	Bus Bar Protection-I Operated at Koradi
Karad - Jaigad - II	IntraState	23/03/2020	18.12		Continued.	HT	Over Voltage
Dhule- Bableshwar - I	IntraState	24/03/2020	20.20		Continued.	HT	Over Voltage
New Koyna - Dabhol-I	IntraState	25/03/2020	18.01		Continued.	T	Over Voltage
Koradi-Khaperkhedda I	IntraState	25/03/2020	20.21	16/04/2020	12.00	T	Over Voltage
Kalwa - Talegaon(PG)	IntraState	28/03/2020	16.47		Continued.	HT	Over Voltage
Padghe - Kalwa-II	IntraState	06/04/2020	00.21		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	07/04/2020	23.58		Continued.	EO	To attend Hot Spot
Khadka-Aurangabad (Waluj)	IntraState	13/04/2020	17.04	17/04/2020	07.12	HT	Over Voltage
Babhaleshwar - Padghe-I	IntraState	13/04/2020	17.21		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	15/04/2020	19.11	16/04/2020	08.45	HT	Over Voltage
Koradi-Bhusawal	IntraState	16/04/2020	11.28	16/04/2020	12.29	T	Bus Bar Protection-I Operated at Koradi
Main Bus-I @ Koradi-II	IntraState	16/04/2020	11.28	16/04/2020	12.00	T	CT Switching Relay Mal-Operation,Bus Bar Protection-I Operated at Koradi
Girwali- Lonikand 2	IntraState	16/04/2020	11.38	16/04/2020	13.09	T	Reactor Backup protection
karad -kolhapur-II	IntraState	16/04/2020	18.52	17/04/2020	08.57	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	17/04/2020	17.22		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	17/04/2020	18.08		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57		Continued.	EO	Testing work (Bushing Tan Delta problem hence kept out.)
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	22/03/2020	10.13		Continued.	HT	Hand tripped from LV end to control Over Voltage.
400/220/33 Kv 315 Mva Ict- 2 @Kharghar	IntraState	25/03/2020	13.59		Continued.	EO	CT Tan Delta High.
400/220/33kv 500MVA ICT 5 @ Padghe	IntraState	25/03/2020	16.32		Continued.	HT	Outage availed for maint. work and ICT out LV side.
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	25/03/2020	17.57		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220/33 Kv 500 MVA ICT-II @Lonikand 2	IntraState	25/03/2020	22.00	17/04/2020	13.16	HT	LV Side CB Hand Tripped For Voltage.
400/220/33kv 315mva Ict3 @Lonikand	IntraState	25/03/2020	22.01		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	28/03/2020	18.07		Continued.	HT	Over Voltage
400/220 KV 500MVA ICT II @ Nanded	IntraState	16/04/2020	09.41	17/04/2020	00.11	PO	To replace ICT-II R&Y phase Unit Thimbles
400/220 KV 300 MVA ICT- I @Koradi	IntraState	16/04/2020	11.28	16/04/2020	12.20	T	Bus Bar Protection-I Operated at Koradi
400/220/33 Kv 500 MVA ICT-I @Lonikand 2	IntraState	17/04/2020	13.19		Continued.	PO	Attending Hot Spot
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
EKLAHARE (OCR) Nasik Navsari II	InterState	16/04/2020	13.58	16/04/2020	19.55	T	B Phase Earth fault

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 16/Apr/2020

Statement-VII

Position as on 6.30 Hrs of 17/Apr/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05		Continued.	PO	Isolation of 220KV Cables on MSETCL Tower NO.240
Lonand-Baramati	IntraState	16/02/2020	09.37		Continued.	PO	Erection of CTT-2 Tower Work For 220Kv Baramati-Lonand & Baramati Jejuri Cables Emanating from 220Kv Baramati S/Stn.
Hinjewadi2 - Hinjewadi 3 ckt 1	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Hinjewadi2 - Hinjewadi 3 ckt II	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Halkarni-Mahalaxmi line	IntraState	16/04/2020	13.40	16/04/2020	14.38	T	Over Current Protection E/F
Abhijeet-Wardha-li	IntraState	16/04/2020	15.42	16/04/2020	18.36	T	Distance Protection
VILEBHAGAD KANDALGAON	IntraState	17/04/2020	09.04	17/04/2020	18.40	PO	CT Tan Delta Testing Work.
Talandage - Sawantwadi I	IntraState	17/04/2020	11.11	17/04/2020	13.52	PO	Replacement Of Flash Overstring At LOC No. 224
Aurangabad (Waluj)-Bhenda	IntraState	17/04/2020	13.14	17/04/2020	14.28	T	Distance Protection
Bableshwar -Bhenda	IntraState	17/04/2020	14.23	17/04/2020	20.30	T	Distance Protection
Aurangabad (Waluj)-Bhenda	IntraState	17/04/2020	14.46	17/04/2020	15.33	T	Distance Protection
Sawantwadi-Bidri	IntraState	17/04/2020	17.48		Continued.	HT	Over Voltage
220 KV ICT Outages/Trippings							
Carnac : 220 / 110 / 33 315 MVA ICT 5	IntraState	14/03/2020	11.00		Continued.	PO	Shifting 220KV Side to New GIS

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage