

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 16/Apr/2023 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	161.598	2592.298	1) Gujrat	-4.216	-65.259
2) Hydro	17.573	326.475	2) Madhya Pradesh	8.652	136.757
3) Gas	3.193	39.704	3) Chattisgarh	3.400	75.690
Total MSPGCL	182.364	2958.477	4) Maharashtra	170.134	2870.128
B) 1) APLM	67.944	1182.291	5) Goa (Amona)	-1.612	-24.170
2) JSWEL	26.040	393.194	Total	176.358	2993.146
3) VIPL	0.000	0.000	a) Mumbai Schedule	28.244	529.593
4) RPL(AMT)	30.771	466.856	b) Mumbai Drawl	31.978	587.206
5) SWPGPL	11.799	181.173	c) MSEDCL Bilateral *	93.065	1526.567
6) Other IPP	19.153	348.555	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	28.244	529.593
C) 1) TPCL Thermal	13.101	187.642	Include PX	0.000	0.000
2) TPCL Hydro	3.553	86.554	Standby	0.000	0.000
3) TPCL Gas	3.369	45.670	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.712	155.845	1) MSEDCL	497.259	8206.600
D) STATE			2) Mumbai Discoms	62.713	1062.913
1) Thermal	341.118	5507.854	3) Other Discoms	9.650	162.315
(A1+C1+C4+(B1-B6))			TOTAL STATE	569.622	9431.828
2) Hydro	21.126	413.029			
(A2+C2)					
3) Gas	6.562	85.374			
(A3+B7+C3)					
4) Wind	7.871	193.978			
6) SOLAR	16.587	238.451			
TOTAL STATE	393.264	6438.686			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6463	6493	6397	7232
MSPGCL Hydro	206	283	1658	484
MSPGCL Gas	121	122	132	142
MSPGCL Total Generation	6790	6898	8187	7858
Central Sector Receipt	9453	9751	6734	6685
WIND	127	95	298	215
CPP / IPP Thermal	5296	6086	7025	6216
CPP / IPP Gas	0	0	0	0
SOLAR	2152	1830	0	553
Exchange with Mumbai	-1615	-1809	-1195	-1257
MSEDCL DEMAND MET	21798	22445	20615	19881
Load Shedding	0	0	0	0
MSEDCL DEMAND	21798	22445	20615	19881
TPCL GENERATION	615	526	1045	605
AEML GENERATION	446	347	484	450
MUMBAI DEMAND	2676	2682	2724	2312
OTHER DISCOM DEMAND	405	406	434	389
STATE DEMAND MET	24879	25533	23773	22582
STATE DEMAND	24879	25533	23773	22582
Frequency (Hz)	50.01	49.95	49.99	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.32 Hz at 18.03 Hrs	49.61 Hz at 22.23 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 16/Apr/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.07	73.74	195	120
Unit 8	6.25	214.31	602	0
Unit 9	13.49	76.58	601	538
Unit 10	13.47	213.98	587	540
Total	37.28	578.62		
Bhusawal				
Unit 3	3.51	53.92	160	125
Unit 4	11.42	138.12	495	455
Unit 5	10.08	169.44	450	390
Total	25.01	361.48		
Parli				
Unit 6	5.55	80.25	250	146
Unit 7	3.80	74.11	248	116
Unit 8	0.00	57.99	0	0
Total	9.35	212.35		
Chandrapur				
Unit 3	3.90	60.26	175	140
Unit 4	3.56	37.51	161	125
Unit 5	9.39	144.26	410	290
Unit 6	9.61	141.24	415	330
Unit 7	0.00	126.27	0	0
Unit 8	11.65	178.93	499	426
Unit 9	11.24	128.40	495	437
Total	49.34	816.88		
Paras				
Unit 3	4.95	70.12	223	171
Unit 4	5.30	68.56	240	175
Total	10.25	138.68		
Khaparkheda				
Unit 1	0.00	42.56	0	0
Unit 2	2.54	37.46	133	82
Unit 3	4.22	61.67	188	130
Unit 4	4.41	68.05	193	136
Unit 5	11.19	149.72	500	420
Total	22.36	359.46		
Nasik				
Unit 3	3.96	63.92	176	120
Unit 4	4.04	32.60	182	132
Unit 5	0.00	28.30	0	0
Total	8.00	124.82		
Uran				
All Units	3.19	39.70	143	118
Total	3.19	39.70		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	1.72	0	0
Total	0.00	1.72		
Koyna				
Stage 1-2	5.21	82.46	525	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	6.39	130.26	1015	0
Stage 3	2.16	45.44	320	0
Total	13.76	258.17		
Hydro				
KDPH	0.80	13.48	34	33
VTRNA	1.00	18.74	61	0
TILLARI	0.00	1.82	0	0
BHIRA T.R.	0.30	4.94	80	0
SMLHY_PTN	1.72	27.61	76	68
GHATGHAR	0.00	0.00	0	0
Total	3.82	66.59		
Wind				
Total	7.87	193.98	0	0
Total	7.87	193.98		
CPP				
APML(Mus)	67.94	1182.29	0	0
JSWEL(Mus)	26.04	393.19	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.77	466.86	0	0
SWPGPL-Mus	11.80	181.17	0	0
Dhariwal	6.30	96.24	272	245
IEPL	5.60	83.94	269	196
Other(Mus)	7.26	168.37	0	0
Total	155.71	2572.07		
SOLAR				
Total	16.59	238.45	0	0
Total	16.59	238.45		
Tata				
Trombay 5	8.54	122.95	432	269
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.03	26.71	107	44
Trombay 7B	1.34	18.96	65	39
TATA Hydro	3.55	86.55	414	2
Trombay 8	4.56	64.69	241	128
Total	20.02	319.87		
AEML				
DTPS U-1&2	10.71	155.84	502	325
Total	10.71	155.84		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	161.60	2592.30	MSPGCL Total	182.36	2958.48
			MSPGCL Thml+Gas	164.79	2632.00	Koyna 1,2 & 4 Total	11.60	212.72
			MSPGCL Hydro	17.57	326.48	State Total	393.26	6438.69

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 16/Apr/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planne d	Trans missio n Constr aint					
1	7162	427	140	7729	787	7087	0	0	5920	6043	-1252	19992	0	0	19992	2820	402	23214	49.94
2	7207	561	142	7910	532	7052	0	0	5811	6050	-1112	20070	0	0	20070	2661	362	23093	49.99
3	7223	546	141	7910	419	7064	0	0	5797	5857	-1014	19893	0	0	19893	2509	343	22745	49.98
4	7213	576	143	7932	465	7073	0	0	5729	5859	-910	20098	0	0	20098	2392	321	22811	49.99
5	7273	890	142	8305	495	7054	0	0	5694	5878	-870	20525	0	0	20525	2344	337	23206	50.02
6	7216	1114	141	8471	349	7014	0	0	5737	6014	-898	20592	0	0	20592	2390	358	23340	49.96
7	7226	1093	140	8459	296	6730	0	86	6296	6676	-1058	20818	0	0	20818	2340	371	23529	50.06
8	7232	484	142	7858	215	6216	0	553	6968	6685	-1257	19881	0	0	19881	2312	389	22582	50.04
9	7116	364	141	7621	176	5544	0	1153	7648	7403	-1378	20107	0	0	20107	2390	412	22909	50.05
10	6614	252	136	7002	170	5253	0	1666	8226	8178	-1415	20425	0	0	20425	2487	429	23341	50.03
11	6440	229	122	6791	150	5240	0	2018	8979	8914	-1537	21175	0	0	21175	2602	401	24178	50.01
12	6463	206	121	6790	127	5296	0	2152	9052	9453	-1615	21798	0	0	21798	2676	405	24879	50.01
13	6411	149	120	6680	88	5666	0	2232	8986	9202	-1661	21795	0	0	21795	2713	412	24920	49.99
14	6426	148	121	6695	89	5752	0	2135	9140	9155	-1657	21766	0	0	21766	2682	403	24851	50.04
15	6493	283	122	6898	95	6086	0	1830	9561	9751	-1809	22445	0	0	22445	2682	406	25533	49.95
16	6485	545	120	7150	161	6507	0	1372	9275	9280	-1853	22190	0	0	22190	2719	427	25336	50.02
17	6436	441	118	6995	276	6540	0	1013	8906	8804	-1698	21486	0	0	21486	2676	444	24606	50.02
18	6421	209	118	6748	341	6542	0	347	8595	8491	-1655	20373	0	0	20373	2596	441	23410	50.03
19	6389	525	126	7040	473	6716	0	30	7279	7442	-1533	19711	0	0	19711	2590	457	22758	50.06
20	6397	1658	132	8187	298	7025	0	0	6203	6734	-1195	20615	0	0	20615	2724	434	23773	49.99
21	6358	1534	141	8033	475	7068	0	0	6128	6197	-1161	20183	0	0	20183	2790	429	23402	49.96
22	6402	1576	142	8120	439	7057	0	0	6059	6086	-1115	20165	0	0	20165	2827	422	23414	49.92
23	6480	1769	140	8389	477	7039	0	0	6034	5902	-1111	20265	0	0	20265	2864	431	23560	49.77
24	6515	1994	142	8651	478	7086	0	0	6161	6304	-1214	20890	0	0	20890	2927	415	24232	49.89
MUs	161.60	17.57	3.19	182.36	7.87	155.71	0.00	16.59	174.18	176.36	-31.98	497.26	0.00	0.00	497.26	62.71	9.65	569.62	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 16/Apr/2023

Position as on 6.30 Hrs of 17/Apr/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	19/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	01/06/2023
MSPGCL	Nasik Unit 5	210	08/04/2023	20:20		Continued.	Boiler Tube Leakage(under tolling from 18.00Hrs DT. 13-04-2023)	
MSPGCL	Chandrapur Unit 7	500	14/04/2023	07:58		Continued.	HPT Top bottom casing Temperature difference	18/04/2023
MSPGCL	Khaparkheda Unit 1	210	15/04/2023	06:30	17/04/2023	06:39	Air heater problem	16/04/2023
MSPGCL	Uran Unit 6	108	15/04/2023	19:47	17/04/2023	00:00	No Schedule.	
MSPGCL	Parli Unit 8	250	15/04/2023	22:05		Continued.	Boiler Tube Leakage	18/04/2023
MSPGCL	Koradi Unit 8	660	16/04/2023	11:24		Continued.	Boiler Tube Leakage	19/04/2023
IPP	SWPGPL U-1	135	16/04/2023	14:47	16/04/2023	17:03	Boiler aux supply MCB trip	
MSPGCL	Bhusawal Unit 4	500	17/04/2023	00:54	17/04/2023	04:15	Class A Protection Operated	
MSPGCL	Uran Unit 6	108	17/04/2023	03:10	17/04/2023	18:27	No Schedule	
MSPGCL	Nasik Unit 3	210	17/04/2023	21:27		Continued.	Boiler Tube Leakage	20/04/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 16/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 17/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 1	IntraState	09/04/2023	22:22			T	Tripped on distance protection
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	15/04/2023	22:58	16/04/2023	05:40	EO	Emergency Shutdown of HVDC Pole-1 BASE FILTER Z11-Z1/Z2 for attending Hotspots at various locations in all the three phase, respective images are also attached
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF KARAD LINE AND 400/220KV 315MVA ICT - 1 @ SOLAPUR (PG)	InterState	15/04/2023	09:39			PO	411-Bay Y.Ph CT Replacement due to oil seepage from porcelain and cementing joint
400 KV MAINBAY Outages/Trippings							
MAIN BAY-425 OF GT-8 @ KORADI-2	IntraState	17/04/2023	09:15	17/04/2023	17:05	PO	Diagnostic testing of Circuit Breaker
220KV AUXILLARY BUS @ KHAPARKHEDA	IntraState	17/04/2023	12:02	17/04/2023	15:50	PO	CONNECTION OF TWIN JUMPERS 220KV AUXILLARY ISOLATOR JUMPERS OF 220KV KANHAN CKT
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/04/2023	11:30			HT	H/T TO CONTROL LINE LOADING OF PUNE PG
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	11/04/2023	09:07			PO	Diagnostic testing and allied bay maintenance work
JEJURI - KARAD	IntraState	16/04/2023	12:52	16/04/2023	14:43	T	Distance Protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	IntraState	15/04/2023	21:38	16/04/2023	04:47	T	ICT TRIPPED ON NDR
400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	IntraState	17/04/2023	09:39	17/04/2023	17:46	PO	For ICT Painting work
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	IntraState	17/04/2023	10:30			PO	1. ICT-II IV Bay Circuit Breaker Pole Overhauling Work. 2. ICT-II IV will be charged through TBC.
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	17/04/2023	16:44		Continued.	PO	1. SFRA Testing 2. 33kV IPS Tube and BPI insulation coating work to avoid NDR Tripping 3. OLTC oil filtration work 4. R ph Unit oil leakage attending work 5. Protection & Colling system Supervisory trials. 6. Diagnostic testing work
220 KV LINE Outages/Trippings							
NALASOPARA - BOISAR PG	InterState	16/04/2023	07:37	16/04/2023	12:47	EO	1) Work is Proposed on newly formed Palghar- Nalasopara line for Attending hot spot work at R Phase Main Bus isolator Jaw main Bus Temp-259 deg.cent) at Nalasopara ss.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 17/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
KALWA - SALESETTE CKT - 5	IntraState	13/04/2023	10:10			PO	Normalization of 110 KV Kalwa Kalyan Salsette 2 section - 220 KV Kalwa Salsette 5 project work.
INFOSYS - PEGASUS	IntraState	15/04/2023	12:39	16/04/2023	11:20	EO	CB overhauling work.
CHAKAN (400KV) - VOLKSWAGEN	IntraState	16/04/2023	07:45	16/04/2023	13:29	HT	HT due to sparking on R-ph CC
KALMESHVAR-PANDHURNA	IntraState	16/04/2023	09:34	16/04/2023	16:21	PO	s/d is for Re-sagging work at loc no 03R-278, 278-294
220KV HINGOLI -KURUNDA CKT	IntraState	16/04/2023	09:48	16/04/2023	15:45	PO	Cold line washing of disc insulator from LOC no 137 to 175
SAHARA-URSE	IntraState	16/04/2023	09:52	16/04/2023	15:22	HT	HT for Load Management
URSE - TALEGAON (AMBI) CKT 2	IntraState	16/04/2023	11:23	16/04/2023	15:12	PO	1) Chemical washing of Insulators. 2)Emergency tree cutting.
KANDALGAON - PIRANGUT	IntraState	16/04/2023	13:40	16/04/2023	14:30	T	Tripped on distance protection
BUS SECTION BREAKER-3 @ TROMBAY	IntraState	16/04/2023	14:51	16/04/2023	15:15	EO	FORRAISING SF6 GAS PRESSURE
NERLE - PEDAMBE	IntraState	16/04/2023	15:20	16/04/2023	18:22	EO	For fixing repair sleeve between loc 83 to 84 bottom ph due to damaged conductor.
TALOJA - PANCHANAND	IntraState	16/04/2023	17:00	16/04/2023	21:40	T	B-ph CC bursted @ Taloja end
YEOTMAL- PUSAD	IntraState	17/04/2023	07:58	17/04/2023	15:40	T	DIST PROT OPTD.
TALOJA II - OCIL 1	IntraState	17/04/2023	09:22			PO	Isolator maintenance & Checking of busbar connections nut-blot tightness.
132 KV KAGZIPURA - DEOGAON RANGARI CKT	IntraState	17/04/2023	10:17	17/04/2023	16:30	PO	CT REPLACEMENT WORK AT KAZIPURA END.
NIWALI - PAWAS LINE	IntraState	17/04/2023	10:28	17/04/2023	18:54	PO	For cold washing of line insulator strings.
GHODBUNDER - GORAI	IntraState	17/04/2023	11:36	17/04/2023	12:58	PO	attending frequent Pole discrepancy alarm and sf6 gas pressure low alarm
NAGOTHANE - POSCO	IntraState	17/04/2023	12:03	17/04/2023	18:08	PO	Pre monsoon maintenance work
WANI-WARORA 1	IntraState	17/04/2023	14:10	17/04/2023	14:38	T	LINE AR SUCCESSFUL AT WARORA END AND TRIPPED AT WANI END.
MIRAJ - ICHALKARANJI	IntraState	17/04/2023	17:05		Continued.	PO	1)For proper load management at 220 kV Tilawani & 220 kV Miraj S/S as on dt. 17.04.2023 outage proposed on 220 kV Talandage-Ichalkaranji Ckt-2. & 220 kV Talandage- Ichalkaranji -1 2)220 kV Miraj- Ichalkaranji line needs to be kept off at 220 kV Ichalkaranji (Tilawani) S/S. 3) 220 kV Miraj - Ichalkaranji line will be in service from 220 kV Miraj S/S end.
URSE-CHINCHWAD	IntraState	17/04/2023	17:11	17/04/2023	19:25	T	Tripped due to heavy rain
TALANDGE - ICHALKARANJI 2	IntraState	17/04/2023	17:13	17/04/2023	18:51	PO	For attending hotspots at T.L No-45 B Phase
CHAKAN -BRIDGESTONE	IntraState	17/04/2023	17:45	17/04/2023	18:46	T	tripped due to heavy rain
TALANDGE - ICHALKARANJI 1	IntraState	17/04/2023	18:56		Continued.	PO	For attending hospot at T.L No 29 B phase & Repairment of damaged conductor in between T L no 33-34, B Phase
BHUGAON - WARDHA (PG)	IntraState	17/04/2023	22:10		Continued.	HT	To control OD

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 16/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 17/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 1	IntraState	17/04/2023	22:34		Continued.	HT	To control OD
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220 / 110 / 33kv 250MVA ICT 2 @ SAKI	IntraState	16/04/2023	08:09	16/04/2023	15:40	PO	Premansoon checks & R/M, testing
220/110 KV 200 MVA ICT - 2 @ ICHALKARANJI - II	IntraState	17/04/2023	08:26	17/04/2023	21:00	PO	1)Quarterly bay maintenance work 2) HV Bushing replacement work due to leakage 3) Diagnostic testing work.
220/132 KV 100 MVA ICT 3 @ RANJANGAON	IntraState	17/04/2023	10:40	17/04/2023	16:02	PO	For replacement of Air Cell and general bay maintenance work.
220/132 KV, 100MVA ICT I	IntraState	17/04/2023	12:59	17/04/2023	19:42	PO	FOR SCADA INTEGRATION WORK DEMANDED BY ZIV ENGINEER AS PER INSTRUCTION OF TESTING UNIT AMRAVATI.
132 KV LINE Outages/Trippings							
MADGI-KAULEWADA CKT II	IntraState	17/04/2023	07:41	17/04/2023	08:48	EO	ATTENDING HOT SPOT ON R PH LINE ISOLATOR.
132KV WASHIM MANGRULPIR CKT	IntraState	17/04/2023	07:53	17/04/2023	11:30	PO	DIAGNOSTIC TESTING AND ROUTINE MAINTENANCE.
PADEGAON-SILLOD	IntraState	17/04/2023	08:26	17/04/2023	18:29	PO	FOR REPLACEMENT OF ALL 3 PHASE R, Y, B CTS OF 132KV SILLOD LINE BAY AT 220KV PADEGAON SS.
AMALNER(220KV)-CHOPDA CKT - 2	IntraState	17/04/2023	09:01	17/04/2023	13:43	EO	TO ATTEND OIL LEAKAGE OF B PH CT.
TELGAON-PANGRI	IntraState	17/04/2023	11:05	17/04/2023	15:28	PO	COLD LINE WASHING WORK OF INSULATORS STRINGS.
CHIKHALI-BULDANA	IntraState	17/04/2023	14:41	17/04/2023	15:04	T	C-B PH ZONE2 DIST -18.67 KM ,IF -3.2KA B ..DIST KM IF--529 AMP,
BULDANA-MOTALA	IntraState	17/04/2023	14:41	17/04/2023	15:17	T	Tripped at Buldhana end.
PARLI-PANGRI	IntraState	17/04/2023	15:37	17/04/2023	19:05	PO	COLD LINE WASHING WORK.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
SALSETTE VIKHROLI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
WAGHIVALI - CHEMBUR	IntraState	04/04/2023	21:59	16/04/2023	03:00	PO	FOR 400 KV KVPTL WORK
WAGHIVALI - MANKHURD	IntraState	04/04/2023	23:57	16/04/2023	02:40	PO	FOR 400 KV KVPTL WORK

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage